

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0093378
APS ID 1045372
Authorization ID 1365101

Applicant and Facility Information

Applicant Name	<u>Assoc Ceramics & Tech Inc.</u>	Facility Name	<u>Assoc Ceramics & Tech</u>
Applicant Address	<u>400 N Pike Road</u> <u>Sarver, PA 16055-1109</u>	Facility Address	<u>400 N Pike Road</u> <u>Sarver, PA 16055-1109</u>
Applicant Contact	<u>Patti-Ann Kanterman</u>	Facility Contact	<u></u>
Applicant Phone	<u>(724) 353-1585</u>	Facility Phone	<u></u>
Client ID	<u>24923</u>	Site ID	<u>240273</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Winfield Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Butler</u>
Date Application Received	<u>August 3, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Minor Sewage Treatment Facility Renewal.</u>		

Summary of Review

The subject NPDES permit (PA0093378) renewal is for a discharge consisting of treated washroom (domestic sewage) and untreated stormwater (roof drains).

Monitoring for pH, DO, and TRC have been set to a frequency of 1/day *(during the days the facility is in operation, which is 5 per week) CWY*, per the Summary of Review on Fact Sheet of the prior permit amendment dated October 27, 2017.

Monitoring for Nitrogen and Total Phosphorus of 1/quarter will be retained per the Summary of Review on Fact Sheet of the prior permit amendment dated October 27, 2017.

There are no open violations listed in WMS for the subject Client ID (24923) as of 11/22/2022. *9/22/2023 CWY*

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	November 22, 2022
X		Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	9/22/2023

Discharge, Receiving Waters and Water Supply Information

Outfall No. 001 Design Flow (MGD) .004
 Latitude 40° 44' 11.22" Longitude -79° 45' 56.94"
 Quad Name Curtisville Quad Code 40079F7
 Wastewater Description: Sewage Effluent

Receiving Waters Unnamed Tributary to Sarver Run (HQ-TSF) Stream Code 42577
 NHD Com ID 123971219 RMI 0.8300
 Drainage Area 0.044 Yield (cfs/mi²) 0.1
 Q₇₋₁₀ Flow (cfs) 0.004 Q₇₋₁₀ Basis Default
 Elevation (ft) 1282 Slope (ft/ft) ---
 Watershed No. 18-F Chapter 93 Class. HQ-TSF
 Existing Use _____ Existing Use Qualifier _____
 Exceptions to Use _____ Exceptions to Criteria _____

Assessment Status Attaining Use(s)
 Cause(s) of Impairment _____
 Source(s) of Impairment _____
 TMDL Status _____ Name _____

Background/Ambient Data Data Source
 pH (SU) 7.0 Default
 Temperature (°F) 20 Default
 Hardness (mg/L) 100 Default
 Other: _____

Nearest Downstream Public Water Supply Intake Allegheny County Sanitary Authority (ALCOSAN)
 PWS Waters Allegheny River Flow at Intake (cfs) 1407
 PWS RMI 1.0 Distance from Outfall (mi) >25

Changes Since Last Permit Issuance: None.

Other Comments: None.

Treatment Facility Summary

Treatment Facility Name: Associated Ceramics

WQM Permit No.	Issuance Date
N/A	N/A

Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Hypochlorite	0.004
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.004	9.7	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None.

Other Comments: Existing treatment facility: bar screen, aeration tank & clarifier, dosing pump, sand filters, chlorine contact tank, then outfall.

Compliance History

DMR Data for Outfall 001 (from July 1, 2021 to June 30, 2022)

Parameter	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21
Flow (MGD) Average Monthly	0.002	0.001	0.0015	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001
pH (S.U.) Instantaneous Minimum	6.82	7.46	6.87	7.22	6.56	6.74	6.55	6.73	6.51	6.83	6.59	6.55
pH (S.U.) Instantaneous Maximum	7.22	7.69	7.45	7.87	7.30	7.31	8.52	7.41	6.89	7.21	7.21	7.75
DO (mg/L) Minimum	7.41	6.65	6.34	6.71	7.43	6.20	8.71	6.79	6.09	6.43	6.12	6.50
TRC (mg/L) Average Monthly	0.02	0.01	0.02	0.04	0.04	0.03	0.03	0.04	0.04	0.02	0.04	0.04
TRC (mg/L) Instantaneous Maximum	0.05	0.03	0.05	0.11	0.11	0.07	0.07	0.09	0.08	0.05	0.14	0.09
CBOD5 (mg/L) Average Monthly	< 2.0	< 2.00	3.07	4.37	< 6.00	< 6.00	4.02	< 2.0	< 2.0	4.65	4.12	< 2.0
CBOD5 (mg/L) Instantaneous Maximum	< 2.00	< 2.00	4.14	6.74	< 6.00	< 6.00	6.04	< 2.0	< 2.0	7.31	6.25	< 2.0
TSS (mg/L) Average Monthly	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0
TSS (mg/L) Instantaneous Maximum	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0
Fecal Coliform (No./100 ml) Geometric Mean	101	21.9	13.60	62.35	< 5	< 5.0	< 5.0	< 5	< 5	< 5.0	< 2	< 5.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	140	30	37	81	< 5	< 5.0	< 5.0	< 5	< 5	< 5.0	< 2	< 5.0
Total Nitrogen (mg/L) Average Quarterly	21.8			24.0			63.0			81.4		
Ammonia (mg/L) Average Monthly	< 0.800	0.800	< 0.800	< 0.800	< 0.800	< 0.800	0.800	< 0.008	< 0.800	< 0.800	< 0.800	< 0.800

Total Phosphorus (mg/L) Average Quarterly	1.6			1.3			3.3			5.4		
---	-----	--	--	-----	--	--	-----	--	--	-----	--	--

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.004</u>
Latitude <u>40° 44' 51.80"</u>	Longitude <u>-79° 46' 17.50"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Effluent limitations from prior permit term are to be retained.

Water Quality-Based Limitations

A “Reasonable Potential Analysis” determined the following parameters were candidates for limitations: Ammonia-Nitrogen

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
NH ₃ -N	3.15	Average Monthly	WQM 7.0 v1.1
	6.3	IMAX	WQM 7.0 v1.1
TRC	0.1	Average Monthly	TRC Spreadsheet
	0.3	IMAX	TRC Spreadsheet

Comments: The existing May 1-Oct 31 Ammonia limitations of 2.1 mg/l average monthly and 4.2 mg/l instantaneous maximum, and Total Residual Chlorine (TRC) are more stringent and shall be retained due to Anti-Backsliding provisions.

Best Professional Judgment (BPJ) Limitations

Comments: Monitoring frequencies for Dissolved Oxygen, pH, and Total Residual Chlorine will be increased to 1/day *(during the days the facility is in use, which is 5 per week) CWY* in congruence with the Department’s SOP entitled “Establishing Effluent Limitations for Individual Sewage Permits” (SOP No. BPNPSM-PMT-033, dated November 9, 2012, Revised August 23, 2013).

Anti-Backsliding

Ammonia and TRC effluent limits will be retained due to Anti-Backsliding provisions.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	5/week	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	5/week	Grab
TRC	XXX	XXX	XXX	0.05	XXX	0.15	5/week	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	6.3	XXX	12.5	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.1	XXX	4.2	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: None.

Attachment 1
 eMap – Location Map



Attachment 2
Google Earth Imagery



TRC Spreadsheet

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.004	= Q stream (cfs)	0.5	= CV Daily	
0.004	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)	
Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA _{afc} = 0.225	1.3.2.iii	WLA _{cfc} = 0.212
PENTOXSD TRG	5.1a	LTAMULT _{afc} = 0.373	5.1c	LTAMULT _{cfc} = 0.581
PENTOXSD TRG	5.1b	LTA _{afc} = 0.084	5.1d	LTA _{cfc} = 0.123
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.103		AFC
		INST MAX LIMIT (mg/l) = 0.338		
WLA _{afc}	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019/Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs/Qd)] \cdot (1 - FOS/100)$			
LTAMULT _{afc}	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA _{afc}	$wla_afc \cdot LTAMULT_afc$			
WLA _{cfc}	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011/Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs/Qd)] \cdot (1 - FOS/100)$			
LTAMULT _{cfc}	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$			
LTA _{cfc}	$wla_cfc \cdot LTAMULT_cfc$			
AML MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$			
AVG MON LIMIT	$MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$			
INST MAX LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$			

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
 18F 42577 Trib 42577 to Sarver Run

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	0.830 Outfall 001	12.61	18.34	12.61	18.34	1	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	0.830 Outfall 001	1.6	3.15	1.6	3.15	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	0.83 Outfall 001	25	25	3.15	3.15	6	6	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
18F	42577	Trib 42577 to Sarver Run	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
0.830	0.004	22.922	7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
0.971	0.273	3.553	0.040
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
15.44	1.260	1.84	0.877
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
6.932	29.582	Owens	6
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>		
1.257	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.126	12.88	1.65
	0.251	10.75	1.48
	0.377	8.97	1.32
	0.503	7.48	1.19
	0.628	6.24	1.06
	0.754	5.21	0.95
	0.880	4.34	0.85
	1.005	3.63	0.76
	1.131	3.02	0.68
	1.257	2.52	0.61

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
18F	42577	Trib 42577 to Sarver Run					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.830	Outfall 001	PA0093378	0.002	CBOD5	25		
				NH3-N	3.15	6.3	
				Dissolved Oxygen			6

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42577	Trib 42577 to Sarver Run	0.830	1282.00	0.04	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Outfall 001	PA0093378	0.0020	0.0040	0.0040	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	6.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42577	Trib 42577 to Sarver Run	0.010	1047.00	0.17	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>			<u>Stream Name</u>							
18F		42577			Trib 42577 to Sarver Run							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
0.830	0.00	0.00	0.00	.0062	0.05428	.273	.97	3.55	0.04	1.257	22.92	7.00
Q1-10 Flow												
0.830	0.00	0.00	0.00	.0062	0.05428	NA	NA	NA	0.04	1.376	23.44	7.00
Q30-10 Flow												
0.830	0.01	0.00	0.01	.0062	0.05428	NA	NA	NA	0.04	1.162	22.54	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		