

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0094200  
APS ID 911432  
Authorization ID 1372289

**Applicant and Facility Information**

Applicant Name	<u>Bear Creek Watershed Authority</u>	Facility Name	<u>Petrolia STP</u>
Applicant Address	<u>259 Argyle Street</u> <u>Petrolia, PA 16050-9702</u>	Facility Address	<u>Rte 268</u> <u>Petrolia, PA 16050</u>
Applicant Contact	<u>Thomas McElravy, Chairman</u>	Facility Contact	<u>Chris Dunmyre, Operator</u>
Applicant Phone	<u>(724) 756-4600</u>	Facility Phone	<u></u>
Applicant E Mail	<u>bearcreekwater@zoominternet.net</u>	Facility E Mail	<u></u>
Client ID	<u>62798</u>	Site ID	<u>724622</u>
Municipality	<u>Fairview Township</u>	County	<u>Butler</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No Limitations</u>
Date Application Received	<u>October 12, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 19, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES renewal</u>		

**Summary of Review**

No current open violations.

Service Area	Contribution	Sewer Type	Population
Fairview Township	11%	Separate	29
Petrolia Borough	83%	Separate	212
Parker Township	6%	Separate	15

Sludge production was 1.94 dry tons from this and other Bear Creek Watershed Authority facilities. Final disposal is to Dalton's Processing Facility.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	January 19, 2023
X		<i>Vacant</i> Environmental Engineer Manager	Okay to Draft JCD 1/19/2023

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.04111</u>
Latitude DP	<u>41° 1' 36.89"</u>	Longitude DP	<u>-79° 42' 57.39"</u>
Latitude NHD	<u>41° 1' 37.25"</u>	Longitude NHD	<u>-79° 42' 56.77"</u>
Quad Name	<u>Parker</u>	Quad Code	<u>1008</u>

Wastewater Description: Treated municipal sanitary sewerage

Receiving Waters	<u>South Branch Bear Creek (WWF)</u>	Stream Code	<u>49141</u>
NHD Com ID	<u>123851468</u>	RMI	<u>2.55</u>
Drainage Area	<u>8.9</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.044</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.39</u>	Q <sub>7-10</sub> Basis	<u>Perennial stream</u>
Elevation (ft)	<u>1154.83</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>17-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>

Comments

Assessment Status	<u>Impaired</u>
Cause(s) of Impairment	<u>Metals, Nutrients, Siltation</u>
Source(s) of Impairment	<u>Abandoned Mine Drainage, Municipal Point Source and Urban Runoff/Storm Sewers</u>
TMDL Status	<u>Name</u>
Comments	<u><b>No TMDL anticipated. Impairment predates NPDES program that has abated the Impairment.</b></u>

Background/Ambient Data		Data Source	
pH (SU)	<u>6.9</u>		<u>1994-95 Bear Creek Basin review</u>
Temperature (°C)	<u>25</u>		<u>WWF default</u>
CBOD <sub>5</sub> (mg/L)	<u>2</u>		<u>Assumed default value</u>
NH <sub>3</sub> -N (mg/l)	<u>0.1</u>		<u>Assumed default value</u>
Hardness (mg/L)	<u>210</u>		<u>1994-95 Bear Creek Basin review</u>
Other:	<u></u>		<u></u>

Nearest Downstream Public Water Supply Intake	<u>Butler District Pennsylvania-American Water Company</u>
PWS Waters	<u>Allegheny River</u>
PWS RMI	<u>69.90</u>
	<u>Flow at Intake (cfs)</u>
	<u>Distance from Outfall (mi)</u> <u>19</u>

Changes Since Last Permit Issuance: none

Other Comments: This is a supplemental water source (water transfer to Lake Oneida)

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Petrolia STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
1083404		8/25/83		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Hypochlorite	0.0411
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0411	115	Not Overloaded	Sludge Holding/Drying Beds	Other WWTP

Changes since the last permit issuance: None

Other Comments:

The WQM permit indicates a runoff flow period of 16-hrs. but the extended aeration plant has a detention time of 35.4 hrs., so the flow (and discharge) should be considered equalized over the entire day (24 -hrs.)

	Month	Flow Mean MGD	BOD5 Mean PPD	Min	Mean	Max	Min	Mean	Max	#
Annual Average Design		0.0411								
Hydraulic Design Capacity		0.0411								
Organic Design Capacity			115							
Annual Average	2018	0.028								
	2019	0.024								
	2020	0.028								
Highest Monthly Average	January	0.032								
pH							7.10		7.77	1460
TRC								0.2	1.25	730
Fecal coliform								374.7	10 000	48
CBOD5								4.76	11.5	48
TSS								8.16		48
NH3N								0.61	5.83	48
N								1.52	37.7	48
P								3.9	5.97	48

Calcium oxide (lime) used to adjust pH.

Compliance History

DMR Data for Outfall 001 (from December 1, 2021 to November 30, 2022)

Parameter	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21
Flow (MGD) Average Monthly	0.0295	0.0281	0.0286	0.0283	0.0281	0.0275	0.0291	0.0286	0.0276	0.0282	0.0275	0.0340
Flow (MGD) Daily Maximum	0.0301	0.0294	0.0304	0.0297	0.0289	0.0286	0.0296	0.0335	0.0330	0.0293	0.0298	0.0363
pH (S.U.) Minimum	7.42	7.41	7.42	7.41	7.41	7.40	7.41	7.41	7.41	7.42	7.42	7.42
pH (S.U.) Maximum	7.44	7.44	7.44	7.43	7.43	7.43	7.45	7.45	7.48	7.45	7.46	7.45
DO (mg/L) Minimum	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0
TRC (mg/L) Average Monthly	0.37	0.34	0.38	0.4	0.38	0.33	0.32	0.43	0.32	0.31	0.39	0.34
TRC (mg/L) Instant Maximum	0.42	0.51	0.50	0.52	0.48	0.50	0.44	0.45	0.54	0.56	0.7	1.24
CBOD5 (lbs/day) Average Monthly	1.3	0.70	1.05	0.70	1.27	1.0	1.5	6.6	0.87	2.1	1.1	3.3
CBOD5 (lbs/day) Weekly Average	1.4	0.74	1.4	0.74	1.32	1.2	1.6	9.13	1.3	2.9	1.6	6.1
CBOD5 (mg/L) Average Monthly	5.2	3.0	4.4	3.0	5.41	4.34	6.3	1.6	3.8	8.72	4.7	11.5
CBOD5 (mg/L) Weekly Average	7.4	3.0	5.5	3.0	5.46	5.07	6.3	2.6	4.6	12.0	6.3	20.0
BOD5 (ppd) Influent Average Monthly	54.6	65.1	17.9	44.8	52.6	63.8	49.5	22.6	33.1	27.5	43.3	47.1
BOD5 (mg/L) Influent Average Monthly	222	278	75.4	190	224.5	278	204	94.7	144	117.1	189	166
TSS (lbs/day) Average Monthly	1.7	2.1	3.1	2.3	1.1	1.5	4.3	2.5	1.8	2.7	2.1	1.5
TSS (ppd) Influent Average Monthly	21.9	34.5	13.1	17.9	33.3	49.1	43.7	15.9	18.2	18.2	26.8	38.0
TSS (lbs/day) Weekly Average	1.8	2.5	6.2	3.3	1.5	1.9	5.1	3.4	2.3	3.1	2.4	2.8
TSS (mg/L) Average Monthly	6.8	9.1	25	9.6	4.6	6.4	17.8	10.4	8.0	11.6	9.0	5.4
TSS (mg/L) Influent Average Monthly	89	147	55.0	76.0	142.0	214	180.0	67.0	79.0	77.5	117	134
TSS (mg/L) Weekly Average	7.2	10.2	34	13.2	6.4	8.0	20.4	12.0	8.4	12.8	9.6	9.2

**NPDES Permit Fact Sheet  
Petrolia STP**

**NPDES Permit No. PA0094200**

Fecal Coliform #./100 ml) Geometric Mean	364	82.5	77.0	53.0	140.6	99.0	58.4	313	155.9	490	291	310
Fecal Coliform #./100 ml) Instant Maximum	586	189	97.0	97.0	470	196.0	61.0	528	180.0	554	701	310
Total Nitrogen (mg/L) Average Monthly	0.8	0.75	1.0	1.0	1.0	0.8	1.0	0.8	2.7	0.6	0.3	0.5
Ammonia (lbs/day) Average Monthly	0.06	0.05	0.05	0.2	0.27	0.2	0.02	0.1	0.023	0.02	0.1	0.04
Ammonia (mg/L) Average Monthly	0.26	0.2	0.2	1.0	1.16	0.7	0.1	0.6	0.1	0.1	0.5	0.13
T Phosphorus (mg/L) Average Monthly	4.8	4.7	4.9	0.6	8.64	3.3	3.8	2.6	2.3	2.1	3.8	3.7

**Median pH 7.4- SU annually and summer**

**Compliance History**

No violations reported

**Development of Effluent Limitations**

Outfall No. 001 Design Flow (MGD) .04111  
 Latitude 41° 1' 36.89" Longitude -79° 42' 57.39"  
 Wastewater Description: Treated sewage effluent

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4.0			BPJ
E Coli	Report			BPJ

Comments: E Coli a new parameter

**Water Quality-Based Limitations**

A Sewerage Program “Reasonable Potential Analysis” determined the following parameters were candidates for limitations: CBOD<sub>5</sub>, Ammonia and DO.

The following limitations were determined through water quality modeling (output files attached):

Parameter		Limit (mg/l)		SBC	Model		
CBOD <sub>5</sub>		25.0	50.0	NA		25.0	50.0
Ammonia-N	Summer	5.5	11.0			12.28	24.56
	Winter	16.0	33.0			36.0	73.0
DO		4.0			4.0		

Comments: previous summer ammonia model recommendation was 12.7-mg/L

**Best Professional Judgment (BPJ) Limitations**

Comments: DO only

**Anti-Backsliding**

With existing limit compliance no changes proposed.

Other Considerations

Initial evaluations used the Toms Run @ Cooksburg gage station data to develop a yield rate for this watershed (0.048 and 0.052-cfs). Stream Stats based on drainage area generates a slightly lower yield rates with 0.044-cfs basin average.

A 2016 stream survey did not find municipal point source impacts in the South Branch and the summary report will be recommending that impairment status be removed. However, this applies only to the municipal discharges and their interaction as the South Branch tributaries remain impaired.

Initially the South Branch Bear Creek basin was limited to 10-PPD BOD5 for all dischargers. No sanitary sewer service was provided, industrial waste and mine drainage were poorly treated, surface coal mines were back filled with industrial waste and the Bruin Lagoon failed.

With the adoption of the Federal Clean Water Act sanitary sewer service was proposed. Permitting was by the South West Regional Office. For some reason the planning review design loads and facility design loads do not always correspond. In parallel with the municipal sewage reviews were stream surveys to determine stream impairments and industrial waste treatment.

Penreco inherited a deep mine discharge as it tried to use the mine for industrial waste disposal. Koppers (Beezer East) tried land application and all industrial facilities seem to back fill surface coal mines with industrial waste. A Koppers report showed that the South Branch Bear Creek hardness was approximately 300-mg/L above, at and below a shallow ground water discharge.

The Koppers facility NPDES permit was for a first flush storm water collection, recycle, and discharge storm water system and evaporator treated contaminated ground water discharge. The storm water discharges were expected to be highly contaminated but only occur a few times in a year.

WITCO and Penreco Clean Water permits were conditioned for an optional sand filter and because Air Quality Control classified the industrial facilities as refineries were required to install oil-water separator covers. No action was taken on the sand filters as the effluent concentrations never approached the calculated effluent concentrations.

Clean Water reserved further ground water action leaving further basin remediation to Mining, Environmental Clean Up and Waste Management.

Bruin, Fairview, and Petrolia STP do not report any industrial waste contribution. With no industrial contribution priority pollutant concentrations should be negligible. Around the year 2000 Central Transport relocated to the Karns City area and proposed a truck wasting discharge to the Bear Creek Authority.

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17C	49141	SOUTH BRANCH BEAR CREEK	2.550	1154.83	8.89	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.044	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	6.90	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Petrolia STP	PA0094200+	0.0411	0.0411	0.0411	0.000	25.00	7.40

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17C	49141	SOUTH BRANCH BEAR CREEK	0.000	1046.74	41.40	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.044	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	6.90	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
	pa	0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.01	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>			<u>Stream Name</u>							
17C		49141			SOUTH BRANCH BEAR CREEK							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
2.550	0.39	0.00	0.39	.0636	0.00803	.457	11.44	25	0.09	1.793	25.00	6.94
<b>Q1-10 Flow</b>												
2.550	0.25	0.00	0.25	.0636	0.00803	NA	NA	NA	0.07	2.207	25.00	6.96
<b>Q30-10 Flow</b>												
2.550	0.53	0.00	0.53	.0636	0.00803	NA	NA	NA	0.10	1.542	25.00	6.93

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

SWP Basin      Stream Code                      Stream Name  
 17C                      49141                      SOUTH BRANCH BEAR CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.550	Petrolia STP	11.41	50	11.41	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.550	Petrolia STP	1.4	12.28	1.4	12.28	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.55	Petrolia STP	25	25	12.28	12.28	4	4	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
17C	49141	SOUTH BRANCH BEAR CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.550	0.041	25.000	6.944	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
11.437	0.457	25.002	0.087	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
5.22	0.425	1.80	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.045	20.205	Owens	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
1.793	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.179	4.74	1.50	7.54
	0.359	4.31	1.25	7.54
	0.538	3.91	1.04	7.54
	0.717	3.55	0.86	7.54
	0.897	3.23	0.72	7.54
	1.076	2.93	0.60	7.54
	1.255	2.67	0.50	7.54
	1.434	2.42	0.41	7.54
	1.614	2.20	0.34	7.54
	1.793	2.00	0.29	7.54

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
17C		49141		SOUTH BRANCH BEAR CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.550	Petrolia STP	PA0094200+	0.041	CBOD5	25		
				NH3-N	12.28	24.56	
				Dissolved Oxygen			4

1A	B	C	D	E	F	G	H	I	J	K	L	M		
	Discharger Site Municipality County NPDES Permit 0.5		Petrolia Petrolia STP Fairview Township Butler PA0094200		Revised			Monday, December 18, 2023 Wednesday, January 18, 2023						
2	<b>TRC EVALUATION</b>													
3	Input appropriate values in B4:B8 and E4:E7													
4	0.3868	= Q stream (cfs)		0.5	= CV Daily									
5	0.0411	= Q discharge (MGD)		0.5	= CV Hourly									
6	30	= no. samples		1	= AFC_Partial Mix Factor									
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor									
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)									
9	0	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)									
	0	= % Factor of Safety (FOS)			= Decay Coefficient (K)									
10	Source		Reference		\FC Calculations			Reference		CFC Calculations				
11	TRC		1.3.2.iii		WLA_afc = 1.960			1.3.2.iii		WLA_cfc = 1.903				
12	PENTOXSD TRG		5.1a		LTAMULT_afc = 0.373			5.1c		LTAMULT_cfc = 0.581				
13	PENTOXSD TRG		5.1b		LTA_afc = 0.730			5.1d		LTA_cfc = 1.106				
14	Source		Effluent Limit Calculations											
16	PENTOXSD TRG		5.1f		AML_MULT = 1.231									
17	PENTOXSD TRG		5.1g		LIMIT (mg/l) = 0.500			BAT/BPJ						
18			LIMIT (mg/l) = 1.635											
	WLA_afc		$(0.19/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot 0.19/Qd) \cdot e^{-k \cdot AFC\_tc}] \dots$											
	LTAMULT_afc		$\dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs/Qd) \cdot (1-FOS/100)$											
	LTA_afc		$EXP((0.5 \cdot LN((cvh^2+1)) - 2.326 \cdot LN((cvh^2+1)^{0.5}))$											
			$wla\_afc \cdot LTAMULT\_afc$											
	WLA_cfc		$(0.11/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot 0.11/Qd) \cdot e^{-k \cdot CFC\_tc}] \dots$											
	LTAMULT_cfc		$\dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs/Qd) \cdot (1-FOS/100)$											
	LTA_cfc		$EXP((0.5 \cdot LN((cvd^2/no\_samples+1)) - 2.326 \cdot LN((cvd^2/no\_samples+1)^{0.5}))$											
			$wla\_cfc \cdot LTAMULT\_cfc$											
	AML_MULT		$EXP(2.326 \cdot LN((cvd^2/no\_samples+1)^{0.5}) - 0.5 \cdot LN((cvd^2/no\_samples+1))$											
	AVG MON LIMIT		$MIN(BAT\_BPJ, MIN(LTA\_afc, LTA\_cfc) \cdot AML\_MULT)$											
	INST MAX LIMIT		$1.5 \cdot ((av\_mon\_limit/AML\_MULT)/L\_TAMULT\_afc)$											
	$(0.011/EXP(-K \cdot CFC\_tc/1440)) + ((CFC\_Yc \cdot Qs \cdot 0.011)/(1.547 \cdot Qd)) \dots$													
	$\dots \cdot EXP(-K \cdot CFC\_tc/1440)) + Xd + (CFC\_Yc \cdot Qs \cdot Xs/1.547 \cdot Qd) \cdot (1-FOS/100)$													
	Stream	Chlorine Required	=	perennial	Chlorine Demand	+	Chlorine Residual							
	Stream	Reach/Node	1	1										
	Stream	Flow	Conditions	Perennial										
	Stream	Code		49141										
	Stream	Function												
	Samples			30										
	reach	outfall	RMI	2.55										
	reach	Reach End	RMI	0										
	reach		feet	13464										
	drainage		sq miles	8.89										
	TRC	limitation	average	mg/L	0.050									
			maximum	mg/L	1.600									
	elevation	modelled	feet	1155.38										
	elevation	modelled	feet	1046.74										
	slope	modelled	foot/foot	0.008										
	low flow		cfs/sq mi	0.044										
	discharge		mgd	0.0411										
	Runoff	Period	hours	24.000										
	BAT controlling													
	stream	flow	cfs	0.38683										
	stream	flow	MGD	0.250013										
	stream	flow	total	MGD	0.291113									
	stream	chlorine	demand	mg/L	0.3									
	discharge	discharge	demand	mg/L										
	stream	Total Stream/Waste	ratio	7.1										
	Extremely rapid dry stream chlorine disipation assumed.													
	BAT	TRC	mean	BAT	0.5									
	BAT	TRC	maximum	BAT	1.6									
	B	C	D	E	F	G	H	I	J	K	L	M		

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	8.5	13.7	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	10.2	15.4	XXX	30	45	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	5.4	XXX	XXX	16.0	XXX	33.0	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	1.8	XXX	XXX	5.5	XXX	11.0	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001 after disinfection