

COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
WATER MANAGEMENT PROGRAM

**AUTHORIZATION TO DISCHARGE UNDER THE  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

**NPDES PERMIT NO. PA0094960 A-1**

In compliance with the provisions of the Clean Water Act, 33 U.S.C. Section 1251 et seq. (the "Act") and Pennsylvania's Clean Streams Law, as amended, 35 P.S. Section 691.1 et seq.,

Urban Life Management, LLC  
40 Van Winkle Avenue  
Garfield, NJ 07026

is authorized to discharge from a facility located at

Barnes Apartments Sewage Treatment Plant  
Somerset Township  
Washington County

to receiving waters named Little Chartiers Creek

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts A, B, and C hereof.

**THIS PERMIT SHALL EXPIRE AT MIDNIGHT, March 31, 2015.**

The authority granted by this permit is subject to the following further qualifications:

1. If there is a conflict between the application, its supporting documents and/or amendments and the terms and conditions of this permit, the terms and conditions shall apply.
2. Failure to comply with the terms, conditions, or effluent limitations of this permit is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal.
3. Complete application for renewal of this permit, or notification of intent to cease discharging by the expiration date, must be submitted to the Department at least 180 days prior to the expiration date (unless permission has been granted by the Department for submission at a later date), using the appropriate NPDES permit application form.

In the event that a timely and complete application for renewal has been submitted and the Department is unable, through no fault of the permittee, to reissue the permit before the expiration date, the terms and conditions of this permit, including submission of the Discharge Monitoring Reports, will be automatically continued and will remain fully effective and enforceable pending the grant or denial of the application for permit renewal.

4. This NPDES permit does not constitute authorization to construct or make modifications to wastewater treatment facilities necessary to meet the terms and conditions of this permit.

DATE PERMIT ISSUED: March 17, 2010

ISSUED BY \_\_\_\_\_

DATE EFFECTIVE: April 1, 2010

Samuel C. Harper  
Southwest Regional Office  
Clean Water Program Manager

TRANSFER ISSUED:

PART A

1. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS FOR OUTFALL 001 WHICH RECEIVES WASTE FROM:  
the sewage treatment plant  
at Latitude 40° 10' 51.4" Longitude 80° 08' 9.2" Stream Code 36943 River Mile Index (RMI) 10.8

- a. The permittee is authorized to discharge during the period from effective date through expiration date.
- b. Based on the production data and/or anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply. Total (dissolved plus suspended fraction) is implied for each parameter unless otherwise indicated.

Discharge Parameter	DISCHARGE LIMITATIONS (gross unless otherwise indicated)					MONITORING REQUIREMENTS		
	Mass Units (lbs/day except flow)			Concentrations (mg/l unless otherwise indicated)		Measurement Frequency	Sample Type	
	Average Monthly	Average Weekly	Max. Daily	Average Monthly	Average Weekly			
Flow (mgd)	0.0023					2/month	measured	
CBOD-5 Day		25				2/month	grab	
Suspended Solids		30				2/month	grab	
Ammonia Nitrogen May 1 to Oct 31		3.0				2/month	grab	
Nov 1 to Apr 30		9.0				2/month	grab	
Phosphorus		6.0				2/month	grab	
Total Residual Chlorine		1.4				4/month	grab	
Dissolved Oxygen		5.0 mg/l minimum				2/month	grab	
Fecal Coliform Organisms May 1 to Sept 30		200/100 ml				2/month	grab	
Oct 1 to Apr 30		Geometric Mean 2,000/100 ml				2/month	grab	
		Geometric Mean						
pH		not less than 6.0 nor greater than 9.0 standard units				2/month	grab	

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location: at the outfall pipe.