

Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. **PA0095524**  
APS ID **1095476**  
Authorization ID **1451950**

**Applicant and Facility Information**

Applicant Name	<u>Tri Comm Sewer Authority</u>	Facility Name	<u>Tri Community STP</u>
Applicant Address	<u>PO Box 86</u>	Facility Address	<u>Treatment Plant Road</u>
	<u>Bolivar, PA 15923-0086</u>		<u>Robinson, PA 15949</u>
Applicant Contact	<u>Pamela Lichtenfels</u>	Facility Contact	<u>Cynthia Shetler</u>
Applicant Phone	<u>(724) 340-2100</u>	Facility Phone	<u>(724) 676-5631</u>
Client ID	<u>43169</u>	Site ID	<u>251682</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>West Wheatfield Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Indiana</u>
Date Application Received	<u>August 4, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>NPDES renewal of a minor sewage facility.</u>		

**Summary of Review**

This is a renewal of an existing discharge for a municipal minor sewage facility.

There are currently no open violations for this client (43169) as of 1/22/2024.

WQM modeling was redone to update modeling calculations for Ammonia-Nitrogen monitoring.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	January 22, 2024
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	January 23, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.25
Latitude	40° 23' 52.26"	Longitude	-79° 8' 45.83"
Quad Name	Bolivar	Quad Code	40079D2
Wastewater Description:	Sewage Effluent		
Receiving Waters	Conemaugh River (WWF)	Stream Code	43832
NHD Com ID	123715325	RMI	
Drainage Area	74.1	Yield (cfs/mi <sup>2</sup> )	0.096
Q <sub>7-10</sub> Flow (cfs)	73.8	Q <sub>7-10</sub> Basis	Stream Gauge 03044000
Elevation (ft)	1003	Slope (ft/ft)	---
Watershed No.	18-D	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Not Assessed		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Final	Name	Kiskiminetas-Conemaugh River Watersheds TMDL
Background/Ambient Data		Data Source	
pH (SU)	7.0	Default	
Temperature (°F)	20	Default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake		Westmoreland County Municipal Authority	
PWS Waters	Conemaugh River	Flow at Intake (cfs)	2576
PWS RMI	30	Distance from Outfall (mi)	8.5

Changes Since Last Permit Issuance: None.

Other Comments: The site discharges to the Conemaugh River, for which the Department has developed a Final TMDL for Aluminum, Iron, and Manganese. The site is listed as a negligible discharge in Appendix c of the TMDL, and therefore, no WLA has been given to the site.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Tri Community STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
3284410	1984			
3284410 A-1	August 5, 2020			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Aerated Lagoon	Chlorine	0.11
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.25	408	Not Overloaded		

**Changes Since Last Permit Issuance:** The WQM permit was amended in 2020 for the addition of a dechlorination tablet feeder.

**Other Comments:** The wastewater treatment process consists of a wet well pump station, primary lagoon, secondary lagoon, a dual chamber chlorine contact tank, and a Norweco Tri-Max tablet feeder using sodium thiosulfate tablets for dechlorination.

Compliance History

DMR Data for Outfall 001 (from November 1, 2023 to October 31, 2024)

Parameter	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23
Flow (MGD) Average Monthly	0.0484	0.0446	0.0641	0.047	0.0551	0.1118	0.2195	0.1246	0.0906	0.213	0.0902	0.0914
Flow (MGD) Daily Maximum	0.0756	0.0637	0.33	0.0663	0.0833	0.3393	0.9523	0.5229	0.2434	0.953	0.3611	0.4506
pH (S.U.) Instantaneous Minimum	6.54	6.51	6.75	6.65	6.43	6.41	6.68	7.22	6.44	6.27	6.73	6.38
pH (S.U.) Instantaneous Maximum	7.1	7.42	7.72	7.83	7.13	7.0	8.87	8.36	8.07	7.34	7.19	7.18
DO (mg/L) Instantaneous Minimum	5.77	3.65	3.06	2.08	2.88	2.26	7.86	8.75	2.67	5.41	14.54	9.9
TRC (mg/L) Average Monthly	0.02	0.03	0.04	0.03	0.04	0.04	0.03	0.1	0.07	0.04	0.04	0.06
TRC (mg/L) Instantaneous Maximum	0.08	0.11	0.12	0.09	0.26	0.17	0.13	0.14	1.08	0.12	0.18	0.21
CBOD5 (lbs/day) Average Monthly	< 1.1	< 2.3	2.7	< 1.3	< 1.7	< 2.0	21.5	8.4	< 3.4	< 4.5	< 1.2	< 1.1
CBOD5 (lbs/day) Weekly Average	2.3	4.3	4.6	2.5	3.9	2.9	73.0	11.5	9.9	11.2	< 1.5	1.7
CBOD5 (mg/L) Average Monthly	< 2.0	< 6.0	7.0	< 3.0	< 4.0	< 3.0	12.0	10.0	< 5.0	< 3.0	< 2.0	< 2.0
CBOD5 (mg/L) Weekly Average	4.0	13.0	11.0	5.0	9.0	5.0	21.0	17.0	14.0	5.0	< 2.0	3.0
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	94	128	96	138	125	174	111	143.0	127	167	151	124
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	105	158	171	246	217	238	150	182	172	245	214	166
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	222	324	234	337	282	218	141	187.0	194	153	247	243

NPDES Permit Fact Sheet  
Tri Community STP

NPDES Permit No. PA0095524

TSS (lbs/day) Average Monthly	5.3	4.1	6.1	< 3.5	2.9	8.8	63.6	17.4	7.2	9.6	5.9	4.8
TSS (lbs/day) Raw Sewage Influent   Average Monthly	98	110	80	115	131	163	122	124	84.0	166	122	131
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	150	209	219	171	237	271	171	194	102.0	258	177	264
TSS (lbs/day) Weekly Average	7.6	6.7	7.5	4.7	3.7	11.1	201.7	22.2	11.2	12.4	10.4	7.3
TSS (mg/L) Average Monthly	12.0	10.0	15.0	< 9.0	7.0	11.0	42.0	23.0	11.0	7.0	9.0	9.0
TSS (mg/L) Raw Sewage Influent   Average Monthly	237	272	196	280	290	206	145	170	130.0	144	198	259
TSS (mg/L) Weekly Average	13.0	15.0	16.0	12.0	9.0	13.0	58.0	42.0	16.0	10.0	15.0	11.0
Fecal Coliform (No./100 ml) Geometric Mean	< 5.0	< 5.0	< 6.0	< 5.0	< 3.0	< 5.0	< 11.0	< 5.0	< 5.0	< 15.0	< 5.0	< 29
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 5.0	< 5.0	10.0	5.0	< 5.0	5.0	113	< 5.0	< 5.0	1124	< 5.0	6016
Total Nitrogen (mg/L) Daily Maximum												17.9
Ammonia (lbs/day) Average Monthly	< 0.07	0.1	< 0.1	< 0.3	< 0.2	3.0	4.0	6.0	6.0	14	3.0	2.0
Ammonia (mg/L) Average Monthly	< 0.161	0.241	< 0.276	< 0.668	0.474	2.81	1.85	7.46	9.4	10.29	5.61	2.9
Total Phosphorus (mg/L) Daily Maximum												4.1

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	0.25	
Latitude	40° 23' 53.00"	Longitude	-79° 8' 46.00"	
Wastewater Description:	Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report	IMAX		92a.61

Comments: E. Coli monitoring is based on the Department's SOP for new and reissued permits.

### Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
N/A	N/A	N/A	N/A

Comments: WQM 7.0b was run, and modeling did not justify any water quality-based limits.

### Best Professional Judgment (BPJ) Limitations

Comments: A dissolved oxygen limit of a minimum of 4.0 mg/l, and monitoring for ammonia-nitrogen, total nitrogen, total phosphorus, influent BOD5 and influent TSS.

### Anti-Backsliding

N/A

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Average Monthly	Weekly Average	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/week	Grab
TRC	XXX	XXX	0.5	XXX	XXX	1.6	1/day	Grab
CBOD5	52.2	78.2	25.0	40.0	XXX	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	Report	XXX	XXX	XXX	1/week	8-Hr Composite
TSS	62.6	93.9	30.0	45.0	XXX	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	Report	XXX	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia	Report	XXX	Report	XXX	XXX	XXX	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: Effluent limits are technology-based limits derived from Chapter 92a and Chapter 95.2, except for Dissolved Oxygen (DO) and Ammonia-Nitrogen (Ammonia), which are Best Professional Judgment standards.

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>											
18C		43832		CONEMAUGH RIVER											
<b>NH3-N Acute Allocations</b>															
<hr/>															
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction								
29.980	Tri Community	9.64	50	9.64	50	0	0								
<b>NH3-N Chronic Allocations</b>															
<hr/>															
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction								
29.980	Tri Community	1.91	25	1.91	25	0	0								
<b>Dissolved Oxygen Allocations</b>															
<hr/>															
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction						
29.98	Tri Community	25	25	25	25	3	3	0	0						

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18C	43832	CONEMAUGH RIVER		
<u>RMI</u> 29.980	<u>Total Discharge Flow (mgd)</u> 0.250	<u>Analysis Temperature (°C)</u> 20.026	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 143.434	<u>Reach Depth (ft)</u> 1.090	<u>Reach WDRatio</u> 131.546	<u>Reach Velocity (fps)</u> 0.476	
<u>Reach CBOD5 (mg/L)</u> 2.12	<u>Reach Kc (1/days)</u> 0.072	<u>Reach NH3-N (mg/L)</u> 0.13	<u>Reach Kn (1/days)</u> 0.701	
<u>Reach DO (mg/L)</u> 8.216	<u>Reach Kr (1/days)</u> 5.573	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.349	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.035	2.11	0.13	8.24
	0.070	2.11	0.12	8.24
	0.105	2.10	0.12	8.24
	0.140	2.10	0.12	8.24
	0.174	2.09	0.11	8.24
	0.209	2.09	0.11	8.24
	0.244	2.08	0.11	8.24
	0.279	2.08	0.11	8.24
	0.314	2.07	0.10	8.24
	0.349	2.07	0.10	8.24

RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
29.980	Tri Community	PA00095524	0.090	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC			
18C	43832 CONEMAUGH RIVER			29.980	1003.00	772.00	0.00000	0.00	<input checked="" type="checkbox"/>			
<b>Stream Data</b>												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH	
Q7-10	0.096	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
<b>Discharge Data</b>												
				Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH			
Name		Permit Number		0.0900	0.2500	0.2500	0.000	25.00	7.00			
<b>Parameter Data</b>												
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
Parameter Name												
CBOD5				25.00	2.00	0.00	1.50					
Dissolved Oxygen				3.00	8.24	0.00	0.00					
NH3-N				25.00	0.00	0.00	0.70					

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
18C		43832 CONEMAUGH RIVER		27.260	967.00	831.00	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>											
<b>Design Cond.</b>											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.095	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
<b>Discharge Data</b>											
Name		Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH			
			0.0000	0.0000	0.0000	0.000	25.00	7.00			
<b>Parameter Data</b>											
Parameter Name			Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
CBOD5			25.00	2.00	0.00	1.50					
Dissolved Oxygen			3.00	8.24	0.00	0.00					
NH3-N			25.00	0.00	0.00	0.70					

**WQM 7.0 Hydrodynamic Outputs**

RMI	Stream Flow	PWS With	Stream Code		Stream Name							
			18C	43832	CONEMAUGH RIVER							
			Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
29.980	74.11	0.00	74.11	.3868	0.00251	1.09	143.43	131.55	0.48	0.349	20.03	7.00
<b>Q1-10 Flow</b>												
29.980	47.43	0.00	47.43	.3868	0.00251	NA	NA	NA	0.37	0.447	20.04	7.00
<b>Q30-10 Flow</b>												
29.980	100.79	0.00	100.79	.3868	0.00251	NA	NA	NA	0.57	0.294	20.02	7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

TRC Spreadsheet- Tri Community STP

TRC EVALUATION							
Input appropriate values in A3:A9 and D3:D9							
Source	Reference	AFC Calculations		Reference	CFC Calculations		
TRC	1.3.2.iii	WLA_afc = 60.891		1.3.2.iii	WLA_cfc = 59.356		
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581		
PENTOXSD TRG	5.1b	LTA_afc = 22.689		5.1d	LTA_cfc = 34.507		
Effluent Limit Calculations							
PENTOXSD TRG	5.1f	AML MULT = 1.231					
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500			BAT/BPJ		
		INST MAX LIMIT (mg/l) = 1.635					
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_afc		$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$					
LTA_afc		wla_afc*LTAMULT_afc					
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_cfc		$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$					
LTA_cfc		wla_cfc*LTAMULT_cfc					
AML MULT		$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$					
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)					
INST MAX LIMIT		$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$					

