

Application Type

**Renewal**

Facility Type

**Non-Municipal**

Major / Minor

**Minor**

Application No.

**PA0096121**

APS ID

**1101905**

Authorization ID

**1463625**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<b>McGuffey School District</b>	Facility Name	<b>Joe Walker Elementary School</b>
Applicant Address	90 McGuffey Drive	Facility Address	2510 Park Avenue
	Claysville, PA 15323-2304		Washington, PA 15323
Applicant Contact	Craig McKee	Facility Contact	Same as Applicant
Applicant Phone	(724) 948-3731	Facility Phone	Same as Applicant
Client ID	23970	Site ID	252115
Ch 94 Load Status	Not Overloaded	Municipality	South Franklin Township
Connection Status	No Prohibitions	County	Washington
Date Application Received	November 30, 2023	EPA Waived?	Yes
Date Application Accepted	December 7, 2023	If No, Reason	
Purpose of Application	NPDES Permit Renewal for Discharge of Treated Sewage Effluent.		

**Summary of Review**

DEP received an application for a renewal of NPDES Permit No. PA0096121, which was previously issued on June 1, 2019. The permit expired on May 31, 2024. A timely renewal application was received on November 30, 2023. The permit was originally issued in 1998.

The design discharge flow rate is 0.0045 MGD, and the discharge is to an unnamed tributary of Chartiers Creek, which is classified as warm water fisheries (WWF) and located in the State Watershed 20-F.


The WQM permit No. 6376412 issued on January 20, 1977 authorized the construction of this facility to serve Joe Walker Elementary School which consist of: comminutor and bar screen, equalization tank, aeration tank, clarifier, sludge digester, sand filters, chlorine contact tank and dechlorination.

An Operations Compliance Check Summary Report was completed by DEP's Operations Section on January 31, 2024 and concluded that there are currently no compliance issues with this sewage treatment plant. Checking on last time this facility was inspected, the inspection report on August 13, 2021 stated that no violations were noticed during this inspection.

The application stated that there were no changes to the facility conditions regarding discharge, receiving stream, or treatment technology. No changes are foreseen for the next five years, and therefore, Act 537 was not needed.

No industrial users are discharging to this facility per the application.

The applicant provides a proof of Act 14, P.L. 834 compliance with the November 28, 2023 letters. No comments were received.

Approve	Deny	Signatures	Date
X		 Hazim Aldalli / Environmental Engineering Specialist	August 12, 2024
X		 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager	October 18, 2024

### Summary of Review

Sludge use and disposal description and location(s): Off site at Allegheny Valley JSA STP, there are no sludge been hauled/applied within this facility.

#### Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	0.0045
Latitude	40° 7' 15"	Longitude	-80° 17' 21"
Quad Name	Prosperity	Quad Code	40080A3
Wastewater Description:	Sewage Effluent		
Receiving Waters	UNT Chartiers Creek (WWF)	Stream Code	37157
NHD Com ID	99694830	RMI	0.07
Drainage Area	0.76	Yield (cfs/mi <sup>2</sup> )	0.0078
Q <sub>7-10</sub> Flow (cfs)	0.00594	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	1231	Slope (ft/ft)	0.0033
Watershed No.	20-F	Chapter 93 Class.	WWF
Existing Use			
Exceptions to Use	None.		
Assessment Status	Impaired		
Cause(s) of Impairment	NUTRIENTS, PATHOGENS, SILTATION GRAZING IN RIPARIAN OR SHORELINE ZONES, RURAL (RESIDENTIAL AREAS), SITE CLEARANCE (LAND DEVELOPMENT OR REDEVELOPMENT), SOURCE UNKNOWN		
Source(s) of Impairment			
TMDL Status	Final	Name	Chartiers/Little Chartiers Creek TMDL for PCBs and Chlordane
Background/Ambient Data	Data Source		
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake	WESTERN PA W CO-WASHINGTON DIS		
PWS Waters	CHARTIERS CREEK	Flow at Intake (cfs)	0.197
PWS RMI	43.7	Distance from Outfall (mi)	>4.0

Changes Since Last Permit Issuance:

- The receiving stream was evaluated as a dry/intermittent stream per the previous pollution report with zero (0.0 cfs) flow calculated. The report also stated that a CBOD<sub>5</sub> of 10 mg/L and TSS of 25 mg/L were assigned to this discharge to avoid public health nuisance. 300 ft northwest from the STP Outfall, the receiving stream is discharging to the Chartiers Creek.
- Q<sub>7-10</sub> flow, elevation, drainage area, and low flow yield were all updated to match USGS Stream Stats new data (see Attachment A).
- DEP updated its WQM 7.0 criteria for Ammonia-Nitrogen (NH<sub>3</sub>-N) in 2019. Limits and conditions of this permit need to be redeveloped to an adequate level to protect water quality.
- *E. Coli* monitoring requirements will be introduced to this renewal which is in compliance with DEP SOP No. BCW-PMT-033 revised February 5, 2024.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Joe Walker Elementary School				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
6376412	January 20, 1977			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Aeration	Chlorination	0.00156
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0045	34.62	Not Overloaded	Sludge Digester	Landfill

Changes Since Last Permit Issuance: None.

Other Comments: None.

**Compliance History**  
**Operations Compliance Check Summary Report**

**Facility:** Joe Walker Elementary School STP

**NPDES Permit No.:** PA0096121

**Compliance Review Period:** 1/1/19-1/31/24

**Inspection Summary:**

INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC
08/13/2021	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted
08/13/2021	Administrative/File Review	PA Dept of Environmental Protection	No Violations Noted

**Violation Summary:**

No violations noted during review period

**Open Violations by Client ID:**

No open violations for Client ID 23970

**Enforcement Summary:**

No enforcements executed during review period

**Effluent Violation Summary:**

MON PD END	PARAMETER	SAMPLE	PERMIT	UNIT	STAT BASE CODE	FACILITY COMMENTS
February-22	Ammonia-Nitrogen	14.15	9	mg/L	Average Monthly	During the month of February this facility will have an Ammonia violation. This violation was caused by cold weather reducing the treatment process. With warmer months ahead we do not expect a violation moving forward.
September-19	Fecal Coliform	2420	1000	No./100 ml	Instantaneous Maximum	The facility will have a fecal coliform max violation. The first sample of the month was just above the max limitation and all samples after were well below. The disinfection system was cleaned to allow for proper disinfection.
May-19	Fecal Coliform	1733	1000	CFU/100 ml	Instantaneous Maximum	For the Fecal (max) violation the operator increased the Chlorine dose.

**Compliance Status:** Facility is generally in compliance with no open violations or pending enforcements.

**Completed by:** Amanda Illar

**Completed date:** 1/31/24

Other Comments: None.

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	0.0045	
Latitude	40° 7' 15.00"	Longitude	-80° 17' 21.00"	
Wastewater Description:	Treated Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/L)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli (No./100 ml)	Report	IMAX	-	92a.61
D.O. (mg/L)	4.0	Min	-	BPJ
NH <sub>3</sub> -N (mg/L)	25	Average Monthly	-	BPJ
	50	IMAX		
Total N (mg/L)	Report	Average Monthly	-	92a.61
Total P (mg/L)	Report	Average Monthly	-	92a.61

### Water Quality-Based Limitations

The existing discharge was evaluated using WQM 7.0 for CBOD<sub>5</sub>, Ammonia Nitrogen and Dissolved Oxygen. The Total Suspended Solids (TSS), pH, and Fecal Coliform parameters are not evaluated using WQM 7.0. The following limitations were determined through water quality modeling, output files attached (Attachment B and C):

Parameter	Limit (mg/L)	SBC	Model
TRC	0.15	Average Monthly	DEP TRC Calculation
CBOD <sub>5</sub> (May1-Oct 31)	25	Average Monthly	WQM7.0
CBOD <sub>5</sub> (Nov 1- Apr 30)	25	Average Monthly	WQM7.0
NH <sub>3</sub> -N (May1-Oct 31)	3.4	Average Monthly	WQM7.0
NH <sub>3</sub> -N (Nov 1- Apr 30)	8.8	Average Monthly	WQM7.0
Dissolved Oxygen	4.0	Minimum	WQM7.0

Comments: WQM 7.0 was used to determine the newly WQBEL seasonal limits for Ammonia Nitrogen (NH<sub>3</sub>-N) following PADEP's Implementation Guidance of Section 93.7 Ammonia Criteria, 1997.; The new Average Monthly Limits (AMLs) of 3.4 mg/L for the warm period is less stringent than the current permit limit of 3.0 mg/L. Previous limits will be carried over in accordance with anti-backsliding requirements. Also, WQM model produced a new AML of 8.8 mg/L for the cold period, which is more stringent than the current permit limit of 9.0 mg/L. Reviewing renewal application effluent sampling and eDMR values for Ammonia-Nitrogen, the facility can meet the newly imposed Ammonia-Nitrogen seasonal limit for the cold period as this plant has achieved lower than the new proposed limits. No compliance schedule is necessary. Weekly monitoring is required.

For the Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>), the WQM 7.0 model generated a WQBEL AML of 25 mg/L a year around, which is less stringent limit than the current permit limit of 10 mg/L. Therefore, previous limits will be carried over in accordance with the anti-backsliding requirements.

### **Best Professional Judgment (BPJ) Limitations**

A minimum Dissolved Oxygen (DO) limit of 4.0 mg/L was established based on Best Professional Judgment (BPJ) to ensure adequate operation and maintenance as Technology-Based Effluent Limitation. Checking on the eDMRs, the facility can meet the newly imposed Dissolved Oxygen limit as the plant has achieved effluent limits of DO greater than the proposed limit. No compliance schedule is necessary.

### **Anti-Backsliding**

The previously imposed limits for pH Effluent Limitation of (6.0 Minimum, and 9.0 Maximum SIU), Fecal Coliform AML Geo Mean seasonal limits of (200 & 2000 CFU/100 ml), TSS AML, and Ins. Max of (25, and 50 mg/L), Carbonaceous Biochemical Oxygen Demand CBOD<sub>5</sub> yearly around AML, and Ins. Max of (10, and 20 mg/L), Ammonia-Nitrogen warm period limit of (3.0 mg/L), TRC AML of (0.10 mg/L) and Ins. Max of (0.3 mg/L); will be all unchanged due to Anti-Backsliding as stated in 40 CFR Section 122.44(l).

### **Total Maximum Daily Load (TMDL) Considerations**

This facility discharges to the Chartiers Creek Watersheds. This Watershed has a Final TMDL and is impaired by Metals and PCBs. Abandoned mine drainage is the source of the TMDL impairment. Also, baren lands and urban areas are considered as contributing sources (see page 5 of the TMDL document). No Waste Load Allocations (WLAs) have been developed for this sewage discharge.

In accordance with 40 CFR § 122.44(d)(1)(vii)(B), when developing WQBELs, the permitting authority shall ensure that effluent limits developed to protect a narrative water quality criterion, a numeric water quality criterion, or both, are consistent with the assumptions and requirements of any available WLA pursuant to 40 CFR § 130.7.

The applicable water quality criteria for this watershed can be summarized in the following table:

Parameter	Application Value (mg/L)	Criterion Value (mg/L)	Total Recoverable/Dissolved
Aluminum (Al)	0.1	0.75	Total Recoverable
Iron (Fe)	0.05	1.5	30-day average; Total
Manganese (Mn)	0.02	1.00	Total Recoverable
pH	6.8-8.0	6.0-9.0	N/A

When the applicant's effluent sampling results are compared with the water quality criteria that's assigned for the Chartiers Creek watershed (see page 12 of the TMDL document), the effluent concentrations for the TMDL parameters do not exceed the water quality criteria. Additionally, natural attenuation of PCB from sediments is expected to achieve the PCB TMDL goals. This sanitary sewage discharge is not expected to contribute to the stream Metals or PCB impairments. Annual monitoring requirements for Total Iron, Total Manganese, and Total Aluminum will be carried over and imposed for this renewal permit.

### **TN and TP Monitoring**

Per SOP (No. BCW-PMT-033, *Establishing Effluent Limitations for Individual Sewage Permits, ver 2.0*):

- Nutrient monitoring is required, at a minimum, to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). Sewage discharges with design flows > 2,000 gpd require monitoring, at a minimum, for Total Nitrogen and Total Phosphorus in new and reissued permits.

The receiving stream (UNT of Chartiers Creek) is not impaired for nutrients (per PA eMAP and the reviewed eDMRs), therefore; advanced treatment requirements for TN, and TP will not be imposed. Also, the newly proposed more stringent Ammonia limits will help in lowering Total Nitrogen.

Annual monitoring is recommended.

### **Disinfection**

Total Residual Chlorine (TRC) AML limit of 0.15 mg/L and IMAX of 0.4 mg/L were calculated based on the DEP preset values entered in the Department Calculation Sheet (Appendix C) for chlorine stream and discharge demands. Due to anti-backsliding rules stated above; a limit of 0.1 mg/L and IMAX of 0.3 mg/L will be carried over from the previous permit for this renewal.

### **E. Coli**

Pursuant to 25 Pa. code § 92a.61(b) annual monitoring for *E. Coli* will be imposed at Outfall 001 to determine if *E. Coli* will be a pollutant of concern, which is consistent with DEP SOP No. BCW-PMT-033 revised February 5, 2024.

### **Monitoring Frequency Considerations**

The previous permit writer agreed with the facility manager to set the monitoring frequency for pH, TRC, and Dissolved Oxygen (DO) on a daily basis and moving from the current frequency of 3/weekday after the facility will start a project to upgrade their sampler, as stated in the previous factsheet dated February 26, 2019. This permit writer sent an email to authority to update DEP on this matter, the Authority responded that "We are requesting a reduction in field parameter (pH, Dissolved Oxygen, and Total Residual Chlorine) frequencies on the new permit. The facility is requesting three day per week field readings to coincide with their contract with the licensed wastewater operator. Also, the Authority mentioned in their response that this facility will be decommissioned once a public sewage line will run to the Elementary School. Currently there is no definite timeline as to when the facility will be connected to public sewer. Since the facility is generally in compliance with no open violation, the Department is allowing this exception during this renewed permit term. The monitoring frequency may be revised to be more stringent during the next permit renewal.

The monitoring frequencies justified above are consistent with current policy and Table 6-3 of DEP's Technical Guidance for the Development and Specification of Effluent Limitations.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.0045	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	3/week	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	3/week	Grab
TRC	XXX	XXX	XXX	0.1	XXX	0.3	3/week	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20.0	2/month	Grab
TSS	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	8.8	XXX	17.6	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	Grab
<i>E. Coli</i> (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report Daily Max	1/year	Grab
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Total Aluminum	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Iron	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Total Manganese	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab


Compliance Sampling Location: Outfall 001.

Other Comments: None.

**ATTACHMENT A:**  
**USGS StreamStats**

## StreamStats Report

Region ID: PA  
Workspace ID: PA20231229161332587000  
Clicked Point (Latitude, Longitude): 40.12077, -80.28883  
Time: 2023-12-29 11:13:53 -0500



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.76	square miles
ELEV	Mean Basin Elevation	1231	feet

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.76	square miles	2.26	1400
ELEV	Mean Basin Elevation	1231	feet	1050	2580

#### Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.021	ft^3/s
30 Day 2 Year Low Flow	0.0411	ft^3/s
7 Day 10 Year Low Flow	0.00594	ft^3/s
30 Day 10 Year Low Flow	0.013	ft^3/s
90 Day 10 Year Low Flow	0.0271	ft^3/s

*Low-Flow Statistics Citations*

**Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.19.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.3.2

**ATTACHMENT B:**  
**WQM7.0 Model Results (Summer)**

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20F		37157 Trib 37157 to Chartiers Creek	0.070	1231.00	0.76	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH	Temp (°C)	Stream pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.008	0.01	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data								
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
Joe Wak Elm STP	PA0096121	0.0045	0.0045	0.0045	0.000	20.00	7.00	
Parameter Data								
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5		25.00	2.00	0.00	1.50			
Dissolved Oxygen		4.00	8.24	0.00	0.00			
NH3-N		25.00	0.00	0.00	0.70			

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC			
20F		37157	Trib 37157 to Chartiers Creek	0.000	1229.00	0.77	0.00000	0.00	<input checked="" type="checkbox"/>			
<b>Stream Data</b>												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	pH	pH
Q7-10	0.008	0.01	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
<b>Discharge Data</b>												
	Name	Permit Number		Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor		Disc Temp (°C)	Disc pH		
	Joe Wak Elm STP	PA0096121		0.0045	0.0045	0.0045	0.000		20.00	7.00		
<b>Parameter Data</b>												
	Parameter Name			Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5			25.00	2.00	0.00	1.50					
	Dissolved Oxygen			4.00	8.24	0.00	0.00					
	NH3-N			25.00	0.00	0.00	0.70					

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>								
20F			37157			Trib 37157 to Chartiers Creek								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH		
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)			
<b>Q7-10 Flow</b>														
0.070	0.01	0.00	0.01	.007	0.00541	.256	2.56	10	0.02	0.218	22.30	7.00		
<b>Q1-10 Flow</b>														
0.070	0.00	0.00	0.00	.007	0.00541	NA	NA	NA	0.02	0.241	21.77	7.00		
<b>Q30-10 Flow</b>														
0.070	0.01	0.00	0.01	.007	0.00541	NA	NA	NA	0.02	0.200	22.69	7.00		

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 D.O.Simulation**

SWP Basin	Stream Code	Stream Name		
20F	37157	Trib 37157 to Chartiers Creek		
RMI	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH	
0.070	0.004	22.302	7.000	
Reach Width (ft)	Reach Depth (ft)	Reach WDRatio	Reach Velocity (fps)	
2.562	0.256	10.000	0.020	
Reach CBOD5 (mg/L)	Reach Kc (1/days)	Reach NH3-N (mg/L)	Reach Kn (1/days)	
14.41	1.386	1.84	0.836	
Reach DO (mg/L)	Reach Kr (1/days)	Kr Equation	Reach DO Goal (mg/L)	
5.954	20.458	Owens	5	
Reach Travel Time (days)	Subreach Results			
0.218	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.022	13.94	1.81	6.27
	0.044	13.48	1.78	6.50
	0.065	13.03	1.74	6.66
	0.087	12.60	1.71	6.79
	0.109	12.19	1.68	6.89
	0.131	11.78	1.65	6.97
	0.152	11.40	1.62	7.04
	0.174	11.02	1.59	7.10
	0.196	10.66	1.56	7.16
	0.218	10.31	1.54	7.22

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>						
20F	37157	Trib 37157 to Chartiers Creek							
<b>NH3-N Acute Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
0.070	Joe Wak Elm ST	8.51	13.16	8.51	13.16	0	0		
<b>NH3-N Chronic Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
0.070	Joe Wak Elm ST	1.58	3.41	1.58	3.41	0	0		
<b>Dissolved Oxygen Allocations</b>									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
0.07	Joe Wak Elm STP	25	25	3.41	3.41	4	4	0	0

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20F	37157	Trib 37157 to Chartiers Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.070	Joe Wak Elm STP	PA0096121	0.004	CBOD5	25		
				NH3-N	3.41	6.82	
				Dissolved Oxygen			4

**ATTACHMENT B:**  
**WQM7.0 Model Results (Winter)**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name		RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
					(ft)	(sq mi)	(ft/ft)	(mgd)	
20F		37157 Trib 37157 to Chartiers Creek		0.070	1231.00	0.76	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>									
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Tributary Temp (°C)	Stream pH (°C)
Q7-10	0.016	0.01	0.00	0.000	0.000	10.0	0.00	0.00	5.00
Q1-10		0.00	0.00	0.000	0.000				
Q30-10		0.00	0.00	0.000	0.000				
<b>Discharge Data</b>									
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
	Joe Wak Elm STP	PA0096121	0.0045	0.0045	0.0045	0.000	15.00	7.00	
<b>Parameter Data</b>									
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5	25.00	2.00	0.00	1.50				
	Dissolved Oxygen	4.00	12.51	0.00	0.00				
	NH3-N	25.00	0.00	0.00	0.70				

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC	
20F		37157	Trib 37157 to Chartiers Creek		0.000	1229.00	0.77	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (°C)	Tributary Temp (°C)	Stream pH (°C)
Q7-10	0.016	0.01	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number		Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor		Disc Temp (°C)	Disc pH
	Joe Wak Elm STP	PA0096121		0.0045	0.0045	0.0045	0.000		15.00	7.00
<b>Parameter Data</b>										
	Parameter Name			Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
	CBOD5			25.00	2.00	0.00	1.50			
	Dissolved Oxygen			4.00	12.51	0.00	0.00			
	NH3-N			25.00	0.00	0.00	0.70			

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>										
20F		37157		Trib 37157 to Chartiers Creek										
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH		
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)			
<b>Q7-10 Flow</b>		0.070	0.01	0.00	0.01	.007	0.00541	.256	2.56	10	0.02	0.218	10.40	7.00
<b>Q1-10 Flow</b>		0.070	0.00	0.00	0.00	.007	0.00541	NA	NA	NA	0.02	0.241	11.47	7.00
<b>Q30-10 Flow</b>		0.070	0.01	0.00	0.01	.007	0.00541	NA	NA	NA	0.02	0.200	9.63	7.00

### **WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
20F	37157	Trib 37157 to Chartiers Creek			
<u>RMI</u>		<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.070		0.004	10.396	7.000	
<u>Reach Width (ft)</u>		<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
2.562		0.256	10.000	0.020	
<u>Reach CBOD5 (mg/L)</u>		<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
14.41		1.394	4.76	0.334	
<u>Reach DO (mg/L)</u>		<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.918		15.425	Owens	5	
<u>Reach Travel Time (days)</u>		<u>Subreach Results</u>			
0.218		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
		0.022	14.13	4.72	8.35
		0.044	13.86	4.69	8.67
		0.065	13.59	4.65	8.91
		0.087	13.33	4.62	9.09
		0.109	13.07	4.59	9.22
		0.131	12.82	4.55	9.32
		0.152	12.57	4.52	9.40
		0.174	12.33	4.49	9.47
		0.196	12.09	4.46	9.52
		0.218	11.85	4.42	9.57

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
20F	37157	Trib 37157 to Chartiers Creek					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.070	Joe Wak Elm ST	18.36	28.38	18.36	28.38	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.070	Joe Wak Elm ST	4.08	8.82	4.08	8.82	1	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)
0.07	Joe Wak Elm STP	25	25	8.82	8.82	4	4
						0	0

**WQM 7.0 Effluent Limits**

SWP Basin	Stream Code	Stream Name					
		20F	37157	Trib 37157 to Chartiers Creek			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.070	Joe Wak Elm STP	PA0096121	0.004	CBOD5	25		
				NH3-N	8.82	17.64	
				Dissolved Oxygen			4

**ATTACHMENT C:**  
**DEP TRC Calculation Sheet**

## TRC EVALUATION

Input appropriate values in A3:A9 and D3:D9

0.00594	= Q stream (cfs)	0.5	= CV Daily
0.0045	= Q discharge (MGD)	0.5	= CV Hourly
12	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.291	1.3.2.iii	WLA_cfc = 0.276
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc= 0.109	5.1d	LTA_cfc = 0.161

Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.382	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.150	AFc
		INST MAX LIMIT (mg/l) = 0.437	

wLA\_afc 
$$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$$

LTAMULT\_afc 
$$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$$

LTA\_afc 
$$wla_afc*LTAMULT_afc$$

WLA\_cfc 
$$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$$

LTAMULT\_cfc 
$$\text{EXP}((0.5*\text{LN}(cvd^2/no\_samples+1))-2.326*\text{LN}(cvd^2/no\_samples+1)^0.5)$$

LTA\_cfc 
$$wla_cfc*LTAMULT_cfc$$

AML MULT 
$$\text{EXP}(2.326*\text{LN}((cvd^2/no\_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no\_samples+1))$$

AVG MON LIMIT 
$$\text{MIN}(\text{BAT_BPJ},\text{MIN}(\text{LTA_afc},\text{LTA_cfc})*\text{AML_MULT})$$

INST MAX LIMIT 
$$1.5*((\text{av\_mon\_limit}/\text{AML\_MULT})/\text{LTAMULT_afc})$$