

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0096521
APS ID 1066217
Authorization ID 1401004

Applicant and Facility Information

Applicant Name	<u>PA DCNR</u>	Facility Name	<u>Boaters Change House STP</u>
Applicant Address	<u>PO Box 105</u> <u>Ohiopyle, PA 15470-0105</u>	Facility Address	<u>168 Dinnerbell Road</u> <u>Ohiopyle, PA 15470</u>
Applicant Contact	<u>David Naill</u>	Facility Contact	<u>Same as applicant</u>
Applicant Phone	<u>(724) 329-8591</u>	Facility Phone	<u>Same as Applicant</u>
Client ID	<u>52524</u>	Site ID	<u>263222</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Stewart Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Fayette</u>
Date Application Received	<u>June 27, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>July 7, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of NPDES permit for sewage discharge</u>		

Summary of Review



The permittee has applied for a renewal of NPDES Permit No. PA0096521 on June 27, 2022. NPDES Permit No. PA0096521 was previously issued by the PA Department of Environmental Protection (DEP) on September 1, 2017 and expired on August 31, 2022.

Sewage from this facility is treated through two aeration tanks connected to clarifiers. After the clarifiers, the effluent flows through chlorine tablet feeders in a chlorine contact tank. After the contact tank, the effluent flows to a dechlorination tablet feeder and then a contact tank. It then discharges to Meadow Run through outfall 001. Meadow Run is classified as High Quality – Cold Water Fishes (HQ-CWF) per Chapter 93 Designated Uses.

The applicant is currently enrolled in and will continue to use eDMR.

The applicant has complied with Act 14 Notifications and no comments were received.

The permittee is currently dealing with chronic effluent violations due to their system being underloaded. The Boaters Change House STP was designed to treat an average daily flow of 10,000 GPD. Currently, during the peak season, the plant treats less than 1000 GPD. The DEP and EPA are offering technical assistance to the permittee to find ways to resolve these issues.

Approve	Deny	Signatures	Date
X		 Jordan Coldsmith / Environmental Engineering Specialist	January 10, 2023
X		 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager	January 23, 2023

Summary of Review

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.01</u>
Latitude	<u>39° 51' 24.32"</u>	Longitude	<u>-79° 29' 47.85"</u>
Quad Name	<u>Ohiopyle</u>	Quad Code	<u>39079G4</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Meadow Run (HQ-CWF)</u>	Stream Code	<u>38488</u>
NHD Com ID	<u>69921685</u>	RMI	<u>0.62</u>
Drainage Area	<u>40.9</u>	Yield (cfs/mi ²)	<u>0.026</u>
Q ₇₋₁₀ Flow (cfs)	<u>1.07</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStat</u>
Elevation (ft)	<u>2030</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>19-E</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u>N/A</u>	Name	<u>N/A</u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>NORTH FAYETTE CNTY MUNI AUTH</u>		
PWS Waters	<u>Youghiogheny River (HQ-CWF)</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>16.3</u>

Changes Since Last Permit Issuance: None

Other Comments: N/A

Treatment Facility Summary				
Treatment Facility Name: Ohiopyle State Park Boaters Change House				
WQM Permit No.		Issuance Date		
2685405 A-1		12/09/1999		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Chlorine With Dechlorination	0.01
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.01	25	Not Overloaded	Drying	Landfill

Changes Since Last Permit Issuance: None

Other Comments: N/A

Compliance History

Operations Compliance Check Summary Report

Facility: Ohio State Park Boaters Change House STP

NPDES Permit No.: PA0096521

Compliance Review Period: 12/2017 – 12/2022

Inspection Summary:

INSP ID	INSPECTED DATE	INSP TYPE	INSPECTION RESULT DESC
3420021	08/12/2022	Administrative/File Review	No Violations Noted
3420019	08/12/2022	Compliance Evaluation	No Violations Noted
3090521	10/06/2020	Compliance Evaluation	No Violations Noted
2908758	07/09/2019	Routine/Partial Inspection	No Violations Noted
2897739	06/20/2019	Compliance Evaluation	No Violations Noted
2896105	06/07/2019	Routine/Partial Inspection	No Violations Noted
2893461	05/24/2019	Routine/Partial Inspection	No Violations Noted

Violation Summary:

No violations

Open Violations by Client ID:

Several CW violations for DCNR State Park STP's in the state.

Enforcement Summary:

No enforcements

DMR Violation Summary:

START	END	NON COMPLIANCE CATEGORY	PARAMETER	SAMPLE	PERMIT	UNIT OF MEASURE	STATISTICAL BASE CODE
09/01/2022	09/30/2022	Concentration 2 Effluent Violation	Total Suspended Solids	12.0	10.0	mg/L	Average Monthly
08/01/2022	08/31/2022	Concentration 1 Effluent Violation	Dissolved Oxygen	1.96	4.0	mg/L	Minimum
08/01/2022	08/31/2022	Concentration 2 Effluent Violation	Ammonia-Nitrogen	1.65	1.5	mg/L	Average Monthly

07/01/2022	07/31/2022	Concentration 2 Effluent Violation	Total Suspended Solids	14.0	10.0	mg/L	Average Monthly
06/01/2022	06/30/2022	Concentration 1 Effluent Violation	Dissolved Oxygen	0.69	4.0	mg/L	Minimum
06/01/2022	06/30/2022	Concentration 2 Effluent Violation	Ammonia- Nitrogen	3.12	1.5	mg/L	Average Monthly
06/01/2022	06/30/2022	Concentration 3 Effluent Violation	Ammonia- Nitrogen	3.89	3.0	mg/L	Instantaneous Maximum
05/01/2022	05/31/2022	Concentration 1 Effluent Violation	Dissolved Oxygen	0.09	4.0	mg/L	Minimum
05/01/2022	05/31/2022	Concentration 3 Effluent Violation	pH	9.08	9.0	S.U.	Maximum
04/01/2022	04/30/2022	Concentration 1 Effluent Violation	Dissolved Oxygen	3.73	4.0	mg/L	Minimum
03/01/2022	03/31/2022	Concentration 1 Effluent Violation	Dissolved Oxygen	0.55	4.0	mg/L	Minimum
03/01/2022	03/31/2022	Concentration 2 Effluent Violation	Carbonaceous Biochemical Oxygen Demand (CBOD5)	18.73	15.0	mg/L	Average Monthly
03/01/2022	03/31/2022	Concentration 3 Effluent Violation	pH	9.27	9.0	S.U.	Maximum
02/01/2022	02/28/2022	Concentration 1 Effluent Violation	Dissolved Oxygen	1.49	4.0	mg/L	Minimum
02/01/2022	02/28/2022	Concentration 3 Effluent Violation	pH	9.51	9.0	S.U.	Maximum
01/01/2022	01/31/2022	Concentration 3 Effluent Violation	pH	10.37	9.0	S.U.	Maximum
12/01/2021	12/31/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	0.76	4.0	mg/L	Minimum
12/01/2021	12/31/2021	Concentration 3 Effluent Violation	pH	9.53	9.0	S.U.	Maximum
11/01/2021	11/30/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	0.60	4.0	mg/L	Minimum
11/01/2021	11/30/2021	Concentration 3 Effluent Violation	pH	9.52	9.0	S.U.	Maximum
10/01/2021	10/31/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	3.82	4.0	mg/L	Minimum
10/01/2021	10/31/2021	Concentration 3 Effluent Violation	pH	9.58	9.0	S.U.	Maximum

09/01/2021	09/30/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	2.44	4.0	mg/L	Minimum
09/01/2021	09/30/2021	Concentration 3 Effluent Violation	pH	9.11	9.0	S.U.	Maximum
08/01/2021	08/31/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	2.10	4.0	mg/L	Minimum
07/01/2021	07/31/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	2.68	4.0	mg/L	Minimum
07/01/2021	07/31/2021	Concentration 2 Effluent Violation	Ammonia- Nitrogen	1.66	1.5	mg/L	Average Monthly
06/01/2021	06/30/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	2.72	4.0	mg/L	Minimum
05/01/2021	05/31/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	2.87	4.0	mg/L	Minimum
05/01/2021	05/31/2021	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	4.10	1.6	mg/L	Instantaneous Maximum
04/01/2021	04/30/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	2.0	4.0	mg/L	Minimum
04/01/2021	04/30/2021	Concentration 2 Effluent Violation	Carbonaceous Biochemical Oxygen Demand (CBOD5)	23.7	15.0	mg/L	Average Monthly
04/01/2021	04/30/2021	Concentration 3 Effluent Violation	Carbonaceous Biochemical Oxygen Demand (CBOD5)	32.9	30.0	mg/L	Instantaneous Maximum
04/01/2021	04/30/2021	Concentration 3 Effluent Violation	pH	9.37	9.0	S.U.	Maximum
03/01/2021	03/31/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	0.37	4.0	mg/L	Minimum
02/01/2021	02/28/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	0.21	4.0	mg/L	Minimum
02/01/2021	02/28/2021	Concentration 1 Effluent Violation	pH	3.3	6.0	S.U.	Minimum
02/01/2021	02/28/2021	Concentration 2 Effluent Violation	Carbonaceous Biochemical Oxygen Demand (CBOD5)	50.4	15.0	mg/L	Average Monthly
02/01/2021	02/28/2021	Concentration 3 Effluent Violation	Carbonaceous Biochemical Oxygen Demand (CBOD5)	77.7	30.0	mg/L	Instantaneous Maximum

01/01/2021	01/31/2021	Concentration 1 Effluent Violation	Dissolved Oxygen	0.42	4.0	mg/L	Minimum
12/01/2020	12/31/2020	Concentration 1 Effluent Violation	Dissolved Oxygen	1.9	4.0	mg/L	Minimum
12/01/2020	12/31/2020	Concentration 2 Effluent Violation	Carbonaceous Biochemical Oxygen Demand (CBOD5)	62.5	15.0	mg/L	Average Monthly
12/01/2020	12/31/2020	Concentration 3 Effluent Violation	Carbonaceous Biochemical Oxygen Demand (CBOD5)	101.0	30.0	mg/L	Instantaneous Maximum
11/01/2020	11/30/2020	Concentration 1 Effluent Violation	Dissolved Oxygen	3.9	4.0	mg/L	Minimum
10/01/2020	10/31/2020	Concentration 1 Effluent Violation	Dissolved Oxygen	3.5	4.0	mg/L	Minimum
08/01/2020	08/31/2020	Concentration 1 Effluent Violation	Dissolved Oxygen	1.93	4.0	mg/L	Minimum
08/01/2020	08/31/2020	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	6.9	1.6	mg/L	Instantaneous Maximum
07/01/2020	07/31/2020	Concentration 1 Effluent Violation	Dissolved Oxygen	3.4	4.0	mg/L	Minimum
07/01/2020	07/31/2020	Concentration 2 Effluent Violation	Ammonia- Nitrogen	2.3	1.5	mg/L	Average Monthly
07/01/2020	07/31/2020	Concentration 3 Effluent Violation	Ammonia- Nitrogen	4.4	3.0	mg/L	Instantaneous Maximum
07/01/2020	07/31/2020	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	5.9	1.6	mg/L	Instantaneous Maximum
06/01/2020	06/30/2020	Concentration 1 Effluent Violation	Dissolved Oxygen	0.8	4.0	mg/L	Minimum
06/01/2020	06/30/2020	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	4.4	1.6	mg/L	Instantaneous Maximum
05/01/2020	05/31/2020	Concentration 1 Effluent Violation	Dissolved Oxygen	0.4	4.0	mg/L	Minimum
04/01/2020	04/30/2020	Concentration 1 Effluent Violation	Dissolved Oxygen	2.4	4.0	mg/L	Minimum
04/01/2020	04/30/2020	Concentration 2 Effluent Violation	Total Residual Chlorine (TRC)	0.7	0.5	mg/L	Average Monthly
04/01/2020	04/30/2020	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	8.8	1.6	mg/L	Instantaneous Maximum
03/01/2020	03/31/2020	Concentration 1 Effluent Violation	Dissolved Oxygen	2.4	4.0	mg/L	Minimum

02/01/2020	02/29/2020	Concentration 1 Effluent Violation	Dissolved Oxygen	3.4	4.0	mg/L	Minimum
02/01/2020	02/29/2020	Concentration 2 Effluent Violation	Total Suspended Solids	12.0	10.0	mg/L	Average Monthly
02/01/2020	02/29/2020	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	5.0	1.6	mg/L	Instantaneous Maximum
12/01/2019	12/31/2019	Concentration 1 Effluent Violation	Dissolved Oxygen	1.9	4.0	mg/L	Minimum
12/01/2019	12/31/2019	Concentration 2 Effluent Violation	Carbonaceous Biochemical Oxygen Demand (CBOD5)	19.9	15.0	mg/L	Average Monthly
12/01/2019	12/31/2019	Concentration 3 Effluent Violation	Carbonaceous Biochemical Oxygen Demand (CBOD5)	39.6	30.0	mg/L	Instantaneous Maximum
11/01/2019	11/30/2019	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	< 2.2	1.6	mg/L	Instantaneous Maximum
08/01/2019	08/31/2019	Concentration 2 Effluent Violation	Fecal Coliform	> 245	200	No./100 ml	Geometric Mean
08/01/2019	08/31/2019	Concentration 2 Effluent Violation	Total Residual Chlorine (TRC)	0.9	0.5	mg/L	Average Monthly
08/01/2019	08/31/2019	Concentration 3 Effluent Violation	Fecal Coliform	> 6000	1000	No./100 ml	Instantaneous Maximum
08/01/2019	08/31/2019	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	2.2	1.6	mg/L	Instantaneous Maximum
07/01/2019	07/31/2019	Concentration 3 Effluent Violation	pH	9.3	9.0	S.U.	Maximum
06/01/2019	06/30/2019	Concentration 2 Effluent Violation	Ammonia- Nitrogen	3.2	1.5	mg/L	Average Monthly
06/01/2019	06/30/2019	Concentration 3 Effluent Violation	Ammonia- Nitrogen	5.3	3.0	mg/L	Instantaneous Maximum
06/01/2019	06/30/2019	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	2.20	1.6	mg/L	Instantaneous Maximum
04/01/2019	04/30/2019	Concentration 2 Effluent Violation	Total Residual Chlorine (TRC)	1.7	0.5	mg/L	Average Monthly
04/01/2019	04/30/2019	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	8.4	1.6	mg/L	Instantaneous Maximum
04/01/2019	04/30/2019	Concentration 3 Effluent Violation	pH	9.6	9.0	S.U.	Maximum
03/01/2019	03/31/2019	Concentration 1 Effluent Violation	pH	5.4	6.0	S.U.	Minimum

02/01/2019	02/28/2019	Concentration 2 Effluent Violation	Total Residual Chlorine (TRC)	6.0	0.5	mg/L	Average Monthly
02/01/2019	02/28/2019	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	6.8	1.6	mg/L	Instantaneous Maximum
01/01/2019	01/31/2019	Concentration 2 Effluent Violation	Total Residual Chlorine (TRC)	1.26	0.5	mg/L	Average Monthly
01/01/2019	01/31/2019	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	8.80	1.6	mg/L	Instantaneous Maximum
12/01/2018	12/31/2018	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	2.4	1.6	mg/L	Instantaneous Maximum
10/01/2018	10/31/2018	Concentration 3 Effluent Violation	pH	10.2	9.0	S.U.	Maximum
09/01/2018	09/30/2018	Concentration 2 Effluent Violation	Total Residual Chlorine (TRC)	0.91	0.5	mg/L	Average Monthly
09/01/2018	09/30/2018	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	8.8	1.6	mg/L	Instantaneous Maximum
09/01/2018	09/30/2018	Concentration 3 Effluent Violation	pH	9.7	9.0	S.U.	Maximum
08/01/2018	08/31/2018	Concentration 2 Effluent Violation	Total Residual Chlorine (TRC)	> 1.7	0.5	mg/L	Average Monthly
08/01/2018	08/31/2018	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	> 8.8	1.6	mg/L	Instantaneous Maximum
07/01/2018	07/31/2018	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	> 2.2	1.6	mg/L	Instantaneous Maximum
07/01/2018	07/31/2018	Concentration 3 Effluent Violation	pH	9.2	9.0	S.U.	Maximum
06/01/2018	06/30/2018	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	> 2.20	1.6	mg/L	Instantaneous Maximum
05/01/2018	05/31/2018	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	> 2.20	1.6	mg/L	Instantaneous Maximum
04/01/2018	04/30/2018	Concentration 2 Effluent Violation	Total Residual Chlorine (TRC)	1.7	0.5	mg/L	Average Monthly
04/01/2018	04/30/2018	Concentration 2 Effluent Violation	Total Suspended Solids	12.0	10.0	mg/L	Average Monthly
04/01/2018	04/30/2018	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	6.2	1.6	mg/L	Instantaneous Maximum
02/01/2018	02/28/2018	Concentration 3 Effluent Violation	Total Residual Chlorine (TRC)	> 2.2	1.6	mg/L	Instantaneous Maximum

Compliance Status:

Permittee is a state-owned facility. Operations is working with technical assistance concerning the effluent violations

Completed by: John Murphy

Completed date: 12/13/2022

Compliance History

DMR Data for Outfall 001 (from December 1, 2021 to November 30, 2022)

Parameter	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21
Flow (MGD) Average Monthly	0.0000076	0.00011	0.00022	0.0009	0.0009	0.0005	0.00017	0.00005	0.00	0.00	0.00	0.00
pH (S.U.) Minimum	8.41	7.80	6.81	7.42	7.31	7.69	7.79	8.29	7.77	7.86	7.59	7.67
pH (S.U.) Maximum	8.81	8.71	8.68	8.85	8.89	8.88	9.08	8.89	9.27	9.51	10.37	9.53
DO (mg/L) Minimum	7.71	6.69	4.42	1.96	4.54	0.69	0.09	3.73	0.55	1.49	5.45	0.76
TRC (mg/L) Average Monthly	0.03	0.018	0.009	0.02	0.05	0.03	0.04	0.011	0.04	0.03	0.003	0.0003
TRC (mg/L) Instantaneous Maximum	0.13	0.09	0.13	0.15	0.98	0.40	0.47	0.05	0.37	0.07	0.04	0.01
CBOD5 (mg/L) Average Monthly	2.6	0.56	1.45	1.64	5.19	13.37	2.75	1.42	18.73	2.30	2.12	< 0.20
CBOD5 (mg/L) Instantaneous Maximum	3.82	0.85	2.19	1.66	9.52	24.72	4.29	2.81	21.27	2.25	1.94	< 0.20
TSS (mg/L) Average Monthly	8.5	< 8.0	12.0	< 8.0	14.0	< 8.0	< 8.0	< 8.0	6.0	6.0	6.0	< 6.0
TSS (mg/L) Instantaneous Maximum	9.0	< 8.0	16.0	< 8.0	20.0	< 8.0	< 8.0	< 8.0	< 6.0	5.0	< 6.0	< 6.0
Fecal Coliform (No./100 ml) Geometric Mean	< 10.0	< 10.0	34.19	17.32	31.62	< 10.0	< 10.0	< 10	10.0	10	< 10	10
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 10.0	< 10.0	400	30	100	< 10.0	< 10.0	< 10	< 10.0	10	< 10	< 10
Total Nitrogen (mg/L) Daily Maximum												102.58
Ammonia (mg/L) Average Monthly	0.07	0.075	0.13	1.65	1.25	3.12	0.095	0.05	0.14	0.05	0.02	0.22

**NPDES Permit Fact Sheet
Boaters Change House STP**

NPDES Permit No. PA0096521

Ammonia (mg/L) Instantaneous Maximum	0.09	0.10	0.19	1.91	1.29	3.89	0.12	0.06	0.16	0.035	< 0.02	0.25
Total Phosphorus (mg/L) Daily Maximum												8.976

Compliance History

Effluent Violations for Outfall 001, from: January 1, 2022 To: November 30, 2022

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
pH	02/28/22	Max	9.51	S.U.	9.0	S.U.
pH	02/28/22	Max	9.51	S.U.	9.0	S.U.
pH	01/31/22	Max	10.37	S.U.	9.0	S.U.
pH	05/31/22	Max	9.08	S.U.	9.0	S.U.
pH	03/31/22	Max	9.27	S.U.	9.0	S.U.
pH	02/28/22	Max	9.51	S.U.	9.0	S.U.
DO	08/31/22	Min	1.96	mg/L	4.0	mg/L
DO	06/30/22	Min	0.69	mg/L	4.0	mg/L
DO	06/30/22	Min	0.69	mg/L	4.0	mg/L
DO	05/31/22	Min	0.09	mg/L	4.0	mg/L
DO	02/28/22	Min	1.49	mg/L	4.0	mg/L
DO	02/28/22	Min	1.49	mg/L	4.0	mg/L
DO	02/28/22	Min	1.49	mg/L	4.0	mg/L
DO	04/30/22	Min	3.73	mg/L	4.0	mg/L
DO	03/31/22	Min	0.55	mg/L	4.0	mg/L

NPDES Permit Fact Sheet
Boaters Change House STP

NPDES Permit No. PA0096521

DO	06/30/22	Min	0.69	mg/L	4.0	mg/L
CBOD5	03/31/22	Avg Mo	18.73	mg/L	15.0	mg/L
TSS	07/31/22	Avg Mo	14.0	mg/L	10.0	mg/L
TSS	09/30/22	Avg Mo	12.0	mg/L	10.0	mg/L
Ammonia	06/30/22	Avg Mo	3.12	mg/L	1.5	mg/L
Ammonia	06/30/22	Avg Mo	3.12	mg/L	1.5	mg/L
Ammonia	06/30/22	Avg Mo	3.12	mg/L	1.5	mg/L
Ammonia	08/31/22	Avg Mo	1.65	mg/L	1.5	mg/L
Ammonia	06/30/22	IMAX	3.89	mg/L	3.0	mg/L
Ammonia	06/30/22	IMAX	3.89	mg/L	3.0	mg/L
Ammonia	06/30/22	IMAX	3.89	mg/L	3.0	mg/L

Summary of Inspections: Permittee is a state-owned facility. Effluent violations are occurring due to the facility being underloaded. **Operations is currently working with technical assistance concerning the effluent violations.**

Other Comments: N/A

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 51' 24.32"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .01
Longitude -79° 29' 47.85"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

Limits for Ammonia-Nitrogen, and CBOD₅ in the previous permit were determined using WQM 6.3. WQM 7.0 water quality modeling was run in order to determine new limits for this permit renewal.

Total Suspended Solids (TSS) limits were 10.0 average monthly and 20.0 IMAX as in the last permit.

The following limitations were imposed in the previous permit and it was determined through WQM 7 modeling (Attachments 2 & 3), TRC Calculations, and anti-backsliding regulations that they will be reimposed for this permit.

Parameter	Limit (mg/l)	SBC	Model
TRC	0.5	Average Monthly	TRC-CALC
	1.6	IMAX	
Ammonia-Nitrogen (May 1 – Oct 31)	1.5	Average Monthly	WQM 7
	3.0	IMAX	
Ammonia-Nitrogen (Nov 1 – Apr 3)	4.5	Average Monthly	WQM 7
	9.0	IMAX	
CBOD ₅	15.0	30.0	WQM 7

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the

time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits.

Additional Considerations

Monitoring frequency for the proposed effluent limits are based upon an agreement between DCNR and DEP for DCNR Sewage Treatment Plants (Attachment 4). This agreement gives the following requirements for pH, DO, and TRC monitoring: 1/day from May to September and 3/week from October to April. This monitoring frequency will be imposed for this permit.

Sewage discharges will include monitoring, at a minimum, for *E. Coli*, in new and reissued permits, with a monitoring frequency of 1/year for facilities with design flows of 0.002 – 0.05 MGD.

An annual sampling frequency for total phosphorus and total nitrogen will be imposed per 25 PA Code §92a.61.

Boaters Change House STP is an existing facility and is not expanding. Therefore, anti-degradation requirements are not evaluated during this permit cycle.

Per DEP SOP New and Reissuance Sewage Individual NPDES Permit Applications SOP No. BCW-PMT-002, that for POTWs with design flows greater than 2,000 GPD, non-municipal sewage facilities, and other non-municipal sewage facilities where justified influent BOD5 and TSS monitoring in the permit using the same frequency and sample type as is used for effluent will be established. Given this facility's history of effluent violations and due to the technical assistance they are receiving from the EPA and DEP, The department finds it appropriate to impose influent BOD5 and TSS monitoring for this facility,

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.01	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.) Oct 1 - Apr 30	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	3/week	Grab
pH (S.U.) May 1 - Sep 30	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO Oct 1 - Apr 30	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	3/week	Grab
DO May 1 - Sep 30	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC Oct 1 - Apr 30	XXX	XXX	XXX	0.5	XXX	1.6	3/week	Grab
TRC May 1 - Sep 30	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	15.0	XXX	30.0	2/month	Grab
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	4.5	XXX	9.0	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	1.5	XXX	3.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments: N/A

Attachment 1
Downstream and Upstream USGS StreamStats Report

StreamStats Report

Region ID: PA
 Workspace ID: PA20221206182556277000
 Clicked Point (Latitude, Longitude): 39.85678, -79.49658
 Time: 2022-12-06 13:26:16 -0500



[Collapse All](#)

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	40.9	square miles
ELEV	Mean Basin Elevation	2030	feet

> Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	40.9	square miles	2.26	1400
ELEV	Mean Basin Elevation	2030	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	2.99	ft ³ /s	43	43
30 Day 2 Year Low Flow	5	ft ³ /s	38	38
7 Day 10 Year Low Flow	1.07	ft ³ /s	66	66
30 Day 10 Year Low Flow	1.83	ft ³ /s	54	54
90 Day 10 Year Low Flow	3.51	ft ³ /s	41	41

Low-Flow Statistics Citations

StreamStats Report

Region ID: PA
 Workspace ID: PA20221206184259002000
 Clicked Point (Latitude, Longitude): 39.86375, -79.49580
 Time: 2022-12-06 13:43:19 -0500



Collapse All

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	41.2	square miles
ELEV	Mean Basin Elevation	2026	feet

> Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	41.2	square miles	2.26	1400
ELEV	Mean Basin Elevation	2026	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	3.01	ft ³ /s	43	43
30 Day 2 Year Low Flow	5.03	ft ³ /s	38	38
7 Day 10 Year Low Flow	1.08	ft ³ /s	66	66
30 Day 10 Year Low Flow	1.84	ft ³ /s	54	54
90 Day 10 Year Low Flow	3.53	ft ³ /s	41	41

Low-Flow Statistics Citations

Attachment 2 Summer WQM7 Modeling

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19E	38488	MEADOW RUN	0.620	2030.00	40.90	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.020	1.07	0.00	0.000	0.000	10.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Boathouse STP	PA0096521	0.0100	0.0000	0.0000	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	9.01	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
19E		38488		MEADOW RUN								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH

Q7-10 Flow

0.620 1.07 0.00 1.07 .0155 0.00124 .579 21.64 37.36 0.09 0.430 20.00 7.00

Q1-10 Flow

0.620 0.68 0.00 0.68 .0155 0.00124 NA NA NA 0.07 0.550 20.00 7.00

Q30-10 Flow

0.620 1.46 0.00 1.46 .0155 0.00124 NA NA NA 0.10 0.363 20.00 7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19E	38488	MEADOW RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.620	Boathouse STP	16.76	50	16.76	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.620	Boathouse STP	1.89	25	1.89	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.62	Boathouse STP	25	25	25	25	4	4	0	0

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19E	38488	MEADOW RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.620	0.010	20.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
21.637	0.579	37.356	0.087	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.33	0.176	0.36	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.939	1.022	Tsivoglou	6	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.430	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.043	2.31	0.35	8.24
	0.086	2.29	0.34	8.24
	0.129	2.28	0.33	8.24
	0.172	2.26	0.32	8.24
	0.215	2.24	0.31	8.24
	0.258	2.22	0.30	8.24
	0.301	2.21	0.29	8.24
	0.344	2.19	0.28	8.24
	0.387	2.17	0.27	8.24
	0.430	2.16	0.26	8.24

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19E	38488	MEADOW RUN					
<u>RMI</u>	<u>Name</u>	<u>Permit Number</u>	<u>Disc Flow (mgd)</u>	<u>Parameter</u>	<u>Effl. Limit 30-day Ave. (mg/L)</u>	<u>Effl. Limit Maximum (mg/L)</u>	<u>Effl. Limit Minimum (mg/L)</u>
0.620	Boathouse STP	PA0096521	0.010	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

Attachment 3 Winter WQM7 Modeling

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19E	38488	MEADOW RUN	0.620	2030.00	40.90	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.050	1.07	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Boathouse STP	PA0096521	0.0100	0.0000	0.0000	0.000	15.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	12.51	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

SWP Basin 19E **Stream Code** 38488 **Stream Name** MEADOW RUN

RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
-----	-------------------	----------------	-----------------------	--------------------------	---------------------	------------	------------	-----------	----------------	------------------------	--------------------	-------------

Q7-10 Flow

0.620 1.07 0.00 1.07 .0155 0.00124 .579 21.64 37.36 0.09 0.430 5.14 7.00

Q1-10 Flow

0.620 0.68 0.00 0.68 .0155 0.00124 NA NA NA 0.07 0.550 5.22 7.00

Q30-10 Flow

0.620 1.46 0.00 1.46 .0155 0.00124 NA NA NA 0.10 0.363 5.11 7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19E	38488	MEADOW RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.620	Boathouse STP	24.1	50	24.1	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.620	Boathouse STP	4.36	25	4.36	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.62	Boathouse STP	25	25	25	25	4	4	0	0

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
19E	38488	MEADOW RUN			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
0.620	0.010	5.143		7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
21.637	0.579	37.356		0.087	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
2.33	0.200	0.36		0.223	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
12.389	0.719	Tsivoglou		6	
<u>Reach Travel Time (days)</u>	Subreach Results				
0.430	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.043	2.32	0.35	11.41	
	0.086	2.31	0.35	11.41	
	0.129	2.30	0.35	11.41	
	0.172	2.29	0.34	11.41	
	0.215	2.28	0.34	11.41	
	0.258	2.27	0.34	11.41	
	0.301	2.26	0.33	11.41	
	0.344	2.25	0.33	11.41	
	0.387	2.24	0.33	11.41	
	0.430	2.23	0.32	11.41	

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19E	38488	MEADOW RUN					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.620	Boathouse STP	PA0096521	0.010	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

Attachment 4
DEP Testing Frequency for DCNR State Park Sewage
Treatment Plants

DCNR State Park Sewage Treatment Plants

DCNR Region	Park	Design Flow (MGD)	NPDES Permit Number	Permit Expiration Date	Op Cert Class	Municipal Contributors	Weekend Sampling Currently?	pH, DO and TRC Requirement for Renewed Permit
1	Black Moshannon	0.05 / 0.2	PA0032441	10/31/2014	D-1	Rush Twp.*	No (not a permit requirement; samples pulled when staffing permits)	1/day year round
	Bald Eagle	0.45 / 0.562	PA0032492	8/31/2016	C-1	Howard Bo. & Liberty Twp.	Yes	1/day year round
	Denton Hill	0.013	PA0032514	12/31/2015	D-1	None	Yes	1/day (May - Sep), 3/week (Oct - Apr)
	Hills Creek	0.02 / 0.07	PA0044547	8/30/2014	D-1	Charleston Twp.	Yes	1/day year round
	Kettle Creek - Lower Campground	0.0022	PA0228869	10/31/2015	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Mount Pisgah	0.02 / 0.06	PA0044652	1/31/2012	D-1	None	Permit requires 5 samples per week. Samples pulled on days STOP is working.	1/day (May - Sep), 3/week (Oct - Apr)
	Parker Dam	0.09	PA0044245	12/31/2014	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Reeds Gap	0.037	PA0032506	4/30/2016	D-1	None	Required by permit - done on weekends while seasonal staff on board.	1/day (May - Sep), 3/week (Oct - Apr)
2	Clear Creek (sub sand filter)	0.00535	PA0240001	12/05/12-renewal submitted	D-2	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Cook Forest	0.079	PA0032468	7/31/2016	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Keystone	0.075	PA0032271	7/31/2014		None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Laurel Hill	0.019	PA0032247	3/31/2014	C-1,3	None	No (not a permit requirement)	1/day (May - Sep), 3/week (Oct - Apr)
	Moraine	0.225 / 0.45	PA0032531	12/16/2006	C-1	Prospect Bo.	No	1/day year round
	Ohiopyle - Boater's Change House	0.008	PA0098521	11/30/2014	B-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Ohiopyle - Campground	0.04	PA0032425	11/30/2014	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Ohiopyle - Presley Ridge	0.0045	PA0046116	8/31/2015	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Oil Creek (sub sand filter)	0.002	PA0045039	6/30/2015	Not Required	None	No	1/week year round
	Presque Isle	0.0175	PA0032549	7/22/2013	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Raccoon Creek	0.1	PA0031984	7/31/2014	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Ryerson Station	0.007	PA0217841	11/30/2013	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Yellow Creek	0.313	PA0032263	11/31/16	C-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
3	Canoe Creek	0.12	PA0044261	2/28/2017	C-1	Frankstown Twp.	No (not a permit requirement)	1/day year round
	Cowans Gap	0.03	PA0032964	12/31/2012	D-1,2	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Gifford Pinchot	0.216	PA0032000	2011 (in draft)	C-1	Wellsville Bo.*	Yes (DEP permits us to read sensors for weekend sampling)	1/day year round
	Greenwood Furnace	0.015	PA0031992	10/31/2013	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Little Buffalo	0.076	PA0031950	4/30/2013	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Prince Gallitzin	0.12	PA0032085	9/30/2014	C-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Shawnee	0.1	PA0032093	10/3/2016	D-1	Schellsburg Bo.	Required by permit - done Memorial Day through Labor Day weekends.	1/day year round
4	Beltzville	0.035	PA0032107	3/31/2017	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Francois Slocum	0.08	PA0032433	10/31/2015	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Hickory Run	0.066	PA0032999	11/30/2015	D-1,2	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Lackawanna	0.108	PA0032140	4/30/12 (in draft)	C-1	None	No (not a permit requirement)	1/day (May - Sep), 3/week (Oct - Apr)
	Locust Lake	0.047	PA0032131	1/31/2013	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Nockamixon	0.02	PA0042641	8/31/2014	D-1	Vo-Tech	No	1/day year round
	Promised Land	0.2	PA0032123	9/30/2013	C-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
	Rickets Glen	0.105	PA0032115	8/30/2015	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)
Tuscarora	0.026	PA0032077	10/31/2013	D-1	None	No	1/day (May - Sep), 3/week (Oct - Apr)	

* Industrial contribution to plant from outside source(s).