

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0096792
APS ID 771656
Authorization ID 912776

Applicant and Facility Information

Applicant Name	<u>The Techs Industries, Inc.</u>	Facility Name	<u>MetalTech Plant</u>
Applicant Address	<u>2400 2nd Avenue</u> <u>Pittsburgh, PA 15219-3116</u>	Facility Address	<u>300 Mifflin Road</u> <u>Pittsburgh, PA 15207-1910</u>
Applicant Contact	<u>Darin Ball</u>	Facility Contact	<u>Same as Applicant</u>
Applicant Phone	<u>412-368-4800 ext. 4868</u>	Facility Phone	<u>Same as Applicant</u>
Client ID	<u>77634</u>	Site ID	<u>249568</u>
SIC Code	<u>3479</u>	Municipality	<u>Pittsburgh City</u>
SIC Description	<u>Manufacturing - Metal Coating and Allied Services</u>	County	<u>Allegheny</u>
Date Application Received	<u>January 30, 2012</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 27, 2012</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Permit coverage renewal</u>		

Summary of Review

The Department received a renewal NPDES permit application from Civil and Environmental Consultants, Inc. on behalf of the Techs Industries, Inc on January 30, 2012 for their MetalTech Plant. The site has an SIC code of 3479, Metal Coating, Engraving, and Allied Services to Manufactures. The facility operates a continuous hot dip zinc galvanizing line. Raw steel coils are purchased from outside vendors, processed on the galvanizing line, and then stored onsite until they are sold. MetalTech obtains the site's water from the local municipal supply. The site has two outfalls, Outfall 001 and Outfall 002. Both Outfalls discharge to the Monongahela River, designated in 25 Pa Code Chapter 93 as a Warm Water Fishery. Outfall 001 discharges non-contact cooling water (NCCW) and stormwater. The NCCW discharges via Outfall 001 are regulated at an Internal Monitoring Point, IMP 101. Outfall 002 discharges stormwater.



The site was last inspected on May 27, 2021, no violations were noted.

The permittee has no open violations.

It is recommended that a Draft NPDES Permit be published for public comment in response to this application.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		 Adam Olesnanik / Project Manager	September 7, 2021
X		 Michael E. Fifth, P.E. / Environmental Engineer Manager	September 20, 2021

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001 (IMP 101)</u>	Design Flow (MGD)	<u>0.28</u>
Latitude	<u>40° 26' 01"</u>	Longitude	<u>-79° 58' 12"</u>
Quad Name	<u>Pittsburgh East</u>	Quad Code	<u>1506</u>
Wastewater Description: <u>Noncontact Cooling Water (NCCW), Stormwater</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>134839847</u>	RMI	<u>2.68</u>
Drainage Area	<u>7370</u>	Yield (cfs/mi ²)	<u>0.167</u>
Q ₇₋₁₀ Flow (cfs)	<u>1,230</u>	Q ₇₋₁₀ Basis	<u>US Army Corp of Engineers</u>
Elevation (ft)	<u>704</u>	Slope (ft/ft)	<u>0.001</u>
Watershed No.	<u>19-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Pathogens, Polychlorinated Biphenyls (PCBS)</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Nearest Downstream Public Water Supply Intake	<u>West View Water Authority</u>		
PWS Waters	<u>Ohio River</u>	Flow at Intake (cfs)	<u>4,730</u>
PWS RMI	<u>976.23</u>	Distance from Outfall (mi)	<u>7.45</u>

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>002</u>	Design Flow (MGD)	<u>0.0</u>
Latitude	<u>40° 26' 01"</u>	Longitude	<u>-79° 58' 16"</u>
Quad Name	<u>Pittsburgh</u>	Quad Code	<u>1506</u>
Wastewater Description: <u>Stormwater</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>134839847</u>	RMI	<u>2.68</u>
Drainage Area	<u>7370</u>	Yield (cfs/mi ²)	<u>0.167</u>
Q ₇₋₁₀ Flow (cfs)	<u>1,230</u>	Q ₇₋₁₀ Basis	<u>US Army Corp of Engineers</u>
Elevation (ft)	<u>704</u>	Slope (ft/ft)	<u>0.001</u>
Watershed No.	<u>19-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Pathogens, Polychlorinated Biphenyls (PCBS)</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Nearest Downstream Public Water Supply Intake	<u>West View Water Authority</u>		
PWS Waters	<u>Ohio River</u>	Flow at Intake (cfs)	<u>4,730</u>
PWS RMI	<u>976.23</u>	Distance from Outfall (mi)	<u>7.45</u>

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 0.28
 Latitude 40° 26' 1" Longitude -79° 58' 12"
 Wastewater Description: Noncontact Cooling Water (NCCW), Stormwater

The non-contact cooling water discharges will be regulated at the internal monitoring point IMP 101.

Technology-Based Effluent limitations:

Outfall 001 will be subject to PAG-03 General Stormwater Permit conditions as a minimum requirement because each outfall discharges stormwater. Based on the site's SIC code, the corresponding appendix that would apply to the facility is Appendix U of the PAG-03. The proposed monitoring requirements are shown in Table 1 below. The benchmark values list below are not effluent limitation, and exceedances so not constitutes permit violations. However, if the permittee's sampling demonstrates exceedances of benchmark values for two consecutive monitoring periods, the permit shall submit a corrective action plan. This requirement will be included in Part C of the permit.

Table 1: PAG-03 Appendix (U) Monitoring Requirements

Parameters	Monitoring Requirements		Benchmark Values
	Minimum Measurement Frequency	Sample Type	
pH (S.U))	1 / 6 Months	Grab	XXX
Total Suspended Solids (TSS) (mg/L)	1 / 6 Months	Grab	100
Nitrate + Nitrite-Nitrogen (mg/L)	1 / 6 Months	Grab	XXX
Total Aluminum (mg/L)	1 / 6 Months	Grab	XXX
Total Iron (mg/L)	1 / 6 Months	Grab	XXX
Total Zinc (mg/L)	1 / 6 Months	Grab	XXX

Water Quality-Based Effluent limitations:

Water quality analyses are typically performed under low-flow (Q7-10) conditions. Stormwater discharges occur at variable rates and frequencies but not however during Q7-10 conditions. Since the discharges from Outfalls 001 are composed of stormwater, a formal water quality analysis cannot be accurately conducted. Accordingly, water quality-based effluent limitations based on water quality analyses are not proposed.

Anti-Backsliding

Previous limits can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 2. These limitations are currently imposed on Outfall 001. Effluent goals were included in a Part C conditions for these parameters at these outfalls.

Table 2. Current Limitations at Outfall 001

Parameter	Monthly Average	Daily Maximum	Measurement Frequency	Sample Type
Flow (mgd)	Monitor	Monitor	1/Quarter	Estimate
Total Suspended Solids	Monitor	Monitor	1/Quarter	Grab
Zinc	Monitor	Monitor	1/Quarter	Grab

Proposed Final Effluent Limitations

The proposed effluent monitoring requirements for Outfall 001 are displayed in Table 3 below, they are the most stringent values from the above effluent limitation development. The monitoring frequency for the existing monitoring requirements has been changed from 1/quarter to semi-annually to reflect that monitoring frequency in the PAG-03 general permit. The flow monitoring requirement has been removed from the permit because flow monitoring on stormwater discharges is generally not practical. The Draft Permit requires a Corrective Action Plan when there are two consecutive exceedances of the benchmark values, which are also included in the Part C condition. The benchmark values are displayed below in Table 10. These values are not effluent limitations, an exceedance of the benchmark value is not a violation. As described above, if there are two consecutive exceedances of the benchmark value, a Corrective Action Plan must be conducted to evaluate site stormwater controls and BMPs. Benchmark monitoring is a feedback tool, along with routine inspections and visual assessments, for assessing the effectiveness of stormwater controls and BMPs. An exceedance of the benchmark provides permittees with an indication that the facility's controls may not be sufficiently controlling pollutants in stormwater.

Table 3: Proposed Effluent Monitoring Requirements for Outfall 001

Parameter	Max Daily Concentration	Benchmark Values (mg/L)	Measurement Frequency	Sample Type
pH (S.U))	Report	XXX	1/6 Months	Grab
Total Suspended Solids (TSS) (mg/L)	Report	100.0	1/6 Months	Grab
Nitrate + Nitrite-Nitrogen (mg/L)	Report	XXX	1/6 Months	Grab
Total Aluminum (mg/L)	Report	XXX	1/6 Months	Grab
Total Iron (mg/L)	Report	XXX	1/6 Months	Grab
Total Zinc (mg/L)	Report	XXX	1/6 Months	Grab

Development of Effluent Limitations

IMP No.	101	Design Flow (MGD)	0.28
Latitude	40° 26' 1"	Longitude	-79° 58' 12"
Wastewater Description: Noncontact Cooling Water (NCCW)			

Technology Based Limitations

Regulatory Effluent Standards and Monitoring Requirements

Flow monitoring is required pursuant to 25 Pa. Code § 92a.61(d)(1).

Temperature limits will be imposed per the Department's "Implementation Guidance for Temperature Criteria." As a policy, DEP normally imposes a maximum temperature limit of 110°F on discharges that contain residual heat. The limit is intended as a safety measure to protect sampling personnel or anyone who may come into contact with the heated discharge where it enters the receiving water.

Pennsylvania regulations at 25 Pa. Code § 92a.48(b) require the imposition of technology-based TRC limits for facilities that use chlorination and that are not already subject to TRC limits based on applicable federal ELGs or a facility-specific BPJ evaluation.

Effluent standards for pH are also imposed on industrial wastes by 25 Pa. Code § 95.2(1) as indicated in Table 4.

Table 4: Regulatory Effluent Standards and Monitoring Requirements for IMP 101

Parameter	Monthly Average	Daily Maximum	IMAX	Units
Flow	Monitor and Report		XXX	MGD
Total Residual Chlorine	0.5	1.0	-	mg/L
Temperature	XXX	XXX	110	°F
pH	Not less than 6.0 nor greater than 9.0			S.U.

Water Quality-Based Limitations

Toxic Pollutants Water Quality Analysis

The discharges from IMP 101 are non-contact cooling water and are non-process discharges, therefore a toxic pollutant water quality analysis was not conducted for the discharge from IMP 101.

Thermal WQBELs for Heated Discharges

Thermal WQBELs are evaluated using a DEP program called "Thermal Discharge Limit Calculation Spreadsheet" created with Microsoft Excel for Windows. The program calculates temperature WLAs through the application of a heat transfer equation, which takes two forms in the program depending on the source of the facility's cooling water. In Case 1, intake water to a facility is from the receiving stream. In Case 2, intake water is from a source other than the receiving stream (e.g., municipal water supply). The determination of which case applies to a given discharge is determined by the input data which include the receiving stream flow rate (Q₇₋₁₀ or the minimum regulated flow for large rivers), the stream intake flow rate, external source intake flow rates, consumptive flow rates and site-specific ambient stream temperatures. Case 1 limits are generally expressed as heat rejection rates while Case 2 limits are usually expressed as temperatures.

Since the temperature criteria from 25 Pa. Code Chapter 93.7(a) are expressed on monthly and semi-monthly bases for three different aquatic life-uses—cold water fishes, warm water fishes and trout stocking—the program generates monthly and semi-monthly limits for each use. DEP selects the output that corresponds to the aquatic life-use of the receiving stream and consequently which limits apply to the discharge. Temperature WLAs are bounded by an upper limit of 110°F for the safety of sampling personnel and anyone who may come into contact with the heated discharge where it enters the receiving water. If no WLAs below 110°F are calculated, an instantaneous maximum limit of 110°F is recommended by the program.

Discharges from IMP are classified under Case 2 because water is obtained from water supply. The flow rate used for modeling is the maximum discharge flow reported from IMP 101, 0.93 MGD. The results of the thermal analysis, included in Attachment B, indicate that no WQBELs for temperature are required at IMP 101.

Total Residual Chlorine

To determine if WQBELs are required for discharges containing total residual chlorine (TRC), a discharge evaluation is performed using a DEP program called TRC_CALC created with Microsoft Excel for Windows. TRC_CALC calculates TRC Waste Load Allocations (WLAs) through the application of a mass balance model which considers TRC losses due to stream and discharge chlorine demands and first-order chlorine decay. Input values for the program include flow rates and chlorine demands for the receiving stream and the discharge, the number of samples taken per month, coefficients of TRC variability, partial mix factors, and an optional factor of safety. The mass balance model calculates WLAs for acute and chronic criteria that are then converted to long term averages using calculated multipliers. The multipliers are functions of the number of samples taken per month and the TRC variability coefficients (normally kept at default values unless site specific information is available). The most stringent limitation between the acute and chronic long-term averages is converted to an average monthly limit for comparison to the BAT average monthly limit of 0.5 mg/l from 25 Pa. Code § 92a.48(b)(2). The more stringent of these average monthly TRC limitations is imposed in the permit. The results of the modeling, included in Attachment C, indicate that no WQBELs are required for TRC

Anti-backsliding

Previous limits can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 5.

Table 5. Existing Effluent Limitations at IMP 101

Parameter	Monthly Average	Daily Maximum	Instantaneous Maximum	Measurement Frequency	Sample Type
Flow (MGD)	Monitor	Monitor		2/Month	Measure
Temperature (°F)			110	2/Month	I-S
pH (S.U.)	Not less than 6.0 nor greater than 9.0			2/Month	Grab

Proposed Effluent Limitations for IMP 101

The proposed effluent limitations and monitoring requirements for IMP 101 are shown below in Table 6. The limits are the most stringent values from the above limitation analysis.

Table 6. Proposed Effluent Limitations at IMP 101

Parameter	Instant. Minimum	Monthly Average	Daily Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Flow (MGD)		Monitor	Monitor		2/Month	Measure
Total Residual Chlorine (mg/L)		0.5	1.0		2/Month	Grab
Temperature (°F)				110	2/Month	I-S
pH (S.U.)	6.0			9.0	2/Month	Grab

Development of Effluent Limitations

Outfall No. <u>002</u>	Design Flow (MGD) <u>0.0</u>
Latitude <u>40° 26' 1"</u>	Longitude <u>-79° 58' 16"</u>
Wastewater Description: <u>Stormwater</u>	

Technology-Based Effluent limitations:

Outfall 002 will be subject to PAG-03 General Stormwater Permit conditions as a minimum requirement because each outfall discharges stormwater. Based on the site's SIC code, the corresponding appendix that would apply to the facility is Appendix U of the PAG-03. The proposed monitoring requirements are shown in Table 7 below. The benchmark values list below are not effluent limitation, and exceedances so not constitutes permit violations. However, if the permittee's sampling demonstrates exceedances of benchmark values for two consecutive monitoring periods, the permit shall submit a corrective action plan. This requirement will be included in Part C of the permit.

Table 7: PAG-03 Appendix (U) Monitoring Requirements

Parameters	Monitoring Requirements		Benchmark Values
	Minimum Measurement Frequency	Sample Type	
pH (S.U))	1 / 6 Months	Grab	XXX
Total Suspended Solids (TSS) (mg/L)	1 / 6 Months	Grab	100
Nitrate + Nitrite-Nitrogen (mg/L)	1 / 6 Months	Grab	XXX
Total Aluminum (mg/L)	1 / 6 Months	Grab	XXX
Total Iron (mg/L)	1 / 6 Months	Grab	XXX
Total Zinc (mg/L)	1 / 6 Months	Grab	XXX

Water Quality-Based Effluent limitations:

Water quality analyses are typically performed under low-flow (Q7-10) conditions. Stormwater discharges occur at variable rates and frequencies but not however during Q7-10 conditions. Since the discharges from Outfalls 002 are composed of stormwater, a formal water quality analysis cannot be accurately conducted. Accordingly, water quality-based effluent limitations based on water quality analyses are not proposed.

Anti-Backsliding

Previous limits can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 8. These limitations are currently imposed on Outfall 002. Effluent goals were included in a Part C conditions for these parameters at these outfalls.

Table 8. Current Limitations at Outfall 002

Parameter	Monthly Average	Daily Maximum	Measurement Frequency	Sample Type
Flow (mgd)	Monitor	Monitor	1/Quarter	Estimate
Total Suspended Solids	Monitor	Monitor	1/Quarter	Grab
Zinc	Monitor	Monitor	1/Quarter	Grab

Proposed Final Effluent Limitations

The proposed effluent monitoring requirements for Outfall 002 are displayed in Table 9 below, they are the most stringent values from the above effluent limitation development. The monitoring frequency for the existing monitoring requirements has been changed from 1/quarter to semi-annually to reflect that monitoring frequency in the PAG-03 general permit. The flow monitoring requirement has been removed from the permit because flow monitoring on stormwater discharges is generally not practical. The Draft Permit requires a Corrective Action Plan when there are two consecutive exceedances of the benchmark values, which are also included in the Part C condition. The benchmark values are displayed below in Table 9. These values are not effluent limitations, an exceedance of the benchmark value is not a violation. As described above, if there are two consecutive exceedances of the benchmark value, a Corrective Action Plan must be conducted to evaluate site stormwater controls and BMPs. Benchmark monitoring is a feedback tool, along with routine inspections and visual assessments, for assessing the effectiveness of stormwater controls and BMPs. An exceedance of the benchmark provides permittees with an indication that the facility's controls may not be sufficiently controlling pollutants in stormwater

Table 9: Proposed Effluent Monitoring Requirements Outfall 002

Parameter	Max Daily Concentration	Benchmark Values (mg/L)	Measurement Frequency	Sample Type
pH (S.U))	Report	XXX	1/6 Months	Grab
Total Suspended Solids (TSS) (mg/L)	Report	100.0	1/6 Months	Grab
Nitrate + Nitrite-Nitrogen (mg/L)	Report	XXX	1/6 Months	Grab
Total Aluminum (mg/L)	Report	XXX	1/6 Months	Grab
Total Iron (mg/L)	Report	XXX	1/6 Months	Grab
Total Zinc (mg/L)	Report	XXX	1/6 Months	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

Attachments

Attachment A: USGS Streams Stats Report

Attachment B: IMP 101 Temperature Model Spreadsheet Evaluation

Attachment C: IMP 101 TRC Spreadsheet Evaluation

Attachment A:
USGS Streams Stats Report

StreamStats Report

Region ID: PA

Workspace ID: PA20210903175229121000

Clicked Point (Latitude, Longitude): 40.43285, -79.97049

Time: 2021-09-03 13:52:54 -0400



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	7370	square miles
ELEV	Mean Basin Elevation	1837	feet

Attachment B:

IMP 101 Temperature Model Spreadsheet Evaluation

Facility:	MetalTech							
Permit Number:	PA0096792							PMF
Stream Name:	Monagehela							0.25
Analyst/Engineer:	Adam Olesnanik							
Stream Q7-10 (cfs):	1230							
	Facility Flows				Stream Flows			
	Intake (Stream) (MGD)	Intake (External) (MGD)	Consumptive Loss (MGD)	Discharge Flow (MGD)	Upstream Stream Flow (cfs)	Adjusted Stream Flow (cfs)	Downstream Stream Flow (cfs)	
Jan 1-31	0	0.93	0	0.93	3936.00	984.00	985.44	
Feb 1-29	0	0.93	0	0.93	4305.00	1076.25	1077.69	
Mar 1-31	0	0.93	0	0.93	8610.00	2152.50	2153.94	
Apr 1-15	0	0.93	0	0.93	11439.00	2859.75	2861.19	
Apr 16-30	0	0.93	0	0.93	11439.00	2859.75	2861.19	
May 1-15	0	0.93	0	0.93	6273.00	1568.25	1569.69	
May 16-30	0	0.93	0	0.93	6273.00	1568.25	1569.69	
Jun 1-15	0	0.93	0	0.93	3690.00	922.50	923.94	
Jun 16-30	0	0.93	0	0.93	3690.00	922.50	923.94	
Jul 1-31	0	0.93	0	0.93	2091.00	522.75	524.19	
Aug 1-15	0	0.93	0	0.93	1722.00	430.50	431.94	
Aug 16-31	0	0.93	0	0.93	1722.00	430.50	431.94	
Sep 1-15	0	0.93	0	0.93	1353.00	338.25	339.69	
Sep 16-30	0	0.93	0	0.93	1353.00	338.25	339.69	
Oct 1-15	0	0.93	0	0.93	1476.00	369.00	370.44	
Oct 16-31	0	0.93	0	0.93	1476.00	369.00	370.44	
Nov 1-15	0	0.93	0	0.93	1968.00	492.00	493.44	
Nov 16-30	0	0.93	0	0.93	1968.00	492.00	493.44	
Dec 1-31	0	0.93	0	0.93	2952.00	738.00	739.44	
Please forward all comments to Tom Starosta at 717-787-4317, tstarosta@state.pa.us.								
Version 2.0 -- 07/01/2005 Reference: Implementation Guidance for Temperature Criteria, DEP-ID: 391-2000-017								
NOTE: The user can only edit fields that are blue.								
NOTE: MGD x 1.547 = cfs.								

**NPDES Permit Fact Sheet
Metaltech Plant**

NPDES Permit No. PA0096792

Facility:	MetalTech							
Permit Number:	PA0096792							
Stream:	Monagehela							
	WWF Criteria	CWF Criteria	TSF Criteria	316 Criteria		Q7-10 Multipliers	Q7-10 Multipliers	
	(°F)	(°F)	(°F)	(°F)		(Used in Analysis)	(Default - Info Only)	
Jan 1-31	40	38	40	0		3.2	3.2	
Feb 1-29	40	38	40	0		3.5	3.5	
Mar 1-31	46	42	46	0		7	7	
Apr 1-15	52	48	52	0		9.3	9.3	
Apr 16-30	58	52	58	0		9.3	9.3	
May 1-15	64	54	64	0		5.1	5.1	
May 16-30	72	58	68	0		5.1	5.1	
Jun 1-15	80	60	70	0		3	3	
Jun 16-30	84	64	72	0		3	3	
Jul 1-31	87	66	74	0		1.7	1.7	
Aug 1-15	87	66	80	0		1.4	1.4	
Aug 16-31	87	66	87	0		1.4	1.4	
Sep 1-15	84	64	84	0		1.1	1.1	
Sep 16-30	78	60	78	0		1.1	1.1	
Oct 1-15	72	54	72	0		1.2	1.2	
Oct 16-31	66	50	66	0		1.2	1.2	
Nov 1-15	58	46	58	0		1.6	1.6	
Nov 16-30	50	42	50	0		1.6	1.6	
Dec 1-31	42	40	42	0		2.4	2.4	
NOTES:								
WWF= Warm water fishes								
CWF= Cold water fishes								
TSF= Trout stocking								

**NPDES Permit Fact Sheet
Metaltech Plant**

NPDES Permit No. PA0096792

Facility:	MetalTech					
Permit Number:	PA0096792					PMF
Stream:	Monagehela					0.25
	WWF			WWF		WWF
	Ambient Stream	Ambient Stream	Target Maximum	Daily	Daily	
	Temperature (°F)	Temperature (°F)	Stream Temp. ¹	WLA ²	WLA ³	at Discharge
	(Default)	(Site-specific data)	(°F)	(Million BTUs/day)	(°F)	Flow (MGD)
Jan 1-31	35	0	40	N/A -- Case 2	110.0	0.93
Feb 1-29	35	0	40	N/A -- Case 2	110.0	0.93
Mar 1-31	40	0	46	N/A -- Case 2	110.0	0.93
Apr 1-15	47	0	52	N/A -- Case 2	110.0	0.93
Apr 16-30	53	0	58	N/A -- Case 2	110.0	0.93
May 1-15	58	0	64	N/A -- Case 2	110.0	0.93
May 16-30	62	0	72	N/A -- Case 2	110.0	0.93
Jun 1-15	67	0	80	N/A -- Case 2	110.0	0.93
Jun 16-30	71	0	84	N/A -- Case 2	110.0	0.93
Jul 1-31	75	0	87	N/A -- Case 2	110.0	0.93
Aug 1-15	74	0	87	N/A -- Case 2	110.0	0.93
Aug 16-31	74	0	87	N/A -- Case 2	110.0	0.93
Sep 1-15	71	0	84	N/A -- Case 2	110.0	0.93
Sep 16-30	65	0	78	N/A -- Case 2	110.0	0.93
Oct 1-15	60	0	72	N/A -- Case 2	110.0	0.93
Oct 16-31	54	0	66	N/A -- Case 2	110.0	0.93
Nov 1-15	48	0	58	N/A -- Case 2	110.0	0.93
Nov 16-30	42	0	50	N/A -- Case 2	110.0	0.93
Dec 1-31	37	0	42	N/A -- Case 2	110.0	0.93
¹ This is the maximum of the WWF WQ criterion or the ambient temperature. The ambient temperature may be either the design (median) temperature for WWF, or the ambient stream temperature based on site-specific data entered by the user. A minimum of 1°F above ambient stream temperature is allocated.						
² The WLA expressed in Million BTUs/day is valid for Case 1 scenarios, and disabled for Case 2 scenarios.						
³ The WLA expressed in °F is valid only if the limit is tied to a daily discharge flow limit (may be used for Case 1 or Case 2). WLA's greater than 110°F are displayed as 110°F.						

Attachment C:

IMP 101 TRC Spreadsheet Evaluation

TRC EVALUATION

1230	= Q stream (cfs)	0.5	= CV Daily
0.93	= Q discharge (MGD)	0.5	= CV Hourly
4	= no. samples	0.25	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	0.25	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
	= %Factor of Safety (FOS)		=Decay Coefficient (K)
Source	Reference	AFC Calculations	Reference CFC Calculations
TRC	1.3.2.iii	WLA_afc = 68.200	1.3.2.iii WLA_cfc = 66.482
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc= 25.413	5.1d LTA_cfc = 38.650
Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML_MULT = 1.720	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.170	
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$		
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$		
LTA_afc	wla_afc * LTAMULT_afc		
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$		
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$		
LTA_cfc	wla_cfc * LTAMULT_cfc		
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$		
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)		
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)		