

Application Type Renewal  
Facility Type Non-Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0096989  
APS ID 1058667  
Authorization ID 1388222

**Applicant and Facility Information**

Applicant Name	<u>Kuntz Assoc Inc.</u>	Facility Name	<u>Sylvan Acres MHP</u>
Applicant Address	<u>4036 Route 217 Highway N</u> <u>Blairsville, PA 15717-5608</u>	Facility Address	<u>Hemlock Road</u> <u>Indiana, PA 15701</u>
Applicant Contact	<u>Gregory Kuntz</u>	Facility Contact	<u></u>
Applicant Phone	<u>(724) 349-5500</u>	Facility Phone	<u></u>
Applicant E Mail	<u>kuntzrentals@gmail.com</u>	Facility E Mail	<u></u>
Client ID	<u>209868</u>	Site ID	<u>248896</u>
Municipality	<u>Armstrong Township</u>	County	<u>Indiana</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u></u>
SIC Description	<u>Fin Ins &amp; Real Est - Dwell Op Expt Apt</u>	SIC code	<u>6514</u>
SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>	SIC code	<u>4952</u>
Date Application Received	<u>March 4, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 22, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Renewal</u>		

**Summary of Review**

No listed inspections, violations, or enforcement actions. Effluent violations for ammonia-nitrogen in July 2022 and fecal coliform in September have been reported. *There is one open violation in WMS as of 4/17/2023 for failure to use a certified laboratory. OK to draft per operations 4/18/2023 CWY*

The applicant has request relaxation of their water quality based TRC limitations. Additional in-stream data has been requested to verify basic modelling assumptions. No additional information has been submitted.

Previous year sludge production 0.75-dry tons. Conveyed by J+D Septic to Eastern Armstrong County Municipal Authority.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	March 8, 2023
X		Chad W. Yurisc Chad W. Yurisc, P.E. Environmental Engineer Manager	4/18/2023

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.025</u>
Latitude DP	<u>40° 36' 32.00"</u>	Longitude DP	<u>-79° 14' 0.00"</u>
Latitude NHD	<u>40° 36' 32.34"</u>	Longitude NHD	<u>-79° 13' 59.54"</u>
Quad Name	<u>Indiana</u>	Quad Code	<u>1412</u>

Wastewater Description: Treated mobile home park domestic wastes

Receiving Waters	<u>Unnamed Tributary to Curry Run</u>	Stream Code	<u>46731</u>
NHD Com ID	<u>123860165</u>	RMI	<u>0.8100</u>
Drainage Area	<u>0.1</u>	Yield (cfs/mi <sup>2</sup> )	<u>0</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0</u>	Q <sub>7-10</sub> Basis	<u>Dry stream</u>
Elevation (ft)	<u>1280</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>17-E</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>

Comments \_\_\_\_\_  
\_\_\_\_\_

Assessment Status Attaining Use(s)

Cause(s) of Impairment \_\_\_\_\_

Source(s) of Impairment \_\_\_\_\_

TMDL Status Final Name Crooked Creek Watershed

Background/Ambient Data	Data Source
pH (SU) _____	_____
Temperature (°F) _____	_____
Hardness (mg/L) _____	_____
Other: _____	_____

Nearest Downstream Public Water Supply Intake Buffalo Township Municipal Authority

PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>30.1</u>	Distance from Outfall (mi)	<u>49.57</u>

Changes Since Last Permit Issuance: none

Other Comments: none

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Sylvan Acres MHP STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
3274410		November 18, 1974		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	chlorination	0.025
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.025		Not Overloaded		landfill

Changes Since Last Permit Issuance: none

Other Comments: extended aeration, clarification, chlorination, and de-chlorination. Final sludge treatment before disposal is at the Eastern Armstrong County Municipal Authority.

	Month	Year	MGD	PPD			
Annual Average Design Flow			0.02500				
Organic Design Capacity							
Annual Average Flow		2019	0.00349				
		2020	0.00383				
		2021	0.00412				
Highest Monthly Average Flow	September		0.00456				
pH			6.0		9.0		1/day
TRC			0.12	0.2	0.51		1/day
Fecal Coliform			372		8664		2/month
CBOD5			2.1	4	10		2/month
TSS			5	12.5	38		2/month
NH3			0.8	1.12	8.0		2/month
N			16.2	21.1	26		1/year
P			0.82	2.01	3.2		1/year

Compliance History

DMR Data for Outfall 001 (from February 1, 2021 to January 31, 2022)

Parameter	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21
Flow (MGD) Average Monthly	0.0043	0.0040	0.00432	0.00378	0.00456	0.00414	0.0043	0.0041	0.0043	0.00396	0.004	0.00384
pH (S.U.) Minimum	6.0	6.0	6.0	6.0	6.0	6.0	6.1	6.0	6.0	6.2	6.2	6.1
pH (S.U.) Maximum	6.7	6.4	6.4	6.4	6.4	6.6	7.0	6.6	6.8	6.7	6.7	7.0
DO (mg/L) Minimum	6.0	6.0	7.0	6.9	6.9	6.8	6.9	6.7	6.1	6.0	6.5	7.0
TRC (mg/L) Average Monthly	0.12	0.25	0.12	0.13	0.16	0.12	0.16	0.11	0.08	0.09	0.09	0.08
TRC (mg/L) Instantaneous Max	0.40	0.40	0.30	0.51	0.40	0.40	0.30	0.26	0.20	0.20	0.19	0.20
CBOD5 (mg/L) Average Monthly	< 2.9	< 10.0	< 2.7	< 3.9	< 7.0	< 2.4	< 3.7	< 8.9	2.9	8.6	2.1	4.8
CBOD5 (mg/L) Instantaneous Max	3.7	18.0	3.7	5.8	< 12.0	2.8	5.4	11.8	3.1	12.0	2.2	5.1
TSS (mg/L) Average Monthly	< 5.0	< 19.5	< 5.0	< 11.5	< 5.0	< 5.0	< 18.5	< 11.5	14.5	16.5	< 12.0	< 18.5
TSS (mg/L) Instant Maximum	< 5.0	34.0	< 5.0	18.0	< 5.0	5.0	32.0	18.0	16.0	18.0	19.0	32.0
Fecal Coliform (#/100 ml) Geo Mean	< 5.0	> 561	141	< 5	< 15	23	133	98	372	121	160	67
Fecal Coliform (#/100 ml) Inst Max	< 5.0	> 12100	152	5	48	26	244	130	8664	200	594	68
Total Nitrogen (mg/L) Daily Maximum		26.0										
Ammonia (mg/L) Average Monthly	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 1.1	< 1.1	< 1.0	< 1.5	< 0.8	< 0.8
Ammonia (mg/L) Instantaneous Max	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	1.4	1.4	1.3	2.2	< 0.8	< 0.8
Total Phosphorus (mg/L) Daily Maximum		0.82										

DMR Data for Outfall 001 (from February 1, 2022 to January 31, 2023)

Parameter	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22	FEB-22
Flow (MGD) Average Monthly	0.0034	0.0023	0.0036	0.0032	0.0043	0.0043	0.0040	0.0045	0.0036	0.00468	0.0045	0.00450
pH (S.U.) Minimum	6.0	6.0	6.0	6.0	6.0	6.0	6.0	6.0	6.0	6.0	6.0	6.0
pH (S.U.) Maximum	6.6	6.3	6.7	6.8	6.7	6.3	6.3	6.2	6.2	6.3	6.3	6.4
DO (mg/L) Minimum	5.0	5.1	5.0	4.9	5.0	5.0	5.0	5.0	6.9	7.0	6.7	6.7
TRC (mg/L) Average Monthly	0.05	0.07	0.06	0.06	0.08	0.09	0.11	0.10	0.12	0.09	0.10	0.11
TRC (mg/L) Instant Maximum	0.11	0.19	0.19	0.16	0.19	0.20	0.40	0.20	0.27	0.20	0.20	0.30
CBOD5 (mg/L) Average Monthly	7.1	< 2.00	< 2.0	< 2.0	2.0	< 2.0	< 7.0	< 2.0	3.0	< 2.0	< 3.2	< 5.9
CBOD5 (mg/L) Instant Maximum	12.2	< 2.00	2.4	< 2.0	2.0	< 2.0	< 12.0	< 2.0	3.0	< 2.0	4.3	9.7
TSS (mg/L) Average Monthly	< 5.0	6.5	5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 6.0
TSS (mg/L) Instant Maximum	< 5.0	8.0	8.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	7.0
Fecal Coliform (#100 ml) Geo Mean	411	228	< 5	< 26	107	138	< 90	88	5	< 8	< 6	< 5
Fecal Coliform (#/100 ml) Instant Max	6498	508	5	131	2306	517	1628	159	5	14	8	5
Total Nitrogen (mg/L) Daily Maximum		6.51										
Ammonia (mg/L) Average Monthly	< 0.8	< 0.8	< 0.8	< 0.80	< 3.16	2.2	10.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8
Ammonia (mg/L) Instant Maximum	< 0.8	< 0.8	< 0.8	< 0.80	5.52	2.32	19.6	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8
Total Phosphorus (mg/L) Daily Maximum		7.4										

Facility is operating at less than 1/5 (20%) of design.

Relatively high TSS/CBOD5 ratio and relatively low pH caused by low flow and long aeration time.

Daily pre-dechlorination TRC/fecal coliform correlation recommended.

**Compliance History**

**Effluent Violations for Outfall 001, from: March 1, 2021 To: January 31, 2022**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	12/31/21	Avg Mo	0.25	mg/L	.17	mg/L
Fecal Coliform	12/31/21	Geo Mean	> 561	No./100 ml	2000	No./100 ml
Fecal Coliform	05/31/21	Geo Mean	372	No./100 ml	200	No./100 ml
Fecal Coliform	05/31/21	IMAX	8664	No./100 ml	400	No./100 ml
Fecal Coliform	12/31/21	IMAX	> 12100	No./100 ml	10000	No./100 ml

**S Effluent Violations for Outfall 001, from: March 1, 2022 To: January 31, 2023**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	07/31/22	IMAX	1628	No./100 ml	400	No./100 ml
Fecal Coliform	08/31/22	IMAX	517	No./100 ml	400	No./100 ml
Fecal Coliform	09/30/22	IMAX	2306	No./100 ml	400	No./100 ml
Ammonia	07/31/22	Avg Mo	10.8	mg/L	5.0	mg/L
Ammonia	07/31/22	IMAX	19.6	mg/L	10.0	mg/L

**Development of Effluent Limitations**

Outfall No. 001 Design Flow (MGD) .025  
 Latitude 40° 36' 32.00" Longitude -79° 14' 0.00"  
 Wastewater Description: Sewage Effluent

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4.0	Daily Minimum		BPJ
E Coli	monitoring			BPJ

Comments: E Coli is a new listed parameter.

**Water Quality-Based Limitations**

A Sewerage Program “Reasonable Potential Analysis” determined the following parameters were candidates for limitations: CBOD<sub>5</sub>, TSS, Ammonia-nitrogen, nitrogen, phosphorus, DO, TRC and pH.

The following limitations were determined through water quality modeling (output files below):

Parameter	Period	Limit (mg/l)		SBC	Model	
CBOD		25.0	50.0		25.0	50.0
TSS		30.0	60.0			
Ammonia Nitrogen	Summer	5.0	10.0		4.6	9.2
	Winter	14.0	28.0		13.8	27.6
Nitrogen		Monitor				
Phosphorus		Monitor				
DO		4.0			4.0	
TRC		0.17	0.56		0.17	0.56
pH		6.0	9/0		6.0	9.0

Comments:

CBOD<sub>5</sub>, ammonia-nitrogen and DO are from WQM7.1 DOSAG model and TRC is from the TRC spreadsheet. E. Coli, nitrogen and phosphorus are being monitored *in accordance with the Department's SOP* for later evaluation.

**Best Professional Judgment (BPJ) Limitations**

Comments: applies to DO only

**Anti-Backsliding**

No changes needed for compliance.

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46216	CROOKED CREEK	34.572	1113.91	1.50	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.029	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
silvan	PA000096989A	0.0250	0.0250	0.0250	0.000	20.00	6.50

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70



Permit No. PA0096989

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46216	CROOKED CREEK	0.000	980.16	292.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)	
Q7-10	0.029	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	20.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Permit No. PA0096989

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
17E		46216				CROOKED CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
34.572	0.04	0.00	0.04	.0387	0.00073	.365	5.57	15.26	0.04	52.366	20.00	6.69
<b>Q1-10 Flow</b>												
34.572	0.03	0.00	0.03	.0387	0.00073	NA	NA	NA	0.04	58.922	20.00	6.65
<b>Q30-10 Flow</b>												
34.572	0.06	0.00	0.06	.0387	0.00073	NA	NA	NA	0.04	47.507	20.00	6.73

Permit No. PA0096989

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Permit No. PA0096989

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
17E	46216	CROOKED CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
34.572	silvan	21.29	36.43	21.29	36.43	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
34.572	silvan	2.04	5	2.04	5	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
34.57	silvan	25	25	5	5	4	4	0	0

Permit No. PA0096989

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
17E	46216	CROOKED CREEK		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
34.572	0.025	20.000	6.694	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
5.565	0.365	15.263	0.040	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
12.87	0.036	2.41	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.239	16.329	Owens	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
52.366	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>
	(days)	(mg/L)	(mg/L)	(mg/L)
	5.237	10.68	0.10	8.24
	10.473	8.87	0.10	8.24
	15.710	7.36	0.10	8.24
	20.946	6.11	0.10	8.24
	26.183	5.07	0.10	8.24
	31.420	4.21	0.10	8.24
	36.656	3.50	0.10	8.24
	41.893	2.90	0.10	8.24
	47.129	2.41	0.10	8.24
	52.366	2.00	0.10	8.24

Permit No. PA0096989

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
17E		46216		CROOKED CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
34.572	silvan	PA000096989A	0.025	CBOD5	25		
				NH3-N	4.6	9.2	
				Dissolved Oxygen			4

1A	B	C	D	E	F	G	H	I	J	K	L	M	
	<b>Discharger</b>	Kuntz Associates Inc.							Revised	Tuesday, March 7, 2023			
	<b>Site</b>	Sylvan Acres MHP STP								Wednesday, March 8, 2023			
	<b>Municipality</b>	Armstrong Township											
	<b>County</b>	Indiana											
	<b>NPDES Permit</b>	PA0096989											
	<b>0.5</b>												
2	<b>TRC EVALUATION</b>												
3	Input appropriate values in B4:B8 and E4:E7												
4	0.043	= Q stream (cfs)	0.5		= CV Daily								
5	0.0250	= Q discharge (MGD)	0.5		= CV Hourly								
6	30	= no. samples	1		= AFC_Partial Mx Factor								
7	0.3	= Chlorine Demand of Stream	1		= CFC_Partial Mx Factor								
8	0	= Chlorine Demand of Discharge	15		= AFC_Criteria Compliance Time (min)								
9	0	= BAT/BPJ Value	720		= CFC_Criteria Compliance Time (min)								
		= % Factor of Safety (FOS)			= Decay Coefficient (K)								
10	Source	Reference	AFC Calculations				Reference	CFC Calculations					
11	TRC	1.3.2.iii	WLA_afc = 0.375				1.3.2.iii	WLA_cfc = 0.358					
12	PENTOX/SD TRG	5.1a	LTAMULT_afc = 0.373				5.1c	LTAMULT_cfc = 0.581					
13	PENTOX/SD TRG	5.1b	LTA_afc = 0.140				5.1d	LTA_cfc = 0.208					
14													
15	Source	Effluent Limit Calculations											
16	PENTOX/SD TRG	5.1f	AML_MULT = 1.231										
17	PENTOX/SD TRG	5.1g	↓ LIMIT (mg/l) = 0.172				AFC						
18			↓ LIMIT (mg/l) = 0.563										
	WLA_afc	$(0.19/(k^*AFC_{tc})) + [(AFC_{Yc}Qs^*0.19/Qd^*e^{-(k^*AFC_{tc})}) \dots + Xd + (AFC_{Yc}Qs^*Xs/Qd)](1-FOS/100)$											
	LTAMULT_afc	$EXP((0.5^*LN((cv^h+1))) - 2.326^*LN((cv^h+1)^0.5))$											
	LTA_afc	$wla\_afc^*LTAMULT\_afc$											
	WLA_cfc	$(0.11/(k^*CFC_{tc})) + [(CFC_{Yc}Qs^*0.11/Qd^*e^{-(k^*CFC_{tc})}) \dots + Xd + (CFC_{Yc}Qs^*Xs/Qd)](1-FOS/100)$											
	LTAMULT_cfc	$EXP((0.5^*LN((cv^d+2/ho\_samples+1))) - 2.326^*LN((cv^d+2/ho\_samples+1)^0.5))$											
	LTA_cfc	$wla\_cfc^*LTAMULT\_cfc$											
	AML_MULT	$EXP(2.326^*LN(((cv^d+2/ho\_samples+1)^0.5) - 0.5^*LN((cv^d+2/ho\_samples+1))))$											
	AVG MON LIMIT	$MIN(BAT\_BPJ\_MIN(LTA\_afc, LTA\_cfc)^*AML\_MULT)$											
	INST MAX LIMIT	$1.5^*((av\_mon\_lim)^*AML\_MULT)^*LTAMULT\_afc$											
	$(0.011/EXP(-k^*CFC_{tc}/1440)) + (((CFC_{Yc}Qs^*0.011)/(1.547^*Qd)) \dots - EXP(-k^*CFC_{tc}/1440)) + Xd + (CFC_{Yc}Qs^*Xs/1.547^*Qd)](1-FOS/100)$												
	Stream	Chlorine Required	=	perennial	2	Chlorine Demand	+	Chlorine Residual					
	Stream	Flow	Conditions	intermittent	Perennial								
	Stream	Code	Function	46731	46708								
	Samples	reach	outfall	RMI	0.81	4.18							
	Reach	End	RMI	0	0								
	reach	feet	4276.8	22053.43536									
	drainage	sq miles	0.036	1.5									
	TRC	limitation	average	mg/L	0.011	0.172							
			maximum	mg/L	0.036	0.560							
	elevation	modelled	feet	1280	1113.913								
	elevation	modelled	feet	1113.91	980.1643								
	slope	modelled	foot/foot	0.039	0.006								
	low flow	flow	cfs/sq mi	0.029	0.029								
	discharge	mgd	0.0411	0.0250									
	Runoff	Period	hours	24.000	24.000								
	Intermittent stream from discharge to Creaked Creek. No aquatic life protection should be necessary in the intermittent stream reach.												
	stream	flow	cfs	0.00104	0.04319								
	stream	flow	MGD	0.000670	0.027917								
	stream	flow	total	MGD	0.041770	0.052917							
	stream	chlorine	demand	mg/L	0.3	0.3							
	discharge	discharge	demand	mg/L									
	stream	Total Stream/Waste	ratio	1.0	2.1								
	Spreadsheet recommends a 0.17-mg/L monthly average and 0.56-mg/L instantaneous maximum to protect aquatic life in Creaked Creek. The current permit has a 0.17-mg/L monthly average and 0.56-mg/L instantaneous maximum that should be retained. The applicant has request relaxed TRC limits to improve disinfection. The applicant has not demonstrated that a higher TRC limitation will protect aquatic life in Creaked Creek. Basin yield significant digests do affect the calculated basin stream flow.												
	BAT	TRC	mean	BAT	0.5	0.5							
	BAT	TRC	maximum	BAT	1.6	1.6							

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.17	XXX	0.56	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
E Coli	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Fecal Coliform (No./100 ml) Nov 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Oct 31	XXX	XXX	XXX	200 Geo Mean	XXX	400	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	14.0	XXX	28.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5.0	XXX	10.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection