



Application Type
Facility Type
Major / Minor

Renewal
Industrial
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. **PA0097462**
APS ID **1102235**
Authorization ID **1464216**

Applicant and Facility Information

Indiana County Municipal Service Authority		Facility Name	Cherry Tree Water Treatment Plant
Applicant Name	602 Kolter Drive	Facility Address	Peg Run Road State Rte 240
Applicant Address	Indiana, PA 15701-3570	Facility Contact	Cherry Tree, PA 15724
Applicant Contact	Tricia Lefko	Facility Phone	(724) 349-6640
Applicant Phone	(724) 349-6640	Site ID	237795
Client ID	38534	Municipality	Cherry Tree Borough
SIC Code	4952	County	Indiana
SIC Description	Trans. & Utilities - Sewerage Systems	EPA Waived?	Yes
Date Application Received	November 27, 2023	If No, Reason	
Date Application Accepted	November 27, 2023		
Purpose of Application	NPDES Renewal.		

Summary of Review

Indiana County Municipal Service Authority (ICMSA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on May 20, 2019 and became effective on June 1, 2019. The permit expired on May 31, 2024.

Based on the review, it is recommended that the permit be drafted.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jinsu Kim Jinsu Kim / Environmental Engineering Specialist	May 6, 2025
X		Adam Olesnak Adam Olesnak, P.E. / Environmental Engineer Manager	May 21, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	.0171
Latitude	40° 42' 28.21"	Longitude	-78° 48' 35.16"
Quad Name	Barnesboro	Quad Code	1315
Wastewater Description: IW Process Effluent without ELG			
Receiving Waters	Peg Run (CWF)	Stream Code	27234
NHD Com ID	61836665	RMI	0.52
Drainage Area	1.93	Yield (cfs/mi ²)	0.0512
Q ₇₋₁₀ Flow (cfs)	0.0988	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	1436	Slope (ft/ft)	0.0313
Watershed No.	8-B	Chapter 93 Class.	CWF
Existing Use	Potable Water Supply	Existing Use Qualifier	
Exceptions to Use	None	Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake			
PWS Waters		Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	>50

Drainage Area

The discharge is to Peg Run at RM 0.52. A drainage area upstream of the discharge point is estimated to be 1.93 sq.mi. according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

USGS StreamStats produced a Q7-10 flow of 0.0988 cfs at the point of discharge.

Treatment Facility Summary

ICSMA operates an on-site wastewater treatment facility for its water treatment facility. About 24,000 gallons/day of raw water from Peg Run Reservoir is withdrawn, filtered and chlorinated before sent to Cherry Tree Water Distribution System. During the filtration process, filter is backwashed via finished water from the clearwell and about 3,000 gallons per day of backwash is generated. This backwash is sent to an underground sediment holding tank before discharged into Peg Run Creek via Outfall 001 to Peg Run.

Compliance History						
Summary of DMRs:	A summary of past 12 month DMR data is presented on the next page.					
Summary of Inspections:	02/18/2025: DEP conducted a routine inspection and there is no significant violation identified at the time of inspection.					
Other Comments:	Since the last permit reissuance, the facility has a number of permit violations particularly associated with effluent limit violations (see below).					

Date	Description	Parameter	Results	Limits	Units	SBC
February-20	Violation of permit condition	Aluminum, Total	4.57	4 mg/L	Average Monthly	
July-20	Violation of permit condition	Manganese, Total	1.34	1 mg/L	Average Monthly	
July-20	Violation of permit condition	Manganese, Total	2.37	2 mg/L	Daily Maximum	
January-21	Violation of permit condition	Aluminum, Total	10.6	4 mg/L	Average Monthly	
January-21	Violation of permit condition	Aluminum, Total	15.9	8 mg/L	Daily Maximum	
January-21	Violation of permit condition	Total Suspended Solids	31.2	30 mg/L	Average Monthly	

Based on DEP's database, there are a number of open violations associated with this facility or permittee in which all of these violations were identified by NWRO Safe Drinking Water Program. A draft permit cover letter will indicate that the permit may not be finalized until all violations are resolved.

Compliance History

DMR Data for Outfall 001 (from March 1, 2024 to February 28, 2025)

Parameter	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24
Flow (MGD) Average Monthly	0.003	0.005	0.006	0.006	0.006	0.006	0.006	0.005	0.006	0.005	0.006	0.007
Flow (MGD) Daily Maximum	0.004	0.006	0.007	0.008	0.006	0.006	0.008	0.006	0.007	0.006	0.008	0.007
pH (S.U.) Daily Minimum	6.97	6.91	7.12	6.91	7.19	7.19	7.47	6.90	7.00	6.90	7.00	7.10
pH (S.U.) Daily Maximum	7.29	7.21	7.32	6.97	7.37	7.21	7.49	7.10	7.10	7.20	7.20	7.10
TRC (mg/L) Average Monthly	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.03	< 0.05
TRC (mg/L) Daily Maximum	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	0.05	< 0.05	< 0.05	< 0.05	0.05	< 0.05
TSS (mg/L) Average Monthly	< 3.4	< 3.00	17.4	< 1.60	3.2	< 3.0	3.8	< 1.80	< 2.2	4.4	3.25	5.6
TSS (mg/L) Daily Maximum	5.20	4.40	23.2	< 1.60	3.60	4.40	4.80	2.00	2.80	6.80	4.50	9.20
Total Aluminum (mg/L) Average Monthly	0.6115	0.425	2.48	0.151	0.49	< 0.371	0.514	0.265	0.355	0.65	0.469	1.069
Total Aluminum (mg/L) Daily Maximum	0.812	0.459	3.23	0.198	0.602	0.642	0.537	0.333	0.439	0.947	0.525	1.48
Total Iron (mg/L) Average Monthly	< 0.200	< 0.200	0.3345	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200
Total Iron (mg/L) Daily Maximum	< 0.200	< 0.200	0.449	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200
Total Manganese (mg/L) Average Monthly	0.105	0.0822	0.192	0.132	0.159	0.179	0.156	0.176	0.203	0.156	0.106	0.0121
Total Manganese (mg/L) Daily Maximum	0.111	0.0851	0.211	0.135	0.162	0.248	0.187	0.186	0.230	0.161	0.131	0.131

Existing Effluent Limits and Monitoring Requirements

The table below summarizes effluent limits and monitoring requirements specified in the existing permit.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	2/month	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	1.0	XXX	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30.0	60.0	XXX	2/month	Grab
Aluminum, Total	XXX	XXX	XXX	4.0	8.0	XXX	2/month	Grab
Iron, Total	XXX	XXX	XXX	2.0	4.0	XXX	2/month	Grab
Manganese, Total	XXX	XXX	XXX	1.0	2.0	XXX	2/month	Grab

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 42' 27.00"
Wastewater Description: IW Process Effluent without ELG

Design Flow (MGD) .003
Longitude -78° 48' 34.00"

Technology-Based Limitations

DEP's technical guidance no. 362-2183-003 addresses technology-based control requirements along with the following recommended Best Practicable Control Technology Currently Available (BPT) effluent requirements for WTP sludge and filter backwash:

Parameter	Limit (mg/l)	SBC
Suspended Solids	30	Average Monthly
	60	Daily Maximum
Iron, Total	2.0	Average Monthly
	4.0	Daily Maximum
Aluminum, Total	4.0	Average Monthly
	8.0	Daily Maximum
Manganese, Total	1.0	Average Monthly
	2.0	Daily Maximum
Flow	Monitor	Average Monthly
pH	6.0	Minimum
	9.0	Maximum
Total Residual Chlorine	0.5	Average Monthly
	1.0	Daily Maximum

These requirements apply, subject to water quality analysis and/or BPJ.

Water Quality-Based Limitations

DEP's SOP no. BPNPSM-PMT-032 recommends the average monthly flow as a design flow in a reasonable potential analysis unless a different flow is determined to be more representative of conditions. DEP has been using 0.003 MGD as the design flow. Based on the review, it is still acceptable to use 0.003 MGD as the design flow in a reasonable potential analysis for this permit renewal.

WQM 7.0

CBOD5 and NH3-N are not pollutants of concern for the water treatment waste as the discharge of these pollutants is not resulting from the water treatment process. Therefore, WQM 7.0 modeling is not necessary and permit requirements for these pollutants are not recommended.

Total Residual Chlorine

The facility uses finished water for filter backwash and this finished water is chlorinated; therefore, Total Residual Chlorine (TRC) effluent level must be regulated under 25 Pa Code § 92a.48(b). DEP's TRC_CALC worksheet showed existing TBELs are still adequate for protection of water quality standards. No change is therefore recommended.

Toxics

Maximum concentrations of toxic pollutants reported on the application were entered into DEP's Toxics Management Spreadsheet (TMS). TMS output shows that there are no pollutants of concern and no water quality based effluent limits are required.

Additional Considerations

Flow Monitoring

Flow monitoring will remain in the permit and is required by 40 CFR § 122.44(i)(1)(ii).

Chesapeake Bay Total Maximum Daily Load (TMDL)

DEP's Supplement to Phase III Watershed Implementation Plan (WIP) indicates that monitoring and reporting of TN and TP are necessary for non-significant IW facilities throughout the permit term anytime the facility has the potential to introduce a net TN or TP increase to the load contained within the intake water used in processing. The facility does not use any chemical products prior to filtration that contain nitrogen or phosphorus and no nutrients are expected to be generated from the water treatment process. Consequently, no nutrient monitoring requirement will be included in the permit.

West Branch Susquehanna River Watershed Total Maximum Daily Load (TMDL)

The discharge is to Peg Run which ultimately is a tributary of West Branch Susquehanna River. DEP has developed a Total Maximum Daily Load (TMDL) for West Branch Susquehanna River watershed on December 3, 2011 to address stream impairments caused by metals including iron, aluminum and manganese as a result of acid mine drainage (AMD). While Peg Run is not impaired, DEP has established TMDLs for those tributaries of West Branch Susquehanna River to ensure no further impairment to be contributed and to maximize the pollutant reductions for water quality protection. This December 3, 2011 TMDL includes the following wasteload allocations for this facility:

Parameter	Monthly Average (mg/L)	Design Flow (MGD)	Allowable Load (lbs/day)
Iron, Total	2.0	0.0009	0.02
Manganese, Total	1.0	0.0009	0.01
Aluminum, Total	4.0	0.0009	0.03

These wasteload allocations have been consistently included in the permit and will continue to be included in the permit without any modification. Given that the TMDL established the load based on the flow of 0.0009 MGD which is significantly lower than the design flow DEP has consistently been using (i.e., 0.003 MGD), only the monthly average concentrations identified in the TMDL will be included in the permit. This approach is consistent with the permitting approach applied during the last permit renewal.

Chemical Additive

The permittee has not reported any chemicals that are considered chemical additives. According to the application, chemicals including Aluminum Sulfate (coagulation), Sodium Hypochlorite (disinfection), Soda Ash (pH control), and KMNO4 (oxidizing agent) are added during water treatment process. Based on the definition of chemical additives (i.e., chemicals used for cleaning, disinfecting or maintenance), these chemicals are not considered chemical additives except for Sodium Hypochlorite. TRC effluent limits are already applied to the permit for Sodium Hypochlorite; therefore no further requirement is needed.

Monitoring Frequencies and Sample Types

All existing monitoring frequencies and sample types will remain unchanged from the permit as DEP has determined that these requirements are still adequate for this facility.

Anti-Degradation Requirements

The effluent limits for this discharge have been developed to ensure the existing in-stream uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Anti-Backsliding Requirements

Unless stated otherwise in this fact sheet, permit requirements proposed in this fact sheet are at least as stringent as existing permit requirements.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0	XXX	2/month	Grab
TRC	XXX	XXX	XXX	0.5	1.0	XXX	2/month	Grab
TSS	XXX	XXX	XXX	30.0	60.0	XXX	2/month	Grab
Total Aluminum	XXX	XXX	XXX	4.0	8.0	XXX	2/month	Grab
Total Iron	XXX	XXX	XXX	2.0	4.0	XXX	2/month	Grab
Total Manganese	XXX	XXX	XXX	1.0	2.0	XXX	2/month	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]


StreamStats Report

Region ID: PA

Workspace ID: PA20250505003320756000

Clicked Point (Latitude, Longitude): 40.70782, -78.80974

Time: 2025-05-04 20:33:46 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	1.93	square miles
ELEV	Mean Basin Elevation	1657	feet
PRECIP	Mean Annual Precipitation	45	inches

General Disclaimers

Parameter values have been edited, computed flows may not apply.

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.93	square miles	2.33	1720
ELEV	Mean Basin Elevation	1657	feet	898	2700

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
PRECIP	Mean Annual Precipitation	45	inches	38.7	47.9

Low-Flow Statistics Disclaimers [Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.229	ft^3/s
30 Day 2 Year Low Flow	0.339	ft^3/s
7 Day 10 Year Low Flow	0.0987	ft^3/s
30 Day 10 Year Low Flow	0.139	ft^3/s
90 Day 10 Year Low Flow	0.206	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1



Discharge Information

Instructions Discharge Stream

Facility: Cherry Tree Water Treatment Plant NPDES Permit No.: PA0097462 Outfall No.: 001

Evaluation Type Major Sewage / Industrial Waste Wastewater Description: Filter Backwash

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.003	40	7						

	Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
				Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod
Group 1	Total Dissolved Solids (PWS)	mg/L	100								
	Chloride (PWS)	mg/L	17.4								
	Bromide	mg/L	< 0.036								
	Sulfate (PWS)	mg/L	32.4								
	Fluoride (PWS)	mg/L	0.213								
Group 2	Total Aluminum	µg/L	1010								
	Total Antimony	µg/L	0.348								
	Total Arsenic	µg/L	0.54								
	Total Barium	µg/L	28.8								
	Total Beryllium	µg/L	< 0.676								
	Total Boron	µg/L	< 56.5								
	Total Cadmium	µg/L	< 0.123								
	Total Chromium (III)	µg/L	1.99								
	Hexavalent Chromium	µg/L	< 0.69								
	Total Cobalt	µg/L	< 0.119								
	Total Copper	µg/L	10.3								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L	< 6								
	Dissolved Iron	µg/L	28								
	Total Iron	µg/L	380								
	Total Lead	µg/L	0.353								
	Total Manganese	µg/L	727								
	Total Mercury	µg/L	< 0.0932								
	Total Nickel	µg/L	< 1.44								
	Total Phenols (Phenolics) (PWS)	µg/L	5								
	Total Selenium	µg/L	< 2.5								
	Total Silver	µg/L	< 1.37								
	Total Thallium	µg/L	0.081								
	Total Zinc	µg/L	3.66								
	Total Molybdenum	µg/L	0.333								
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								
	Carbon Tetrachloride	µg/L	<								



Stream / Surface Water Information

Instructions Discharge Stream

Cherry Tree Water Treatment Plant, NPDES Permit No. PA0097462, Outfall 001

Toxics Management Spreadsheet
Version 1.4, May 2023

Receiving Surface Water Name: Peg Run

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	027234	0.52	1436	1.93			Yes
End of Reach 1	027234	0	1373	45.2			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
Point of Discharge	0.52	0.1	0.0982							
End of Reach 1	0	0.1	2.83							

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
Point of Discharge	0.52									
End of Reach 1	0									



Model Results

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

Cherry Tree Water Treatment Plant, NPDES Permit No. PA0097462, Outfall 001

Toxics Management Spreadsheet
Version 1.4, May 2023

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis pH:

Analysis Hardness (mg/l):

Pollutants	Stream Conc (µg/L)	Stream Cv	trib Conc (µg/L)	trib Coef	WQC (µg/L)	WQ Obj (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A
Chloride (PWS)	0	0		0	N/A	N/A	N/A
Sulfate (PWS)	0	0		0	N/A	N/A	N/A
Fluoride (PWS)	0	0		0	N/A	N/A	N/A
Total Aluminum	0	0		0	750	16,619	
Total Antimony	0	0		0	1,100	24,375	
Total Arsenic	0	0		0	340	7,534	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	465,344	
Total Boron	0	0		0	8,100	179,490	
Total Cadmium	0	0		0	1,961	2,07	Chem Translator of 0.945 applied
Total Chromium (III)	0	0		0	557,097	1,763	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16,3	Chem Translator of 0.932 applied
Total Cobalt	0	0		0	95	95,0	2,105
Total Copper	0	0		0	13,096	13,6	Chem Translator of 0.946 applied
Dissolved Iron	0	0		0	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	
Total Lead	0	0		0	62,679	78,8	1,747
Total Manganese	0	0		0	N/A	N/A	
Total Mercury	0	0		0	1,400	1,65	Chem Translator of 0.85 applied
Total Nickel	0	0		0	457,487	458	10,158
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	Chem Translator of 0.998 applied
Total Selenium	0	0		0	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	3,068	3,61	80,0
Total Thallium	0	0		0	65	65,0	Chem Translator of 0.85 applied
Total Zinc	0	0		0	114,486	117	2,594

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Page 5

Model Results

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	
Total Antimony	0	0	0	0	220	220	
Total Arsenic	0	0	0	0	150	150	
Total Barium	0	0	0	0	4,100	4,100	
Total Boron	0	0	0	0	1,600	1,600	
Total Cadmium	0	0	0	0	0.241	0.27	5.88 Chem Translator of 0.91 applied
Total Chromium (III)	0	0	0	0	72,467	84.3	1,867 Chem Translator of 0.86 applied
Hexavalent Chromium	0	0	0	0	10	10.4	230 Chem Translator of 0.962 applied
Total Cobalt	0	0	0	0	19	19.0	421
Total Copper	0	0	0	0	8,748	9.11	202 Chem Translator of 0.96 applied
Dissolved Iron	0	0	0	0	N/A	N/A	
Total Iron	0	0	0	0	1,500	1,500	
Total Lead	0	0	0	0	2,443	3,07	68.1
Total Manganese	0	0	0	0	N/A	N/A	
Total Mercury	0	0	0	0	0.770	0.91	20.1
Total Nickel	0	0	0	0	50,813	51.0	1,129 Chem Translator of 0.937 applied
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	
Total Selenium	0	0	0	0	4,600	4,99	111 Chem Translator of 0.922 applied
Total Silver	0	0	0	0	N/A	N/A	
Total Thallium	0	0	0	0	13	13.0	288 Chem Translator of 1 applied
Total Zinc	0	0	0	0	115,423	117	2,594 Chem Translator of 0.986 applied

THH CCT (min): 0.975 PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	500,000	500,000	N/A
Chloride (PWS)	0	0	0	0	250,000	250,000	N/A
Sulfate (PWS)	0	0	0	0	250,000	250,000	N/A
Fluoride (PWS)	0	0	0	0	2,000	2,000	N/A
Total Aluminum	0	0	0	0	N/A	N/A	N/A
Total Antimony	0	0	0	0	5.6	5.6	124
Total Arsenic	0	0	0	0	10	10.0	222
Total Barium	0	0	0	0	2,400	2,400	53,182
Total Boron	0	0	0	0	3,100	3,100	68,694
Total Cadmium	0	0	0	0	N/A	N/A	N/A
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	0	N/A	N/A	N/A
Middle Results, Dissolved Iron	0	0	0	0	300- _{1/4} 1/2D ₂ D ₃ 00	300	6,648

Page 6

Total Iron	0	0	0	0	0	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	0	1,000	1,000	22,159
Total Mercury	0	0	0	0	0.050	0.05	1.11
Total Nickel	0	0	0	0	610	610	13,517
Total Phenols (Phenolics) (PWS)	0	0	0	0	5	5.0	N/A
Total Selenium	0	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0	0.24	0.24	5.32
Total Zinc	0	0	0	0	N/A	N/A	N/A

CRL

CCT (min): 0.239

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Analysis WQ Obj: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trb Conc (µg/L)	Fate Coef	WQC (µg/L)	WQA Obj (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A
Fluoride (PWS)	0	0	0	0	N/A	N/A	N/A
Total Aluminum	0	0	0	0	N/A	N/A	N/A
Total Antimony	0	0	0	0	N/A	N/A	N/A
Total Arsenic	0	0	0	0	N/A	N/A	N/A
Total Barium	0	0	0	0	N/A	N/A	N/A
Total Boron	0	0	0	0	N/A	N/A	N/A
Total Cadmium	0	0	0	0	N/A	N/A	N/A
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	0	N/A	N/A	N/A
Dissolved Iron	0	0	0	0	N/A	N/A	N/A
Total Iron	0	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	0	N/A	N/A	N/A
Total Mercury	0	0	0	0	N/A	N/A	N/A
Total Nickel	0	0	0	0	N/A	N/A	N/A
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A
Total Selenium	0	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0	N/A	N/A	N/A
Total Zinc	0	0	0	0	N/A	N/A	N/A

Comments

7. Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Model Results	Detectable	Mass Limits	MDL	AML	Mn	Concentration Limits	1/4 PDRSS	1/8	Governing	WQBEL	Comments	Page 7
---------------	------------	-------------	-----	-----	----	----------------------	-----------	-----	-----------	-------	----------	--------

Parameter	(lbs/day)	Comments						
-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	----------

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	10,652	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	124	µg/L	Discharge Conc ≤ 10% WQBEL
Total Arsenic	222	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	53,182	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	35,455	µg/L	Discharge Conc < TQL
Total Cadmium	5.88	µg/L	Discharge Conc < TQL
Total Chromium (III)	1,867	µg/L	Discharge Conc ≤ 10% WQBEL
Hexavalent Chromium	230	µg/L	Discharge Conc < TQL
Total Cobalt	421	µg/L	Discharge Conc < TQL
Total Copper	194	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	6,648	µg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	33,239	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	68.1	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	22,159	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	1.11	µg/L	Discharge Conc < TQL
Total Nickel	1,129	µg/L	Discharge Conc < TQL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	111	µg/L	Discharge Conc < TQL
Total Silver	51.3	µg/L	Discharge Conc ≤ 10% WQBEL
Total Thallium	5.32	µg/L	Discharge Conc ≤ 10% WQBEL
Total Zinc	1,663	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS

WEST BRANCH SUSQUEHANNA RIVER WATERSHED TMDL

**Clearfield, Indiana, Cambria, Centre, Clinton,
Cameron, Elk, Potter, Tioga, Lycoming,
Union, Northumberland, Montour,
Sullivan, Bradford, Columbia,
McKean, and Wyoming Counties**

Prepared for:

Pennsylvania Department of Environmental Protection



Dec 3, 2011

Table D66. WLA for WBSR 16.0				
Company	Permit(s)	Effluent limits (mg/L)	Design Flow (MGD)	WLAs (lbs/day)
Twin Brook Coal Co.	PA0125504, 32813001	Fe – 3.0 Mn – 2.0 Al – 0.75	0.0445	Fe – 1.11 Mn – 0.74 Al – 0.28
TOTAL				Fe – 1.11 Mn – 0.74 Al – 0.28

CTBMA: Cherry Tree Borough Municipal Authority

The Cherry Tree Borough Municipal Authority (NPDES PA0097462) has one outfall (001) in the West Branch Watershed. This outfall has effluent limits for total iron, total manganese, and total aluminum. Table D67 shows the WLA for this discharge.

Table D67. WLA Cherry Tree Borough Municipal Authority				
Parameter	Outfall 001	Monthly Average Conc. (mg/L)	Design Flow (MGD)	Allowable Load (lbs/day)
Fe		2.0	0.0009	0.02
Mn		1.0	0.0009	0.01
Al		4.0	0.0009	0.03

PRKW: Cherry Tree Mine, Parkwood Resources, Inc.

Parkwood Resources, Inc. (17031301, PA0235571) has three outfalls from their Cherry Tree Deep Mine. Outfall 001 is drainage from the deep mine with effluent limits for iron, manganese, and flow. Outfalls 002 and 003 are for erosion and sediment. These outfalls then enter an unnamed tributary to the West Branch Susquehanna River. The following table shows the waste load allocation for these discharges (Table I68).

Table D68. Waste Load Allocation for NPDES Permit No. PA0215007				
Parameter	Outfall 001	Monthly Average Conc. (mg/L)	Design Flow (MGD)	Allowable Load (lbs/day)
Fe		3.0	3.36	84.13
Mn		2.0	3.36	56.09
Al		0.75	3.36	21.03
Outfall 002				
Fe		7.0	0.0445	2.60
Outfall 003				
Fe		7.0	0.0445	2.60

WBSR 16.0: West Branch Susquehanna River downstream of Cush Cushion Creek