

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0097535
APS ID 1056140
Authorization ID 1384063

Applicant and Facility Information

Applicant Name	<u>Norma Pennsylvania Inc.</u> <u>DBA Breeze Ind Products Corp</u>	Facility Name	<u>Breeze Ind Clamp Division</u>
Applicant Address	<u>3582 Tunnelton Road</u> <u>Saltsburg, PA 15681-3305</u>	Facility Address	<u>3582 Tunnelton Road</u> <u>Saltsburg, PA 15681-3305</u>
Applicant Contact	<u>Sean Gillespie</u>	Facility Contact	
Applicant Phone	<u>(724) 639-1018</u>	Facility Phone	
Applicant E Mail	<u>Sean.gillespie@normagroup.com</u>	Facility E Mail	
Client ID	<u>27210</u>	Site ID	<u>237060</u>
Municipality	<u>Conemaugh Township</u>	County	<u>Indiana</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No requirements</u>
Date Application Received	<u>February 1, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>February 23, 2022</u>	If No, Reason	
Purpose of Application	<u>NPDES renewal</u>		

Summary of Review

A NOV was issued on February 8, 2022 for effluent violations by Susan Black and remains pending in WMS. *In reviewing this with operations, it appears that the facility has been in compliance, and it is anticipated that this violation will be closed.*
JCD

Previously storm water discharges were reported.

Sludge use and disposal description and location(s): 1.021 tons dry sludge was sent to AVISA at Cheswick for disposal.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	October 12, 2022
X		vacant Environmental Engineer Manager	Okay to Draft JCD 12/7/2022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.002</u>
Latitude DP	<u>40° 28' 52.00"</u>	Longitude DP	<u>-79° 23' 5.00"</u>
Latitude NHD	<u>40° 28' 50.52"</u>	Longitude NHD	<u>-79° 23' 4.83"</u>
Quad Name	<u>Saltsburg</u>	Quad Code	<u>1510</u>
Wastewater Description: <u>Treated Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Elders Run</u>	Stream Code	<u>43845</u>
NHD Com ID	<u>123722098</u>	RMI	<u>1.20</u>
Drainage Area	<u>0.55</u>	Yield (cfs/mi ²)	<u>0.0157</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.0086</u>	Q ₇₋₁₀ Basis	<u>Beaver Run</u>
Elevation (ft)	<u>1155.00</u>	Slope (ft/ft)	<u>0.0548</u>
Watershed No.	<u>18-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>End of Reach RMI 0,4 Elevation 900 feet Drainage 1.0 square mile</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u>Final</u>	Name	<u>Kiskiminetas-Conemaugh River TMDL</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	default	<u></u>
Temperature (°C)	<u>20</u>	CWF default	<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Municipal Authority of Westmoreland County</u>		
PWS Waters	<u>Conemaugh River</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>0.930661</u>	Distance from Outfall (mi)	<u>4.852218</u>

Changes Since Last Permit Issuance: none

Other Comments: Alternate name for Municipal Authority of Westmoreland County is Saltsburg Boro Muni Waterworks.

Treatment Facility Summary				
Treatment Facility Name: Norma PA Inc. Dba Breeze Ind Products Corp				
WQM Permit No.		Issuance Date		
3287402		12/30/1987		
3287402-A1		1999		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary with NH3-N removal	Septic tank/sand filter/ biotower	tablet	0.002
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.002	29.75	Not Overloaded	Septic tank	

Changes Since Last Permit Issuance: None

Other Comments: Organic capacity calculated by multiplying 0.17 lbs/capita x 175 workers.

The existing STP has 3 septic tanks, 1 dosing tank, 1 bio-tower, 2 above ground sand filters, 1 recirculation tank, 1 chlorine contact tank, and 1 de-chlorination tank. The facility was initially constructed to treat a design flow of 5600 gpd. It obviously was not designed in accordance with Small Flow Treatment Facilities Manual (32-0300-002) due to the design flow volume. In addition, the facility was constructed prior to publication of that design manual.

Flow measurement is taken by using a bucket and stopwatch.

Compliance History

DMR Data for Outfall 001 (from January 1, 2021 to December 31, 2021)

Parameter	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21
Flow (MGD) Average Monthly	0.0020	0.0047	0.0047	0.0069	0.0020	0.0020	0.0020	0.0013	0.0013	0.0014	0.0016	0.0013
pH (S.U.) Minimum	6.54	6.15	6.09	6.0	6.16	6.20	6.0	6.10	6.10	6.1	6.64	6.90
pH (S.U.) Maximum	7.01	7.07	6.92	6.79	6.76	7.03	6.69	6.64	7.12	7.12	7.3	7.33
DO (mg/L) Minimum	7.04	8.32	6.10	5.97	7.38	4.15	4.15	4.09	6.20	6.2	6.63	8.82
TRC (mg/L) Average Monthly	0.24	0.30	0.41	0.15	0.44	0.53	0.21	0.54	0.34	0.2	0.05	0.17
TRC (mg/L) Instantaneous Max	0.62	0.65	1.35	0.33	1.40	1.50	1.30	1.44	0.85	0.5	0.12	0.27
CBOD5 (mg/L) Average Monthly	3.0	3.0	3.0	3.0	3.4	3.0	3.0	3.0	3.0	3.7	3.0	7.7
CBOD5 (mg/L) Instantaneous Max	3.0	3.0	3.0	3.0	3.8	3.0	3.0	3.0	3.0	4.4	3.0	12.3
TSS (mg/L) Average Monthly	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	4.5	6.5	3.5	8.5
TSS (mg/L) Instantaneous Max	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	6.0	10.0	4.0	14.0
Fecal Coliform (#/100 ml) Geometric Mean	1	1.0	6.0	13.0	50	1.0	50	2420	1.0	14	38	1
Fecal Coliform (#/100 ml) Instant Max	1	1.0	32	153.0	2420	1.0	2420	2420	1.0	194	1414	1
Ammonia (mg/L) Average Monthly	12.80	2.31	3.39	2.23	2.20	1.05	11.31	15.10	8.34	7.35	16.84	26.43
Ammonia (mg/L) Instantaneous Max	14.10	4.46	4.44	4.09	2.68	1.80	15.30	24.30	8.77	8.18	24.60	37.90

Summer pH median 6.480 SU Annual median 6.665 SU

Ammonia high average in May and June, High Maximum in May.

Fecal coliforms high average in May and high maximums in May, June and August

De-chlorination permitted. High average in May and high maximums in May, June, July, August, and October

Design hydraulic capacity 0.0056-MGD The facility has been down rated to 0.002-MGD. The high September through November flows should not cause any operation failures.

Minimum 4.0-mg/l DO should be acceptable

DMR Data for Outfall 001 (from September 1, 2021 to August 31, 2022)

NPDES Permit Fact Sheet
Breeze Ind Clamp Division

NPDES Permit No. PA0097535

Parameter	AUG-22	JUL-22	JUN-22	MAY-22		APR-22	MAR-22	FEB-22	JAN-22				
Flow (MGD) Average Monthly	0.0020	0.0020	0.0020	0.0020		0.0020	0.0020	0.0020	0.0020				
pH (S.U.) Minimum	6.20	6.2	6.24	6.49		6.45	6.78	7.05	7.04				
pH (S.U.) Maximum	7.21	6.87	7.23	8.50		6.89	7.50	7.80	7.60				
DO (mg/L) Minimum	8.54	9.50	7.19	6.50		8.30	7.20	8.70	9.72				
TRC (mg/L) Average Monthly	0.23	0.19	0.21	0.07		0.14	0.07	0.22	0.31				
TRC (mg/L) Instantaneous Maximum	0.62	0.52	0.41	0.21		0.62	0.27	0.68	0.71				
CBOD5 (mg/L) Average Monthly	3.0	3.0	3.0	3.0		3.0	3.0	3.8	3.0				
CBOD5 (mg/L) Instantaneous Max	3.0	3.0	3.0	3.0		3.0	3.0	4.0	3.0				
TSS (mg/L) Average Monthly	3.0	3.0	4.5	4.0		3.0	3.0	3.0	3.0				
TSS (mg/L) Instantaneous Max	3.0	3.0	6.0	5.0		3.0	3.0	3.0	3.0				
Fecal Coliform (#./100 ml) Geometric Mean	1	8.0	1.0	42.00		1.0	1.0	1.0	1				
Fecal Coliform (#./100 ml) Instantaneous Maximum	1.0	58.0	1.0	1733		1.0	1.0	1.0	1				
Ammonia (mg/L) Average Monthly	0.21	1.31	0.214	7.14		5.65	16.30	38.95	23.35				
Ammonia (mg/L) Instantaneous Maxi	0.27	1.46	4.08	9.48		6.17	18.60	49.60	32.50				

Summer pH median 6,535 SU Annual median 6.965 SU
 Long term Summer pH median 6,480 SU Annual median 6.830 SU
 No problems reported after May 2022
 Minimum 4.0-mg/l DO should be acceptable
 High ammonia average and maximum in February

Compliance History

Effluent Violations for Outfall 001, from: February 1, 2021 To: December 31, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Flow	09/30/21	Avg Mo	0.0069	MGD	.002	MGD
Flow	10/31/21	Avg Mo	0.0047	MGD	.002	MGD
Flow	11/30/21	Avg Mo	0.0047	MGD	.002	MGD
pH	04/30/21	Min	3.0	S.U.	6.0	S.U.
TRC	05/31/21	Avg Mo	0.54	mg/L	.5	mg/L
TRC	07/31/21	Avg Mo	0.53	mg/L	.5	mg/L
Fecal Coliform	05/31/21	Geo Mean	2420	No./100 ml	200	No./100 ml
Fecal Coliform	06/30/21	IMAX	2420	No./100 ml	1000	No./100 ml
Fecal Coliform	05/31/21	IMAX	2420	No./100 ml	1000	No./100 ml
Fecal Coliform	08/31/21	IMAX	2420	No./100 ml	1000	No./100 ml
Ammonia	06/30/21	Avg Mo	11.31	mg/L	9.2	mg/L
Ammonia	05/31/21	Avg Mo	15.10	mg/L	9.2	mg/L
Ammonia	05/31/21	IMAX	24.30	mg/L	18.4	mg/L
Flow	11/30/21	Avg Mo	0.0047	MGD	.002	MGD
Flow	10/31/21	Avg Mo	0.0047	MGD	.002	MGD
Fecal Coliform	05/31/22	IMAX	1733	No./100 ml	1000	No./100 ml
Ammonia	02/28/22	Avg Mo	38.95	mg/L	27.6	mg/L

Other Comments: Flows are well within the original design basis. The TRC violations are not significant. No current violations reported

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.002</u>
Latitude <u>40° 28' 51.00"</u>	Longitude <u>-79° 23' 5.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E.Coli	monitoring			
DO	4.0	Daily Minimum		BPJ

Comments: Self-monitoring reports the 4.0-mg/L daily minimum DO is achievable. Because of the small flow classification E.Coli monitoring is not proposed.

Water Quality-Based Limitations

A Sewerage Program “Reasonable Potential Analysis” determined the following parameters were candidates for limitations: CBOD₅, TSS, ammonia, TGRC and pH.

The following limitations were determined through water quality modeling (output files attached):

Parameter		Limit (mg/l)			SBC	Model		
Name	Period	Minimum	Average	Maximum		Minimum	Average	Maximum
Ammonia	Summer		8.5	17.0	NA		8.54	17.08
	Winter		25.5	51.0			25.5	51.0

Comments: *The previous NH₃-N limitations were 9.2 mg/l AML summertime and 27.6 mg/l AML wintertime. The facility should be able to meet the slightly more stringent limitations. Therefore, no compliance schedule is being proposed as part of the draft permit.*

Best Professional Judgment (BPJ) Limitations

Comments: Applicable to the proposed achievable 4.0-mg/L minimum daily DO limitation.

Anti-Backsliding

Applied to CBOD₅ and TSS.

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18C	43845	Trib 43845 to Elders Run	0.000	900.00	1.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.016	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18C	43845	Trib 43845 to Elders Run	1.212	1155.00	0.55	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.016	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Breeze Ind	PA0097535A	0.0020	0.0020	0.0020	0.000	25.00	6.50

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Uniform Treatme	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18C		43845				Trib 43845 to Elders Run						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
1.212	0.01	0.00	0.01	.0031	0.03985	.251	1.98	7.91	0.02	3.137	21.32	6.80
Q1-10 Flow												
1.212	0.01	0.00	0.01	.0031	0.03985	NA	NA	NA	0.02	3.727	21.79	6.75
Q30-10 Flow												
1.212	0.01	0.00	0.01	.0031	0.03985	NA	NA	NA	0.03	2.750	21.04	6.84

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
18C	43845	Trib 43845 to Elders Run

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.212	Breeze Ind	NA	50	17.33	48.1	1	4

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.212	Breeze Ind	NA	25	1.86	8.54	1	66

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.21	Breeze Ind	25	25	8.54	8.54	4	4	0	0

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18C	43845	Trib 43845 to Elders Run		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
1.212	0.002	21.319		6.804
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
1.982	0.251	7.907		0.024
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
8.07	0.418	2.33		0.775
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
7.124	23.541	Owens		5
<u>Reach Travel Time (days)</u>	Subreach Results			
3.137	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.314	7.02	1.82	8.24
	0.627	6.10	1.43	8.24
	0.941	5.31	1.12	8.24
	1.255	4.62	0.88	8.24
	1.568	4.02	0.69	8.24
	1.882	3.49	0.54	8.24
	2.196	3.04	0.42	8.24
	2.509	2.64	0.33	8.24
	2.823	2.30	0.26	8.24
	3.137	2.00	0.20	8.24

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18C		43845				Trib 43845 to Elders Run						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
1.212	0.01	0.00	0.01	.0031	0.03985	.251	1.98	7.91	0.02	3.137	21.32	6.80
Q1-10 Flow												
1.212	0.01	0.00	0.01	.0031	0.03985	NA	NA	NA	0.02	3.727	21.79	6.75
Q30-10 Flow												
1.212	0.01	0.00	0.01	.0031	0.03985	NA	NA	NA	0.03	2.750	21.04	6.84

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18C		43845		Trib 43845 to Elders Run			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
1.212	Breeze Ind	PA0097535A	0.002	CBOD5	25		
				NH3-N	8.54	17.08	
				Dissolved Oxygen			4

1A	B	C	D	E	F	G	H	I	J	K	L	M
	Discharger Site	Breeze Industrial STP								Wednesday, October 12, 2022		
	Municipality	Breeze Industrial STP						Revised		Wednesday, October 12, 2022		
	County	Conemaugh Township										
	NPDES Permit	Indiana										
	0.5	PA0097535										
2	TRC EVALUATION											
3	Input appropriate values in B4:B8 and E4:E7											
4	0.0086	= Q stream (cfs)				0.5	= CV Daily					
5	0.0020	= Q discharge (MGD)				0.5	= CV Hourly					
6	4	= no. samples				1	= AFC_Partial Mix Factor					
7	0.3	= Chlorine Demand of Stream				1	= AFC_Partial Mix Factor					
8	0	= BAT/BPJ Value				15	= AFC_Criteria Compliance Time (min)					
9	0	= % Factor of Safety (FOS)				720	= CFC_Criteria Compliance Time (min)					
							=Decay Coefficient (K)					
10	Source	Reference	AFC Calculations			Reference	CFC Calculations					
11	TRC	1.3.2.iii		WLA_afc = 0.909		1.3.2.iii		WLA_cfc = 0.879				
12	PENTOXSD TRG	5.1a		LTAMULT_afc = 0.373		5.1c		LTAMULT_cfc = 0.581				
13	PENTOXSD TRG	5.1b		LTA_afc = 0.339		5.1d		LTA_cfc = 0.511				
14												
15	Source	Effluent Limit Calculations										
16	PENTOXSD TRG	5.1f		AML_MULT = 1.720								
17	PENTOXSD TRG	5.1g		↓ LIMIT (mg/l) = 0.500				BAT/BPJ				
18				↑ LIMIT (mg/l) = 1.170								
	WLA_afc	$\frac{(0.19/e^{-(k \cdot AFC_tc)}) + [(AFC_Yc \cdot Qs \cdot 0.19 / Qd) \cdot e^{-(k \cdot AFC_tc)}] \dots}{\dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)} \cdot (1 - FOS / 100)$										
	LTAMULT_afc	$EXP((0.5 \cdot LN((cvh^2 + 1)) - 2.326 \cdot LN((cvh^2 + 1)^{0.5}))$										
	LTA_afc	wla_afc * LTAMULT_afc										
	WLA_cfc	$\frac{(0.11/e^{-(k \cdot CFC_tc)}) + [(CFC_Yc \cdot Qs \cdot 0.11 / Qd) \cdot e^{-(k \cdot CFC_tc)}] \dots}{\dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)} \cdot (1 - FOS / 100)$										
	LTAMULT_cfc	$EXP((0.5 \cdot LN((cvd^2 / no_samples + 1)) - 2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}))$										
	LTA_cfc	wla_cfc * LTAMULT_cfc										
	AML_MULT	EXP(2.326 * LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 * LN((cvd^2 / no_samples + 1))										
	AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)										
	INST MAX LIMIT	1.5 * ((av_mon_limit * AML_MULT) / LTA_MULT_afc)										
	$\frac{(0.011 / EXP(-k \cdot CFC_tc / 1440)) + ((CFC_Yc \cdot Qs \cdot 0.011) / (1.547 \cdot Qd)) \dots}{\dots + EXP(-k \cdot CFC_tc / 1440)) + Xd + (CFC_Yc \cdot Qs \cdot Xs / 1.547 \cdot Qd)} \cdot (1 - FOS / 100)$											
	Stream	Chlorine Required	=	perennial	Chlorine Demand	+	Chlorine Residual					
	Stream	Reach/Node	1	1								
	Stream	Flow	Conditions	intermittent								
	Stream	Code		43845								
	Stream	Function										
	Samples			4								
	reach	outfall	RMI	1.20								
	reach	Reach End	RMI	0								
	reach		feet	6336								
	drainage		sq miles	0.55								
	TRC	limitation	average	mg/L	0.148							
			maximum	mg/L	0.484							
	elevation		modelled	feet	1155							
	elevation		modelled	feet	900							
	slope		modelled	foot/foot	0.040							
	low flow			cfs/sq mi	0.016							
	discharge			mgd	0.0020							
	Runoff	Period		hours	24.000							
	BAT should suffice											
	stream	flow		cfs	0.00864							
	stream	flow		MGD	0.005581							
	stream	flow	total	MGD	0.007581							
	stream	chlorine	demand	mg/L	0.3							
	discharge	discharge	demand	mg/L								
	stream	Total Stream/Waste		ratio	3.8							
	BAT	TRC	mean	BAT	0.5							
	BAT	TRC	maximum	BAT	1.6							
			Municipality									

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Average Monthly	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.002	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Min	XXX	9.0	XXX	2/month	Grab
Dissolved Oxygen	XXX	XXX	4.0 Min	XXX	XXX	XXX	2/month	Grab
Total Residual Chlorine (TRC)	XXX	XXX	0.5	XXX	XXX	1.2	4/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	20.0	XXX	XXX	40.0	2/month	Grab
Total Suspended Solids	XXX	XXX	20.0	XXX	XXX	40.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	25.5	XXX	XXX	51.0	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	8.5	XXX	XXX	17.0	2/month	Grab

Compliance Sampling Location: Outfall 00 after disinfection

Public Water Intake Notes

4.852218	1.2	43845 To Elders Run
3.652218	0.396557	43844 Elders Run
2.255601	4.186262	43832 Conemaugh River
0	0.930661	Intake/Source SALTSBURG BORO MUNI WATERWORKS/WESTMORELAND CNTY MUNI AUTH
	27.1157	42816 Kiskiminetas River
	313.045495	42122 Allegheny River
	310.994374	intake/source BUFFALO TWP MUNI