

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0098060
 APS ID 893475
 Authorization ID 1371063

Applicant and Facility Information

Applicant Name	<u>Eugene J. Smith, Jr. and Jackie A. Smith</u>	Facility Name	<u>Smithwind MHP STP</u>
Applicant Address	<u>106 Chrissy's Crossing Fombell, PA 16123-1804</u>	Facility Address	<u>Lancaster Road Fombell, PA 16123</u>
Applicant Contact	<u>Eugene/Jackie Smith</u>	Facility Contact	<u>Same as applicant</u>
Applicant Phone	<u>(724) 816-7640</u>	Facility Phone	<u>Same as applicant</u>
Client ID	<u>43972</u>	Site ID	<u>240130</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Franklin Township</u>
Connection Status	<u></u>	County	<u>Beaver</u>
Date Application Received	<u>September 21, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 30, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for a renewal of an NPDES permit for discharge of treated sewage</u>		

Summary of Review



The permittee has applied for a renewal of NPDES Permit No. PA0098060. NPDES Permit No. PA0098060 was previously issued by the PA Department of Environmental Protection (DEP) on April 1, 2017 and expires on March 31, 2022.

Sewage from this facility is treated with:

- Four (4) septic tanks
- Two (2) holding tanks
- Two (2) wet wells (with float system)
- Two (2) gravity sand filters
- One (1) chlorinator
- One (1) dechlorinator

The applicant is currently enrolled in and will continue to use eDMR.

The Act-14 PL 834 Municipal Notification was provided by the June 30, 2021 letters and no comments were received.

Approve	Deny	Signatures	Date
X		 Grace Polakoski, E.I.T. / Environmental Engineering Specialist	October 6, 2021
X		 Christopher Kriley, P.E. / Program Manager	October 21, 2021

Summary of Review

Sludge use and disposal description and location(s): sludge is hauled off-site by an external operator

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0022</u>
Latitude	<u>40° 50' 48.00"</u>	Longitude	<u>-80° 12' 3.00"</u>
Quad Name	_____	Quad Code	_____
Wastewater Description: <u>Sewage Effluent</u>			

Receiving Waters	<u>UNT of Slippery Rock Creek</u>	Stream Code	<u>34037</u>
NHD Com ID	_____	RMI	<u>0.2</u>
Drainage Area	<u>0.0886 sq mi</u>	Yield (cfs/mi ²)	<u>0.0047</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.000417</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>1,153</u>	Slope (ft/ft)	_____
Watershed No.	<u>17-D</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	_____	Exceptions to Criteria	_____

Assessment Status Attaining Use(s)

Cause(s) of Impairment _____

Source(s) of Impairment _____

TMDL Status _____ Name _____

Background/Ambient Data	Data Source
pH (SU)	_____
Temperature (°F)	_____
Hardness (mg/L)	_____
Other:	_____

Nearest Downstream Public Water Supply Intake	<u>PA American Water Co Ellwood City</u>
PWS Waters	_____
PWS RMI	_____
	Flow at Intake (cfs) _____
	Distance from Outfall (mi) <u>3.6</u>

Changes Since Last Permit Issuance:

Other Comments:

Treatment Facility Summary				
Treatment Facility Name: Smithwind MHP STP				
WQM Permit No.		Issuance Date		
0487410		06/13/1989		
0487410 T-1		05/09/1994		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Septic tank with sand filter	Chlorine	0.0022
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0022	30	Not Overloaded	N/A	External hauler

Changes Since Last Permit Issuance: N/A

Other Comments:

Compliance History

DMR Data for Outfall 001 (from September 1, 2020 to August 31, 2021)

Parameter	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20
Flow (MGD) Average Monthly	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001
Flow (MGD) Daily Maximum	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001
pH (S.U.) Minimum	6.5	6.55	6.8	6.51	6.61	7.29	7.21	7.31	7.18	6.93	7.18	6.59
pH (S.U.) Maximum	6.7	7.55	7.11	7.05	7.08	7.68	7.53	7.7	7.67	7.40	7.31	7.33
DO (mg/L) Minimum	5.01	5.59	6.0	6.01	6.0	6.01	6.04	6.01	6.01	6.01	6.32	7.20
TRC (mg/L) Average Monthly	0.01	0.01	0.02	0.019	0.22	0.01	0.02	0.01	0.01	0.02	0.02	0.021
TRC (mg/L) Instantaneous Maximum	0.03	0.06	0.04	0.06	0.07	0.03	0.07	0.05	0.03	0.09	0.06	0.07
CBOD5 (mg/L) Average Monthly	9.80	9.75	7.9	7.0	17.25	8.95	6.4	7.5	7.16	5.55	6.03	5.95
TSS (mg/L) Average Monthly	8.0	7.0	2.4	3.5	67.5	1.5	1.0	4.0	5.66	1.0	8.66	5.95
Fecal Coliform (No./100 ml) Geometric Mean	14.83	9.48	9.64	4.89	10.39	4.2	0.02	1.00	5.60	1.00	6.83	4.47
Fecal Coliform (No./100 ml) Instantaneous Maximum	22	15	31	6	36	18	1.0	1.00	11	1.00	32	20
Total Nitrogen (mg/L) Instantaneous Maximum									12.0			
Ammonia (mg/L) Average Monthly	4.45	0.5	1.36	1.04	2.52	0.30	2.52	3.24	2.53	1.83	2.39	0.6
Ammonia (mg/L) Instantaneous Maximum	6.07	0.7	1.75	1.44	3.0	0.30	2.66	3.24	6.04	2.83	4.99	0.90
Total Phosphorus (mg/L) Instantaneous Maximum									2.0			

Compliance History

Effluent Violations for Outfall 001, from: October 1, 2020 To: August 31, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	04/30/21	Avg Mo	0.22	mg/L	0.06	mg/L
TSS	04/30/21	Avg Mo	67.5	mg/L	30.0	mg/L
Ammonia	08/31/21	Avg Mo	4.45	mg/L	2.5	mg/L
Ammonia	08/31/21	IMAX	6.07	mg/L	5.0	mg/L

Summary of Inspections:

Other Comments:

Compliance Review Period: 10/7/2016 – 10/7/2021

Open Violations by Client Summary:

None.

Inspection Summary

INSP ID	INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC	INSPECTION COMMENT	# OF VIOLATIONS
2533120	11/01/2016	Administrative/File Review	PA Dept of Environmental Protection	Violation(s) Noted		1
2575749	03/24/2017	Complaint Inspection	PA Dept of Environmental Protection	No Violations Noted		0
3209074	06/22/2021	Administrative/File Review	PA Dept of Environmental Protection	Administratively Closed	Review of eDMR Non-Compliance data for routine monitoring	0
2797146	11/01/2018	Administrative/File Review	PA Dept of Environmental Protection	Violation(s) Noted		1
2838889	02/12/2019	Compliance Evaluation	PA Dept of Environmental Protection	Violation(s) Noted		1
2726074	05/03/2018	Administrative/File Review	PA Dept of Environmental Protection	Violation(s) Noted		1

Violation Summary

VIOL ID	VIOLATION DATE	VIOLATION TYPE	VIOLATION TYPE DESC	RESOLVED DATE
771459	11/01/2016	302.202	Operator Certification - Failure to submit annual system fee	11/15/2016
815653	05/03/2018	92A.62	NPDES - Failure to pay annual fee	05/09/2018
832238	11/01/2018	302.202	Operator Certification - Failure to submit annual system fee	01/31/2019
845005	02/12/2019	92A.44	NPDES - Violation of effluent limits in Part A of permit	03/26/2019

Enforcement Summary

ENF ID	ENF TYPE DESC	EXECUTED DATE	ENF FINALSTATUS	ENF CLOSED DATE
348336	Notice of Violation	11/01/2016	Comply/Closed	11/15/2016
363674	Notice of Violation	05/03/2018	Comply/Closed	05/09/2018
368936	Notice of Violation	11/01/2018	Comply/Closed	01/31/2019
373347	Notice of Violation	03/26/2019	Administrative Close Out	12/09/2019

eDMR Violation Summary: 10/7/2016 – 10/7/2021

MONITORING END DATE	OUTFALL	PARAMETER	SAMPLE VALUE	PERMIT VALUE	UNIT OF MEASURE	STATISTICAL BASE CODE
05/31/2017	001	Dissolved Oxygen	0.0	5.0	mg/L	Minimum
05/31/2017	001	Carbonaceous Biochemical Oxygen Demand (CBOD5)	116.4	25.0	mg/L	Average Monthly
05/31/2017	001	Total Residual Chlorine (TRC)	0.60	0.06	mg/L	Average Monthly
05/31/2017	001	Total Suspended Solids	227.0	30.0	mg/L	Average Monthly
05/31/2017	001	Total Residual Chlorine (TRC)	0.90	0.14	mg/L	Instantaneous Maximum
06/30/2017	001	Dissolved Oxygen	0.0	5.0	mg/L	Minimum
06/30/2017	001	Carbonaceous Biochemical Oxygen Demand (CBOD5)	30.75	25.0	mg/L	Average Monthly
06/30/2017	001	Fecal Coliform	347	200	No./100 ml	Geometric Mean
06/30/2017	001	Total Suspended Solids	46.0	30.0	mg/L	Average Monthly
06/30/2017	001	Fecal Coliform	24200	1000	No./100 ml	Instantaneous Maximum
07/31/2017	001	Dissolved Oxygen	3.4	5.0	mg/L	Minimum
07/31/2017	001	Fecal Coliform	219	200	No./100 ml	Geometric Mean
07/31/2017	001	Total Residual Chlorine (TRC)	0.07	0.06	mg/L	Average Monthly
07/31/2017	001	Fecal Coliform	4839	1000	No./100 ml	Instantaneous Maximum
07/31/2017	001	Total Residual Chlorine (TRC)	0.56	0.14	mg/L	Instantaneous Maximum
08/31/2017	001	Total Residual Chlorine (TRC)	0.82	0.06	mg/L	Average Monthly
08/31/2017	001	Total Residual Chlorine (TRC)	6.06	0.14	mg/L	Instantaneous Maximum
09/30/2017	001	Total Residual Chlorine (TRC)	0.87	0.06	mg/L	Average Monthly
09/30/2017	001	Total Residual Chlorine (TRC)	6.05	0.14	mg/L	Instantaneous Maximum
10/31/2017	001	Total Residual Chlorine (TRC)	0.41	0.06	mg/L	Average Monthly
03/31/2018	001	Total Residual Chlorine (TRC)	0.11	0.06	mg/L	Average Monthly

03/31/2018	001	Total Residual Chlorine (TRC)	0.62	0.14	mg/L	Instantaneous Maximum
06/30/2018	001	Dissolved Oxygen	4.9	5.0	mg/L	Minimum
06/30/2018	001	Fecal Coliform	2420	1000	No./100 ml	Instantaneous Maximum
07/31/2018	001	Dissolved Oxygen	4.81	5.0	mg/L	Minimum
07/31/2018	001	Total Residual Chlorine (TRC)	0.30	0.14	mg/L	Instantaneous Maximum
10/31/2018	001	Total Residual Chlorine (TRC)	0.45	0.06	mg/L	Average Monthly
01/31/2019	001	Dissolved Oxygen	4.09	5.0	mg/L	Minimum
03/31/2019	001	Dissolved Oxygen	4.03	5.0	mg/L	Minimum
04/30/2019	001	Total Residual Chlorine (TRC)	0.24	0.06	mg/L	Average Monthly
05/31/2019	001	Fecal Coliform	28412	200	No./100 ml	Geometric Mean
05/31/2019	001	Fecal Coliform	6000	1000	No./100 ml	Instantaneous Maximum
10/31/2019	001	Ammonia-Nitrogen	2.8	2.5	mg/L	Average Monthly
10/31/2019	001	Ammonia-Nitrogen	5.4	5.0	mg/L	Instantaneous Maximum
06/30/2020	001	Ammonia-Nitrogen	14.5	2.5	mg/L	Average Monthly
06/30/2020	001	Ammonia-Nitrogen	15.0	5.0	mg/L	Instantaneous Maximum
07/31/2020	001	Ammonia-Nitrogen	2.58	2.5	mg/L	Average Monthly
04/30/2021	001	Total Residual Chlorine (TRC)	0.22	0.06	mg/L	Average Monthly
04/30/2021	001	Total Suspended Solids	67.5	30.0	mg/L	Average Monthly
08/31/2021	001	Ammonia-Nitrogen	4.45	2.5	mg/L	Average Monthly
08/31/2021	001	Ammonia-Nitrogen	6.07	5.0	mg/L	Instantaneous Maximum

Compliance Status:

Facility has had numerous effluent violations since 2017, and Operations will be inspecting this site in the future to deal with continued noncompliance.

Completed by: David Roote

Completed date: 10/7/2021

Development of Effluent Limitations

Outfall No. 001
 Latitude 40° 50' 48.00"
 Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.0022
 Longitude -79° 12' 3.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

Water Quality-Based Limitations

The discharge was evaluated using WQM 7.0 to evaluate the CBOD₅, Ammonia Nitrogen and Dissolved Oxygen parameters. The modeling results show technology based effluent limitations for CBOD₅ are appropriate. The modeling results also confirm that Ammonia-Nitrogen and Dissolved Oxygen limitations are necessary to meet in-stream water quality criterion.

The discharge was evaluated using the Total Residual Chlorine (TRC) spreadsheet. The modeling results confirm that a total residual chlorine limit is necessary to meet the in-stream water quality criterion. The TRC spreadsheet did recommend a limit of 0.027 mg/L but since the detection limit for TRC is 0.02 mg/L, the limit has been rounded to 0.03 mg/L for this permit.

The summer Ammonia-Nitrogen, dissolved oxygen, and total residual chlorine limits for this permit are stricter than those previously imposed, however, the facility should be able to comply with the new limits.

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Dissolved Oxygen	5.0	Minimum	WQM7.0
Ammonia-Nitrogen (Nov 1 – Apr 30)	6.0	Average Monthly	WQM7.0
Ammonia-Nitrogen (May 1 – Oct 31)	2.2	Average Monthly	WQM7.0
Total Residual Chlorine (TRC)	0.03	Average Monthly	WQM7.0

Comments:

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 **(I) Reissued permits. (1) Except as provided in paragraph (I)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.**

The facility is not seeking to revise the previously permitted effluent limits.

Additional Considerations

Sewage discharges will include monitoring, at a minimum, for E. coli, in new and reissued permits, with a monitoring frequency of 1/year for design flows ≥ 0.002 and < 0.05 MGD.

The receiving stream is not impaired for nutrients, therefore, annual sampling for nitrogen and phosphorus will be imposed per 25 PA Code §92a.6.

For pH, DO, and TRC, a monitoring frequency of 1/day has been imposed. In general, less frequent monitoring may be established only when the permittee demonstrates that there will be no discharge on days where monitoring is not required.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.0022	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.03	XXX	0.087	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	6.0	XXX	12.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.2	XXX	4.4	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments:

ATTACHMENT A:
WQM7.0 MODELING RESULTS (SUMMER)

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34037	Trib 34037 of Slippery Rock Creek	0.200	1153.00	0.09	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.005	0.00	0.00	0.000	0.000	10.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Smithwind MHP	PA0098060	0.0022	0.0000	0.0000	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	9.01	0.00	0.00
NH3-N	2.50	0.00	0.00	0.70

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
20C		34037		Trib 34037 of Slippery Rock Creek								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
0.200	0.00	0.00	0.00	.0034	0.00399	.221	1.11	5.04	0.02	0.747	20.00	7.00
Q1-10 Flow												
0.200	0.00	0.00	0.00	.0034	0.00399	NA	NA	NA	0.02	0.764	20.00	7.00
Q30-10 Flow												
0.200	0.00	0.00	0.00	.0034	0.00399	NA	NA	NA	0.02	0.731	20.00	7.00

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>					
20C		34037		Trib 34037 of Slippery Rock Creek					
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
0.200	Smithwind MHP	16.76	5	16.76	5	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
0.200	Smithwind MHP	1.89	2.2	1.89	2.2	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.20	Smithwind MHP	25	25	2.2	2.2	6	6	0	0

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20C	34037	Trib 34037 of Slippery Rock Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.200	Smithwind MHP	PA0098060	0.002	CBOD5	25		
				NH3-N	2.2	4.4	
				Dissolved Oxygen			6

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
20C	34037	Trib 34037 of Slippery Rock Creek			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
0.200	0.002	20.000		7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
1.112	0.221	5.038		0.016	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
22.49	1.473	1.96		0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
6.328	21.803	Owens		6	
<u>Reach Travel Time (days)</u>	Subreach Results				
0.747	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.075	20.15	1.86	6.67	
	0.149	18.05	1.77	6.93	
	0.224	16.17	1.68	7.15	
	0.299	14.49	1.59	7.34	
	0.373	12.98	1.51	7.52	
	0.448	11.62	1.43	7.68	
	0.523	10.41	1.36	7.82	
	0.597	9.33	1.29	7.95	
	0.672	8.36	1.23	8.06	
	0.747	7.49	1.16	8.17	

ATTACHMENT B:
WQM7.0 MODELING RESULTS (WINTER)

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34037	Trib 34037 of Slippery Rock Creek	0.200	1153.00	0.09	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.009	0.00	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Smithwind MHP	PA0098060	0.0022	0.0000	0.0000	0.000	5.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	12.51	0.00	0.00
NH3-N	6.00	0.00	0.00	0.70

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		34037				Trib 34037 of Slippery Rock Creek						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
0.200	0.00	0.00	0.00	.0034	0.00399	.225	1.14	5.08	0.02	0.705	5.00	7.00
Q1-10 Flow												
0.200	0.00	0.00	0.00	.0034	0.00399	NA	NA	NA	0.02	0.734	5.00	7.00
Q30-10 Flow												
0.200	0.00	0.00	0.00	.0034	0.00399	NA	NA	NA	0.02	0.678	5.00	7.00

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>			
20C		34037				Trib 34037 of Slippery Rock Creek			
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
0.200	Smithwind MHP	24.1	12	24.1	12	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
0.200	Smithwind MHP	4.36	5.81	4.36	5.81	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.20	Smithwind MHP	25	25	5.81	5.81	5	5	0	0

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20C	34037	Trib 34037 of Slippery Rock Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.200	Smithwind MHP	PA0098060	0.002	CBOD5	25		
				NH3-N	5.81	11.62	
				Dissolved Oxygen			5

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
20C	34037	Trib 34037 of Slippery Rock Creek			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>		
0.200	0.002	5.000	7.000		
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>		
1.142	0.225	5.076	0.016		
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>		
20.48	1.462	4.67	0.221		
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>		
6.476	15.334	Owens	6		
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>				
0.705	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)	
	0.070	19.45	4.60	9.46	
	0.141	18.47	4.53	10.53	
	0.211	17.53	4.46	10.94	
	0.282	16.65	4.39	11.12	
	0.352	15.81	4.32	11.23	
	0.423	15.01	4.26	11.30	
	0.493	14.26	4.19	11.37	
	0.564	13.54	4.13	11.43	
	0.634	12.86	4.06	11.45	
	0.705	12.21	4.00	11.45	

ATTACHMENT C:
TOTAL RESIDUAL CHLORINE (TRC)
MODELING RESULTS

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.000417	= Q stream (cfs)	0.5	= CV Daily	
0.0022	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 0.058		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.022		5.1d
		WLA_cfc = 0.049		
		LTAMULT_cfc = 0.581		
		LTA_cfc = 0.029		
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.027		AFC
		INST_MAX_LIMIT (mg/l) = 0.087		
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$			
AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST_MAX_LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$			

ATTACHMENT D:
USGS STREAMSTATS REPORT

StreamStats Report

Region ID: PA
 Workspace ID: PA20211006150014084000
 Clicked Point (Latitude, Longitude): 40.84656, -80.20045
 Time: 2021-10-06 11:00:34 -0400



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.0886	square miles
ELEV	Mean Basin Elevation	1217	feet

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.0886	square miles	2.26	1400

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
ELEV	Mean Basin Elevation	1217	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0018	ft ³ /s
30 Day 2 Year Low Flow	0.00388	ft ³ /s
7 Day 10 Year Low Flow	0.000417	ft ³ /s
30 Day 10 Year Low Flow	0.00107	ft ³ /s
90 Day 10 Year Low Flow	0.00248	ft ³ /s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.6.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.1.2