

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0098299
 APS ID 795256
 Authorization ID 1210134

Applicant and Facility Information

Applicant Name	<u>Bruno Family Trust</u>	Facility Name	<u>Donegal Center Inc.STP</u>
Applicant Address	<u>71 E Pine Avenue</u> <u>Washington, PA 15301-6722</u>	Facility Address	<u>212 Snyder Road</u> <u>Donegal, PA 15628-9704</u>
Applicant Contact	<u>Mr. Robert A. Bruno</u>	Facility Contact	<u>Same as Applicant</u>
Applicant Phone	<u>(724) 228-1592</u>	Facility Phone	<u>Same as Applicant</u>
Client ID	<u>279533</u>	Site ID	<u>252712</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Donegal Township</u>
Connection Status		County	<u>Westmoreland</u>
Date Application Received	<u>December 4, 2017</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 13, 2017</u>	If No, Reason	
Purpose of Application	<u>Application for a renewal of an existing NPDES permit for discharge of treated Sewage.</u>		

Summary of Review

The applicant has applied for a renewal of NPDES Permit No. PA0098299, which was previously issued by the Department on May 22, 2013. That permit expired on May 31, 2018

WQM Permit No. 6569426 issued on November 26, 1969 authorized construction of the plant to treat an average design flow of 0.022 mgd. That plant ran in an extended aeration mode with intermittent sand filtration and chlorination. That plant was in disrepair and was replaced.

Part II Permit No. 6569426 A-1, issued on December 21, 2010, approved the construction of a new extended aeration type activated sludge plant with UV disinfection. The design flow of the STP remained unchanged at 0.022 mgd.

The receiving stream, Swale to an UNT to Fourmile Run, is classified as a TSF and is located in State Watershed No.18-C.

The applicant has complied with Act 14 Notifications and no comments were received.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		/s/ William C. Mitchell, E.I.T. / Project Manager	October 2, 2019
X		/s/ Christopher Kriley, P.E. / Environmental Program Manager	October 3, 2019

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.022</u>
Latitude	<u>40° 06' 29.00"</u>	Longitude	<u>-79° 22' 33.00"</u>
Quad Name	_____	Quad Code	_____
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Swale to an Unnamed Tributary to Fourmile Run (TSF)</u>	Stream Code	<u>Swale to 43542</u>
NHD Com ID	<u>125294356</u>	RMI	<u>16.0 on 43542</u>
Drainage Area	<u>0.01</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>Dry drainage swale shown on USGS map.</u>
Elevation (ft)	_____	Slope (ft/ft)	<u>0.083</u>
Watershed No.	<u>18-C</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	<u>NONE</u>	Exceptions to Criteria	<u>NONE</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	_____		
Source(s) of Impairment	_____		
TMDL Status	<u>Final</u>	Name	<u>Kiskiminetas-Conemaugh River Watersheds TMDL</u>
Background/Ambient Data	Data Source		
pH (SU)	_____	_____	
Temperature (°F)	_____	_____	
Hardness (mg/L)	_____	_____	
Other:	_____	_____	
Nearest Downstream Public Water Supply Intake	<u>Latrobe Municipal Authority</u>		
PWS Waters	<u>Loyalhanna Creek</u>	Flow at Intake (cfs)	_____
PWS RMI	_____	Distance from Outfall (mi)	_____

Changes Since Last Permit Issuance: STP resumed operation in early 2019.

Other Comments: Donegal Lake is located approximately 2 miles downstream from the STP. Aquatic Biologist Richard Spear stated on November 15, 2012 that a trophic study has not been done on this dam to date, but that it may be put on a list for a future survey. I requested an update on the status of Donegal Lake in September 2019. Any information provided by Mr. Spear will be included in the Fact Sheet Addendum. There have been no reported nutrient problems in the lake. Sewage discharges with design flows > 2,000 gpd require monitoring, at a minimum, for Total Nitrogen and Total Phosphorus in reissued permits. A monitoring frequency of once per year is considered acceptable for this facility.

This facility indirectly discharges into the Kiskiminetas-Conemaugh River Watersheds, which has a Final TMDL for metals. The contribution of metals from a sewage plant of this nature is expected to be less than water quality criteria and therefore not contributing to stream impairment. Furthermore, an aggregate waste load allocation was included in the TMDL for these types of facilities. A 1/year monitoring requirement for Iron, Manganese, and Aluminum is established in the permit to verify that the sewage discharge is not contributing to the impairment of the receiving stream. The monitoring frequency is yearly for plants rated less than 0.499 MGD.

Treatment Facility Summary				
Treatment Facility Name: Donegal Center Inc.				
WQM Permit No.		Issuance Date		
6569426		11/26/1969		
6569426 A-1		12/21/2010		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with Ammonia Reduction	Activated Sludge	UV Disinfection	
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.022	42.0	Not Overloaded		

Changes Since Last Permit Issuance: STP resumed operation in early 2019.

Compliance History

Other Comments: An Operations Compliance Check for this facility was requested on September 12, 2019. Mr. John Murphy responded and stated that this facility was put into operation in early 2019. He also stated that Ms. Lisa Milsop issued an NOV for this facility in June of 2019. An Operations Compliance Check Report will be included in the Fact Sheet Addendum.

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) .022
 Latitude 40° 06' 29.00" Longitude -79° 22' 33.00"
 Wastewater Description: Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

The discharge was previously modeled using WQM6.3 to evaluate CBOD₅, Ammonia Nitrogen and Dissolved Oxygen parameters and there have been no changes to the discharge or the receiving stream. Therefore, it is not necessary to remodel those three parameters using the current WQM 7.0 model because the same effluent results are computed for a single discharge scenario. The modeling results show technology based effluent limitations for CBOD₅ are appropriate and that Ammonia-Nitrogen and Dissolved Oxygen limitations are necessary to meet in-stream water quality criterion.

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia-Nitrogen May 1 - Oct 31	2.5	Average Monthly	WQM6.3
Ammonia-Nitrogen Nov 1 - Apr 30	7.5	Average Monthly	WQM6.3
Dissolved Oxygen	5.0	Minimum	WQM6.3

Best Professional Judgment (BPJ) Limitations

Comments: **N/A**

Anti-Backsliding

N/A

Additional Considerations:

For pH, Dissolved Oxygen (DO) and UV Light Transmittance, a monitoring frequency 1/day has been imposed. In general, less frequent monitoring may be established only when the permittee demonstrates that there will be no discharge on days where monitoring is not required.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.022	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	7.5	XXX	15.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.5	XXX	5.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Aluminum	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Iron	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Manganese	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall # 001

Summer Swale

HEADWATER DATA

Q ₇₋₁₀	=	0.0
TEMP.	=	25
pH	=	7
D.O.	=	85% Saturation
CBOD ₅	=	2
NH ₃ -N	=	.1
K _c	=	0

Q _d	=	.022
TEMP.	=	20
pH	=	7
D.O.	=	2
CBOD ₅	=	25
NH ₃ -N	=	25
K _c	=	1.5

Used as starting limits since no nuisance conditions reported in Swale

Q _t	=	0.0
TEMP.	=	
pH	=	
CBOD ₅	=	
NH ₃ -N	=	

D.O.	=	3
K _r	=	.6
Slope	=	.083
Length	=	1200'
D.A.	=	.01
W/D ratio	=	10

Pt of discharge to confluence with Fourmile Run

*Summer
 Four mile*

HEADWATER DATA

Q ₇₋₁₀	=	.011
TEMP.	=	7
pH	=	2.5
D.O.	=	85% Attenuation
CBOD ₅	=	2
NH ₃ -N	=	.1
K _c	=	0

Q _d	=	.022
TEMP.	=	20
pH	=	7
D.O.	=	3.1
CBOD ₅	=	22.3
NH ₃ -N	=	23.9
K _c	=	1.3

Q _t	=	
TEMP.	=	
pH	=	
CBOD ₅	=	
NH ₃ -N	=	

*9
 End of reach
 From Swale*

D.O.	=	5
K _c	=	
Slope	=	60/1300 = .04%
Length	=	1300
D.A.	=	.18
W/D ratio	=	10

*End of first
 reach to
 confluence with
 downstream tub*

HEADWATERS AND TRIBUTARY DATA

NO. OF REACHES : 1

RH	Q7-10 (CFS)	T (C)	PH	DO (MG/L)	CBOD5 (MG/L)	NH3-N (MG/L)
HW	1E-03	25	7	7.54	2	.1
1	0					

LAUREL HIGHLAND ML DISCHARGE ON DRY SWALE
 FILE: LAUREL DRY.WQM6.3

DISCHARGER DATA
 Q7-10 DESIGN CONDITIONS

RH Q	T	PH	DO	CBOD5	NH3-N	KC
MGD	(C)		MG/L	MG/L	MG/L	
1	.022	20.7	5	25	10.7	1.5

REACH CHARACTERISTICS

RH	D.O. GOAL (/D)	KN (/D)	RCH. SL. (FT/FT)	RCH. LEN. (FT.)	DRAIN AREA (MI^2)	W/D
1	3	.6	.083	1200	1E-0310	

↑
 Dry
 Swale
 no.

↑
 minimal

LAUREL HIGHLAND ML DISCHARGE ON DRY SWALE
 FILE: LAUREL DRY.WQM6.3

DISCHARGER DATA
 07-10 DESIGN CONDITIONS

RH #	MGD	T (C)	PH	DO (MG/L)	CBOD5 (MG/L)	NH3-N (MG/L)	KC
1	.022	20	7	3	25	25	1.5

MULTIPLE DISCHARGE LIMITATIONS

(TOTAL) DISCHARGE = .022 MGD
 TEMP = 20.1 PH = 7
 CBOD-5 = 24.34 NH3-N = 24.29 D.O. = 3.13
 KC = 1.496 KN = .6 D.O. GOAL = 3
 KR = 20 (USR DEF.)
 DIS. 1 RCH. 1 TRVL TIME: .075

*Set, original
 Calculated
 276* →

TR. TM. (DAYS)	CBOD-5 (MG/L)	NH3-N (MG/L)	D.O. (MG/L)
7E-03	24.07	24.18	3.12
.015	23.8	24.07	3.11
.022	23.53	23.96	3.12
.03	23.27	23.85	3.12
.037	23.01	23.74	3.14
.045	22.75	23.64	3.16
.052	22.5	23.53	3.18
.06	22.24	23.42	3.2
.067	22	23.32	3.23
.075	21.75	23.21	3.26

LAUREL HIGHLAND ML DISCHARGE ON DRY SWALE
 FILE: LAUREL DRY.WQM6.3

D.O. ALLOCATIONS

DIS #	Q (MGD)	---NH3-N---		---CBOD5---		CRIT. RCH.	PCT. REM. (PCT)
		IND. CONC. (MG/L)	CUM. CONC. (MG/L)	IND. CONC. (MG/L)	CUM. CONC. (MG/L)		
1	.0220	25.00	25.00	25.00	25.0000		

LAUREL HIGHLAND DISCHARGE TO FOURMILE RUN
 FILE:

No reduction

HEADWATERS AND TRIBUTARY DATA

NO. OF REACHES : 1

RH	Q7-10 (CFS)	T (C)	PH	DO (MG/L)	CBOD5 (MG/L)	NH3-N (MG/L)
HW 1	.011	25	7	7.79	2	.1

Fourmile Run

DISCHARGER DATA
 Q7-10 DESIGN CONDITIONS

RH Q	T (C)	PH	DO (MG/L)	CBOD5 (MG/L)	NH3-N (MG/L)	KC
1 .022	20	7	3.1	22.3	23.9	1.3

End of reach characteristics of discharge

LAUREL HIGHLAND DISCHARGE TO FOURMILE RUN
 FILE:

REACH CHARACTERISTICS						
RH	D.O. GOAL (/D)	KN (/D)	RCH. SL. (FT/FT)	RCH. LEN. (FT.)	DRAIN AREA (MI^2)	W/D
1	5	.6	.043	1300	.18	10

NH3-N DISCHARGE ALLOCATIONS AT 030-10

DIS	Q (MGD)	IND. CONC. (MG/L)	ALL. CONC. (MG/L)	CRIT. RCH. (%)	PCT. RED. (%)
1	.022	2.43	2.43	0	0

LAUREL HIGHLAND DISCHARGE TO FOURMILE RUN
 FILE: LAUREL FOUR.WQM6.3

NH3-N DISCHARGE ALLOCATIONS AT Q1-10

DIS	Q (MGD)	IND. CONC. (MG/L)	ALL. CONC. (MG/L)	CRIT. RCH.	PCT. RED. (%)
1	.022	10.95	10.95	0	0

MULTIPLE DISCHARGE LIMITATIONS

(TOTAL) DISCHARGE = .022 MGD
 TEMP = 21.2 PH = 7
 CBOD-5= 17.34 NH3-N= 1.86 D.O. = 5
 KC = 1.257 KN = .6 D.O. GOAL = 5
 KR = 20 (USR DEF.)
 DIS. 1 RCH. 1 TRVL TIME: .233

*See Calc.
around
40*

TR. TM. (DAYS)	CBOD-5 (MG/L)	NH3-N (MG/L)	D.O. (MG/L)
.023	16.81	1.83	5.74
.047	16.3	1.8	6.22
.07	15.8	1.78	6.54
.093	15.32	1.75	6.77
.117	14.85	1.72	6.92
.14	14.4	1.7	7.04
.163	13.96	1.67	7.13
.187	13.53	1.64	7.21
.21	13.12	1.62	7.27
.233	12.72	1.59	7.33

Note - For S/D Classified Streams, a DO Criteria of 5.0 mg/l is in effect when the Q7-10 low flow is generally lower (8/11-2/14) & 6.0 mg/l is in effect when the Q7-10 low flow is higher (2/15-7/31). The modeling was assumed to be adequate to maintain the DO criteria year-round.

LAUREL HIGHLAND DISCHARGE TO FOURMILE RUN
 FILE: LAUREL FOUR.WQM6.3

D.O. ALLOCATIONS

DIS #	Q (MGD)	---NH3-N---		---CBOD5---		CRIT. RCH.	PCT. REM. (PCT)
		IND. CONC. (MG/L)	CUM. CONC. (MG/L)	IND. CONC. (MG/L)	CUM. CONC. (MG/L)		
1	.0220	2.400	2.400	22.30	22.3000		

EFFLUENT LIMITATIONS DISPLAY

DIS #	Q MGD	NH3-N TOX.		DISS. OXYGEN		
		1 DAY	30 DAY	C-BOD5 30-DAY	NH3-N 30-DAY	EFF. D.O.
1	.022	4.9	2.4	22.3	2.4	4.1

Equation from 1/27/88 memo dealing with toxics

Toxics No reduction

*EL₂ = 2.4
 EDC = 23.9
 DC₁ = 25
 γ =*

$$\frac{(2.4)(25)}{23.9} = 2.51$$

*Impose - 2.5 mg/l NH3-N
 25 mg/l CBOD
 D.O - 5*

HEADWATER DATA

page

*Trusted
 Amals*

Q ₇₋₁₀	=	0.0
TEMP.	=	5
pH	=	7
D.O.	=	85% Saturation
CBOD ₅	=	2
NH ₃ -N	=	.1
K _c	=	0

Q _d	=	.022
TEMP.	=	20-15
pH	=	7
D.O.	=	2
CBOD ₅	=	25
NH ₃ -N	=	25
K _c	=	1.5

Q _t	=	0.0
TEMP.	=	
pH	=	
CBOD ₅	=	
NH ₃ -N	=	

D.O.	=	3
K _s	=	.6
Slope	=	.083
Length	=	1200'
D.A.	=	.01
W/D ratio	=	10

*Pt of discharge
 to confluence
 with Fourmile Run*

HEADWATER DATA

page

*Winter
 Fourmile*

Q _{1.10}	=	.011 .022
TEMP.	=	7
pH	=	7.5 5
D.O.	=	85% Atmulation
CBOD ₅	=	2
NH ₃ -N	=	.1
K ₁	=	0

Q _d	=	.022
TEMP.	=	20.15
pH	=	7
D.O.	=	3.1 5.2
CBOD ₅	=	22.3 22.9
NH ₃ -N	=	2.3 4.24.8
K _c	=	1.3

Q ₂	=	
TEMP.	=	
pH	=	
CBOD ₅	=	
NH ₃ -N	=	

DO	=	5
K ₂	=	.6
Slope	=	60/1300 = .046
Length	=	1300
D.A.	=	.18
W/D ratio	=	10

*End of first
 reach to
 confluence with
 downstream hits*

LAUREL HIGHLAND ML DISCHARGE ON DRY SWALE
 FILE: LAUREL DRY.WQM4.3

Inter

HEADWATERS AND TRIBUTARY DATA

NO. OF REACHES : 1

RH	Q7-10 (CFS)	T (C)	PH	DO (MG/L)	CBOD5 (MG/L)	NH3-N (MG/L)
HW	1E-03	5	7	10.79	2	.1
1	0					

DISCHARGER DATA
 Q7-10 DESIGN CONDITIONS

RH	Q MGD	T (C)	PH	DO MG/L	CBOD5 MG/L	NH3-N MG/L	KC
1	.022	15	7	3	25	25	1.5

LAUREL HIGHLAND ML DISCHARGE ON DRY SWALE
 FILE: LAUREL DRY WINTER.WQM6.3

MULTIPLE DISCHARGE LIMITATIONS
 (TOTAL) DISCHARGE = .022 MGD
 TEMP = 14.7 PH = 7
 CBOD-5= 24.34 NH3-N= 24.29 D.O. = 3.22
 KC = 1.496 KN= .6 D.O.GOAL = 3
 KR= 20 (USR DEF.)
 DIS. 1 RCH. 1 TRVL TIME:.075

TR. TM. (DAYS)	CBOD-5 (MG/L)	NH3-N (MG/L)	D.O. (MG/L)
7E-03	24.13	24.22	3.58
.015	23.92	24.14	3.9
.022	23.71	24.07	4.17
.03	23.5	24	4.41
.037	23.3	23.93	4.62
.045	23.09	23.86	4.8
.052	22.89	23.79	4.96
.06	22.69	23.72	5.11
.067	22.49	23.64	5.23
.075	22.3	23.57	5.34

DISCHARGE CHARACTERISTICS

END OF REACH 1

(TOTAL) FLOW-MGD.....:0.022
 TEMPERATURE.....:15
 PH.....:7
 DISSOLVED OXYGEN (MG/L).....:5.2
 C-BOD5 (MG/L).....:22.9
 NH3-N (MG/L).....:24.3
 KC (1/DAY).....:1.5

LAUREL HIGHLAND DISCHARGE TO FOURMILE RUN
 FILE: LAUREL FOUR.WQM6.3

REACH # 1
 HEADWATERS AND TRIBUTARY DATA

NO. OF REACHES : 1

RH	Q7-10 (CFS)	T (C)	PH	DO (MG/L)	CBOD5 (MG/L)	NH3-N (MG/L)
HW	.022	5	7	10.79	2	.1
1	0					

DISCHARGER DATA
 Q7-10 DESIGN CONDITIONS

RH	Q MGD	T (C)	PH	DO MG/L	CBOD5 MG/L	NH3-N MG/L	KC
1	.022	15	7	5.2	22.9	24.3	1.3

LAUREL HIGHLAND DISCHARGE TO FOURMILE RUN
 FILE: LAUREL FOUR WINTER.WQM6.3

NH3-N DISCHARGE ALLOCATIONS AT Q30-10

DIS	Q (MGD)	IND. CONC. (MG/L)	ALL. CONC. (MG/L)	CRIT. RCH.	PCT. RED. (%)
1	.022	7.39	7.39	0	0

NH3-N DISCHARGE ALLOCATIONS AT Q1-10

DIS	Q (MGD)	IND. CONC. (MG/L)	ALL. CONC. (MG/L)	CRIT. RCH.	PCT. RED. (%)
1	.022	24.73	24.73	0	0

LAUREL HIGHLAND DISCHARGE TO FOURMILE RUN
 FILE: LAUREL FOUR WINTER.WQM6.3

MULTIPLE DISCHARGE LIMITATIONS
 (TOTAL) DISCHARGE = .022 MGD
 TEMP = 11.1 PH = 7
 CBOD-5= 14.69 NH3-N= 4.53 D.O. = 7.39
 KC = 1.224 KN = .6 D.O. GOAL = 5
 KR = 20 (USR DEF.)
 DIS. 1 RCH. 1 TRVL TIME: .206

TR. TM. (DAYS)	CBOD-5 (MG/L)	NH3-N (MG/L)	D.O. (MG/L)
.021	14.45	4.5	8.21
.041	14.21	4.47	8.75
.062	13.97	4.44	9.11
.083	13.74	4.41	9.36
.103	13.51	4.39	9.53
.124	13.29	4.36	9.65
.144	13.07	4.33	9.73
.165	12.85	4.31	9.79
.186	12.64	4.28	9.83
.206	12.43	4.25	9.87

D.O. ALLOCATIONS

DIS #	Q (MGD)	---NH3-N---		---CBOD5---		CRIT. RCH.	PCT. REM. (PCT)
		IND. CONC. (MG/L)	CUM. CONC. (MG/L)	IND. CONC. (MG/L)	CUM. CONC. (MG/L)		
1	.0220	7.400	7.400	22.90	22.9000		

↑
 EL₂ - 7.4
 EDC - 24.3
 DC₁ - 25

↑
 No reduction

$$\frac{(7.4)(25)}{24.3} = 7.6$$

Impose
 25 mg/L CBOD
 7.5 mg/L NH₃-N
 5 mg/L D.O.



Low-Flow Statistics for Pennsylvania Streams



Developed by the U.S. Geological Survey for the Pennsylvania Department of Environmental Protection

Pennsylvania Low-Flow Statistics - Query Results

LOW-FLOW STATISTICS

[All flow statistics in cubic feet per second (ft³/s)]

Mouse over or click on table headings to view definition of statistic

STREAM NAME: Loyalhanna Creek GAGE OR BRIDGE SITE: gage REFERENCE GAGE: ¹ 03045000	COUNTY: Westmoreland USGS QUAD: Derry STATION NAME: Loyalhanna Creek at Kingston, PA <i>near Latrobe Mun. Auth. Water Intake</i>	LATITUDE: 401733 LONGITUDE: 792027 DRAINAGE AREA (sq. mi.): 172
--	---	---

Entire Period of Record ²	Q _{1,10}	Q _{7,10}	Q _{30,10}	MEAN	MEDIAN	HARMONIC MEAN
1941-95	1.96	2.90	5.94	299	163	40.7

FLOW DURATION TABLE (Probability of Exceedance)										
P5	P10	P20	P30	P40	P50	P60	P70	P80	P90	P95
1060	712	442	310	224	163	113	72.3	43.0	21.1	12.2

- ¹ Reference Gage indicates which USGS gage was used in the computation of lowflow statistics for the specified locations
- ² Period of Record for climatic year, April 1 through March 31
- ³ Period of record refers to pre-regulation conditions
- ⁴ Period of record refers to post-regulation conditions
- ** Statistic not computed due to insufficient data

RETURN TO PREVIOUS PAGE

RETURN TO START PAGE

This system designed and developed by the U.S. Geological Survey, Water Resources Division, New Cumberland, Pa. © 2002.

Unnamed Dam, Fourmile, approx 2 miles downstream
Bulletin 5, Pg 93
Permit 65-126

Dam Storage Volume - 290 mg

average flow

D.A - 5.8 mi²

Yield = 1.5 CFS/mi² (Rules & Regs 95.6C)

$$= (1.5)(5.8) = 8.7 \text{ CFS}$$

$$5.65 \text{ mgd}$$

Detention Time = Storage / Stream flow

$$= 290 / 5.65 = 51.3 \text{ day}$$

51 days is greater than 14 days

Biologist should put on list
to be studied.

Year 2007 - See attached email from Abbey Falcone of our Watershed Mgmt.
Bureau concerning putting this dam on list for future trophic survey
to see if phosphorus limits may be required