

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0098345
 APS ID 1013029
 Authorization ID 1308463

Applicant and Facility Information

Applicant Name	<u>CNP Mountain Plaza, LLC</u>	Facility Name	<u>CNP Mountain Plaza</u>
Applicant Address	<u>3508 Regent Court</u> <u>Murrysville, PA 15668-8520</u>	Facility Address	<u>1542 Indian Creek Valley Road</u> <u>Melcroft, PA 15462-1004</u>
Applicant Contact	<u>Jerry Lewis</u>	Facility Contact	<u>Jerry Lewis</u>
Applicant Phone	<u>(724) 708-4122</u>	Facility Phone	<u>(724) 708-4122</u>
Client ID	<u>354950</u>	Site ID	<u>239866</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Saltlick Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Fayette</u>
Date Application Received	<u>March 11, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal and Transfer of Minor Sewage Facility <0.05 MGD NPDES Permit.</u>		

Summary of Review

The Department received an NPDES Permit Renewal Application (received March 11, 2020) and Transfer Application (received February 05, 2020) from CNP Mountain Plaza, LLC for the CNP Mountain Plaza property located in Saltlick Township, Fayette County.

The existing permittee of the property is the Connellsville Area School District – Clifford Pritts Elementary School with NPDES Permit PA0098345 and Water Quality Management (WQM) Part II Permit 466S35. The Clifford Pritts Elementary School has been closed and has not processed wastewater since August 2017.

The existing treatment system is a Minor Sewage Facility <0.05 MGD consisting of: Flow Equalization, Extended Aeration, WAS, Final Clarification, Tablet Chlorination followed by Tablet De-chlorination.

The receiving stream is Indian Creek, which is classified by Chapter 93 as High-Quality Cold-Water Fishes (HQ-CWF) located in watershed 19-E.

To establish the renewal effluent limitations, the Water Quality Based Effluent Limitations (WQBEL) are compared to the minimum technology based and BPJ standards for individual sewage permits. The most stringent of those limitations are imposed on the renewal permit as per the SOP-Establishing Effluent Limitations for Individual Sewage Permits.

WQM 7.0 and TRC spreadsheet modeling results are enclosed.

The applicant submitted eDMR transfer forms.

Approve	Deny	Signatures	Date
X		<i>Curtis Holes</i> Curtis Holes, P.E. / Environmental Engineering Specialist	January 22, 2021
X		<i>Donald Leone</i> Donald J. Leone, P.E. / Environmental Engineer Manager	January 28, 2021

Summary of Review

The Act – 14 PL 834 Municipal Notification were provided by the February 27, 2020 letters and no comments were received.

An Operations Compliance Check Summary Report was completed, and permit transfer is suggested.

It is recommended that a draft permit be published for public comment in response to this application.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.007735</u>
Latitude	<u>40° 03' 31"</u>	Longitude	<u>79° 22' 14"</u>
Quad Name	<u>Seven Springs</u>	Quad Code	<u>1811</u>
Wastewater Description: <u>Treated Sewage</u>			
Receiving Waters	<u>Indian Creek</u>	Stream Code	<u>38235</u>
NHD Com ID	<u>69915995</u>	RMI	<u>18.9</u>
Drainage Area	<u>32.9 mi²</u>	Yield (cfs/mi ²)	<u>0.0255</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.838 cfs</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>1435</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>19-E</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	<u>Recreational</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Supporting</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Nearest Downstream Public Water Supply Intake	<u>Indian Creek Valley Water Authority (400,000 GPD)</u>		
PWS Waters	<u>Mill Run Reservoir</u>	Flow at Intake (cfs)	<u>3.59</u>
PWS RMI	<u>4.3</u>	Distance from Outfall (mi)	<u>14.4</u>

Changes Since Last Permit Issuance:

Other Comments: None

Treatment Facility Summary				
Treatment Facility Name: CNP Mountain Plaza STP				
WQM Permit No.		Issuance Date		
466S24-A1		10/31/1990		
466S24		04/29/1966		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with Ammonia Reduction	Extended Aeration	Chlorine with Dechlorination	
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0077		Not Overloaded	Dewatering	Other WWTP

Changes Since Last Permit Issuance:

Other Comments:

Compliance History

Facility: CNP Mountain Plaza/Connellsville Elementary School

NPDES Permit No.: PA0098345

Compliance Review Period: 11/2015 – 11/2020

Inspection Summary:

INSP ID	INSPECTED DATE	INSP TYPE	INSPECTION RESULT DESC
2944101	10/02/2019	Routine/Partial Inspection	No Violations Noted

Violation Summary:

VIOL ID	VIOLATION DATE	VIOLATION TYPE	VIOLATION TYPE DESC	RESOLVED DATE	INSP TYPE
788432	06/15/2017	92A.41(A)5	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance	06/20/2017	Routine/Partial Inspection
777478	01/11/2017	92A.41(A)5	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance	01/30/2017	Routine/Partial Inspection
777479	01/11/2017	92A.61(G)	NPDES - Failure to use a format or process required by DEP for self-monitoring results	01/30/2017	Routine/Partial Inspection
755183	03/09/2016	92A.61(C)	NPDES - Failure to monitor pollutants as required by the NPDES permit	03/25/2016	Compliance Evaluation

Open Violations by Client ID:

No open violations for Client ID 63783

Enforcement Summary:

ENF ID	ENF TYPE	ENF CREATION DATE	VIOLATIONS	# OF VIOLATIONS	ENF FINALSTATUS	ENF CLOSED DATE
354415	NOV	06/20/2017	92A.41(A)5	1	Administrative Close Out	08/30/2019
350602	NOV	01/30/2017	92A.41(A)5; 92A.61(G)	2	Administrative Close Out	08/30/2019
341078	NOV	03/25/2016	92A.61(C)	1	Administrative Close Out	08/27/2019

DMR Violation Summary: No DMR exceedances.

Compliance Status: Permit transfer/issuance is suggested.

Completed by: John Murphy

Completed date: 11/16/2019

Development of Effluent Limitations

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.007735</u>
Latitude	<u>40° 03' 31"</u>	Longitude	<u>-79° 22' 14"</u>
Wastewater Description: <u>Treated Sewage Effluent</u>			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	50	IMAX	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	60	IMAX	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
TRC	0.5	Average Monthly	TRC_CALC

Comments:

WQM 7.0 Modeling confirmed Technology-Based Limitations and Best Professional Judgment Limitations for CBOD₅, Ammonia and DO.

In-stream and discharge chlorine demand of 0.3 mg/L and 0.0 mg/L respectively are to be used as default values in the TRC spreadsheet model to calculate water quality-based TRC limits unless site-specific data supporting different values have been collected in accordance with the Implementation Guidance Total Residual Chlorine Regulation. A TRC limit of 0.5 mg/L as an average monthly limit, which confirms the technology-based limitation.

Please refer to Attachment C for the DMR Summary of TRC Concentration. The summary of TRC concentrations are from March 2015 to May 2017. The average of the reported concentrations are within the more stringent TRC effluent limitations. The facility will have to evaluate the system and add de-chlorination if needed prior to re-activating the treatment system.

Best Professional Judgment (BPJ) Limitations

Comments:

A minimum DO limit of 4.0 mg/L per Pa Code Chapter 93 and BPJ. The WQM 7.0 Modeling confirmed the BPJ limitation of DO.

For existing sewage discharges, if WQM 7.0 Modeling results for summer indicates that an average monthly limit of 25 mg/L is acceptable, the minimum requirement for Ammonia-Nitrogen is year-round Monitor and Report requirement.

Sewage discharges with design flows > 2,000 GPD are required to monitor for Total Nitrogen and Total Phosphorus in new and reissued permits. Monitor and Report requirements for Total Nitrogen and Total Phosphorus with a once per year sampling frequency is imposed.

Additional Comments:

Monitoring frequencies for the proposed effluent limits are based upon Table 6-3 Self-Monitoring Requirements for Sewage Dischargers of the DEP's Technical Guidance for the Development and Specification of Effluent Limitations.

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.007735 Annl Avg	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	5/week	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	5/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	5/week	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) (5/1 – 9/30)	XXX	XXX	XXX	200 Geo Mean	XXX	1,000 Geo Mean	2/month	Grab
Fecal Coliform (No./100 ml) (10/1 – 4/30)	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000 Geo Mean	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	XXX	Report Daily Max	1/year	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	XXX	Report Daily Max	1/year	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab

Compliance Sampling Location: Outfall 001

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment A)
<input type="checkbox"/>	TMS Model (see Attachment)
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment B)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment)
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment)
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP:
<input type="checkbox"/>	Other:

Attachment A – WQM 7.0 Model Output File

Attachment B – TRC_CALC

Attachment A – WQM 7.0 Model Output File

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19E	38235	INDIAN CREEK	18.900	1435.00	32.90	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.025	0.00	0.84	0.000	0.000	0.0	35.00	4.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
CNP Plaza	PA0098345	0.0000	0.0077	0.0000	0.000	25.00	7.00

Parameter Data					
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)	
CBOD5	25.00	2.00	0.00	1.50	
Dissolved Oxygen	4.00	8.24	0.00	0.00	
NH3-N	25.00	0.00	0.00	0.70	

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
19E		38235		INDIAN CREEK								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
18.900	0.84	0.00	0.84	.012	0.00240	4	35	8.75	0.01	146.960	20.07	7.00
Q1-10 Flow												
18.900	0.54	0.00	0.54	.012	0.00240	NA	NA	NA	0.00	227.821	20.11	7.00
Q30-10 Flow												
18.900	1.14	0.00	1.14	.012	0.00240	NA	NA	NA	0.01	108.463	20.05	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19E	38235	INDIAN CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
18.900	CNP Plaza	9.6	50	9.6	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
18.900	CNP Plaza	1.91	25	1.91	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
18.90	CNP Plaza	25	25	25	25	4	4	0	0

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19E	38235	INDIAN CREEK		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
18.900	0.008	20.070		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
35.000	4.000	8.750		0.006
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.32	0.001	0.35		0.704
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
8.183	0.126	O'Connor		5
<u>Reach Travel Time (days)</u>	Subreach Results			
146.960	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	14.696	2.29	0.00	8.23
	29.392	2.26	0.00	8.23
	44.088	2.22	0.00	8.23
	58.784	2.19	0.00	8.23
	73.480	2.16	0.00	8.23
	88.176	2.12	0.00	8.23
	102.872	2.09	0.00	8.23
	117.568	2.06	0.00	8.23
	132.264	2.03	0.00	8.23
	146.960	2.00	0.00	8.23

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
19E		38235		INDIAN CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
18.900	CNP Plaza	PA0098345	0.000	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

Attachment B – TRC_CALC

TRC EVALUATION

0.838	= Q stream (cfs)		0.5	= CV Daily
0.007735	= Q discharge (MGD)		0.5	= CV Hourly
30	= no. samples		0.995	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)
	= % Factor of Safety (FOS)			=Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference CFC Calculations
TRC	1.3.2.iii	WLA_afc =	22.247	1.3.2.iii WLA_cfc = 21.791
PENTOXSD		LTAMULT_afc =	0.373	5.1c LTAMULT_cfc = 0.581
TRG	5.1a	LTA_afc =	8.290	5.1d LTA_cfc = 12.668
PENTOXSD				
TRG	5.1b			
Source	Effluent Limit Calculations			
PENTOXSD		AML MULT =	1.231	
TRG	5.1f	AVG MON LIMIT (mg/l)	=	BAT/BPJ
PENTOXSD		INST MAX LIMIT (mg/l)	=	
TRG	5.1g		1.635	
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)			

Attachment C – DMR Summary of TRC Concentration

**Cliffard Pritts Elementary School
 PA0098345**

DMR Summary of TRC Concentration

Date	Average Monthly	IMAX
May-17	0.2	1.3
April-17	0.4	2.2
March-17	0.1	1.8
January-17	0.1	1.4
January-17	0.6	2.0
December-16	0.2	1.2
November-16	0.6	2.7
October-16	0.5	1.3
September-16	0.5	1.0
August-16	0.5	0.8
July-16	0.5	0.7
June-16	0.5	0.6
May-16	0.5	0.9
April-16	0.7	0.9
March-16	0.6	1.1
February-16	0.5	0.9
January-16	0.5	0.8
December-15	0.5	0.7
November-15	0.4	0.8
October-15	0.6	1.2
September-15	0.6	0.9
June-15	0.6	0.9
May-15	0.6	0.9
April-15	0.6	1.0
March-15	0.8	1.1
Average	0.5	1.2
Proposed New TRC Limit	0.5	1.6