

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

**PA0098817**

APS ID

**1121477**

Authorization ID

**1499215**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<u>RMZ Holdings, Inc.</u>	Facility Name	<u>Hickory Acres STP</u>
Applicant Address	<u>600 Pittsburgh Road</u>	Facility Address	<u>669 Nelson Road R</u>
	<u>Uniontown, PA 15401-2214</u>		<u>Farmington, PA 15437-1225</u>
Applicant Contact	<u>John Klink</u>	Facility Contact	<u>Edgar Harris</u>
Applicant Phone	<u>(724) 984-2110</u>	Facility Phone	<u>724-966-2278</u>
Client ID	<u>235845</u>	Site ID	<u>236773</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Wharton Township</u>
Connection Status		County	<u>Fayette</u>
Date Application Received	<u>August 29, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>NPDES permit renewal.</u>		

**Summary of Review**

The Pa Department of Environmental Protection (PADEP/Department) received an NPDES permit renewal application from H&H Water Controls, Inc. (consultant) on behalf of RMZ Holdings, Inc. (permittee) on August 29, 2024 for Permittee's Hickory Acres STP (facility). This is a minor sewage facility with a design flow of 0.0049 MGD that discharges into an UNT to Meadow Run (HQ-CWF) in state watershed 19-E. The current permit will expire on November 30, 2024. The terms and conditions of the current permit is automatically extended since the renewal application was received at least 180 days prior to expiration date. Renewal NPDES permit application under Clean Water Program are not covered by PADEP's PDG per 021-2100-001. This fact sheet is developed in accordance with 40 CFR §124.56.

Changes to existing permit: Added: E-Coli.

Sludge use and disposal description and location(s): Offsite disposal to other WWTP.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		Reza H. Chowdhury, E.I.T. / Project Manager 	September 25, 2024
X		Pravin C. Patel Pravin C. Patel, P.E. / Environmental Engineer Manager	09/25/2024

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.0049
Latitude	39° 49' 3.24"	Longitude	-79° 34' 40.26"
Quad Name	Fort Necessity	Quad Code	2009
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to Meadow Run (HQ-CWF)	Stream Code	38523
NHD Com ID	69922689	RMI	0.65
Drainage Area	1.84 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.0022
Q <sub>7-10</sub> Flow (cfs)	0.004	Q <sub>7-10</sub> Basis	Previous fact sheet
Elevation (ft)		Slope (ft/ft)	
Watershed No.	19-E	Chapter 93 Class.	HQ-CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	North Fayette County Municipal Authority		
PWS Waters	Youghiogheny River	Flow at Intake (cfs)	
PWS RMI	46.67	Distance from Outfall (mi)	24.41

Changes Since Last Permit Issuance: None

Other Comments: The receiving stream, UNT to Meadow Run, is a High-Quality stream. The discharge existed before the stream designation, therefore, it is grandfathered and exempted from ABACT limits, unless the facility expands.

**Treatment Facility Summary**

**Treatment Facility Name:** Hickory Acres Apartments STP

WQM Permit No.	Issuance Date


Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia And Phosphorus	Septic Tank Sand Filter	Tablet chlorine	0.0049

Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.005	5	Not Overloaded	Holding Tank	Other WWTP

Changes Since Last Permit Issuance: None

**Facility Information**

Hickory Acres STP is a minor non-municipal sewage treatment plant, serving 15 apartments. The NPDES permit was issued as new in 1988 even though the Part II WQM permit was issued in 1968 under permit number 468S071. The receiving stream is UNT to Meadow Run which has a Ch. 93 classification of High-Quality Cold-Water Fisheries (HQ-CWF). The stream was designated as CWF during the WQM permit issuance and re-designated on October 6, 1979. This facility was grandfathered from ABACT requirements since the permit was issued prior to stream designation. A water quality modeling was done at the time and current limits are based on that modeling efforts. The TRC limits were calculated during 1999 renewal and was re-evaluated during 2014 renewal. The facility consists of the following treatment units:



The day to day operation and maintenance aspects of the facility is contracted to H&H Water Controls, Inc.

Compliance History

DMR Data for Outfall 001 (from August 1, 2023 to July 31, 2024)

Parameter	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23
Flow (MGD) Average Monthly	0.00004	0.00005	0.00005	0.00008	0.00006	0.0006	0.00006	0.00005	0.00005	0.00005	0.00005	0.00004
pH (S.U.) Instantaneous Minimum	7.0	7.0	7.0	6.7	6.7	6.5	6.6	6.7	6.6	6.6	6.7	6.6
pH (S.U.) IMAX	7.1	7.2	7.2	7.2	7.4	7.0	7.0	7.0	7.0	6.9	7.0	7.1
DO (mg/L) Instantaneous Minimum	7.1	7.0	7.1	7.2	7.1	7.0	7.1	7.1	7.1	7.1	7.1	7.0
TRC (mg/L) Average Monthly	0.01	0.01	< 0.02	< 0.02	0.01	0.01	0.01	0.01	< 0.01	< 0.02	0.02	< 0.02
TRC (mg/L) IMAX	0.02	0.01	0.02	0.02	0.02	0.02	0.02	0.01	0.02	< 0.02	0.02	0.02
CBOD5 (mg/L) Average Monthly	2.0	2.0	2.0	3.7	2.0	3.8	2.0	2.4	3.0	2.0	2.1	2.0
CBOD5 (mg/L) IMAX	2.0	2.0	2.0	5.3	2.0	5.5	2.0	2.8	3.9	2.0	2.1	2.0
TSS (mg/L) Average Monthly	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
TSS (mg/L) IMAX	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
Fecal Coliform (No./100 ml) Geometric Mean	1	1	1	1	1	1	1	1	1	1	1	1
Fecal Coliform (No./100 ml) IMAX	2	1	1	1	1	1	1	1	1	1	1	2
Total Nitrogen (mg/L) Daily Maximum								12.4				
Ammonia (mg/L) Average Monthly	0.7	0.3	0.7	1.8	0.7	1.2	2.7	5.9	2.7	0.3	0.4	0.2
Ammonia (mg/L) IMAX	1.0	0.4	0.9	2.8	0.9	1.8	3.0	6.8	5.2	0.5	0.5	0.2
Total Phosphorus (mg/L) Daily Maximum								0.2				

Inspection Report: A CEI was conducted on November 10, 2021. The inspection report didn't identify any violation. No issues were identified with the STP. The appearance of the outfall at the receiving stream didn't indicate any loss of solids or other discharge issues.

There's currently no open violation against the facility. No eDMR violations noted during a review of past 12 months eDMR data.

**Existing Effluent Limitations**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.0049	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	3/week	Grab
Dissolved Oxygen	XXX	XXX	7.0 Inst Min	XXX	XXX	XXX	3/week	Grab
TRC	XXX	XXX	XXX	0.3	XXX	0.7	3/week	Grab
CBOD5 Nov 1 - Apr 30	XXX	XXX	XXX	25	XXX	50	2/month	Grab
CBOD5 May 1 - Oct 31	XXX	XXX	XXX	20	XXX	25	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	15.0	XXX	30.0	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	6.0	XXX	12.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 39° 49' 3.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .0049  
Longitude -79° 34' 40.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

Since there's no change in the discharge quality, quantity, receiving stream designation etc. since the last time the model was utilized, a re-evaluation of the WQM modeling isn't necessary, per SOP BCW-PMT-033. All of the existing limits will be carried over. The previous model outputs will be attached with this fact sheet for reference.

**E-Coli:**

Pa Code 25 § 92a. 61 requires monitoring of E. Coli. DEP's SOP titled "Establishing Effluent Limitations for Individual Sewage Permits (BCW-PMT-033, revised March 24, 2021) recommends yearly E. Coli monitoring for sewage dischargers with a design flow between 2,000-50,000 GPD. This requirement will be applied from this permit term.

**Anti-Backsliding**

The proposed limits are at least as stringent as were in the current permit, therefore, anti-backsliding prohibition isn't applicable.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.0049	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	3/week	Grab
DO	XXX	XXX	7.0 Inst Min	XXX	XXX	XXX	3/week	Grab
TRC	XXX	XXX	XXX	0.3	XXX	0.7	3/week	Grab
CBOD5 Nov 1 - Apr 30	XXX	XXX	XXX	25	XXX	50	2/month	Grab
CBOD5 May 1 - Oct 31	XXX	XXX	XXX	20	XXX	25	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Calculation
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15.0	XXX	30.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	6.0	XXX	12.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: At Outfall 001

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

TRC\_CALC.xlsx

1A	B	C	D	E	F	G
2	<b>TRC EVALUATION</b>					
3	Input appropriate values in B4:B8 and E4:E7					
4	0.004	= Q stream (cfs)		0.235	= CV Daily	
5	0.0019	= Q discharge (MGD)		0.235	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 0.453	1.3.2.iii	WLA_cfc = 0.434	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.599	5.1c	LTAMULT_cfc = 0.767	
13	PENTOXSD TRG	5.1b	LTA_afc = 0.271	5.1d	LTA_cfc = 0.333	
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML MULT = 1.104			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.300		AFc	
18			INST MAX LIMIT (mg/l) = 0.680			
	WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
	LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$				
	LTA_afc	wla_afc*LTAMULT_afc				
	WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
	LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$				
	LTA_cfc	wla_cfc*LTAMULT_cfc				
	AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$				
	AVG MON LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$				
	INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$				

Chlorine demands of stream and discharge in conformance with SOPs.

DMRs confirm discharge flows consistently below 0.002 mgd.

CVs based on last 12 DMRs on file.

No. of samples consistent with current SOP requirements.

*Summer*

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19E	38523	Trib 38523 to Meadow Run					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.650	Hickory Acres	PA0098817	0.005	CBOD5	25		
				NH3-N	14.43	28.86	
				Dissolved Oxygen			3

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19E	38523	Trib 38523 to Meadow Run	0.650	1830.00	1.89	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.02	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Hickory Acres	PA0098817	0.0049	0.0049	0.0000	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19E	38523	Trib 38523 to Meadow Run	0.000	1740.00	2.13	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.03	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000			
						25.00	7.00
<b>Parameter Data</b>							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>		<u>Stream Name</u>								
19E			38523		Trib 38523 to Meadow Run								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
0.650	0.02	0.00	0.02	.0076	0.02623	.295	3.52	11.93	0.03	1.324	20.00	7.00	
<b>Q1-10 Flow</b>													
0.650	0.02	0.00	0.02	.0076	0.02623	NA	NA	NA	0.03	1.582	20.00	7.00	
<b>Q30-10 Flow</b>													
0.650	0.05	0.00	0.05	.0076	0.02623	NA	NA	NA	0.04	0.941	20.00	7.00	

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	2.11	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	85.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>				
19E	38523	Trib 38523 to Meadow Run				

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	0.650 Hickory Acres	9.67	28.87	9.67	28.87	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	0.650 Hickory Acres	1.92	14.46	1.92	14.46	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	0.65 Hickory Acres	25	25	28.87	28.87	3	3	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19E	38523	Trib 38523 to Meadow Run		
<u>RMI</u>		<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
0.650		0.005	20.000	7.000
<u>Reach Width (ft)</u>		<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
3.515		0.295	11.929	0.030
<u>Reach CBOD5 (mg/L)</u>		<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
7.61		0.888	7.04	0.700
<u>Reach DO (mg/L)</u>		<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
6.964		19.851	Owens	6
<u>Reach Travel Time (days)</u>		<u>Subreach Results</u>		
1.324		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
		D.O. (mg/L)		
		0.132	6.77	6.42
		0.265	6.02	5.85
		0.397	5.35	5.33
		0.530	4.76	4.86
		0.662	4.23	4.43
		0.794	3.76	4.04
		0.927	3.34	3.68
		1.059	2.97	3.35
		1.191	2.64	3.06
		1.324	2.35	2.79
				7.79

WQM 7.0 Effluent Limits

Winter

SWP Basin	Stream Code	Stream Name					
		19E	38523	Trib 38523 to Meadow Run			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.650	Hickory Acres	PA0098817	0.005	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19E	38523	38523 to Meadow Run			0.650	1830.00	1.89	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH
Q7-10	0.100	0.02	0.00	0.000	0.000	0.0	0.00	0.00	5.00	7.00
Q1-10		0.00	0.00	0.000	0.000				0.00	0.00
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor		Disc Temp (°C)	Disc pH		
Hickory Acres	PA0098817	0.0049	0.0049	0.0000	0.000		15.00	7.00		
<b>Parameter Data</b>										
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
CBOD5		25.00	2.00	0.00	1.50					
Dissolved Oxygen		3.00	8.24	0.00	0.00					
NH3-N		25.00	0.00	0.00	0.70					

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19E	38523	Trib 38523 to Meadow Run	0.000	1740.00	2.13	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.03	0.00	0.000	0.000	0.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
		0.0000	0.0000	0.0000				
Parameter Data								
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5		25.00	2.00	0.00	1.50			
Dissolved Oxygen		3.00	8.24	0.00	0.00			
NH3-N		25.00	0.00	0.00	0.70			

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
19E		38523		Trib 38523 to Meadow Run								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.650	0.02	0.00	0.02	.0076	0.02623	.295	3.52	11.93	0.03	1.324	7.44	7.00
<b>Q1-10 Flow</b>												
0.650	0.02	0.00	0.02	.0076	0.02623	NA	NA	NA	0.03	1.582	8.35	7.00
<b>Q30-10 Flow</b>												
0.650	0.05	0.00	0.05	.0076	0.02623	NA	NA	NA	0.04	0.941	6.33	7.00

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	2.11	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	85.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>															
19E	38523	Trib 38523 to Meadow Run																
<b>NH3-N Acute Allocations</b>																		
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction											
0.650 Hickory Acres		20.59	50	20.59	50	0	0											
<b>NH3-N Chronic Allocations</b>																		
0.650 Hickory Acres		4.08	25	4.08	25	0	0											
<b>Dissolved Oxygen Allocations</b>																		
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)											
0.65 Hickory Acres		25	25	25	25	3	3											
						0	0											

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19E	38523	Trib 38523 to Meadow Run		
<u>RMI</u> 0.650	<u>Total Discharge Flow (mgd)</u> 0.005	<u>Analysis Temperature (°C)</u> 7.439	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 3.515	<u>Reach Depth (ft)</u> 0.295	<u>Reach WDRatio</u> 11.929	<u>Reach Velocity (fps)</u> 0.030	
<u>Reach CBOD5 (mg/L)</u> 7.61	<u>Reach Kc (1/days)</u> 1.040	<u>Reach NH3-N (mg/L)</u> 6.10	<u>Reach Kn (1/days)</u> 0.266	
<u>Reach DO (mg/L)</u> 6.964	<u>Reach Kr (1/days)</u> 14.737	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 1.324	<u>Subreach Results</u>			
TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)	
0.132	7.04	5.89	8.24	
0.265	6.52	5.68	8.24	
0.397	6.03	5.49	8.24	
0.530	5.58	5.30	8.24	
0.662	5.17	5.11	8.24	
0.794	4.78	4.94	8.24	
0.927	4.43	4.76	8.24	
1.059	4.10	4.60	8.24	
1.191	3.79	4.44	8.24	
1.324	3.51	4.29	8.24	