

Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. **PA0100960**
APS ID **1110900**
Authorization ID **1479486**

Applicant and Facility Information

Applicant Name	<u>Bloomfield Township Sewer Authority</u>	Facility Name	<u>Bloomfield Township STP</u>
Applicant Address	<u>22978 Shreve Ridge Road</u>	Facility Address	<u>22978 Shreve Ridge Road</u>
Applicant Contact	<u>Union City, PA 16438-3540</u>	Facility Contact	<u>Union City, PA 16438-3540</u>
Applicant Phone	<u>(814) 694-3409</u>	Facility Phone	<u>(814) 694-2453</u>
Client ID	<u>44311</u>	Site ID	<u>571455</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Bloomfield Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Crawford</u>
Date Application Received	<u>March 15, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	This is an application for a renewal of an Individual Sewage Permit for Bloomfield Township's Sewage Treatment Plant.		

Summary of Review

The Bloomfield Township STP is an existing discharge that serves Bloomfield Township. Treatment consists of a two-lagoon system with chlorine disinfection.

Act 14 – Notifications were submitted and received.

Various changes to the effluent limitations are proposed with the renewal of this permit. No evidence exists of modeling being performed in the last two permit cycles and some of the WQBELs the modeling projected are more stringent than existing models. Effluent limit development will be discussed further into the fact sheet.

Sludge use and disposal description and location(s): Sludge is land filled.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Dustin Hargenrater Dustin Hargenrater / Civil Engineer (General)	February 11, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	February 11, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.35
Latitude	41° 47' 44.85"	Longitude	-79° 50' 25.76"
Quad Name	Lake Canadohta	Quad Code	41079G7
Wastewater Description:	Sewage Effluent		
Receiving Waters	Oil Creek (CWF)	Stream Code	54128
NHD Com ID	100468789	RMI	0.0200
Drainage Area	8.3	Yield (cfs/mi ²)	0.053
Q ₇₋₁₀ Flow (cfs)	0.44	Q ₇₋₁₀ Basis	USGS - StreamStats
Elevation (ft)	1,369	Slope (ft/ft)	---
Watershed No.	16-E	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Background/Ambient Data		Data Source	
pH (SU)	7.0	Default	
Temperature (°F)	20	Default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake		Aqua Pennsylvania Inc. - Emlenton	
PWS Waters	Allegheny River	Flow at Intake (cfs)	1,376
PWS RMI	90.0	Distance from Outfall (mi)	83.6

Changes Since Last Permit Issuance: StreamStats calculated Q₇₋₁₀ values used with this permit issuance. Previously Q₇₋₁₀ flow was based on the Oil Creek at Rouseville gauge station.

Treatment Facility Summary				
Treatment Facility Name: Bloomfield Township STP				
WQM Permit No.	Issuance Date			
2005403	1/9/2006			
2005403 A-1	9/5/2008			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Aerated Lagoon	Gas Chlorine	0.35
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.35	584	Not Overloaded	Sludge Lagoon	Landfill

Changes Since Last Permit Issuance: No changes since last permit issuance.

Other Comments: WQM application 2082401 dated 1/4/1982, revised July & August 1982, issued on 7 October 1982 with 1972 standard sewerage conditions 3, 4, 5, 7, 8, 9, 10, 11, 14, 15, 16, 19, 20, 21, 22, 30, 31, 32, and 33, and all undated soil erosion control conditions, and special conditions A for recording and B for PA Fish Commission for a trout stocked fishery is for a two cell aerated lagoon system and 8 pump stations. Single lagoon volume is 3 523 000-gallons. The TSS load is 220-mg/L or 642-PPP based on 0.35-MGD and 0.18-ppcd. The organic load is 200-mg/l or 584-PPD based on 0.35-MGD and 0.17-ppcd. The design load is flow and concentration based as the stated design per capita values are different with a 595-PPD organic load and 630-PPD inorganic load.

The facility design included season operation (3500 people in summer and 1000 people in winter).

Pump Stations

	Capacity	
	gpm	gpd
Ghost Town Grinder	6	864
#1	94	135 360
#2	150	216 000
#3	250	360 000
#4	350	504000
#5	550	792 000
#6	650	936 000
#7	150	216 000
#8	400	576 000
#1a	29	41 760
9	29	41 760

Compliance History	
Summary of DMRs:	Two violations of effluent limitations for TSS were reported on the 8/2023 DMR. The operator submitted the non-compliance report form and commented that algae was high due to high temps and excessive sunny days.
Summary of Inspections:	There have been 4 inspections in the last permit term. None of the inspections resulted in violations to the facility.

Other Comments: There are no open violations in WMS for the subject Client ID (44311) as of 1/30/25.

Certified full-time operators are Michael Kelly and Wayne Tyson

Development of Effluent Limitations

Outfall No. 001
Latitude 41° 47' 44.99"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .35
Longitude -79° 50' 25.45"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Fecal Coliform maximum limits were subject to a typo in the last permit. The typo consisted of the maximum limits being 10 times more than the standards set forth in Chapter 92a.47(a)(4). This renewal corrects these limits and the facility will still be able meet the limits.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
DO	5.0	Daily Minimum	5.0 (WQM 7.0)
NH3-N (Summer)	3.0	Average Monthly	3.11 (WQM 7.0)
TRC	0.31	Average Monthly	0.312 (TRC_CALC)

Dissolved Oxygen is being proposed as a 5.0 mg/l daily minimum limitation based on the Water Quality Standards in 25 PA Code Chapter 93.7. The standards state "For flowing waters, 7-day average 6.0 mg/L minimum; minimum 5.0 mg/L". This is more stringent than the current limitations and the facility already meets this limit so a compliance schedule will not be proposed for Dissolved Oxygen.

Ammonia Nitrogen limitations are being proposed as a 3.0 mg/L monthly average limit and 6 mg/L instantaneous maximum limit and load limits of 9.0 lbs/day average monthly limits. The limitations are based on modeling in WQM 7.0 and are more stringent than the current limitations so the more stringent limits will be implemented. This parameter is subject to seasonal variations of three times the proposed summer limit. There has been one instance in 4 years of effluent data that the facility will not meet the proposed limit. Since the facility already meets the new limit at least 75% of the time a compliance schedule is not proposed.

Total Residual Chlorine limitations are proposed as 0.31 mg/L monthly average and 0.94 mg/L instantaneous maximum limitations. These limits are more stringent than the limits on the current permit term and the facility does not already meet this limitation 75% of the time. A 3-year compliance schedule is proposed within the permit to give the facility time to adjust the treatment at the facility if needed.

Anti-Backsliding

No anti-backsliding limits are proposed for this renewal.

Other Notable Changes:

CBOD5 and TSS loading limits have been adjusted. Based on the conversion (Facility Design Flow (MGD) x Proposed Effluent Limit (mg/L) x 8.34 (conversion factor)) the mass loading limits are between the current and proposed mass loading limitations. After looking into why this would be changing although the concentration limits were not changed was due to the use of improper rounding techniques that do not conform to the Permit Writers' Manual.

E. Coli monitoring is introduced into the renewal permit based on the SOP for Establishing Effluent Limitations in Individual Sewage Permits. Based on the SOP sewage dischargers will include monitoring, at a minimum, for E. Coli in new and reissued permits, with a monitoring frequency of 1/quarter for design flows ≥ 0.05 and < 1 MGD.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Three Years After Permit Effective Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.43	XXX	1.4	1/day	Grab
CBOD5	70.0	100	XXX	25.0	35.0	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	8-Hr Composite
TSS	85.0	130.0	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Ammonia Nov 1 - Apr 30	26.0	XXX	XXX	9.0	XXX	18	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	9.0	XXX	XXX	3.0	XXX	6	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Three Years After Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.31	XXX	0.94	1/day	Grab
CBOD5	70.0	100	XXX	25.0	35.0	50	1/week	Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	Composite
TSS	85.0	130.0	XXX	30.0	45.0	60	1/week	Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Ammonia Nov 1 - Apr 30	26.0	XXX	XXX	9.0	XXX	18	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	9.0	XXX	XXX	3.0	XXX	6	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection.

WQM 7.0 Modeling Output Files

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54128	OIL CREEK	40.700	1369.00	8.30	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.053	0.00	0.44	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Bloomfield Twp	PA0100960	0.3500	0.3500	0.3500	0.000	25.00	7.66

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
						(ft)	(sq mi)	(ft/ft)	(mgd)	
16E	54128	OIL CREEK			40.200	1356.00	17.50	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.057	0.00	0.99	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
Discharge Data										
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH			
		0.0000	0.0000	0.0000	0.000	25.00	7.00			
Parameter Data										
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
CBOD5		25.00	2.00	0.00	1.50					
Dissolved Oxygen		5.00	8.24	0.00	0.00					
NH3-N		25.00	0.00	0.00	0.70					

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>									
16E		54128		OIL CREEK									
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
Q7-10 Flow													
40.700	0.44	0.00	0.44	.5414 0.00492		.51	14.76	28.93	0.13	0.234	22.76	7.24	
Q1-10 Flow													
40.700	0.28	0.00	0.28	.5414 0.00492		NA	NA	NA	0.12	0.259	23.29	7.31	
Q30-10 Flow													
40.700	0.60	0.00	0.60	.5414 0.00492		NA	NA	NA	0.14	0.216	22.38	7.20	

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>						
16E	54128	OIL CREEK							
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
40.700	Bloomfield Twp	9.11	13.85	9.11	13.85	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
40.700	Bloomfield Twp	1.48	3.11	1.48	3.11	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
40.70	Bloomfield Twp	25	25	3.11	3.11	5	5	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
16E	54128	OIL CREEK	
<u>RMI</u> 40.700	<u>Total Discharge Flow (mgd)</u> 0.350	<u>Analysis Temperature (°C)</u> 22.758	<u>Analysis pH</u> 7.245
<u>Reach Width (ft)</u> 14.759	<u>Reach Depth (ft)</u> 0.510	<u>Reach WDRatio</u> 28.930	<u>Reach Velocity (fps)</u> 0.130
<u>Reach CBOD5 (mg/L)</u> 14.69	<u>Reach Kc (1/days)</u> 1.389	<u>Reach NH3-N (mg/L)</u> 1.71	<u>Reach Kn (1/days)</u> 0.866
<u>Reach DO (mg/L)</u> 6.454	<u>Reach Kr (1/days)</u> 20.547	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 5
<u>Reach Travel Time (days)</u> 0.234	<u>Subreach Results</u>		
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
		14.16	1.68
		13.64	1.65
		13.15	1.61
		12.67	1.58
		12.21	1.55
		11.77	1.52
		11.34	1.49
		10.93	1.46
		10.53	1.43
		10.15	1.40
			7.16

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
16E	54128	OIL CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
40.700	Bloomfield Twp	PA0100960	0.350	CBOD5	25		
				NH3-N	3.11	6.22	
				Dissolved Oxygen			5

TRC_CALC Output Files

TRC_CALC

TRC EVALUATION							
Input appropriate values in A3:A9 and D3:D9							
Source	Reference	AFC Calculations		Reference	CFC Calculations		
TRC	1.3.2.iii	WLA_afc = 0.632		1.3.2.iii	WLA_cfc = 0.608		
PENTOXSD TRG	5.1a		LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581		
PENTOXSD TRG	5.1b		LTA_afc = 0.235	5.1d	LTA_cfc = 0.354		
Effluent Limit Calculations							
PENTOXSD TRG	5.1f		AML MULT = 1.326				
PENTOXSD TRG	5.1g		AVG MON LIMIT (mg/l) = 0.312		INST MAX LIMIT (mg/l) = 0.948	AFC	
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)*(1-FOS/100)]$					
LTAMULT_afc		$\text{EXP}((0.5^2\text{LN}(cvh^2+1))-2.326^2\text{LN}(cvh^2+1)^{0.5})$					
LTA_afc		wla_afc*LTAMULT_afc					
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)*(1-FOS/100)]$					
LTAMULT_cfc		$\text{EXP}((0.5^2\text{LN}(cvd^2/no_samples+1))-2.326^2\text{LN}(cvd^2/no_samples+1)^{0.5})$					
LTA_cfc		wla_cfc*LTAMULT_cfc					
AML MULT		$\text{EXP}(2.326^2\text{LN}((cvd^2/no_samples+1)^{0.5})-0.5^2\text{LN}(cvd^2/no_samples+1))$					
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)					
INST MAX LIMIT		$1.5 * ((av_mon_limit/AML_MULT)/LTAMULT_afc)$					