



Application Type
Facility Type
Major / Minor

Renewal
Industrial
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. **PA0101052**
APS ID **1095386**
Authorization ID **1451803**

Applicant and Facility Information

Applicant Name	Union City Borough Municipal Authority	Facility Name	Union City Borough WTP
Applicant Address	22 North Main Street	Facility Address	9530 Route 6n
	Union City, PA 16438-1329		Union City, PA 16438
Applicant Contact	Daniel Brumagin	Facility Contact	Daryl Nunemaker
Applicant Phone	(814) 438-3721	Facility Phone	(814) 438-3611
Client ID	77400	Site ID	270926
SIC Code	4941	Municipality	Union Township
SIC Description	Trans. & Utilities - Water Supply	County	Erie
Date Application Received	<u>August 4, 2023</u>	EPA Waived?	Yes
Date Application Accepted	<u>September 11, 2023</u>	If No, Reason	
Purpose of Application	Renewal of existing NPDES permit		

Summary of Review

The Union City Municipal Authority (UCMA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of a NPDES permit for the Union City Borough WTP. The permit was last reissued on January 22, 2019 with an effective date of February 1, 2019. The permit expired on January 31, 2024, but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
x		Aaron Baar Aaron Baar / Project Manager	April 13, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	April 14, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	0.025
Latitude	41° 54' 22.51"	Longitude	-79° 49' 10.71"
Quad Name	Union City	Quad Code	01041
Wastewater Description: IW Process Effluent without ELG			
Receiving Waters	Bentley Run (CWF)	Stream Code	53663
NHD Com ID	127354077	RMI	1.46
Drainage Area	2.66 mi ²	Yield (cfs/mi ²)	0.0474
Q ₇₋₁₀ Flow (cfs)	0.126	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	1342.39	Slope (ft/ft)	
Watershed No.	16-A	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	ORGANIC ENRICHMENT, SILTATION		
Source(s) of Impairment	SOURCE UNKNOWN, SOURCE UNKNOWN		
TMDL Status		Name	
Background/Ambient Data			
pH (SU)	7.8	Data Source	June 30, 1993 stream survey
Temperature (°C)	20		CWF default
Hardness (mg/L)	100		Model default
Other:			
Nearest Downstream Public Water Supply Intake			
PWS Waters	French Creek	Cambridge Springs Waterworks	
PWS RMI	49 mi	Flow at Intake (cfs)	49
		Distance from Outfall (mi)	approx. 30 mi

Drainage Area

The discharge is to Bentley Run at RMI 1.46. A drainage area upstream of the discharge is determined to be 2.66 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, the watershed has a Q₇₋₁₀ of 0.126 cfs. This information was used to obtain a Low Flow Yield (LFY), a chronic 30-day (Q₃₀₋₁₀) and acute (Q₁₋₁₀) exposure stream flows for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned}
 Q_{7-10} &= 0.126 \text{ cfs} \\
 Q_{30-10} &= 1.36 * 0.126 \text{ cfs} = 0.1714 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.126 \text{ cfs} = 0.0806 \text{ cfs} \\
 \text{LFY} &= 0.126 \text{ cfs} / 2.66 \text{ mi}^2 = 0.0474 \text{ cfs/mi}^2
 \end{aligned}$$

Bentley Run

25 Pa Code §93.9 classifies the receiving water, Bentley Run, with a Cold-Water Fishery (CWF) Existing Use designation. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed as impaired for aquatic life due to siltation (dam or impoundment) and organic enrichment (source unknown).

Local Watershed Total Maximum Daily Loads (TMDLs)

According to PA's 2024 Integrated Water Quality Monitoring and Assessment Report, Bentley Run in the vicinity of the point of discharge is impaired for aquatic life due to siltation (dam or impoundment) and organic enrichment (source unknown). The waterway's impairments are listed as Category 5 in the 2024 Integrated Report, indicating that the receiving water is impaired for one or more uses by a pollutant that require the development of a TMDL. No TMDL has been developed for Bentley Run to date, so no local watershed TMDL has been taken into consideration during this review.

Public Water Supply Intake

The nearest downstream public water supply intake is the Cambridge Springs Waterworks intake, located on French Creek approximately 30 miles from the point of discharge. Considering the nature of the discharge and distance, the discharge is not expected to impact the water supply.

Class A Wild Trout Streams

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

Miscellaneous

During the previous permit cycle, it was noted that there was an inquiry made to the Regional Biologist as to the probability that endangered mussels were located in the receiving stream. It was determined at the time that no stream survey information exists that indicates that endangered mussels are present in the Bentley Run.

Treatment Facility Summary				
Treatment Facility Name: Union City Municipal Authority WTP				
WQM Permit No.	Issuance Date			
2514201	May 29, 2014			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial			No Disinfection	0.025
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.179	0			

UCMA operates and owns the wastewater treatment facility located at RD #3 Corry Road (Union Township, Erie County). The facility currently only treats industrial wastewater generated at the Union City Water Treatment Plant. The facility has a permitted annual average design flow of 0.025 MGD.

Treatment units consist of two settling impoundments.

1. One impoundment is dedicated to receiving flow from three sources:
 - a. filter backwash from gravity filters
 - b. filter wastewater from plant activation
 - c. and analyzer wastewater.

Discharge flow and sampling is obtained from this impoundment during day-to-day operations.

2. The other impoundment is used for sedimentation basin cleaning. Water from basin cleaning is flushed into this impoundment, where it is retained and not discharged until the impoundment is cleaned (typically annually).

The facility alternates the usages of impoundments annually. Discharge flow can manually be controlled from each impoundment.

Ferric Chloride is utilized as a coagulant and Sodium Permanganate is utilized as an oxidizer.

Note: The facility's 2013 NPDES renewal was based on the facility's design annual average flow of 0.025 mgd, while the facility's 2019 NPDES renewal was based on actual flow rates through the facility. Given that the treatment plant is rated for 0.025 mgd in the facility's 2014 WQM permit and in the 2013 NPDES renewal, the value utilized in the last renewal will be treated as anomalous. All limits determined in the course of this renewal utilize the facility's design annual average flow of 0.025 mgd.

Compliance History													
Summary of DMRs:	DMR results for the past year are presented below.												
Summary of Inspections:	<p>Since the last renewal of the facility's NPDES permit, the following inspection has been logged in WMS:</p> <p>December 14, 2022: A routine CEI was conducted by Shane Krause. No violations were noted. Non-Compliance was noted for not submitting DMRs in a timely manner.</p>												

Other Comments: As of April 13, 2025, the following open violations are associated with this facility:

CLIENT ID	CLIENT	PF ID	FACILITY	PF KIND	PF STATUS	INSP PROGRAM	PROGRAM SPECIFIC ID	INSP ID	VIOLATION ID	INSPECTION CATEGORY	VIOLATION DATE	VIOLATION CODE	VIOLATION	PF INSPECTOR	INSP REGION
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293594	UNION CITY MUNI AUTH	Water Purveyor	Active	Water Planning and Conservation	102285-001	3853404	8196993	PF	11/30/2023	110.301	Reporting for all water withdrawals and usage	BLASHAW,JUSTIN	NWRO
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293594	UNION CITY MUNI AUTH	Water Purveyor	Active	Water Planning and Conservation	102285-001	3872207	8208718	PF	11/20/2024	110.301	Reporting for all water withdrawals and usage	BLASHAW,JUSTIN	NWRO
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293595	UNION CITY MUNICIPAL AUTHORITY	Community	Active	Safe Drinking Water	6250064	3794367	8193809	PF	07/10/2024	C7	FAILURE TO COMPLY WITH A PERMIT CONDITION	BLASHAW,JUSTIN	NWRO
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293595	UNION CITY MUNICIPAL AUTHORITY	Community	Active	Safe Drinking Water	6250064	3794367	8193810	PF	07/10/2024	C3B	FAILURE TO OPERATE A PUBLIC WATER SYSTEM TO PROVIDE THE LEVEL OF TREATMENT APPROVED IN ITS PERMIT	BLASHAW,JUSTIN	NWRO
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293595	UNION CITY MUNICIPAL AUTHORITY	Community	Active	Safe Drinking Water	6250064	3794367	8193811	PF	07/10/2024	C4A	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	BLASHAW,JUSTIN	NWRO
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293595	UNION CITY MUNICIPAL AUTHORITY	Community	Active	Safe Drinking Water	6250064	3794367	8193812	PF	07/10/2024	B5A	FAILURE OF A PUBLIC WATER SYSTEM TO OBTAIN A PERMIT	BLASHAW,JUSTIN	NWRO
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293595	UNION CITY MUNICIPAL AUTHORITY	Community	Active	Safe Drinking Water	6250064	3794367	8193813	PF	07/10/2024	D2E	FAILURE TO SUBMIT OR REVISE A MONITORING PLAN FOR THE LEAD AND COPPER RULE	BLASHAW,JUSTIN	NWRO
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293595	UNION CITY MUNICIPAL AUTHORITY	Community	Active	Safe Drinking Water	6250064	3794367	8193815	PF	07/10/2024	C3E	FAILURE TO IMPLEMENT A FILTER BED EVALUATION PROGRAM	BLASHAW,JUSTIN	NWRO
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293595	UNION CITY MUNICIPAL AUTHORITY	Community	Active	Safe Drinking Water	6250064	3920421	8217716	PF	01/08/2025	C3F	FAILURE TO TEST ALARM AND SHUTDOWN EQUIPMENT FOR RESPOND TO ALARM AND SHUTDOWN EQUIPMENT FAILURE	BLASHAW,JUSTIN	NWRO
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293595	UNION CITY MUNICIPAL AUTHORITY	Community	Active	Safe Drinking Water	6250064	3920421	8217717	PF	01/08/2025	C4A	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	BLASHAW,JUSTIN	NWRO
77400	UNION CITY BORO MUNI AUTH ERIE CNTY	293595	UNION CITY MUNICIPAL AUTHORITY	Community	Active	Safe Drinking Water	6250064	3920421	8217718	PF	01/08/2025	C2D	FAILURE TO CALIBRATE TURBIDIMETERS USED FOR COMPLIANCE MONITORING	BLASHAW,JUSTIN	NWRO

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/week	Grab
TRC	XXX	XXX	XXX	0.13	XXX	0.2	1/week	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Total Aluminum	0.51	XXX	XXX	3.4	XXX	6.8	2/month	8-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	XXX	2	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001

Compliance History

DMR Data for Outfall 001 (from March 1, 2024 to February 28, 2025)

Parameter	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24
Flow (MGD) Average Monthly	0.027	0.027	0.034	0.027	0.024	0.022	0.021	0.032	0.022	0.02	0.024	0.028
pH (S.U.) Instantaneous Minimum	7.0	6.9	7.0	6.9	7.0	6.9	6.9	6.9	6.9	6.9	7.0	6.9
pH (S.U.) Instantaneous Maximum	7.3	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.3	7.3
TRC (mg/L) Average Monthly	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.03	0.04	0.03	0.03
TRC (mg/L) Instantaneous Maximum	0.03	0.04	0.03	0.02	0.03	0.03	0.03	0.03	0.04	0.05	0.04	0.04
TSS (mg/L) Average Monthly	< 3	< 3	< 3	< 3	< 3	< 4	< 3	< 3	< 3	< 3	< 3	< 3
Total Aluminum (lbs/day) Average Monthly	0.10	< 0.008	< 0.03	< 0.03	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.03	< 0.03
Total Aluminum (mg/L) Average Monthly	0.4	< 0.03	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
Total Iron (mg/L) Average Monthly	0.18	0.55	0.34	0.27	0.15	0.12	0.13	0.33	0.44	0.36	0.58	0.3
Total Manganese (mg/L) Average Monthly	0.11	0.16	0.19	0.32	0.25	0.3	0.25	0.35	0.36	0.45	0.22	0.23

Development of Effluent Limitations

Outfall No. 001

Latitude 41° 54' 23.00"

Design Flow (MGD) 0.025

Longitude -79° 49' 10.71"

Wastewater Description: IW Process Effluent without ELG

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
Total Suspended Solids	30	Average Monthly		362-2183-001
Total Suspended Solids	60	Daily Maximum		362-2183-001
Aluminum	4.0	Average Monthly		362-2183-001
Aluminum	8.0	Daily Maximum		362-2183-001
Manganese	1.0	Average Monthly		362-2183-001
Manganese	2.0	Daily Maximum		362-2183-001
Total Iron	2.0	Average Monthly		362-2183-001
Total Iron	4.0	Daily Maximum		362-2183-001
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Residual Chlorine	1.0	Daily Maximum		362-2183-001
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)

Comments: The DEP Guidance "Technology-based Control Requirements for Water Treatment Plant Wastes" (362-2183-001) provides these limits that are based on Best Practical Control Technology (BPT). The Union City Borough WTP is not subject to Federal Effluent Limitation Guidelines (ELGs) as the SIC code is not listed under 40 CFR parts 405 through 471.

Water Quality-Based Limitations

Toxics

The Department's Toxics Management Spreadsheet (Version 1.4) was used to perform a Reasonable Potential (RP) Analysis for all Group 1 and Group 2 priority pollutants at a pH of 7.1 and a discharge hardness of 103.8 mg/L. The RP Analysis was done for all priority pollutants using the sampling results provided with the application with the exception of Total Aluminum, Total Iron and Total Manganese. Total Aluminum, Total Iron and Total Manganese historical data from the facility's DMRs from the preceding 24 months (March 2023 thru February 2025) was compiled and evaluated using the Department's TOXCONC spreadsheet. The TOXCONC output of the mean value and the CV value for Total Aluminum, Total Iron and Total Manganese was entered as the input to the Toxics Management Spreadsheet (Version 1.4). The model output recommended the following monitoring and reporting requirements:

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Model Results

4/13/2025

Page 7

Pollutants	Mass Limits		Concentration Limits					Comments	
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units	Governing WQBEL	WQBEL Basis	
Total Copper	Report	Report	Report	Report	Report	mg/L	0.039	AFC	Discharge Conc > 10% WQBEL (no RP)
Total Iron	Report	Report	Report	Report	Report	ug/L	6,387	CFC	Discharge Conc > 10% WQBEL (no RP)
Total Manganese	Report	Report	Report	Report	Report	ug/L	4,258	THH	Discharge Conc > 10% WQBEL (no RP)

The facility currently has limits for Total Iron and Total Manganese; due to anti-backsliding provisions, those limits are proposed to remain intact. Based on the Reasonable Potential Analysis, a new monitor and report requirement for Total Copper is proposed to be included in this renewal.

The sampling interval for Total Copper is proposed as 2/month in conformity with DEP's Technical Guidance for the Development and Specification of Effluent Limitations (PA Doc. No. 362-0400-001), Table 6-3 (plant design flow 5.0 to 25.0 mgd).

All model inputs and outputs are included at the end of this fact Sheet.

Best Professional Judgment (BPJ) Limitations

TDS / Sulfate / Chloride / Bromide / 1,4-Dioxane:

Total Dissolved Solids (TDS) and its major constituents including sulfate, chloride, and bromide have emerged as pollutants of concern in several major watersheds in the Commonwealth. The conservative nature of these solids allows them to accumulate in surface waters and they may remain a concern even if the immediate downstream public water supply is not directly impacted. Under the authority of § 92a.61, statewide guidance distributed by the Department's Central Office on January 23, 2014 stated the following:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

- *Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.*
- *Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.*
- *Where the concentration of 1,4-dioxane (CAS 123-91-1) in a discharge exceeds 10 µg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for 1,4-dioxane. Discharges of 0.1 MGD or less should monitor and report for 1,4-dioxane if the concentration of 1,4-dioxane in the discharge exceeds 100 µg/L.*

The table below compares the above thresholds for monitoring requirements with the concentrations documented in the current application:

Department Monitoring Thresholds and Expected Discharge Concentrations for TDS and Related Parameters

Parameter	Threshold for Discharges ≤0.1 MGD	Max. Concentration in Application
TDS	5,000 mg/L	1560 mg/L
Sulfate	NA	6.48 mg/L
Chloride	NA	45.2 mg/L
Bromide	10 mg/L	<0.036 mg/L
1,4-Dioxane	100 µg/L	Not Tested

Based on the sampling results in the application, no additional limits are proposed in the draft permit. 1,4-Dioxane was not evaluated as drinking water associated Treatment Plants are only required to sample Group 1 and Group 2 priority pollutants.

Total Residual Chlorine

Since chlorine is used for disinfection, Total Residual Chlorine (TRC) effluent levels must be regulated in accordance with 25 Pa Code §92a.48(b). DEP's TRC_CALC worksheet is utilized to determine if the existing BAT TBEL is still appropriate. The worksheet indicates that the existing limits of 0.13 mg/L (average monthly) and 0.2 mg/L (IMAX) are still protective of water quality.

The Department's TRC_CALC worksheet is presented at the end of this report.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii). The current permit requires the flow to be monitored 1/week. No change is proposed.

Monitoring Frequency and Sample Type

Unless discussed otherwise above, the permit's monitoring frequency and sample type for all parameters will remain unchanged from the last permit renewal.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-backsliding Requirement

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal unless noted otherwise above. This approach is in accordance with 40 CFR §122.44(l)(1).

Annual Fees

An annual fee clause is continued in the permit in accordance with 25 Pa. Code § 92a.62. The facility covered by the permit is classified in the Minor IW Facility without ELG fee category, which has an annual fee of \$1,500.

Mass Loading Limitations

As documented in the facility's 2013 renewal, the previous permit's mass limits were not included except for the one associated with the water quality based Total Aluminum limit. This makes the permit design consistent with other water treatment plant permit's issued in the Region. The Total Aluminum mass loading effluent limit is calculated based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34).

Proposed Effluent Limitations and Monitoring Requirements


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/week	Grab
TRC	XXX	XXX	XXX	0.13	XXX	0.2	1/week	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Total Aluminum	0.51	XXX	XXX	3.4	XXX	6.8	2/month	8-Hr Composite
Total Copper	XXX	XXX	XXX	Report Daily Max	XXX	2/month	8-Hr Composite	8-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	XXX	2	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]



Outfall 001


StreamStats Report

Region ID: PA

Workspace ID: PA20250413132425094000

Clicked Point (Latitude, Longitude): 41.90758, -79.81771

Time: 2025-04-13 09:24:55 -0400



[Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	2.66	square miles
ELEV	Mean Basin Elevation	1464	feet
PRECIP	Mean Annual Precipitation	45	inches

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	2.66	square miles	2.33	1720
ELEV	Mean Basin Elevation	1464	feet	898	2700

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
PRECIP	Mean Annual Precipitation	45	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.289	ft ³ /s	43	43
30 Day 2 Year Low Flow	0.43	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.126	ft ³ /s	54	54
30 Day 10 Year Low Flow	0.18	ft ³ /s	49	49
90 Day 10 Year Low Flow	0.266	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.
(<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Downstream Reach


StreamStats Report

Region ID: PA

Workspace ID: PA20250413132829765000

Clicked Point (Latitude, Longitude): 41.90133, -79.83209

Time: 2025-04-13 09:28:56 -0400



[Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	3.37	square miles
ELEV	Mean Basin Elevation	1449	feet
PRECIP	Mean Annual Precipitation	45	inches

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	3.37	square miles	2.33	1720
ELEV	Mean Basin Elevation	1449	feet	898	2700

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
PRECIP	Mean Annual Precipitation	45	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.365	ft ³ /s	43	43
30 Day 2 Year Low Flow	0.541	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.161	ft ³ /s	54	54
30 Day 10 Year Low Flow	0.229	ft ³ /s	49	49
90 Day 10 Year Low Flow	0.338	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.
[\(http://pubs.usgs.gov/sir/2006/5130/\)](http://pubs.usgs.gov/sir/2006/5130/)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


Effluent pH Modelling

	Feb-25	Jan-25	Dec-24	Nov-24	Oct-24	Sep-24	Aug-24	Jul-24	Jun-24	May-24	Apr-24	Mar-24
Min pH:	7	6.9	7	6.9	7	6.9	6.9	6.9	6.9	6.9	7	6.9
10 ⁸ -pH	1E-07	1.26E-07	1E-07	1.26E-07	1E-07	1.26E-07	1.26E-07	1.26E-07	1.26E-07	1.26E-07	1E-07	1.26E-07
Max pH:	7.3	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.3	7.3
10 ⁸ -pH	5.01E-08	6.31E-08	5.01E-08	3.98E-08	5.01E-08	5.01E-08						
AVG:	7.51E-08	9.45E-08	7.51E-08	8.8E-08	7.51E-08	8.8E-08	8.8E-08	8.8E-08	8.8E-08	8.29E-08	7.51E-08	8.8E-08
AVG pH:	7.1	7.0	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1
Mean pH:	7.1											

Elevation at 001



Elevation at Downstream Reach



TOXCONC Imputs

Facility: Union City Municipal Authority WTP			
NPDES #: PA0101052			
Outfall No: 001			
n (Samples/Month): 4			
Reviewer/Permit Engineer: Aaron Baar			
Parameter Name	Total Aluminum	Total Iron	Total Manganese
Units	mg/L	mg/L	mg/L
Detection Limit	0.01	0.02	0.002
Sample Date	When entering values below the detection limit, enter "ND" or use the < notation (eg. <0.02)		
2/11/2025	0.38	0.2	0.1
2/25/2025	0.42	0.15	0.1
1/14/2025	<0.03	0.64	0.19
1/24/2025	<0.03	0.45	0.12
1/20/2024	<0.1	0.32	0.11
1/17/2024	<0.1	0.36	0.26
1/12/2024	<0.1	0.17	0.44
1/18/2024	<0.1	0.36	0.19
1/15/2024	<0.1	0.18	0.24
1/22/2024	<0.1	0.11	0.26
9/10/2024	<0.1	0.11	0.34
9/17/2024	<0.1	0.12	0.26
8/13/2024	<0.1	0.12	0.22
8/20/2024	<0.1	0.14	0.27
7/16/2024	<0.1	0.37	0.3
7/12/2024	<0.1	0.28	0.39
6/11/2024	<0.1	0.55	0.31
6/18/2024	<0.1	0.33	0.4
5/7/2024	<0.1	0.21	0.2
5/14/2024	<0.1	0.5	0.69
4/9/2024	<0.1	0.46	0.16
4/16/2024	<0.1	0.69	0.28
3/5/2024	<0.1	0.38	0.29
3/19/2024	<0.1	0.22	0.16
2/6/2024	<0.1	0.45	0.27
2/13/2024	<0.1	0.22	0.13
1/9/2024	<0.1	0.27	0.25
1/16/2024	<0.1	0.64	0.14
12/11/2023	<0.1	0.53	0.53
12/19/2023	<0.1	0.3	0.61
11/14/2023	<0.1	0.09	0.26
11/19/2023	<0.1	0.12	0.91
10/2/2023	<0.1	0.29	0.23
10/19/2023	<0.1	0.37	0.27
9/6/2023	<0.1	0.14	0.32
9/20/2023	<0.1	0.05	0.64
8/9/2023	<0.1	0.1	0.32
8/16/2023	<0.1	0.32	0.32
7/17/2023	<0.1	0.221	0.162
7/24/2023	<0.1	0.242	0.435
6/7/2023	<0.1	<0.2	0.08
6/19/2023	<0.1	0.343	0.162
5/8/2023	<0.1	<0.2	0.258
5/15/2023	<0.1	<0.2	0.134
4/12/2023	<0.1	0.688	0.199
4/17/2023	<0.1	<0.2	0.129
3/6/2023	<0.1	<0.2	0.0807
3/15/2023	<0.1	0.554	0.159

TOXCONC Output

TRC Modelling

TRC_CALC

1A	B	C	D	E	F	G						
2 TRC EVALUATION												
3 Input appropriate values in B4:B8 and E4:E7												
4	0.126	= Q stream (cfs)		0.5	= CV Daily							
5	0.018	= Q discharge (MGD)		0.5	= CV Hourly							
6	30	= no. samples		1	= AFC_Partial Mix Factor							
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor							
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)							
9	0.13	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)							
	0	= % Factor of Safety (FOS)			=Decay Coefficient (K)							
10	Source	Reference	AFC Calculations	Reference	CFC Calculations							
11	TRC	1.3.2.iii	WLA_afc = 1.462	1.3.2.iii	WLA_cfc = 1.418							
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581							
13	PENTOXSD TRG	5.1b	LTA_afc= 0.545	5.1d	LTA_cfc = 0.824							
14												
15	Source	Effluent Limit Calculations										
16	PENTOXSD TRG	5.1f	AML MULT = 1.231									
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.130		BAT/BPJ							
18			INST MAX LIMIT (mg/l) = 0.425									
	WLA_afc	$(.019/e(-k* AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k* AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$										
	LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$										
	LTA_afc	$wla_afc*LTAMULT_afc$										
	WLA_cfc	$(.011/e(-k* CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k* CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$										
	LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$										
	LTA_cfc	$wla_cfc*LTAMULT_cfc$										
	AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$										
	AVG MON LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$										
	INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$										

TMS Inc



Discharge Information

Instructions **Discharge** Stream

Facility: **Union City Municipal Authority WTP** NPDES Permit No.: **PA0101052** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Water Treatment Plant Backwash**

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.025	103.8	7.1						

		Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
Group 1	Group 2				Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
		Total Dissolved Solids (PWS)	mg/L	1560									
		Chloride (PWS)	mg/L	45.2									
		Bromide	mg/L	< 0.036									
		Sulfate (PWS)	mg/L	6.48									
		Fluoride (PWS)	mg/L										
		Total Aluminum	µg/L	< 129.9565			2.9785						
		Total Antimony	µg/L	< 0.07									
		Total Arsenic	µg/L	< 2.5									
		Total Barium	µg/L	40.5									
		Total Beryllium	µg/L	< 0.135									
		Total Boron	µg/L	376									
		Total Cadmium	µg/L	< 0.025									
		Total Chromium (III)	µg/L	< 1.99									
		Hexavalent Chromium	µg/L	< 0.25									
		Total Cobalt	µg/L	0.278									
		Total Copper	mg/L	0.00945									
		Free Cyanide	µg/L										
		Total Cyanide	µg/L	< 6									
		Dissolved Iron	µg/L	127									
		Total Iron	µg/L	< 644.938			0.8059						
		Total Lead	µg/L	0.083									
		Total Manganese	µg/L	523.0377			0.5963						
		Total Mercury	µg/L	< 0.093									
		Total Nickel	µg/L	7.2									
		Total Phenols (Phenolics) (PWS)	µg/L	< 5									
		Total Selenium	µg/L	< 2.5									
		Total Silver	µg/L	< 0.274									
		Total Thallium	µg/L	< 0.014									
		Total Zinc	mg/L	< 0.00354									
		Total Molybdenum	µg/L	0.631									
		Acrolein	µg/L	<									
		Acrylamide	µg/L	<									
		Acrylonitrile	µg/L	<									
		Benzene	µg/L	<									
		Bromoform	µg/L	<									



Stream / Surface Water Information

Instructions Discharge Stream

Union City Municipal Authority WTP, NPDES Permit No. PA0101052, Outfall 001

Receiving Surface Water Name: Bentley Run

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANC0 Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	053663	1.46	1342.39	2.66			Yes
End of Reach 1	053663	0.41	1285.48	3.37			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
			Stream	Tributary								
Point of Discharge	1.46		0.126									
End of Reach 1	0.41		0.161									

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
Point of Discharge	1.46		Stream	Tributary								
End of Reach 1	0.41											



Model Results

<input type="button" value="Instructions"/>	<input checked="" type="button" value="Results"/>
<input type="button" value="RETURN TO INPUTS"/>	<input type="button" value="SAVE AS PDF"/>
<input type="button" value="PRINT"/>	<input checked="" type="radio"/> All <input type="radio"/> Inputs <input type="radio"/> Results <input type="radio"/> Limits

Union City Municipal Authority WTP, NPDES Permit No. PA0101052, Outfall 001

Hydrodynamics

Wasteload Allocations

AFC CCT (min): 1.488

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc [mg/L]	Stream CV	Trib Conc [µg/L]	Fate Coef	WQC Obj [µg/L]	WLA [µg/L]	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	
Total Aluminum	0	0	0	0	750	3,193	
Total Antimony	0	0	0	0	1,100	4,684	
Total Arsenic	0	0	0	0	340	1,448	Chem Translator of 1 applied
Total Barium	0	0	0	0	21,000	89,416	
Total Boron	0	0	0	0	8,100	34,489	
Total Cadmium	0	0	0	0	2,031	9,177	Chem Translator of 0.944 applied
Total Chromium (III)	0	0	0	0	573.925	1,816	7,733
Hexavalent Chromium	0	0	0	0	16	16.3	69.4
Total Cobalt	0	0	0	0	95	95.0	405
Total Copper	0	0	0	0	13.552	14.1	60.1
Dissolved Iron	0	0	0	0	N/A	N/A	Chem Translator of 0.96 applied
Total Iron	0	0	0	0	N/A	N/A	
Total Lead	0	0	0	0	65.209	82.6	352
Total Manganese	0	0	0	0	N/A	N/A	
Total Mercury	0	0	0	0	1,400	1.65	7.01
Total Nickel	0	0	0	0	471.769	473	2,013
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	Chem Translator of 0.85 applied
Total Silver	0	0	0	0	3,266	3.84	16.4
Total Thallium	0	0	0	0	65	65.0	277
Total Zinc	0	0	0	0	118.066	121	514
							Chem Translator of 0.97 applied

CFC CCT (min): 1.488

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	220	220	937	
Total Arsenic	0	0	0	0	150	150	639	Chem Translator of 1 applied
Total Barium	0	0	0	0	4,100	4,100	17,457	
Total Boron	0	0	0	0	1,600	1,600	6,813	
Total Cadmium	0	0	0	0	0.248	0.27	1.16	Chem Translator of 0.909 applied
Total Chromium (III)	0	0	0	0	74.656	86.8	370	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0	0	0	10	10.4	44.3	Chem Translator of 0.962 applied
Total Cobalt	0	0	0	0	19	19.0	80.9	
Total Copper	0	0	0	0	9,024	9.4	40.0	Chem Translator of 0.96 applied
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	1,500	1,500	6,387	WQC = 30 day average; PMF = 1
Total Lead	0	0	0	0	2,541	3.22	13.7	Chem Translator of 0.79 applied
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	0.770	0.91	3.86	Chem Translator of 0.85 applied
Total Nickel	0	0	0	0	52.399	52.6	224	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	4,600	4.99	21.2	Chem Translator of 0.922 applied
Total Silver	0	0	0	0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0	0	0	13	13.0	55.4	
Total Zinc	0	0	0	0	119,032	121	514	Chem Translator of 0.986 applied

THH CCT (min): PMF: Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	500,000	500,000	N/A	
Chloride (PWS)	0	0	0	0	250,000	250,000	N/A	
Sulfate (PWS)	0	0	0	0	250,000	250,000	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	5.6	5.6	23.8	
Total Arsenic	0	0	0	0	10	10.0	42.6	
Total Barium	0	0	0	0	2,400	2,400	10,219	
Total Boron	0	0	0	0	3,100	3,100	13,200	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A	
Total Cobalt	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	

Dissolved Iron	0	0	0	0	300	300	1,277
Total Iron	0	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	0	1,000	1,000	4,258
Total Mercury	0	0	0	0	0.050	0.05	0.21
Total Nickel	0	0	0	0	610	610	2,597
Total Phenols (Phenolics) (PWS)	0	0	0	0	5	5.0	N/A
Total Selenium	0	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0	0.24	0.24	1.02
Total Zinc	0	0	0	0	N/A	N/A	N/A

CRL

CCT (min):

PMF: 1 Analysis Hardness (mg/l):

Analysis pH: N/A

Pollutants	Stream Conc ($\mu\text{g/L}$)	Stream CV	Trib Conc ($\mu\text{g/L}$)	Fate Coef	WQC ($\mu\text{g/L}$)	WQC Obj ($\mu\text{g/L}$)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	N/A	N/A	N/A	
Total Arsenic	0	0	0	0	N/A	N/A	N/A	
Total Barium	0	0	0	0	N/A	N/A	N/A	
Total Boron	0	0	0	0	N/A	N/A	N/A	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A	
Total Cobalt	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	N/A	N/A	N/A	
Total Nickel	0	0	0	0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	N/A	
Total Silver	0	0	0	0	N/A	N/A	N/A	
Total Thallium	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., \leq Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	8,200	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	10,219	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	6,813	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cadmium	1.16	µg/L	Discharge Conc < TQL
Total Chromium (III)	370	µg/L	Discharge Conc < TQL
Hexavalent Chromium	44.3	µg/L	Discharge Conc < TQL
Total Cobalt	80.9	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	1,277	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	13.7	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	0.21	µg/L	Discharge Conc < TQL
Total Nickel	224	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)			
Total Selenium	21.2	µg/L	Discharge Conc < TQL
Total Silver	10.5	µg/L	Discharge Conc < TQL
Total Thallium	1.02	µg/L	Discharge Conc < TQL
Total Zinc	0.33	mg/L	Discharge Conc < TQL
Total Molybdenum	N/A	N/A	No WQS