

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0101087  
 APS ID 1154495  
 Authorization ID 1556008

**Applicant and Facility Information**

Applicant Name	<u>Overlook Holdings LLC</u>	Facility Name	<u>Twilight MHP</u>
Applicant Address	<u>PO Box 254</u> <u>Edinburg, PA 16116-0254</u>	Facility Address	<u>Route 551</u> <u>Edinburg, PA 16116</u>
Applicant Contact	<u>Timothy St John</u>	Facility Contact	<u>Timothy St John</u>
Applicant Phone	<u>(724) 333-2801</u>	Facility Phone	<u>(724) 333-2801</u>
Client ID	<u>396136</u>	Site ID	<u>262956</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Mahoning Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lawrence</u>
Date Application Received	<u>January 22, 2026</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of Minor Sewage Facility NPDES Permit for a Mobile Home Park</u>		

**Summary of Review**

The Department received a renewal application for NPDES Individual Permit No. PA0101087 on January 22, 2026. The permit is for a Mobile Home Park with one outfall (Outfall 001) that discharges to Tributary 35853 to Shenango River (WWF).

This renewal also includes a transfer from Twilight Mobile Home Park LLC to Overlook Holdings LLC. The transferred WQM Permit will be issued in conjunction with the final NPDES permit.

Act 14 notifications were submitted and received.

The facility is currently in the eDMR system.

The last inspection was conducted on August 20, 2025. Violations were noted.

There are no open violations in WMS for the subject Client ID (396136) as of February 3, 2026.

Proposed Changes:

- Addition of E. Coli monitoring
- More stringent Total Residual Chlorine (TRC) limits are proposed
- More stringent Ammonia-Nitrogen limits are proposed

Approve	Deny	Signatures	Date
X		Carlee Wilson Carlee Wilson / Environmental Engineering Specialist	February 10, 2026
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	March 5, 2026

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0175</u>
Latitude	<u>41° 2' 55.14"</u>	Longitude	<u>-80° 26' 5.16"</u>
Quad Name	<u>Edinburg</u>	Quad Code	<u>41080A4</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary of Shenango River (WWF)</u>	Stream Code	<u>35853</u>
NHD Com ID	<u>130025482</u>	RMI	<u>0.25</u>
Drainage Area	<u>0.18</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.005</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.001</u>	Q <sub>7-10</sub> Basis	<u>USGS - StreamStats</u>
Elevation (ft)	<u>1107</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>20-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	
Temperature (°F)	<u>68</u>	Default	
Hardness (mg/L)	<u>100</u>	Default	
Other:	<u>-</u>	-	
Nearest Downstream Public Water Supply Intake	<u>PA American Water Company, New Castle</u>		
PWS Waters	<u>Shenango</u>	Flow at Intake (cfs)	<u>16.2</u>
PWS RMI	<u>5.1</u>	Distance from Outfall (mi)	<u>5.49</u>

Changes Since Last Permit Issuance: Q7-10 Flow was adjusted using StreamStats data from USGS. Elevation was changed using Google Earth.

Public Participation


DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Twilight MHP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
3773412 T-4	May 22, 2024			
3773412 A-1	December 31, 2009			
3773412 T-3	June 8, 1983			
3773412 T-2	December 23, 1980			
3773412 T-1	October 23, 1980			
377341	December 26, 1973			
367-S-034	February 23, 1968			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary With Ammonia And Phosphorus	Activated Sludge	Hypochlorite	0.0175
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0175	35.4	Not Overloaded	Aerobic Digestion	

Changes Since Last Permit Issuance: None

Other Comments: Treatment consists of 3 aeration tank bays, a clarifier tank, a sludge holding tank, a wet well, two accessible sand filters, then a chlorine contact tank w/tablet chlorinator.

Sludge use and disposal description and location(s): New Castle Sanitation Authority



Compliance History

DMR Data for Outfall 001 (from January 1, 2025, to December 31, 2025)

Parameter	DEC-25	NOV-25	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25
Flow (MGD) Average Monthly	0.0006	0.0008	0.001	0.0004	0.0009	0.001	0.0012	0.0013	FF	0.0001	0.0001	0.0006
pH (S.U.) Instantaneous Minimum	7.2	6.9	6.8	6.8	6.9	7.2	7.0	6.8	E	7.4	7.0	6.8
pH (S.U.) Instantaneous Maximum	7.8	7.8	7.8	7.9	8.2	8.4	7.9	8.2	E	7.8	7.6	7.6
DO (mg/L) Instantaneous Minimum	7.6	7.9	5.6	5.3	6.7	5.5	6.3	6.1	E	8.9	8.9	8.1
TRC (mg/L) Average Monthly	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	0.02	< 0.02	< 0.02	E	< 0.02	< 0.01	0.02
TRC (mg/L) Instantaneous Maximum	0.05	0.04	0.05	0.04	0.04	0.05	0.05	0.05	E	0.03	0.04	0.03
CBOD5 (mg/L) Average Monthly	4.6	16.1	4.9	< 4.9	7.7	5.7	< 3.1	3.3	E	E	4.4	< 3.6
TSS (mg/L) Average Monthly	< 4	< 11	< 4.0	< 5	< 5	20	< 4	< 4	E	E	10	4
Fecal Coliform (No./100 ml) Geometric Mean	63	5	< 1	< 4	> 9	> 16	> 18	< 6	E	< 1	34	< 10
Total Nitrogen (mg/L) Average Monthly	21.2	28.1	33.1	35.3	35.6	28.1	19	26.3	E	E	18.2	19.8
Ammonia (mg/L) Average Monthly	13.2	10.3	3.4	4.4	17.5	23.8	1.66	3.04	E	E	< 0.13	< 0.19
Total Phosphorus (mg/L) Average Monthly	1.6	2.9	2.7	1.56	0.76	1.43	< 0.19	1.38	E	E	0.44	0.82

**Compliance History**

Effluent Violations for Outfall 001, from: February 1, 2025, To: December 31, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Ammonia	08/31/25	Avg Mo	17.5	mg/L	2.0	mg/L
Ammonia	07/31/25	Avg Mo	23.8	mg/L	2.0	mg/L
Ammonia	05/31/25	Avg Mo	3.04	mg/L	2.0	mg/L
Ammonia	09/30/25	Avg Mo	4.4	mg/L	2.0	mg/L
Ammonia	10/31/25	Avg Mo	3.4	mg/L	2.0	mg/L
Ammonia	11/30/25	Avg Mo	10.3	mg/L	6.0	mg/L
Ammonia	12/31/25	Avg Mo	13.2	mg/L	6.0	mg/L
Total Phosphorus	07/31/25	Avg Mo	1.43	mg/L	1.0	mg/L
Total Phosphorus	11/30/25	Avg Mo	2.9	mg/L	1.0	mg/L
Total Phosphorus	09/30/25	Avg Mo	1.56	mg/L	1.0	mg/L
Total Phosphorus	10/31/25	Avg Mo	2.7	mg/L	1.0	mg/L
Total Phosphorus	12/31/25	Avg Mo	1.6	mg/L	1.0	mg/L
Total Phosphorus	05/31/25	Avg Mo	1.38	mg/L	1.0	mg/L

Other Comments: Effluent violations are considered significant.

**Table 1. 5-Year Inspection Summary**

<b>Client</b>	<b>Facility Name</b>	<b>Inspection Date</b>	<b>Inspection Type</b>	<b>Inspection Result</b>	<b>Inspector</b>	<b>No. of Violations</b>
NORMAN J CUTRI D/B/A TWILIGHT MHP	TWILIGHT MHP	02/03/2021	Administrative/File Review	Violation(s) Noted	OPILA, TAMI	1
NORMAN J CUTRI D/B/A TWILIGHT MHP	TWILIGHT MHP	03/15/2023	Compliance Evaluation	Violation(s) Noted	PUDLICK, DAN	3
NORMAN J CUTRI D/B/A TWILIGHT MHP	TWILIGHT MHP	06/07/2022	Administrative/File Review	Violation(s) Noted	BLOOM, KRYSTAL	1
TWILIGHT MHP LLC	TWILIGHT MHP	12/28/2023	Administrative/File Review	Violation(s) Noted	KING, WILLIAM	1
TWILIGHT MHP LLC	TWILIGHT MHP	09/11/2024	Administrative/File Review	Violation(s) Noted	KICHER, ERIC	2
TWILIGHT MHP LLC	TWILIGHT MHP	08/06/2024	Administrative/File Review	Violation(s) Noted	OPILA, TAMI	1
TWILIGHT MHP LLC	TWILIGHT MHP	08/20/2025	Administrative/File Review	Violation(s) Noted	RIOS MARTINEZ, WANDA	1

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.0175</u>
<b>Latitude</b> <u>41° 2' 54.56"</u>	<b>Longitude</b> <u>-80° 26' 5.36"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

**Table 2. Minimum Technology-Based and BPJ Standards for Individual Sewage Permits**

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Nitrogen	Report	Average Monthly	-	92a.61
Total Phosphorous	Report	Average Monthly	-	92a.61
E. Coli	Report	IMAX	-	92a.61

The above limits are minimum technology-based and BPJ standards for individual sewage permits which are found in the Department's "Establishing Effluent Limitations for Individual Sewage Permits" document (SOP. No. BCW-PMT-033). The limits for pH are technology-based on Chapter 93.7. The limits for Total Suspended Solids and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus are based on Chapter 92a.61.

E. Coli monitoring is established at 1/year as stated in the SOP for facilities with design flows between 0.002 and 0.5 MGD in this renewal.

A phosphorous limit of 1.0 mg/l will be retained in this renewal from the previous permit.

**Water Quality-Based Limitations**

**Table 3. Input Parameters**

<b>Outfall 001</b>	River Mile Index (RMI)	0.25
	Elevation (ft)	1107
	Drainage Area	0.18
	Yield	0.005
	Q7-10 Flow	0.001
<b>Endpoint</b>	River Mile Index (RMI)	0
	Elevation (ft)	1038
	Drainage Area	0.21
	Yield	0.006
	Q7-10 Flow	0.001

**Table 4. WQM 7 and TRC Spreadsheet Results**

Parameter	Limit (mg/l)	SBC	Model
CBOD5	25	Average Monthly	WQM 7
	50	IMAX	
NH3 - N	1.46	Average Monthly	
	2.92	Instantaneous Maximum	
DO	5	Daily Minimum	
TRC	0.014	Average Monthly	
	0.046	IMAX	

The parameters in Table 3 were found using Google Earth, StreamStats, and eMapPA. These parameters are used in the Department's Water Quality Modeling program (WQM 7) and TRC Spreadsheet to determine limits for CBOD5, NH3-N, Dissolved Oxygen, and TRC. Table 4 displays the results of these evaluations.

**CBOD5**

The attached results of the WQM 7.0 stream model (Attachment 5) indicate that a monthly average limit (AML) of 25 mg/L CBOD5 for summer months is required to protect the water quality of the stream. The recommended limits are consistent with the existing permit limits and will be retained in this renewal.

**NH3-N**

The attached results of the WQM 7.0 stream model (Attachment 5) are displayed above in Table 4. As per the Department's Permit Writer's Manual, rounding guidelines for conventional pollutants between 1.0 and 10.0 shall be rounded down to the nearest 0.5. Therefore, an average monthly limit (AML) of 1.0 mg/l and an IMAX limit of 2.5 mg/l are proposed in this renewal. A seasonal multiplier of 3 is applied to find a winter AML of 3.0 mg/L and an IMAX of 7.5 mg/L for the months of November through April. These limits are more stringent than the existing limits, and since the DMR reports indicate the facility currently cannot meet the new limits consistently, a 3-year compliance schedule has been implemented into the permit.

**DO**

The attached results of the WQM 7.0 stream model (Attachment 5) indicate that a minimum concentration of DO of 5 mg/l is required to protect water quality. The recommended limit is consistent with the existing permit limit and will be retained in this renewal.

**TRC**

The results of the TRC Spreadsheet are presented in Attachment 6 which indicate an AML of 0.014 mg/l and an IMAX limit of 0.046 mg/l. As per the Department's Permit Writer's Manual, rounding guidelines for pollutants between 0.01 and 0.1 shall be rounded down to the nearest 0.01. Therefore, an AML of 0.01 mg/l and an IMAX limit of 0.04 mg/l are proposed in this renewal. These limits are more stringent than the current permit limits (Table 5) and since the permittee does not demonstrate its ability to achieve these new limits a 3-year compliance schedule has been implemented into the permit.

These proposed AML is lower than the Quantitation Limit (QL), as defined in 25 Pa. Code § 252.1, of the most sensitive existing EPA-approved (40 CFR Part 136) test method or other DEP-approved method. A Part C condition has been added into the permit where if the sensitivity of the specified method improves or a more sensitive test method becomes available, DEP may modify the permit to require use of the more sensitive method. For the purpose of compliance, a statistical value reported on the DMR that is less than the QL (0.02 mg/l) will be considered to be in compliance.

**Anti-Backsliding**

**Table 5. Current Permit Effluent Limitations for Outfall 001**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	6.0	XXX	12	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	1.0	XXX	2	2/month	8-Hr Composite
TRC	XXX	XXX	XXX	0.02	XXX	0.06	1/day	Grab

Comments: More stringent limits are proposed for the highlighted items above. All other permit limitations, monitoring requirements, and conditions will be retained in the next permit with the addition of E. Coli monitoring.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Three Years After Permit Effective Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.02	XXX	0.06	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	6.0	XXX	12	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	1.0	XXX	2	2/month	8-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection

**Proposed Effluent Limitations and Monitoring Requirements**


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Three Years After Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.01	XXX	0.04	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	2.0	XXX	7.5	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	1.0	XXX	2.5	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	1.0	XXX	2	2/month	8-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection

Attachment 1  
eMapPA – Receiving Stream Designation and Location



**Attachment 2**  
**StreamStats Report – Outfall 001**

StreamStats Report

Region ID: PA  
 Clicked Point (Latitude, Longitude): 41.04953, -80.43981  
 Time: 2026-02-09 13:21:41 -0500



➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.18	square miles	2.26	1400
ELEV	Mean Basin Elevation	1153.4	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.00385	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.00803	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.000969	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.00235	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.00519	ft <sup>3</sup> /s


Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.

**Attachment 3**  
**StreamStats Report - Endpoint**

StreamStats Report

Region ID: PA  
 Clicked Point (Latitude, Longitude): 41.04874, -80.43316  
 Time: 2026-02-05 08:27:50 -0500



► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.21	square miles	2.26	1400
ELEV	Mean Basin Elevation	1134.6	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.00453	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.00936	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.00116	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.00278	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.00606	ft <sup>3</sup> /s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.

Attachment 4  
Google Earth – Aerial Site View



Image © 2026 Airbus

**Attachment 5  
WQM 7**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35853	Trib 35853 of Shenango River	0.250	1107.00	0.18	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.005	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Twilight MHP	PA0101087	0.0175	0.0175	0.0175	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35853	Trib 35853 of Shenango River	0.000	1038.00	0.21	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.006	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin	Stream Code	Stream Name
20A	35853	Trib 35853 of Shenango River

RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
-----	-------------------	----------------	-----------------------	--------------------------	---------------------	------------	------------	-----------	----------------	------------------------	--------------------	-------------

**Q7-10 Flow**

0.250 0.00 0.00 0.00 .0271 0.05227 .303 1.84 6.06 0.05 0.304 24.82 7.00

**Q1-10 Flow**

0.250 0.00 0.00 0.00 .0271 0.05227 NA NA NA 0.05 0.306 24.88 7.00

**Q30-10 Flow**

0.250 0.00 0.00 0.00 .0271 0.05227 NA NA NA 0.05 0.301 24.76 7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20A	35853	Trib 35853 of Shenango River

---

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.250	Twilight MHP	11.18	11.44	11.18	11.44	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.250	Twilight MHP	1.39	1.46	1.39	1.46	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.25	Twilight MHP	25	25	1.46	1.46	5	5	0	0

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	35853	Trib 35853 of Shenango River		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.250	0.018	24.822	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
1.838	0.303	6.060	0.050	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
24.18	1.494	1.41	1.015	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
5.116	29.839	Owens	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.304	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.030	22.85	1.36	5.64
	0.061	21.59	1.32	5.93
	0.091	20.41	1.28	6.11
	0.121	19.28	1.24	6.26
	0.152	18.22	1.21	6.38
	0.182	17.22	1.17	6.49
	0.212	16.27	1.13	6.59
	0.243	15.38	1.10	6.69
	0.273	14.53	1.07	6.78
	0.304	13.73	1.03	6.86

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20A	35853	Trib 35853 of Shenango River					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.250	Twilight MHP	PA0101087	0.018	CBOD5	25		
				NH3-N	1.46	2.92	
				Dissolved Oxygen			5



Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment 5)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment 6)