

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0101290
APS ID 1029888
Authorization ID 1338694

Applicant and Facility Information

Applicant Name	<u>Sandy Township Clearfield County</u>	Facility Name	<u>Sandy Township Main Sewer System STP</u>
Applicant Address	<u>PO Box 267</u> <u>DuBois, PA 15801-0267</u>	Facility Address	<u>163 Tannery Row Road</u> <u>DuBois, PA 15801</u>
Applicant Contact	<u>Shawn Arbaugh, Twp. Manager</u>	Facility Contact	<u>Matt Smith, Operator</u>
Applicant Phone	<u>(814) 371-4220</u>	Facility Phone	<u>(814) 590-3520</u>
Client ID	<u>78360</u>	Site ID	<u>251534</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Sandy Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Clearfield</u>
Date Application Received	<u>December 29, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 11, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit for an existing discharge of treated sewage</u>		

Summary of Review

The subject facility is a Publicly Owned Treatment Works (POTW) serving a portion of Sandy Township, Clearfield County.

A map of the discharge location is attached.

Sludge use and disposal description and location(s): The facility's sludge is transferred to other facilities for further processing. Per the application, 6.745 dry tons were produced in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	April 28, 2021
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	May 6, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.1</u>
Latitude	<u>41° 8' 39.45"</u>	Longitude	<u>-78° 47' 39.54"</u>
Quad Name	<u>Falls Creek, PA</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Wolf Run (CWF)</u>	Stream Code	<u>48728</u>
NHD Com ID	<u>123859394</u>	RMI	<u>0.6</u>
Drainage Area	<u>25.1 mi²</u>	Yield (cfs/mi ²)	<u>0.0526</u>
Q ₇₋₁₀ Flow (cfs)	<u>1.32</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>1394</u>	Slope (ft/ft)	<u>0.0019</u>
Watershed No.	<u>17-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Nearest Downstream Public Water Supply Intake	<u>Hawthorn Area Water Authority</u>		
PWS Waters	<u>Redbank Creek</u>	Distance from Outfall (mi)	<u>Approx. 53</u>

Changes Since Last Permit Issuance: None. The above stream and drainage characteristics were determined for the previous review and remain adequate.

Other Comments: No downstream water supply is expected to be affected by the discharge at this time with the limitations and monitoring proposed.

Treatment Facility Summary				
Treatment Facility Name: Sandy Township STP				
WQM Permit No.	Issuance Date	Permit For:		
1773403	A-1 - /3/74	Treatment plant, pump stations and collection system		
	A-2 - 6/14/17	Chlorine Removal		
WQG02171101	3/16/11	Pump Station		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Contact Stabilization	Chlorine With Dechlorination	0.1
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.1	270	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: WQM Permit Amendment No. 1773403 Amendment No. 2 for chlorine removal was approved in 2017 to address more TRC stringent limits in the previous NPDES renewal.

Other Comments: The treatment plant, as authorized by WQM Permit No. 1773403 is a contact stabilization process that consists of bar screen, comminutor, two aeration tanks, one clarifier, chlorination with contact tank, dechlorination, and aerobic digester.

Trucked-In Waste
The facility has not received any hauled-in waste in the past three years and does not anticipate receiving hauled-in waste during the next permit term.

Compliance History

DMR Data for Outfall 001 (from March 1, 2020 to February 28, 2021)

Parameter	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20
Flow (MGD) Average Monthly	0.025	0.028	0.029	0.028	0.028	0.027	0.035	0.03	0.032	0.029	0.03	0.040
Flow (MGD) Daily Maximum	0.045	0.046	0.057	0.037	0.053	0.056	0.061	0.05	0.079	0.045	0.045	0.071
pH (S.U.) Minimum	7.3	7.3	7.2	7.1	7.41	7.4	6.8	7.1	7.3	7.5	7.4	7.2
pH (S.U.) Maximum	7.5	7.6	7.8	7.6	7.71	7.9	7.8	7.8	7.7	7.8	7.8	7.7
DO (mg/L) Minimum	4.13	4.44	3.55	2.87	4.28	4.61	4.14	3.83	4.25	4.98	4.99	3.58
TRC (mg/L) Average Monthly	0.06	0.05	0.04	0.1	0.03	0.07	0.03	0.05	0.03	0.02	0.03	0.03
TRC (mg/L) Instantaneous Maximum	0.33	0.19	0.16	0.9	0.1	0.52	0.11	0.48	0.1	0.07	0.12	0.12
CBOD5 (lbs/day) Average Monthly	< 0.7	1	1	2	1	< 0.9	2	4	12	0.9	3	< 1
CBOD5 (lbs/day) Weekly Average	0.9	2	2	2	2	2	3	9	42	1	9	2
CBOD5 (mg/L) Average Monthly	< 5	5	6	8	6	< 4	6	17	27	4	12	< 4
CBOD5 (mg/L) Weekly Average	6	7	10	11	8	7	9	34	64	5	28	9
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	47	46	42	43	71	68	68	61	117	70	79	53
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	64	63	61	49	80	86	92	67	223	103	136	53
BOD5 (mg/L) Raw Sewage Influent Average Monthly	309	205	191	202	352	321	235	303	403	311	271	160
TSS (lbs/day) Average Monthly	0.6	< 0.8	< 0.09	1	1	1	3	4	6	0.9	< 1	< 0.7
TSS (lbs/day) Raw Sewage Influent Average Monthly	25	36	30	30	39	43	46	35	40	34	52	26

**NPDES Permit Fact Sheet
Sandy Township Main Sewer System STP**

NPDES Permit No. PA0101290

TSS (lbs/day) Raw Sewage Influent Daily Maximum	45	54	54	57	50	71	67	65	90	37	80	32
TSS (lbs/day) Weekly Average	0.7	2	1	2	3	2	5	8	17	1	1	0.8
TSS (mg/L) Average Monthly	4	< 3	< 4	4	6	6	12	19	19	4	< 4	< 3
TSS (mg/L) Raw Sewage Influent Average Monthly	164	169.3	134.9	147	192	199	158	162	130	153	177	100
TSS (mg/L) Weekly Average	5	5	5	6	12	9	21	32	26	5	5	3
Fecal Coliform (CFU/100 ml) Geometric Mean	< 5	10	10	< 1	< 2	< 2	< 1	< 4	< 10	< 1	< 1	< 3
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	21.6	345.2	98.8	2	22.6	29.2	1	23.1	2419.6	4.1	< 1	28.8
Ammonia (lbs/day) Average Monthly	0.5	0.5	0.6	0.7	0.6	< 2.0	10.0	< 4.0	8.0	3.0	4	3
Ammonia (mg/L) Average Monthly	3.196	2.084	1.556	3.48	3.23	< 7.0	37.4	< 19.5	24.14	12.4	13.42	12.745

Compliance History

Effluent Violations for Outfall 001, from: March 1, 2020 To: February 28, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
CBOD5	06/30/20	Wkly Avg	42	lbs/day	33	lbs/day
CBOD5	06/30/20	Avg Mo	27	mg/L	25	mg/L
CBOD5	06/30/20	Wkly Avg	64	mg/L	40	mg/L
Fecal Coliform	06/30/20	IMAX	2419.6	CFU/100 ml	1000	CFU/100 ml
Ammonia	07/31/20	Avg Mo	< 19.5	mg/L	18.5	mg/L
Ammonia	06/30/20	Avg Mo	24.14	mg/L	18.5	mg/L
Ammonia	08/31/20	Avg Mo	37.4	mg/L	18.5	mg/L

Compliance History, Cont'd

Summary of Inspections:	The facility has been inspected at least annually by the Department over the past permit term. The most recent inspection on October 15, 2020 identified effluent violations but no operation violations at the time of inspection.
Other Comments:	A query in WMS found no open violations for Sandy Township, Clearfield County in eFACTS. The Township received an NOV on January 16, 2019 as a result of effluent violations.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	21	33	XXX	25.0	40.0	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	25	38	XXX	30.0	45.0	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/year	8-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	15.4	XXX	XXX	18.5	XXX	XXX	1/week	8-Hr Composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/year	8-Hr Composite

Development of Effluent Limitations

Outfall No. 001
Latitude 41° 8' 39.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.1
Longitude -78° 47' 41.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above applicable requirements are included in the existing permit and will remain.

Water Quality-Based Limitations

CBOD₅, NH₃-N, and DO

The discharge has an existing water quality-based May through October limit for ammonia-nitrogen of 18.5 mg/L.

The WQM7 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. The current model includes recent updates to the NH₃-N criteria in Chapter 93. WQM7.0 modeling was performed (see Attachment B) for the discharge to Wolf Run and indicated that the existing secondary limit for CBOD listed above and the current summer NH₃-N limit of 18.5 mg/L are adequate to protect the receiving stream. The model did indicate that DO levels are continuing to decline at the end of the reach but the end of the reach is the confluence with Sandy Lick Creek which will provide adequate additional dilution. No limitations should be necessary for the rest of the year given the additional stream flow and lower temperatures typical for the rest of the year.

Total Residual Chlorine

The BAT limit of 0.5 mg/L from 25 PA Code 92a.48 is included in the existing permit. The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's TRC in a receiving stream, accounting for available dilution. The attached results of the TRC spreadsheet from the previous review (see Attachment C) show that the technology-based limit of 0.5 mg/l is adequate to protect the receiving stream.

Nutrient Monitoring

Annual nutrient monitoring was included in the existing permit. The average Total Nitrogen over the past permit term was 19.8 mg/L and the average Total Phosphorus was 1.75 mg/L. Therefore, because the average nutrient load from the facility has been characterized no further monitoring for TN and TP will be required at this time.

Toxics Management

No further "Reasonable Potential Analysis" was performed for this minor municipal sewage facility to determine additional toxic parameters as candidates for limitations or monitoring.

Best Professional Judgment (BPJ) Limitations

Comments: No additional BPJ limits are necessary beyond the technology and water quality-based limits noted above.

Anti-Backsliding

No limitations have been made less stringent consistent with the anti-degradation requirements of the Clean Water Act and 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	21	33	XXX	25.0	40.0	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	25	38	XXX	30.0	45.0	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	15.4	XXX	XXX	18.5	XXX	XXX	1/week	8-Hr Composite



Compliance Sampling Location: Outfall 001

Other Comments: Total Nitrogen and Total Phosphorus monitoring have been removed from the proposed permit as noted above.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 8/23/13
<input type="checkbox"/>	Other: [redacted]

Attachments:

- Discharge Location Map
- WQM7.0 Model
- TRC Model



Permit No. PA0101290

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17C	48728	WOLF RUN	0.600	1394.00	25.10	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.053	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Sandy Twp	PA0101290	0.1000	0.0000	0.0000	0.000	25.00	7.50

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	18.50	0.00	0.00	0.70

Permit No. PA0101290

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17C	48728	WOLF RUN	0.000	1388.00	25.20	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.053	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
17C	48728	WOLF RUN										
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
0.600	1.33	0.00	1.33	.1547	0.00189	.577	21.61	37.43	0.12	0.308	20.52	7.03
Q1-10 Flow												
0.600	0.85	0.00	0.85	.1547	0.00189	NA	NA	NA	0.10	0.383	20.77	7.05
Q30-10 Flow												
0.600	1.81	0.00	1.81	.1547	0.00189	NA	NA	NA	0.14	0.263	20.39	7.02

Permit No. PA0101290

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
17C	48728	WOLF RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.600	Sandy Twp	15.05	37	15.05	37	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.600	Sandy Twp	1.82	18.5	1.82	18.5	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.60	Sandy Twp	25	25	18.5	18.5	3	3	0	0

Permit No. PA0101290

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
17C	48728	WOLF RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.600	0.100	20.521		7.032
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
21.610	0.577	37.433		0.119
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
4.40	0.801	1.93		0.729
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
7.697	2.169	Tsivoglou		6
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.308	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.031	4.29	1.88	7.44
	0.062	4.18	1.84	7.20
	0.092	4.08	1.80	6.99
	0.123	3.97	1.76	6.80
	0.154	3.87	1.72	6.63
	0.185	3.78	1.68	6.48
	0.216	3.68	1.65	6.35
	0.246	3.59	1.61	6.23
	0.277	3.50	1.57	6.12
	0.308	3.41	1.54	6.03

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			<u>Eff. Limit 30-day Ave. (mg/L)</u>	<u>Eff. Limit Maximum (mg/L)</u>	<u>Eff. Limit Minimum (mg/L)</u>
17C	48728	WOLF RUN					
<u>RMI</u>	<u>Name</u>	<u>Permit Number</u>	<u>Disc Flow (mgd)</u>	<u>Parameter</u>			
0.600	Sandy Twp	PA0101290	0.100	CBOD5	25		
				NH3-N	18.5	37	
				Dissolved Oxygen			3

Permit No. PA0101290

TRC EVALUATION						
Client			Date			
1.32 = Q stream (cfs)			0.5 = CV Daily			
0.1 = Q discharge (MGD)			0.5 = CV Hourly			
30 = no. samples			0.972 = AFC_Partial Mix Factor			
0.3 = Chlorine Demand of Stream			1 = CFC_Partial Mix Factor			
0 = Chlorine Demand of Discharge			15 = AFC_Criteria Compliance Time (min)			
0.5 = BAT/BPJ Value			720 = CFC_Criteria Compliance Time (min)			
= % Factor of Safety (FOS)			0 = Decay Coefficient (K)			
Source	Reference	AFC Calculations		Reference	CFC Calculations	
TRC	1.3.2.iii	WLA_afc =	2.665	1.3.2.iii	WLA_cfc =	2.665
PENTOXSD TRG	5.1a	LTAMULT_afc =	0.373	5.1c	LTAMULT_cfc =	0.581
PENTOXSD TRG	5.1b	LTA_afc =	0.993	5.1d	LTA_cfc =	1.549
		WQBEL_afc =	1.222		WQBEL_cfc =	1.907
Source		Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML MULT = 1.231				
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ		
		INST MAX LIMIT (mg/l) = 1.635				
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...]$ $...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$					
LTA_afc	wla_afc*LTAMULT_afc					
WLA_cfc	$(.011/e(-k*CFC_tc) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...]$ $...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$					
LTA_cfc	wla_cfc*LTAMULT_cfc					
AML_MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$					
AVG_MON_LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)					
INST_MAX_LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$					