

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0101702  
 APS ID 1023881  
 Authorization ID 1328131

**Applicant and Facility Information**

Applicant Name	<u>Rocky Ridge Village LLC</u>	Facility Name	<u>Rocky Ridge Village MHP</u>
Applicant Address	<u>156 Maple Grove Circle</u> <u>Franklin, PA 16323-3662</u>	Facility Address	<u>Washington Boulevard</u> <u>Franklin, PA 16323</u>
Applicant Contact	<u>Ryan Williams</u>	Facility Contact	<u>Ryan Williams</u>
Applicant Phone	<u>(814) 516-5900</u>	Facility Phone	<u>(814) 516-5900</u>
Client ID	<u>307509</u>	Site ID	<u>239527</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Sandycreek Township</u>
Connection Status		County	<u>Venango</u>
Date Application Received	<u>September 1, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 30, 2020</u>	If No, Reason	
Purpose of Application	<u>Renewal of an NPDES Permit for an existing discharge of treated sewage.</u>		

**Summary of Review**

The permittee is currently registered for and is using the eDMR system for reporting.

No changes to the permit were proposed by the permittee as part of this renewal.

There is currently one open violation for this permittee in EFACTS (11/01/2021), for a plant operator not being fully certified, and for failure to maintain calibration reports per the NOV dated 02/13/2020 and mailed to the permittee.

The existing facility predates the watershed designation as Exceptional Value (EV), and as the plant's treatment discharge quantity and treatment process remains unchanged. Therefore, anti-degradation requirements are satisfied by continuing to model the discharge as being to a WWF.

Sludge use and disposal description and location(s): Hauled offsite.

Due to ongoing compliance issues, daily monitoring for pH, TRC, and DO is proposed in the draft permit. The previous permit relaxed the monitoring for these parameters to 4/week.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Civil Engineer Trainee	November 1, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	November 2, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.015</u>
Latitude	<u>41° 20' 5.97"</u>	Longitude	<u>-79° 51' 5.59"</u>
Quad Name	<u>Kenderell</u>	Quad Code	<u>41079C7</u>
Wastewater Description: <u>Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Ditzenberger Run (EV - existing use)</u>	Stream Code	<u>51324</u>
NHD Com ID	<u>100478185</u>	RMI	<u>0.4</u>
Drainage Area	<u>0.0361</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.001</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0 dry stream / 0.06 perennial reach</u>	Q <sub>7-10</sub> Basis	<u>Previous model</u>
Elevation (ft)	<u>1360</u>	Slope (ft/ft)	<u>0.18227</u>
Watershed No.	<u>16-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>EV (EXCEPTIONAL VALUE)</u>	Existing Use Qualifier	<u>RBP - Antidegradation</u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	<u></u>
Temperature (°F)	<u>20</u>	Default	<u></u>
Hardness (mg/L)	<u>100</u>	Default	<u></u>
Other: NH <sub>3</sub> -N	<u>0.1</u>	Default	<u></u>
Nearest Downstream Public Water Supply Intake	<u>Aqua Pennsylvania, Inc. - Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1376</u>
PWS RMI	<u>90.0</u>	Distance from Outfall (mi)	<u>24.3</u>

Changes Since Last Permit Issuance: None.

Other Comments: DEP has evaluated information indicating that the existing use of the receiving waters is different than the designated use under 25 Pa. Code § 93.9. In developing the draft NPDES permit, DEP is proposing to protect the existing use of the receiving waters. Following DEP's notice of the receipt of the application and the draft permit in the Pennsylvania Bulletin, DEP will accept written comments during the public comment period regarding DEP's tentative determination to protect the existing use. DEP will make a final determination on existing use protection for the receiving waters as part of the final permit action.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Rocky Ridge Village MHP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6176401 T-2		12/19/2013		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration With Solids Removal	No Disinfection	0.0125
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0125	30.3	Not Overloaded		

Changes Since Last Permit Issuance: The existing facility predates the watershed designation as Exceptional Value (EV), and as the plant's treatment process remains unchanged, current anti-degradation limits associated with an EV discharge are not applied as the limits associated with a WWF discharge should be protective.

Other Comments: None.

Compliance History

DMR Data for Outfall 001 (from October 1, 2020 to September 30, 2021)

Parameter	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20
Flow (MGD) Average Monthly	0.00667	0.00654	0.0065	0.0068	0.00647 5	0.00657 5	0.00638	0.0078	0.00777 5	0.00804	0.00727	0.00825
Flow (MGD) Daily Maximum	0.0063	0.0075	0.0072	0.0079	0.0073	0.0069	0.0069	0.0085	0.0071	0.0085	0.0079	0.0099
pH (S.U.) Minimum	6.8	6.8	6.7	6.6	6.6	6.7	6.5	6.7	6.8	6.7	6.7	6.5
pH (S.U.) Maximum	7.2	7.4	7.4	7.1	7.1	7.1	7.2	7.2	7.4	7.3	7.3	7.2
DO (mg/L) Minimum	7.0	6.9	7.0	6.8	7.0	6.9	6.8	7.0	7.0	7.0	7.0	6.8
TRC (mg/L) Average Monthly	0.245	0.187	0.2105	0.205	0.212	0.194	0.175	0.20	0.208	0.215	0.225	0.22
TRC (mg/L) Instantaneous Maximum	0.37	0.29	0.37	0.31	0.31	0.29	0.24	0.26	0.32	0.31	0.36	0.31
CBOD5 (mg/L) Average Monthly	3.1	3	3	9.3	3.35	7.15	5.8	6.55	3	3.3	12.35	3.7
TSS (mg/L) Average Monthly	3	3.5	6	3	5.5	11	6	8.5	3	6	3	3.5
Fecal Coliform (CFU/100 ml) Geometric Mean	1	49.19	1	1	1	1	49.19	1	1	1	1.414	20.27
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	1	2420	1	1	1	1	2420	1	1	1	2	411
Total Nitrogen (mg/L) Annual Average										9.39		
Ammonia (mg/L) Average Monthly	3.955	6.925	0.395	5.875	12.6	6.1	7.58	6.2	3.42	4.53	5.23	5.915
Total Phosphorus (mg/L) Annual Average										1.23		

**Compliance History**

**Effluent Violations for Outfall 001, from: November 1, 2020 To: September 30, 2021**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	08/31/21	IMAX	2420	CFU/100 ml	1000	CFU/100 ml
Ammonia	05/31/21	Avg Mo	12.6	mg/L	6.5	mg/L
Ammonia	08/31/21	Avg Mo	6.925	mg/L	6.5	mg/L

Summary of Inspections: There is currently one open violation for this permittee in EFACTS (11/01/2021), for a plant operator not being fully certified, and for failure to maintain calibration reports per the NOV dated 02/13/2020 and mailed to the permittee.

Other Comments: None.

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.015</u>
<b>Latitude</b> <u>41° 20' 6.00"</u>	<b>Longitude</b> <u>-79° 51' 6.00"</u>
<b>Wastewater Description:</b> <u>Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: None.

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia Nitrogen	6.5	Average Monthly	WQM 7.1b

Comments: New modeling indicated a limit of 8.7 mg/l as an average monthly is protective; however the existing limit will remain due to anti-backsliding provisions. Seasonal multiplier of 3 was used for the wintertime limit in accordance with the Department’s SOP entitled “Establishing Effluent Limitations for Individual Sewage Permits.”

The calculated WQBEL for TRC at the start of the perennial reach is 0.463 mg/L. Given that the discharge is on a dry stream reach approximately 0.4-miles from the perennial stream, TRC levels are expected to be well below the 0.463 mg/L if the discharge effluent limitation is set at the technology-based limitation of 0.5 mg/L.

**Best Professional Judgment (BPJ) Limitations**

Comments: A dissolved oxygen limit of a minimum of 4.0 mg/l and monitoring for total nitrogen and total phosphorus are placed in the permit in accordance with the Department’s SOP entitled “Establishing Effluent Limitations for Individual Sewage Permits.”

**Anti-Backsliding**

The TRC IMAX limit of 1.2 mg/l is being retained for this discharge due to anti-backsliding provisions. It is based on a sampling frequency of 4/month (previous sampling frequency).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.2	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	20	XXX	40	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	6.5	XXX	13	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: E. Coli limit added per PADEP SOP for Establishing Effluent Limitations in Individual Sewage Permits.

## eMAP with Aerial Imagery and Stream Existing Use Information

The screenshot displays the Pennsylvania eMAP web application interface. At the top, the Pennsylvania Department of Environmental Protection logo is on the left, and navigation links for PA STATE AGENCIES, ONLINE SERVICES, Tom Wolf, Governor, Patrick McDonnell, and DEP Home are on the right. The main interface includes a legend on the left, a map area in the center, and a data popup window on the right.

**Legend:**

- Regulated Facilities and Related Information
- Streams and Water Resources
  - Water Quality
    - Existing Use Streams
      - Cold Water Fish
      - Exceptional Value
      - High Quality
      - Trout Stocking
      - Warm Water Fish
      - Overlap
    - Designated Use Streams
      - Cold Water Fish
      - Exceptional Value
      - High Quality
      - Trout Stocking
      - Warm Water Fish
      - Overlap
      - Missing from CH93
  - Boundaries
    - County Boundaries
    - Municipalities

**Map Area:** The map shows aerial imagery with stream segments overlaid. A popup window titled "Existing Use Streams (1 of 4)" is open, displaying the following information:

- Existing Use Gen ID: 1281
- GNIS Name:
- GNIS ID:
- ReachCode: 05010003003379
- COMID: 100478185
- Length Miles: 0.425
- Use Description: EV(EXCEPTIONAL VALUE)
- Qualifier: RBP - Antidegradation
- Migratory\_Fish: N
- HUC: 05010003
- Basin: Y
- Basin Narrative: This is a BASIN delineation. It includes ALL tributaries draining into the stream segment described below. The stream code listed below is that of the mainstem. The stream codes of the tributaries are not listed.
- Segment Narrative: Ditzenberger Run Basin
- Map Symbology: EV
- Evaluation Date: 0/13/2011
- Zoom to

**Locate Latitude and Longitude:** A form on the right side of the map area allows for entering coordinates. It shows Latitude: 41 20 6 and Longitude: -79 51 6.

**Scale:** A scale bar at the bottom left of the map area indicates 0, 0.1, and 0.2 miles.

**Imagery Source:** Imagery Source: Esri, Maxar, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community; ESRI Streets: Sources: Esri, HERE, Garmin, USGS, Intermap, INCREMENT P, NRCan, Esri Japan, METI, Esri China (Hong Kong), Esri Korea, Esri (Thailand), NGCC, (c) OpenStreetMap contributors, and the GIS User Community.



DRY STREAM REACH

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16G	51324	Trib 51324 to Ditzenberger Run	0.400	1364.00	0.01	0.00000	0.00	<input type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	6.90	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Rocky Ridge	PA0101702	0.0125	0.0125	0.0125	0.000	20.00	6.90

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16G	51324	Trib 51324 to Ditzenberger Run	0.010	960.00	0.24	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	6.90	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16G		51324				Trib 51324 to Ditzenberger Run						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.400	0.00	0.00	0.00	.0193	0.19619	.389	.58	1.49	0.09	0.277	20.00	6.90
<b>Q1-10 Flow</b>												
0.400	0.00	0.00	0.00	.0193	0.19619	NA	NA	NA	0.09	0.277	20.00	6.90
<b>Q30-10 Flow</b>												
0.400	0.00	0.00	0.00	.0193	0.19619	NA	NA	NA	0.09	0.277	20.00	6.90

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16G	51324	Trib 51324 to Ditzenberger Run

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.400	Rocky Ridge	NA	50	18.18	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.400	Rocky Ridge	NA	25	1.95	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.40	Rocky Ridge	25	25	25	25	6	6	0	0

**WQM 7.0 D.O. Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
16G	51324	Trib 51324 to Ditzenberger Run	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
0.400	0.012	20.000	6.900
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
0.578	0.389	1.485	0.086
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
24.99	1.500	24.99	0.700
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
6.001	24.094	Owens	NA
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>		
0.277	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.028	23.97	24.51
	0.055	23.00	24.04
	0.083	22.06	23.58
	0.111	21.17	23.12
	0.138	20.31	22.68
	0.166	19.48	22.25
	0.194	18.69	21.82
	0.221	17.93	21.40
	0.249	17.20	20.99
	0.277	16.50	20.59

TRAVEL TIME TO ENTER INTO NH3-N DECAY CALCULATION

INPUT INTO PERENNIAL MODEL

PERENNIAL REACH

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
16G		51324		Trib 51324 to Ditzenberger Run			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.400	Rocky Ridge	PA0101702	0.013	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			6

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16G	51322	SANDY CREEK	0.500	980.00	1.56	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.038	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Rocky Ridge 2	PA0101702_2	0.0125	0.0125	0.0125	0.000	20.00	6.90

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	16.50	2.00	0.00	1.50
Dissolved Oxygen	4.70	7.54	0.00	0.00
NH3-N	20.59	0.10	0.00	0.70

**FROM DRY REACH MODEL**



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16G	51322	SANDY CREEK	0.260	935.00	1.59	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.038	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16G		51322				SANDY CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.500	0.06	0.00	0.06	.0193	0.03551	.348	4.19	12.02	0.05	0.272	23.77	6.97
<b>Q1-10 Flow</b>												
0.500	0.04	0.00	0.04	.0193	0.03551	NA	NA	NA	0.05	0.325	23.31	6.96
<b>Q30-10 Flow</b>												
0.500	0.08	0.00	0.08	.0193	0.03551	NA	NA	NA	0.06	0.238	24.03	6.98

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16G	51322	SANDY CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.500	Rocky Ridge 2	13.14	38.72	13.14	38.72	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.500	Rocky Ridge 2	1.47	7.16	1.47	7.16	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.50	Rocky Ridge 2	16.5	16.5	7.16	7.16	4.7	4.7	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
16G	51322	SANDY CREEK	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
0.500	0.012	23.770	6.973
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
4.185	0.348	12.021	0.054
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
5.57	1.017	1.84	0.936
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
6.841	23.636	Owens	6
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>		
0.272	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.027	5.39	1.79
	0.054	5.21	1.75
	0.082	5.04	1.70
	0.109	4.88	1.66
	0.136	4.72	1.62
	0.163	4.57	1.58
	0.190	4.42	1.54
	0.217	4.28	1.50
	0.245	4.14	1.46
	0.272	4.01	1.42

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
16G		51322		SANDY CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.500	Rocky Ridge 2	PA0101702_2	0.013	CBOD5	16.5		
				NH3-N	7.16	14.32	
				Dissolved Oxygen			4.7

$$C_T = C_0 e^{-kt}$$

$$C_0 = 7.16 e^{(0.7)(0.277)}$$

$$C_0 = 8.7 \text{ mg/L}$$

CBOD5 and DO limits are the same as the inputs from the dry reach model. Therefore, 25 mg/L CBOD5 and 4.0 mg/L DO are acceptable limits.

**TRC Evaluation at Perennial Conditions (~ 0.4 miles downstream of discharge)**

1A	B	C	D	E	F	G
2	<b>TRC EVALUATION</b>					
3	Input appropriate values in B4:B8 and E4:E7					
4	0.06	= Q stream (cfs)		0.5	= CV Daily	
5	0.0125	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations		Reference	CFC Calculations
11	TRC	1.3.2.iii	WLA_afc = 1.009		1.3.2.iii	WLA_cfc = 0.976
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
13	PENTOXSD TRG	5.1b	LTA_afc = 0.376		5.1d	LTA_cfc = 0.567
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.463		AFC	
18			INST MAX LIMIT (mg/l) = 1.513			
	WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
	LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
	LTA_afc	wla_afc * LTAMULT_afc				
	WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
	LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
	LTA_cfc	wla_cfc * LTAMULT_cfc				
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
	AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
	INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				