

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0101940
 APS ID 1023097
 Authorization ID 1326730

Applicant and Facility Information

Applicant Name	<u>Andrew Narlee</u>	Facility Name	<u>Country Estates MHP</u>
Applicant Address	<u>5676 State Route 308</u> <u>Kennerdell, PA 16374</u>	Facility Address	<u>5676 State Route 308</u> <u>Kennerdell, PA 16374</u>
Applicant Contact	<u>Andrew Narlee</u>	Facility Contact	<u>Andrew Narlee</u>
Applicant Phone	<u>(724) 301-1042</u>	Facility Phone	<u>(724) 301-1042</u>
Client ID	<u>145338</u>	Site ID	<u>447242</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Clinton Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Venango County</u>
Date Application Received	<u>August 25, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 11, 2020</u>	If No, Reason	<u>-</u>

Purpose of Application Renewal of an NPDES permit for an existing discharge of treated Sewage. This application also amends the NPDES Permit to increase the permitted flow from 0.0105 MGD to 0.017 MGD.

Summary of Review

Act 14 - Proof of Notification was submitted and received.
 A Part II Water Quality Management permit is not required at this time.
 The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into Sewers
- B. Right of Way
- C. Solids Handling
- D. Public Sewerage Availability
- E. Effluent Chlorine Optimization and Minimization
- F. Little or No Assimilative Capacity or Dilution

SPECIAL CONDITIONS:

- II. Solids Management
- III. Compliance Schedule for Ammonia-Nitrogen (NH3-N)

There are no open violations in effects for Client ID 145338 as of 8/5/2021.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	8/5/2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	9/1/2021

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.017</u>
Latitude	<u>41° 14' 40.7"</u>	Longitude	<u>-79° 53' 39.2"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Trout Run (CWF)</u>	Stream Code	<u>51257</u>
NHD Com ID	<u>100479497</u>	RMI	<u>2.21</u>
Drainage Area	<u>0.21 (dry), 0.52 (perennial)</u>	Yield (cfs/mi ²)	<u>0.1 (default)</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.021</u>	Q ₇₋₁₀ Basis	<u>calculated</u>
Elevation (ft)	<u>1417</u>	Slope (ft/ft)	<u>0.03348</u>
Watershed No.	<u>16-G</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Impaired*</u>		
Cause(s) of Impairment	<u>Metals and pH</u>		
Source(s) of Impairment	<u>Acid Mine Drainage</u>		
TMDL Status	<u>Final, 5/19/2008</u>	Name	<u>Scrubgrass Creek Watershed</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Aqua Pennsylvania, Inc. - Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1,375</u>
PWS RMI	<u>90.0</u>	Distance from Outfall (mi)	<u>215</u>

* - There is a TMDL for AMD-related pH and metals including Aluminum, Iron, and Manganese. Due to the TMDL, monitoring was previously set for Aluminum, Iron, and Manganese, which will be retained with this renewal.

Sludge use and disposal description and location(s): Sludge is not used, it is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an increase in discharge flow from 0.0105 MGD to 0.017 MGD of treated sewage from an existing MHP in Clinton Township, Venango County

Treatment permitted under WQM Permit 6174404 consists of: Two facultative flow through treatment ponds in series, tablet chlorine disinfection with a chlorine contact tank, and dechlorination.

1. Streamflow:

Unnamed Tributary to the Trout Run at Outfall 001:

Yieldrate:	<u>0.1</u>	cfsm	Default used in absence of Stream Gage
Drainage Area:	<u>0.21</u>	sq. mi.	(USGS StreamStats)
Q ₇₋₁₀ :	<u>0.021</u>	cfs	calculated
% of stream allocated:	<u>100%</u>	Basis:	No nearby discharges

2. Wasteflow:

Maximum discharge: 0.017 MGD = 0.026 cfs

Runoff flow period: 24 hours Basis: Runoff flow for a pond-based STP

There is less than 3 parts stream flow (Q7-10) to 1 part effluent (design flow). In accordance with the SOP, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were evaluated for this facility. Since this is an existing discharge (with an increased design flow based on an engineering evaluation of the existing treatment), the more stringent treatment requirements cannot be achieved, and the receiving stream is not impaired by the discharge, the standards in DEP guidance (391-2000-014) will not be applied.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH₃-N, CBOD₅, Dissolved Oxygen, and Total Residual Chlorine.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits. The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

b. Total Suspended Solids

Limits are 30 mg/l as a monthly average and 60 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP.

e. Phosphorus

- Limit necessary due to:
- Discharge to lake, pond, or impoundment
 - Discharge to stream

Basis: N/A

- Limit not necessary

Basis: Chapter 96.5 does not apply. However, the Total Phosphorus monitoring requirement will be retained as recommended by the SOP to provide data for review during the next renewal application to ensure the discharge is not high in nutrients.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 7.3 Standard Units (S.U.)

Basis: eDMR data

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background NH₃-N concentration: 0.1 mg/l

Basis: Default value.

Calculated NH₃-N Summer limits: 10.9 mg/l (monthly average)
21.8 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1). The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern,

they will be used. Due to the increase in the design flow, the calculated limits are more restrictive than the previous permit. Based on the renewal application and the eDMR data, the new limits may not be attainable, so the three year compliance schedule for water quality-based limits will be included.

h. CBOD₅

Median discharge pH to be used: 7.3 Standard Units (S.U.)

Basis: eDMR data

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value

CBOD₅ Summer limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

CBOD₅ Winter limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1), which are the same as in the previous permit. The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern, they will be used. Since the summer and winter limits are technology-based, per the SOP, the year-round limit of 25.0 mg/l monthly average and 50.0 mg/l instantaneous maximum will be retained with this renewal.

i. Dissolved Oxygen (DO)

3.0 mg/l - minimum required due to discharge going to a drainage swale or ditch.

4.0 mg/l - minimum desired in effluent to protect all aquatic life.

5.0 mg/l - desired in effluent for Warm Water / Trout-Stocked Fisheries.

6.0 mg/l - desired in effluent for Cold Water Fisheries.

7.0 mg/l - required due to discharge going to a High Quality / Exceptional Value stream

8.0 mg/l - required due to discharge going to a naturally reproducing salmonid stream

Discussion: The Dissolved Oxygen minimum of 4.0 mg/l will be retained with this renewal. The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61. The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

j. Total Residual Chlorine (TRC)

No limit necessary

Basis: N/A

- TRC limits: 0.29 mg/l (monthly average)
0.97 mg/l (instantaneous maximum)

Basis: The TRC limits above are water quality-based using the TRC Calc Spreadsheet at the first point of perennial conditions (see Attachment 2). Due to the increase in the design flow, the calculated limits are more restrictive than the previous permit. Based on eDMR data, the new limits should be attainable, so a compliance schedule will not be necessary. The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

4. Reasonable Potential Analysis for Receiving Stream:

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

5. Reasonable Potential for Downstream Public Water Supply (PWS):

The Reasonable Potential Analysis performed above does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no data was provided, mass-balance calculations were not able to be performed.

Nearest Downstream potable water supply (PWS): Aqua Pennsylvania, Inc. - Emlenton

Distance downstream from the point of discharge: 215 miles (approximate)

- No limits necessary
 Limits needed

Basis: Significant dilution available.

6. Anti-Backsliding:

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

7. Attachment List:

Attachment 1 - WQ Modeling Printouts

Attachment 2 - TRC_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from July 1, 2020 to June 30, 2021)

Parameter	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20
Flow (MGD) Average Monthly			0.012			0.012	0.01		0.012	0.012		
pH (S.U.) Minimum			7.2			7.2	7.3		7.1	6.9		
pH (S.U.) Maximum			7.5			7.5	7.5		7.6	7.7		
DO (mg/L) Minimum			4.8			5.23	5.21		4.51	4.21		
TRC (mg/L) Average Monthly			0.04			0.088	0.04		0.07	0.11		
TRC (mg/L) Instantaneous Maximum			0.26			0.26	0.21		0.34	0.31		
CBOD5 (mg/L) Average Monthly			5.3			3.2	< 4.3		6.25	5.3		
CBOD5 (mg/L) Instantaneous Maximum			6.3			3.2	5.6		8.6	5.3		
TSS (mg/L) Average Monthly			< 3.5			9	17		7.5	27		
TSS (mg/L) Instantaneous Maximum			4			9	20		12	32		
Fecal Coliform (CFU/100 ml) Geometric Mean			< 1			130	508		2.24	< 1		
Fecal Coliform (CFU/100 ml) Instantaneous Maximum			1			130	1986		3	1		
Total Nitrogen (mg/L) Average Monthly			7.9			33.42	14.7		14.95	12.83		
Ammonia (mg/L) Average Monthly			4.1			9.97	10		10.95	7.9		
Total Phosphorus (mg/L) Average Monthly			0.9			1.22	1.13		1.37	1.2		

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through September 30, 2024.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Weir
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.29	XXX	0.97	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are technology based on Chapter 92a.47. The limits for CBOD5, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for E. Coli, Total Nitrogen, Ammonia-Nitrogen, and Total Phosphorus is based on Chapter 92a.61.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: October 1, 2024 through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Weir
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.29	XXX	0.97	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	10.9	XXX	21.8	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are water quality-based on Chapter 93.7. The limits for CBOD5, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7.

Attachment 1

WQM 7.0 Effluent Limits (Perennial Reach Model)

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
16G		51257	TROUT RUN				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.680	Country Est MHP	PA0101940b	0.017	CBOD5	5.49		
				NH3-N	6.22	12.44	
				Dissolved Oxygen			6

The results for CBOD5 and Dissolved Oxygen are the same as the inputs from the Dry Reach Model, so the Dry Reach Model inputs are protective.

For NH3-N, the limit can be back calculated using the equation: $C_t = (C_o)e^{-(kt)}$

where $C_t = 6.22$ mg/l

$k = 0.7$ days⁻¹ = constant for NH3-N

$t = 0.803$ days = Dry Reach Model travel time

$$6.22 \text{ mg/l} = (C_o)e^{-(0.7 \text{ days}^{-1})(0.803 \text{ days})}$$

$$C_o = 10.9 \text{ mg/l}$$

$$\underline{\text{NH3-N} = 10.9 \text{ mg/l}}$$

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
16G	51257	TROUT RUN			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
1.680	0.017	21.679		7.080	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
3.249	0.349	9.319		0.069	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
3.17	0.288	2.09		0.797	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
7.490	26.482	Owens		6	
<u>Reach Travel Time (days)</u>	Subreach Results				
1.485	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.149	3.03	1.86	7.99	
	0.297	2.89	1.65	7.99	
	0.446	2.76	1.46	7.99	
	0.594	2.64	1.30	7.99	
	0.743	2.52	1.16	7.99	
	0.891	2.41	1.03	7.99	
	1.040	2.30	0.91	7.99	
	1.188	2.19	0.81	7.99	
	1.337	2.09	0.72	7.99	
	1.485	2.00	0.64	7.99	

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16G	51257	TROUT RUN	1.680	1369.00	0.52	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Country Est MHP	PA0101940b	0.0170	0.0000	0.0000	0.000	25.00	7.30

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	5.49	2.00	0.00	1.50
Dissolved Oxygen	6.00	8.24	0.00	0.00
NH3-N	10.93	0.00	0.00	0.70

(from Dry Model)

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16G	51257	TROUT RUN	0.000	1021.00	29.20	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16G	51257	TROUT RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.680	Country Est MHP	12.61	21.86	12.61	21.86	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.680	Country Est MHP	1.69	6.22	1.69	6.22	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.68	Country Est MHP	5.49	5.49	6.22	6.22	6	6	0	0

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16G		51257				TROUT RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
1.680	0.05	0.00	0.05	.0263	0.03923	.349	3.25	9.32	0.07	1.485	21.68	7.08
Q1-10 Flow												
1.680	0.03	0.00	0.03	.0263	0.03923	NA	NA	NA	0.06	1.731	22.21	7.11
Q30-10 Flow												
1.680	0.07	0.00	0.07	.0263	0.03923	NA	NA	NA	0.08	1.317	21.36	7.06

WQM 7.0 D.O.Simulation (Dry Reach Model)

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16G	51257	TROUT RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
2.240	0.017	24.996		7.300
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
2.143	0.288	7.432		0.043
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
24.98	1.500	24.98		1.028
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
4.003	29.425	Owens		NA
<u>Reach Travel Time (days)</u>	Subreach Results			
0.803	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.080	21.47	23.00	2.58
	0.161	18.45	21.18	3.00
	0.241	15.85	19.50	3.52
	0.321	13.62	17.95	4.01
	0.402	11.71	16.53	4.44
	0.482	10.06	15.22	4.82
	0.562	8.65	14.01	5.17
	0.643	7.43	12.90	5.48
	0.723	6.38	11.88	5.76
	0.803	5.49	10.93	6.00

(Put in Perennial Reach Model as inputs)

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16G	51257	TROUT RUN	2.240	1417.00	0.21	0.00000	0.00	<input type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.000	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Country Est MHP	PA0101940a	0.0170	0.0000	0.0000	0.000	25.00	7.30

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16G	51257	TROUT RUN	1.680	1369.00	0.52	0.00000	0.00	<input type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.000	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Country Est MHP	PA0101940b	0.0170	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	5.49	2.00	0.00	1.50
Dissolved Oxygen	6.00	8.24	0.00	0.00
NH3-N	10.93	0.00	0.00	0.70

WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Simulation	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16G		51257				TROUT RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
2.240	0.00	0.00	0.00	NA	0.01623	.288	2.14	7.43	0.04	0.803	25.00	7.30
Q1-10 Flow												
2.240	0.00	0.00	0.00	NA	0.01623	NA	NA	NA	0.00	0.000	0.00	0.00
Q30-10 Flow												
2.240	0.00	0.00	0.00	NA	0.01623	NA	NA	NA	0.00	0.000	0.00	0.00

Attachment 2

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.052	= Q stream (cfs)		0.5	= CV Daily	
0.017	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.650		1.3.2.iii	WLA_cfc = 0.626
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.242		5.1d	LTA_cfc = 0.364
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.298		AFC	
		INST MAX LIMIT (mg/l) = 0.975			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				