



Application Type
Facility Type
Major / Minor

Renewal
Non-Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. **PA0102181**
APS ID **1136088**
Authorization ID **1524770**

Applicant and Facility Information

Applicant Name	<u>Venango County</u>	Facility Name	<u>Two Mile Run County Park</u>
Applicant Address	471 Beach Road	Facility Address	471 Beach Road
	Franklin, PA 16323-7519		Franklin, PA 16323-7519
Applicant Contact	<u>Luke Kauffman</u>	Facility Contact	<u>Luke Kauffman</u>
Applicant Phone	<u>(814) 676-6116</u>	Facility Phone	<u>(814) 676-6116</u>
Client ID	<u>24051</u>	Site ID	<u>450406</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Sugarcreek Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Venango</u>
Date Application Received	<u>April 4, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	<u>---</u>
Purpose of Application	<u>Renewal Application for a Minor Sewage Facility</u>		

Summary of Review

The permittee is requesting reissuance of Individual NPDES Permit No. PA0102181. This is an existing discharge with a design flow of 0.02 MGD. A total plant replacement is being proposed for 2025/2026.

Act 14 notifications were submitted and received.

This facility is currently using the eDMR system.

The addition of monitoring E. coli is the only change to the effluent limitations in this permit renewal.

SPECIAL CONDITIONS: NONE

The EPA waiver is in effect.

There are no open violations for the subject Client ID (24051) as of May 7, 2025.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Carlee Wilson Carlee Wilson / Environmental Engineering Trainee	May 7, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	May 12, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No. 001
Latitude 41° 27' 56.43"
Quad Name _____
Wastewater Description: Sewage Effluent

Design Flow (MGD) .02
Longitude -79° 46' 17.56"
Quad Code _____

Receiving Waters Twomile Run (CWF)
NHD Com ID 100475937
Drainage Area 8.63
Q₇₋₁₀ Flow (cfs) 0.372
Elevation (ft) 1172
Watershed No. 16-E
Existing Use ---
Exceptions to Use ---
Assessment Status Attaining Use(s)
Cause(s) of Impairment ---
Source(s) of Impairment ---
TMDL Status ---

Stream Code 54094
RMI 0.4500
Yield (cfs/mi²) 0.04
Q₇₋₁₀ Basis USGS – StreamStats
Slope (ft/ft) ---
Chapter 93 Class. CWF
Existing Use Qualifier ---
Exceptions to Criteria ---

Background/Ambient Data
pH (SU) 7.0
Temperature (°F) 68
Hardness (mg/L) ---
Other: ---

Data Source
Default
Default

Nearest Downstream Public Water Supply Intake
PWS Waters Allegheny River
PWS RMI 90.57

Aqua Pa (Emlenton Water Co)
Flow at Intake (cfs) NA
Distance from Outfall (mi) 32

Changes Since Last Permit Issuance: None

Other Comments: None

Treatment Facility Summary				
Treatment Facility Name: Two Mile Run County Park				
WQM Permit No.	Issuance Date			
6172414	September 3, 2004			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Activated Sludge	Hypochlorite	0.02
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.02	90	Not Overloaded	Aerobic Digestion	

Changes Since Last Permit Issuance: N/A

Other Comments: The existing technology and processes consist of (WQM Permit No. 6172414): The influent flows into an aeration tank, travels into the first of two settling clarifiers with surface skimmers, returns sludge to the bottom, and is then returned to aeration. The clarifiers flow into the chlorine contact tank for disinfection before going into the pump tank.

Compliance History

DMR Data for Outfall 001 (from April 1, 2024, to March 31, 2025)

Parameter	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24
Flow (MGD) Average Monthly	0.0045	0.008	0.0022	0.0015	0.0014	0.0015	0.0048	0.003	0.0013	0.0009	0.001	0.0229
pH (S.U.) Instantaneous Minimum	7.41	7.43	7.41	7.46	7.45	7.40	7.1	7.45	7.44	7.44	7.34	7.39
pH (S.U.) Instantaneous Maximum	7.72	7.58	7.58	7.55	7.56	7.61	7.6	7.59	7.62	7.52	7.52	7.96
DO (mg/L) Daily Minimum	9.05	9.15	9.11	9.08	9.2	9.18	9.2	9.22	9.28	9.3	9.27	9.28
TRC (mg/L) Average Monthly	0.1	0.1	0.1	0.1	0.1	0.1	0.10	0.1	0.1	0.1	0.1	0.1
CBOD5 (mg/L) Average Monthly	3.0	< 3.0	< 2.0	< 3.0	< 2.0	< 2.0	< 2.0	< 4.0	< 3.0	3.0	6.0	< 2.0
TSS (mg/L) Average Monthly	11.0	30.0	< 8.0	< 5.0	< 7.0	< 7.0	< 7.0	10.0	< 7.0	8.0	9.0	15.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 3.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	1.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0
Total Nitrogen (mg/L) Annual Average				2.73								
Ammonia (mg/L) Annual Average				0.2								
Total Phosphorus (mg/L) Annual Average				3.74								

Compliance History	
Summary of DMRs:	There have been no effluent violations in the last 5 years.
Summary of Inspections:	The last facility inspection was conducted on April 20, 2022. No violations were noted.

Development of Effluent Limitations

Outfall No. 001
Latitude 41° 27' 55.86"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .02
Longitude -79° 46' 18.73"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	§ 92a.61
Total Phosphorus	Report	Average Monthly	-	§92a.61
Total Nitrogen	Report	Average Monthly	-	§92a.61

Comments: Monitoring for E. Coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Water Quality-Based Limitations

CBOD₅, Ammonia, and DO are evaluated using WQM 7.0 (Attachment 4). TRC is evaluated using the Department's TRC evaluation spreadsheet (Attachment 5).

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
CBOD ₅	25	Average Monthly	WQM 7.0
	50	IMAX	
NH ₃ -N	25	Average Monthly	WQM 7.0
	50	IMAX	
DO	4.0	Daily Minimum	WQM 7.0
TRC	0.5	Average Monthly	TRC Spreadsheet
	1.6	IMAX	

Comments: The limits from the previous permit cycle are retained.

Best Professional Judgment (BPJ) Limitations

Comments: Monitoring for dissolved oxygen, total nitrogen, total phosphorus and raw sewage influent monitoring for CBOD₅ and TSS are placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Anti-Backsliding - N/A

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.


Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Ammonia	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite


Compliance Sampling Location: Outfall 001 – after disinfection

Other Comments: According to the Permit Writers' Manual, the sampling frequency for total nitrogen, ammonia, and total phosphorus is recommended at 2/month however, since the facility is meeting limits, the 1/year sampling frequency is retained. Additionally, the sample type for CBOD5, TSS, total nitrogen, total phosphorus, and ammonia is recommended as "grab", but will be retained as 8-Hr Composite.

Attachment 1
eMapPA – Receiving Stream Location and Data



Attachment 2
Google Earth – Aerial Site View



Attachment 3
StreamStats – Drainage Area Data

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	8.63	square miles
ELEV	Mean Basin Elevation	1448	feet
PRECIP	Mean Annual Precipitation	43	inches

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	8.63	square miles	2.33	1720
ELEV	Mean Basin Elevation	1448	feet	898	2700
PRECIP	Mean Annual Precipitation	43	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.857	ft ³ /s	43	43
30 Day 2 Year Low Flow	1.23	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.373	ft ³ /s	54	54
30 Day 10 Year Low Flow	0.528	ft ³ /s	49	49
90 Day 10 Year Low Flow	0.779	ft ³ /s	41	41

Low-Flow Statistics Citations

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific](#)

Attachment 4
WQM 7.0 Modeling

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
				(ft)	(sq mi)	(ft/ft)	(mgd)	
16E		54094 TWOMILE RUN	5.540	1172.00	8.62	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.040	0.00	0.37	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
Outfall 001	PA0102181	0.0200	0.0000	0.0200	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc	Trib Conc	Stream Conc	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

Input Data WQM 7.0

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC	
				Rch Trav Time (days)	Rch Velocity (fps)							
Q7-10	0.040	0.00	0.38	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
Discharge Data												
				Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
						0.0000	0.0000	0.0000	0.000	25.00	7.00	
Parameter Data												
				Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
				CBOD5		25.00	2.00	0.00	1.50			
				Dissolved Oxygen		3.00	8.24	0.00	0.00			
				NH3-N		25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
16E		54094		TWOMILE RUN								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
5.540	0.37	0.00	0.37	.0309	0.00285	.457	11.75	25.72	0.08	0.757	20.38	7.00
Q1-10 Flow												
5.540	0.24	0.00	0.24	.0309	0.00285	NA	NA	NA	0.06	0.950	20.58	7.00
Q30-10 Flow												
5.540	0.51	0.00	0.51	.0309	0.00285	NA	NA	NA	0.09	0.645	20.29	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16E	54094	TWOMILE RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	5.540 Outfall 001	15.98	50	15.98	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	5.540 Outfall 001	1.85	25	1.85	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	5.54 Outfall 001	25	25	25	25	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
16E	54094	TWOMILE RUN			
<u>RMI</u>		<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
5.540		0.020	20.384	7.000	
<u>Reach Width (ft)</u>		<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
11.751		0.457	25.717	0.075	
<u>Reach CBOD5 (mg/L)</u>		<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
3.77		0.558	1.92	0.721	
<u>Reach DO (mg/L)</u>		<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.917		16.448	Owens	6	
<u>Reach Travel Time (days)</u>		<u>Subreach Results</u>			
0.757		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
		0.076	3.61	1.82	8.18
		0.151	3.46	1.72	8.18
		0.227	3.31	1.63	8.18
		0.303	3.17	1.54	8.18
		0.379	3.04	1.46	8.18
		0.454	2.91	1.38	8.18
		0.530	2.79	1.31	8.18
		0.606	2.67	1.24	8.18
		0.682	2.56	1.17	8.18
		0.757	2.45	1.11	8.18

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>				
16E	54094	TWOMILE RUN				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)
5.540	Outfall 001	PA0102181	0.020	CBOD5	25	
				NH3-N	25	50
				Dissolved Oxygen		4

Attachment 5
TRC Spreadsheet

TRC EVALUATION

0.372	= Q stream (cfs)	0.5	= CV Daily
0.02	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
	= % Factor of Safety (FOS)		=Decay Coefficient (K)
Source	Reference	AFC Calculations	Reference
TRC	1.3.2.iii	WLA_afc = 3.854	1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c
PENTOXSD TRG	5.1b	LTA_afc= 1.436	5.1d
Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635	