

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0102369
APS ID 936814
Authorization ID 1175554

Applicant and Facility Information



Applicant Name	<u>Rainbow Valley MHP</u>	Facility Name	<u>Rainbow Valley MHP</u>
Applicant Address	<u>400 Lord Road</u> <u>Fairview, PA 16415-1526</u>	Facility Address	<u>11682 Route 97 North</u> <u>Waterford, PA 16441</u>
Applicant Contact	<u>Jack R. Foht</u>	Facility Contact	<u>J. Brian Foht</u>
Title	<u>owner</u>	Title	<u>President</u>
Applicant Phone	<u>(814) 474-1102</u>	Facility Phone	<u>(814) 474-1102</u>
E mail	<u></u>	E mail	<u>jbrianfoht2@gmail.com</u>
Client ID	<u>43742</u>	Site ID	<u>258566</u>
Municipality	<u>Waterford Township</u>	County	<u>Erie</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No Limitations</u>
SIC Code	<u>6515</u>	SIC Code	<u>4952</u>
SIC Description	<u>Fin, Ins & Real Est - MH Site Oper</u>	SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>
Application Received	<u>March 28, 2017</u>	EPA Waived?	<u>Yes</u>
Application Accepted	<u>April 11, 2017</u>	If No, Reason	<u></u>
Application Purpose	<u>NPDES permit renewal.</u>		

Summary of Review

The facility is currently in compliance.

DO, pH and TRC monitoring has been increased from weekly to daily, the minimum daily DO has been increased from 3-mg/l to 4-mg/L and winter ammonia, total nitrogen, and total phosphorus monitoring has been added.

The self-monitoring reports indicate no problems with the proposed changes.

Approve	Deny	Signatures	Date
		William H. Mentzer, P.E. Environmental Engineering Specialist	February 27, 2020
		Justin C. Dickey, P.E. Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.05</u>
Latitude DP	<u>41° 57' 49.95"</u>	Longitude DP	<u>-79° 59' 32.92"</u>
Latitude NHD	<u>41° 57' 49.90"</u>	Longitude NHD	<u>-79° 59' 32.64"</u>
Quad Name	<u>Waterford</u>	Quad Code	<u>0306</u>
Wastewater:	<u>Mobile home park domestic wastes</u>		
Receiving Waters	<u>Unnamed Tributary to LeBoeuf Creek</u>	Stream Code	<u>53523</u>
NHD Com ID	<u>127355143</u>	RMI	<u>0.51</u>
Drainage Area	<u>0.78</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>Dry stream</u>
Elevation (ft)	<u>1218.53</u>	Slope (ft/ft)	<u>0.01269</u>
Watershed No.	<u>16-A</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>Perennial stream at confluence with LeBoeuf Creek RMI 8.67; drainage 41.1-square-mile Elevation 1204.93-feet</u>		
Low Flow Basis	<u>French Creek near Union City</u>	Station Number	<u>03021520</u> RMI <u> </u>
	Low Flow (cfs) <u>17.407</u>	Drainage (sq-mi) <u>211</u>	Yield (cfs/sq-mi) <u>0.0825</u>
Comments	<u>An alternative low flow basis is Walnut Creek based on a 1944-57 correlation.</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	_____		
Source(s) of Impairment	_____		
TMDL Status	_____	Name	_____
Background/Ambient Data		Data Source	
pH (SU)	_____		_____
Temperature (°C)	_____		_____
Hardness (mg/L)	_____		_____
CBOD ₅ (mg/L)	<u>2.0</u>		<u>default</u>
Ammonia as N (mg/L):	<u>0.1</u>		<u>default</u>
Other	_____		_____
Nearest Downstream Public Water Supply Intake	<u>Cambridge Springs Borough</u>		
PWS Waters	<u>French Creek</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>50.28</u>	Distance from Outfall (mi)	<u>18.85</u>

Changes Since Last Permit Issuance: none

Other Comments: none

Treatment Facility Summary				
Treatment Facility Name: Rainbow Valley M H P				
WQM Permit No.	Issuance Date			
2585401	May 3, 1985	May 3, 1985	May 3, 1985	
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Hypochlorite	0.05
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.05	120	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: none

Other Comments:

1 operator present

Comminution followed by parallel extended aeration and clarification and common disinfection

No industrial users reported

No outside waste sources reported

No sludge removal reported

	month	year	Influent			#	Effluent			#
			mean MGD	mean PPD	max		min mg/L	mean mg/L	max mg/L	
Annual Average Design Hydraulic Design			0.0500							
Organic Load										
Annual Average		2016	0.0220							
		2015	0.0267							
		2014	0.0244							
High Monthly Average	May	2016	0.0389							
pH						7.15		7.72		208
TRC							0.235	0.67		104
Fecal Coliform							42.95	2400		48
CBOD5							4.35	8.0		48
TSS							7.72	13.75		48
Ammonia							0.965	2.19		24
Nitrogen							24	24		1
Phosphorus							2.19	2.19		1

Compliance History

DMR Data for Outfall 001 (from March 1, 2016 to February 28, 2017)

Parameter	FEB-17	JAN-17	DEC-16	NOV-16	OCT-16	SEP-16	AUG-16	JUL-16	JUN-16	MAY-16	APR-16	MAR-16
Flow (MGD) Ave Monthly	0.0298	0.0276	0.0277	0.0214	0.0246	0.0253	0.0291	0.2310	0.0308	0.03089	0.030896	0.0308
pH (S.U.) Minimum	7.48	7.31	7.29	7.21	7.16	7.41	7.48	7.44	7.52	7.54	7.54	7.51
pH (S.U.) Maximum	7.66	7.56	7.36	7.33	7.57	7.62	7.62	7.61	7.61	7.74	7.68	7.66
DO (mg/L) Minimum	8.46	7.59	8.42	7.69	7.92	6.48	5.66	5.06	6.22	7.16	7.01	6.56
TRC (mg/L) Ave Monthly	0.36	0.30	0.27	0.29	0.35	0.32	0.20	0.16	0.19	0.22	0.33	0.19
TRC (mg/L) Instant Max	0.48	0.42	0.36	0.39	0.44	0.46	0.31	0.19	0.23	0.31	0.46	0.27
CBOD5 (mg/L) Average Monthly	< 4	4.2	4	4.0	< 4	4.0	4.0	4	4	4	4	4.0
TSS (mg/L) Ave Monthly	11.25	18.1	5	5.0	< 5	5.0	5.0	5	6.50	6	11	7.50
Fecal Coliform (#/100 ml) Geometric Mean	< 1	< 1	1.4	1	2	1.0	12	1	1	1	1.0	1
Fecal Coliform (#/100 ml) Instant Maximum	< 1	< 1	2	1	3	1.0	142	1	1	1	1.0	1
Ammonia (mg/L) Average Monthly					0.94	0.62	0.30	1.35	2.04	0.45		

Data for Outfall 001 (from January 1, 2019 to December 31, 2019)

Parameter	DEC-19	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19
Flow (MGD) Ave Monthly	0.0206	0.01824	0.018	0.01952	0.01884	0.0195	0.0322	0.0244	0.0226	0.0224	0.02367	0.02185
pH (S.U.) Minimum	7.44	7.46	7.48	7.42	7.42	7.34	7.62	7.41	7.54	7.50	7.60	7.50
pH (S.U.) Maximum	7.56	7.64	7.66	7.55	7.52	7.62	7.66	7.72	7.78	7.76	7.66	7.62
DO (mg/L) Minimum	7.34	6.64	7.60	7.06	7.40	7.29	7.96	8.66	8.80	7.21	7.10	6.92
TRC (mg/L) Ave Monthly	0.26	0.26	0.258	0.25	0.28	0.28	0.29	0.26	0.34	0.29	0.20	0.268
TRC (mg/L) Instant Max	0.34	0.46	0.34	0.31	0.36	0.30	0.34	0.33	0.62	0.34	0.28	0.36
CBOD5 (mg/L) Average Monthly	8.1	10.85	< 4.0	< 4.0	< 4.0	< 4.0	< 4.0	< 4.0	4.25	< 4.0	< 4.0	< 4.0
TSS (mg/L) Ave Monthly	18	< 5.0	< 5.0	5.75	< 5.0	5.50	< 5.0	5.0	6.0	6.0	7.25	9.25
Fecal Coliform (#/100 ml) Geometric Mean	3.16	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	1.0	48.98	48.9	< 1.0	< 1.0	< 1.0
Fecal Coliform (#/100 ml) Instant Maximum	10	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	1.0	2400	2400	< 1.0	< 1.0	< 1.0
Ammonia (mg/L) Average Monthly			0.685	0.575	0.815	1.51	0.52	3.48				

Compliance History

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) .05
 Latitude 41° 57' 49.95" Longitude -79° 59' 32.92"
 Wastewater Description: Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4.9-mg/L	Daily minimum		BPJ

Comments: none

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files submitted w/WQPR):

Parameter	Limit (mg/l)			SBC	Model		
	min	mean	max		min	mean	max
Dissolved Oxygen	4.0			NA	4.0		
Ammonia-Nitrogen	5/1 – 10/31	15	30	NA		15	30
TRC		0.5	1.2			0.5	1.6

Comments: determined through WQM7 modeling.

Additional Considerations

Modelling using the Walnut Creek partial record gauge station with 1944-1957 data correlated to Sugar Creek at Sugarcreek and a 25% reserve provides a 0.0223-cfs/square mile basin yield and ammonia limitations similar to the existing established requirements.

Modelling using low flows based on French Creek near Union City provides higher basin yields. Lowest basin yield is 9.6-cfs or 0.0455-cfs/square mile for the period 1911 through 1972. The current yield is 14.407 cfs or 0.0825-cfs/square mile. The winter ammonia requirements predate 1996 and remain in effect as the facility has shown compliance with this requirement. Also the submitted self-monitoring reports show compliance with the existing TRC daily maximum limitation so that no change to the TRC daily maximum is necessary or proposed.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/day	Grab
Dissolved Oxygen	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.2	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) Nov 1 - Apr 30	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) May 1 - Oct 31	XXX	XXX	XXX	20.0	XXX	40.0	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	15.0	XXX	30.0	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: At Outfall 001 after disinfection

Other Comments: Total nitrogen monitoring is new. Total phosphorus is from the existing NPDES permit.