

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0102547  
 APS ID 1009284  
 Authorization ID 1301645

**Applicant and Facility Information**

Applicant Name	<u>Oak Springs MHP Inc.</u>	Facility Name	<u>Oak Springs MHP</u>
Applicant Address	<u>PO Box 1922</u> <u>Cranberry Twp, PA 16066-0922</u>	Facility Address	<u>Old US Route 19</u> <u>Cranberry Twp, PA 16066-0035</u>
Applicant Contact	<u>Mark Mashuda</u>	Facility Contact	<u></u>
Applicant Phone	<u>(724) 452-4469</u>	Facility Phone	<u></u>
Applicant E Mail	<u></u>	Facility E Mail	<u></u>
Client ID	<u>57495</u>	Site ID	<u>450930</u>
Municipality	<u>Cranberry Township</u>	County	<u>Butler</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No Limitations</u>
Application Received	<u>January 2, 2020</u>	EPA Waived?	<u>Yes</u>
Application Accepted	<u>January 21, 2020</u>	If No, Reason	<u></u>
Application Purpose	<u>NPDES sewage discharge permit renewal</u>		

**Summary of Review**

No open violations.  
 No changes proposed

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E Environmental Engineering Specialist	December 8, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	December 14, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.022</u>
Latitude DP	<u>40° 44' 15.00"</u>	Longitude DP	<u>-80° 6' 47.00"</u>
Latitude NHD	<u>40° 43' 54.90"</u>	Longitude NHD	<u>-80° 6' 48.29"</u>
Quad Name	<u>Mars</u>	Quad Code	<u>1305</u>
Wastewater:	<u>treated sanitary wastewater</u>		
Receiving Waters	<u>Unnamed Tributary to Brush Creek</u>	Stream Code	<u>unknown</u>
NHD Com ID	<u>126220300</u>	RMI	<u>0.38</u>
Drainage Area	<u>25.8 acres (0.04 square miles)</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.048</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.02773</u>	Q <sub>7-10</sub> Basis	<u>Buffalo Creek</u>
Elevation (ft)	<u>1150.45</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>20-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>First point of use Tributary 34832 RMI 0.66, drainage 0.59-sq mi and elevation 1070.7 ft</u>		
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>NUTRIENTS, SILTATION</u>		
Source(s) of Impairment	<u>agriculture, highway/road/bridge runoff (non-construction related)</u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	<u>default</u>	
Temperature (°C)	<u>25</u>	<u>WWF default</u>	
Hardness (mg/L)	<u></u>	<u></u>	
Other:	<u></u>	<u></u>	
Nearest Downstream Public Water Supply Intake	<u>Pa American Water</u>		
PWS Waters	<u>Connoquenessing Creek</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>0.0</u>	Distance from Outfall (mi)	<u>26.72</u>

The  
Changes Since Last Permit Issuance: The Beaver Falls Municipal Authority public water intake at Beaver River RMI 3.5 and 600miles downstream was replaced by Pa American public water intake at the mouth of the Connoquenessing Creek. This discharge should not affect any downstream public water use.

Other Comments: None

..

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Oak Springs MHP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
1069405				
1073414				
1077405				
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Tertiary	Extended Aeration With Solids Removal	Hypochlorite	0.02
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.02	30.0	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: none

**Treatment:**

An extended aeration package treatment plant consisting of a 16,000-gallon aeration tank, a 3,400-gallon settling tank, and a 1,950-gallon sludge holding tank, aluminum sulfate feed for phosphorus control, a 750-gallon dosing tank, two 900 square foot intermittent sand filters, and tablet chlorination with an 1,800-gallon contact tank.

**Design:**

People Flow			Design					BOD5/TSS			NPDES		
#	gpccd	MGD	MGD	MGD	MGD	MGD	Max	MGD	ppccd	PPD	mg/L	PPD	PPD
214	60	0.01284	0.013	0.015	0.019	0.02	0.09	19.26	180	19.8	30.0		

For the NPDES permit the facility appears rerated at slightly above the maximum design.

Compliance History

DMR Data for Outfall 001 (from May 1, 2020 to April 30, 2021)

Parameter	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20
Flow (MGD) Average Monthly	0.0160	0.0160	0.0164	0.0129	0.0129	0.0121	0.0192	0.0182	0.0198	0.0185	0.0189	0.0185
Flow (MGD) Daily Maximum	0.0188	0.0188	0.0212	0.0147	0.0147	0.0167	0.0291	0.0237	0.0212	0.0237	0.0212	0.0237
pH (S.U.) Minimum	6.4	6.0	6.2	6.0	6.2	6.3	6.3	6.3	6.6	6.5	6.5	6.1
pH (S.U.) Maximum	7.1	7.0	7.0	6.9	7.1	7.4	7.0	7.1	7.0	7.0	7.0	6.9
DO (mg/L) Minimum	6.2	7.0	6.9	6.5	6.7	6.2	6.0	6.0	6.0	7.0	6.0	5.0
TRC (mg/L) Average Monthly	0.24	0.22	0.31	0.38	0.39	0.34	0.35	0.217	0.12	0.17	0.14	0.18
TRC (mg/L) Instant Maximum	1.04	0.68	1.32	1.41	1.55	1.42	1.25	1.04	0.64	0.81	1.45	0.72
CBOD5 (mg/L) Average Monthly	3.0	3.0	4.3	4.6	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
TSS (mg/L) Average Monthly	3.0	5.5	4.5	10.7	6.0	4.0	4.5	3.5	3.0	3.0	3.0	7.0
Fecal Coliform (#/100 ml) Geometric Mean	1.41	4	49	2.45	21	2.4	4.8	17	45	34	2.45	57.4
Fecal Coliform (#/100 ml) Instant Maximum	2	10	2420	3	435	6	23	36	166	579	6.0	75
Total Nitrogen (mg/L) Average Monthly	14.2	17.4	20.7	16.95	20.3	22.2	17.8	14.2	10.9	10.6	7.57	13.9
Ammonia (mg/L) Average Monthly	0.275	0.23	0.65	0.86	0.36	0.34	0.295	0.205	0.41	0.285	0.34	0.29
Total Phosphorus (mg/L) Average Monthly	0.215	0.19	0.10	0.375	0.24	0.26	0.375	0.315	0.39	0.47	0.47	0.285

Summer median pH 6.8 SU

DMR Data for Outfall 001 (from December 1, 2018 to November 30, 2019)

Parameter	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18
Flow (MGD) Average Monthly	0.0163	0.0156	0.0122	0.0116	0.0145	0.0176	0.0158	0.0153	0.0185	0.0249	0.0192	0.0161
Flow (MGD) Daily Maximum	0.0212	0.0188	0.0147	0.0147	0.0263	0.0263	0.0237	0.0188	0.0237	0.0422	0.0237	0.0237
pH (S.U.) Minimum	6.5	6.5	6.5	6.2	6.5	6.5	6.6	6.5	6.0	6.0	6.0	6.0
pH (S.U.) Maximum	7.0	7.2	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0
DO (mg/L) Minimum	8.0	5.0	8.0	5.0	7.0	6.0	7.0	4.0	4.0	5.0	4.0	4.0
TRC (mg/L) Average Monthly	0.31	0.25	0.18	0.22	0.21	0.295	0.22	0.31	0.36	0.37	0.249	0.21
TRC (mg/L) Instantaneous Maximum	1.03	1.42	1.00	0.69	1.49	0.54	0.98	0.83	1.85	1.83	0.81	0.58
CBOD5 (mg/L) Average Monthly	3.0	3.0	3.0	3.0	3.0	3.0	3.6	3.2	3.1	3.0	3.6	3.0
TSS (mg/L) Average Monthly	3.0	3.0	4.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.5
Fecal Coliform (#/100 ml) Geometric Mean	18.6	4.12	220	7.5	1.73	1	1	36	224	3	2.24	282
Fecal Coliform (#100 ml) Instantaneous Maximum	345	17	2420	56	3.0	1	1	1300	980	9	5	549
Total Nitrogen (mg/L) Average Monthly	20.4	15.0	17.6	11.6	13.5	15.5	15.2	15.4	15.2	13.7	28.9	16.7
Ammonia (mg/L) Average Monthly	0.26	0.12	0.105	0.20	0.17	0.10	0.165	0.32	0.28	0.26	0.35	0.11
Total Phosphorus (mg/L) Average Monthly	0.59	0.75	0.56	0.76	0.60	0.445	0.34	0.275	0.27	0.26	0.265	0.48

Summer median and average pH 6.8-SU

Effluent Violations for Outfall 001, from: January 1, 2019 to: November 30, 2019

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	03/31/19	IMAX	1.85	mg/L	1.6	mg/L
TRC	02/28/19	IMAX	1.83	mg/L	1.6	mg/L
Fecal Coliform	09/30/19	Geo Mean	220	CFU/100 ml	200	CFU/100 ml
Fecal Coliform	09/30/19	IMAX	2420	CFU/100 ml	1000	CFU/100 ml

Summary of Inspections: none filed

Other Comments: Cited on July 17, 2017 for pH, CBOD5, TRC ammonia self-monitoring violations from December 2015 to April 2017.

**Development of Effluent Limitations**

Outfall No. 001 Design Flow (MGD) .022  
 Latitude 40° 44' 15.00" Longitude -80° 6' 47.00"  
 Wastewater Description: Sewage Effluent

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4.0	Mg/L		BPJ

Comments: none

**Water Quality-Based Limitations**

A "Reasonable Potential Analysis" based on sewerage determined the following parameters were candidates for limitations: Phosphorus, CBOD<sub>5</sub>, TSS, Ammonia, Nitrogen, pH and DO.

Phosphorus is limited to 2.0-mg/L in the Connoquenessing Creek basin above Slippery Rock Creek.

The first point of use is estimated to be at the drainage swale confluence with un-named tributary 34832 at RMI 0.66.

Chlorine should be adequately controlled through technology. Natural in stream reduction should achieve aquatic life protection levels prior to achieving perennial stream conditions.

The following limitations were determined through water quality modeling (output files attached):

Parameter		Limit (mg/l)		SBC		Model	
BOD <sub>5</sub>		10.0	20.0	NA		25.0	50.0
Ammonia	Summer	2.0	4.0	NA		3.09	6.18
DO		4.0	4.0	NA	4.0		

Comments: With no reported ammonia and CBOD<sub>5</sub> violations anti-backsliding is appropriate.

**Best Professional Judgment (BPJ) Limitations**

Comments: Applied to DO. *1/year E.Coli monitoring added per the SOP for Establishing Effluent Limitations for Individual Sewage Permits.* JCD

**Anti-Backsliding**

Applies to ammonia.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E.Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	6.0	XXX	12	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001 after disinfection

## Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34832	Trib 34832 of Brush Creek	<b>1.040</b>	1150.45	0.04	0.00000	0.00	<input type="checkbox"/>

### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)									
<b>Q7-10</b>	0.048	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitte d Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Oak Springs	PA0102547	0.0330	0.0330	0.0330	0.000	25.00	6.80

### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70



### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34832	Trib 34832 of Brush Creek	<b>0.660</b>	1070.70	0.59	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
	<b>Q7-10</b>	0.048	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Oak Springs	PA0202547B	0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	8.24	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34832	Trib 34832 of Brush Creek	<b>0.000</b>	1002.90	1.76	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
	<b>Q7-10</b>	0.048	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		34832				Trib 34832 of Brush Creek						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
1.040	0.00	0.00	0.00	.0511	0.03975	.373	1.45	3.89	0.10	0.238	25.00	6.81
0.660	0.03	0.00	0.03	.0511	0.01946	.339	3.67	10.83	0.06	0.631	25.00	6.86
<b>Q1-10 Flow</b>												
1.040	0.00	0.00	0.00	.0511	0.03975	NA	NA	NA	0.10	0.239	25.00	6.80
0.660	0.02	0.00	0.02	.0511	0.01946	NA	NA	NA	0.06	0.682	25.00	6.84
<b>Q30-10 Flow</b>												
1.040	0.00	0.00	0.00	.0511	0.03975	NA	NA	NA	0.10	0.236	25.00	6.81
0.660	0.04	0.00	0.04	.0511	0.01946	NA	NA	NA	0.07	0.590	25.00	6.88

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	3		

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20C	34832	Trib 34832 of Brush Creek

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.040	Oak Springs	NA	50	12.85	21.64	2	57
0.660	Oak Springs	NA	NA	12.51	NA	NA	NA

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.040	Oak Springs	NA	25	1.45	3.09	2	88
0.660	Oak Springs	NA	NA	1.43	NA	NA	NA

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.04	Oak Springs	25	25	3.09	3.09	4	4	0	0
0.66	Oak Springs	NA	NA	NA	NA	NA	NA	NA	NA

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
20C	34832	Trib 34832 of Brush Creek			
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
1.040	0.033	25.000		6.806	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
1.452	0.373	3.891		0.098	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
24.17	1.494	2.98		1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
4.154	31.864	Owens		NA	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>				
0.238	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>	
	(days)	(mg/L)	(mg/L)	(mg/L)	
	0.024	23.11	2.91	5.06	
	0.048	22.10	2.84	5.54	
	0.071	21.14	2.77	5.81	
	0.095	20.21	2.71	5.99	
	0.119	19.33	2.64	6.12	
	0.143	18.49	2.58	6.23	
	0.166	17.68	2.52	6.32	
	0.190	16.91	2.45	6.41	
	0.214	16.17	2.40	6.49	
	0.238	15.46	2.34	6.56	
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
0.660	0.033	25.000		6.861	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
3.667	0.339	10.830		0.064	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
10.98	1.325	1.59		1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
7.123	28.691	Owens		3	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>				
0.631	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>	
	(days)	(mg/L)	(mg/L)	(mg/L)	
	0.063	9.89	1.49	7.21	
	0.126	8.90	1.40	7.32	
	0.189	8.01	1.31	7.41	
	0.252	7.21	1.23	7.50	
	0.316	6.49	1.15	7.58	
	0.379	5.84	1.08	7.65	
	0.442	5.26	1.01	7.72	
	0.505	4.73	0.95	7.78	
	0.568	4.26	0.89	7.83	
	0.631	3.84	0.83	7.88	
<hr/>					

## WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
20C		34832		Trib 34832 of Brush Creek			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.040	Oak Springs	PA0102547	0.033	CBOD5	25		
				NH3-N	3.09	6.18	
				Dissolved Oxygen			4

**Discharger** Oak Spring STP  
**Site** Oak Spring STP  
**Municipality** Cranberry Township  
**County** Butler  
**NPDES Permit** PA0102547  
**0.5**

Revised  
 Thursday, December 9, 2021

**TRC EVALUATION**

Input appropriate values in B4:B8 and E4:E7

0.0282	= Q stream (cfs)	0.5	= CV Daily
0.0330	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
	= % Factor of Safety (FOS)		= Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA afc = 0.195	1.3.2.iii	WLA cfc = 0.183
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373	5.1c	LTAMULT cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.073	5.1d	LTA_cfc = 0.106

Source	Effluent Limit Calculations
PENTOXSD TRG	5.1f AML MULT = 1.231
PENTOXSD TRG	5.1g LIMIT (mg/l) = 0.090 AFC
	X LIMIT (mg/l) = 0.293

WLA afc  $(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$   
 LTAMULT afc  $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1) \cdot 0.5)$   
 LTA\_afc  $wla\_afc \cdot LTAMULT\_afc$   
 WLA\_cfc  $(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$   
 LTAMULT\_cfc  $EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1) \cdot 0.5)$   
 LTA\_cfc  $wla\_cfc \cdot LTAMULT\_cfc$   
 AML MULT  $EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1) \cdot 0.5) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$   
 AVG MON LIMIT  $MIN(BAT\_BPJ, MIN(LTA\_afc, LTA\_cfc) \cdot AML\_MULT)$   
 INST MAX LIMIT  $1.5 \cdot ((av\_mon\_limit / AML\_MULT) / LTAMULT\_afc)$

$(0.011 / EXP(-k \cdot CFC\_tc / 1440)) + ((CFC\_Yc \cdot Qs \cdot 0.011) / (1.547 \cdot Qd)) \dots$   
 $\dots \cdot EXP(-k \cdot CFC\_tc / 1440)) + Xd + (CFC\_Yc \cdot Qs \cdot Xs / 1.547 \cdot Qd)] \cdot (1 - FOS / 100)$

Stream	Chlorine Required	=	perennial	Chlorine Demand	+	Chlorine Residual
Stream	Reach/Node	2	1	2		
Stream	Flow	Conditions	dry	perennial		
Stream	Code		unknown	34832		
Stream	Function					
Samples			30	30		
reach	outfall	RMI	0.38	0.66		
reach	Reach End	RMI	0	0		
reach		feet	2006.4	3484.8		
drainage		sq miles	0.04	0.59		
TRC	limitation	average	mg/L	0.020	0.090	
		maximum	mg/L	0.050	0.293	
elevation	modelled	feet	1150.45	1070.7		
elevation	modelled	feet	1070.7	1002.9		
slope	modelled	foot/foot	0.040	0.019		
low flow		cfs/sq mi	0.048	0.048		
discharge		mgd	0.0330	0.0330		
Runoff	Period	hours	24.000	24.000		

Dry stream discharge. Discharge adjusted for 16-hour runoff. TRC revised at outfall and estimated perennial stream conditions. Stream chlorine is expected to naturally abated prior to reaching perennial flow conditions.

stream	flow	cfs	0.00191	0.02821
stream	flow	MGD	0.001236	0.018231
stream	flow	total	MGD	0.034236
stream	chlorine	demand	mg/L	0.4
discharge	discharge	demand	mg/L	0.3
stream	Total Stream/Waste	ratio	1.0	1.6
permitted	TRC	mean	BAT	0.5
permitted	TRC	maximum	BAT	1.6