

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0102580
APS ID 1063772
Authorization ID 1396867

Applicant and Facility Information

Applicant Name	<u>Jones Estates Baxter's PA, LLC</u>	Facility Name	<u>Baxter MHP</u>
Applicant Address	<u>2310 South Miami Boulevard</u> <u>Durham, NC 27703</u>	Facility Address	<u>457 Jamisonville Road</u> <u>Butler, PA 16001</u>
Applicant Contact	<u>Kellen Buss, Director</u> <u>(kbuss@rentstackhouse.com)</u>	Facility Contact	<u>Kellen Buss, Director</u> <u>(kbuss@rentstackhouse.com)</u>
Applicant Phone	<u>(419) 357-9091</u>	Facility Phone	<u>(419) 357-9091</u>
Client ID	<u>370135</u>	Site ID	<u>244069</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Center Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Butler County</u>
Date Application Received	<u>January 31, 2022 / May 9, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>February 1, 2022 / May 19, 2022</u>	If No, Reason	<u>-</u>

Purpose of Application Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater. This application also transfers ownership from Ernest J. Baxter to the Jones Estates Baxters PA, LLC.

Summary of Review

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into Sewers
- B. Right of Way
- C. Solids Handling
- D. Public Sewerage Availability
- E. Effluent Chlorine Optimization and Minimization
- F. Little or No Assimilative Capacity

SPECIAL CONDITIONS:

- II. Solids Management
- III. Requirements for Total Residual Chlorine (TRC)

There are no open violations in EFACTS associated with the subject Client ID (370135) as of 9/26/2022.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	9/26/2022
X		Adam J. Pesek (Lead Reviewer) for Vacant / Environmental Engineer Manager	9/27/2022

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	0.025
Latitude	40° 56' 28.44"	Longitude	-79° 56' 59.33"
Quad Name	-	Quad Code	-
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to the Stony Run (WWF)	Stream Code	N/A
NHD Com ID	126221000	RMI	N/A
Drainage Area	-	Yield (cfs/mi ²)	-
Q ₇₋₁₀ Flow (cfs)	-	Q ₇₋₁₀ Basis	-
Elevation (ft)	-	Slope (ft/ft)	-
Watershed No.	20-C	Chapter 93 Class.	WWF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Impaired*		
Cause(s) of Impairment	Metals		
Source(s) of Impairment	Acid Mine Drainage		
TMDL Status	-	Name	-
Background/Ambient Data		Data Source	
pH (SU)	-		-
Temperature (°F)	-		-
Hardness (mg/L)	-		-
Other:	-		-
Nearest Downstream Public Water Supply Intake	Beaver Falls Municipal Authority - Eastvale		
PWS Waters	Beaver River	Flow at Intake (cfs)	561
PWS RMI	3.5	Distance from Outfall (mi)	62.0

* The aquatic life in the Unnamed Tributary to the Stony Run is impaired due to metals from Abandoned Mine Drainage (AMD). This STP only treats sanitary sewage with no industrial users. As a result, 1/year monitoring for Aluminum, Iron, and Manganese has been added to provided data in the event a TMDL is developed.

Sludge use and disposal description and location(s): All sludge is disposed of at an approved STP and ultimately disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.025 MGD of treated sewage from a non-municipal STP in Center Township, Butler County.

Treatment permitted under WQM Permit 1086406 consists of: A Hydro-Aerobics package extended aeration unit containing a comminutor and bar screen, a 25,000 gallon aeration tank, alum addition for Phosphorus control, a clarifier, a clearwell for holding filter backwash, an aerated sludge holding tank, and tablet chlorine disinfection with a contact tank. Following the package STP are two 8.68 square foot rapid sand/anthracite filters.

1. Streamflow:

Unnamed Tributary to the Stony Run at Outfall 001:

Yieldrate: 0.1 cfsm (default - no nearby stream gages)
Drainage Area: 0.0466 sq. mi. (from USGS StreamStats)
% of stream allocated: 100% Basis: No nearby discharges
Q₇₋₁₀: 0.0046 cfs (calculated)

2. Wasteflow:

Maximum discharge: 0.025 MGD = 0.038 cfs

Runoff flow period: 16 hours Basis: Runoff flow for a MHP

24 hour flow: 0.025 MGD x 24/16 = 0.037 MGD = 0.057 cfs

There is less than 3 parts stream flow (Q₇₋₁₀) to 1 part effluent (design flow). However, since this is an existing discharge, the more stringent treatment requirements cannot be achieved, and the receiving stream is not impaired by the discharge, the standards in DEP guidance (391-2000-014) will not be applied.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH₃-N, CBOD₅, Dissolved Oxygen, and Total Residual Chlorine.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency will remain as 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits. Since the previous limits are more restrictive and are being attained, the previous limits that were based on the old dry streams guidance will be retained. Per DEP policy, the TSS limits were changed from seasonal to year round.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)
10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows greater than 0.002 MGD and less than 0.05 MGD.

e. Phosphorus

Limit necessary

Basis: Phosphorus limits of 2.0 mg/l monthly average and 4.0 instantaneous maximum are from the Connoquenessing Creek implementation plan.

Limit not necessary

Basis: N/A

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 7.0 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background NH₃-N concentration: 0.0 mg/l

Basis: Default value

Calculated NH₃-N Summer limits: 5.4 mg/l (monthly average)
10.8 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 16.2 mg/l (monthly average)
32.4 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated NH3-N limits above (see Attachment 1). The winter limits are calculated as three times the summer limits, per the SOP. Since the previous limits are more restrictive and are being attained, the previous limits will be retained.

h. CBOD₅

Median discharge pH to be used: 7.0 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD₅ limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated limits above (see Attachment 1). Since the previous limits are more restrictive and are being attained, the previous limits that were based on the old dry streams guidance will be retained. Per DEP policy, the CBOD5 limits were changed from seasonal to year round.

i. Dissolved Oxygen (DO)

The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61.

The measurement frequency will remain as 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

j. Total Residual Chlorine (TRC)

TRC limits: 0.28 mg/l (monthly average)
0.91 mg/l (instantaneous maximum)

Basis: The TRC limits above were calculated using the Department's TRC Calculation Spreadsheet (see Attachment 3). The limits are water quality-based on the first point of use, per the SOP. Since the calculated limits are more restrictive than in the previous permit, and may not be attainable, a 3 year compliance schedule and special condition will be added.

The measurement frequency will remain as 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

4. **Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was not performed in accordance with State practices using the Department's Toxics Management Spreadsheet since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

5. Reasonable Potential for Downstream Public Water Supply (PWS):

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no sample data was provided, mass-balance calculations were not performed.

Nearest Downstream potable water supply (PWS): Beaver Falls Municipal Authority - Eastvale

Distance downstream from the point of discharge: 62.0 miles (approximate)

- No limits necessary
- Limits needed

Basis: Significant dilution available

6. Anti-Backsliding:

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

7. Attachment List:

Attachment 1 - WQ Modeling Printouts - Perennial Reach

Attachment 2 - WQ Modeling Printouts - Dry Reach

Attachment 3 - TRC_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from August 1, 2021 to July 31, 2022)

Parameter	JUL-22	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21
Flow (MGD) Average Monthly	0.008	0.005	0.005	0.006	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Flow (MGD) Daily Maximum	0.010	0.006	0.005	0.008	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
pH (S.U.) Minimum	6.3	6.8	6.6	6.8	7.0	6.6	6.8	6.8	7.0	7.3	7.0	7.0
pH (S.U.) Maximum	7.6	7.5	7.3	7.5	7.2	6.8	6.8	7.0	7.0	7.3	7.4	7.3
DO (mg/L) Minimum	4.5	4.4	4.2	6.2	7.5	7.5	7.3	7.5	7.3	7.5	7.5	7.0
TRC (mg/L) Average Monthly	0.08	0.09	0.10	0.07	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
TRC (mg/L) Instantaneous Maximum	0.20	0.50	0.4	0.2	1.5	1.5	1.5	1.5	1.5	1.5	1.4	1.5
CBOD5 (mg/L) Average Monthly	3.0	5.6	3.0	3.0	2.0	3.5	4.1	2.6	2.0	2.1	2.1	2.1
TSS (mg/L) Average Monthly	3.0	3.0	8.0	6.5	5.0	5.0	5.5	5.0	5.0	14.4	8.1	6.1
Fecal Coliform (No./100 ml) Geometric Mean	1	1	1	49	1	1	1	1	2.2	1	1	1
Fecal Coliform (No./100 ml) Instantaneous Maximum	1	1	1	2420	1	1	1	1	5	1	1	1
Total Nitrogen (mg/L) Average Monthly	6.5	4.9	8.1	8.3	6.6	12.8	14.4	7.5	11.1	5.0	17.9	1.5
Ammonia (mg/L) Average Monthly	0.2	1.3	0.9	0.2	1.8	0.5	0.5	0.5	0.7	0.5	0.5	0.5
Total Phosphorus (mg/L) Average Monthly	2.2	0.4	1.6	1.4	0.6	0.5	0.3	0.2	0.9	2.2	2.7	0.8
Total Aluminum (mg/L) Annual Average								0.29				
Total Iron (mg/L) Annual Average								0.08				
Total Manganese (mg/L) Annual Average								0.05				

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through December 31, 2025.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	4.5	XXX	9	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	1.5	XXX	3	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through December 31, 2025)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Aluminum	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Iron	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Manganese	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are technology-based on Chapter 92a.48. The limits for CBOD₅, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for Total Nitrogen is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. The limits for Total Phosphorus are technology-based on Chapter 96.5. Aluminum, Iron, and Manganese are monitor only based on Chapter 92a.61.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: January 1, 2026 through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.28	XXX	0.91	1/day	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	4.5	XXX	9	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	1.5	XXX	3	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab

Outfall 001 , Continued (from January 1, 2026 through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Iron	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Manganese	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are water quality-based on Chapter 93.7. The limits for CBOD₅, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for Total Nitrogen is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. The limits for Total Phosphorus are technology-based on Chapter 96.5. Aluminum, Iron, and Manganese are monitor only based on Chapter 92a.61.

Attachment 1

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
20C		35275	STONY RUN				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
4.260	Perennial Reach	PA0102580b	0.037	CBOD5	18.27		
				NH3-N	4.81	9.62	
				Dissolved Oxygen			.63

The results for CBOD5 and DO are the same as the inputs from the Dry Reach Model, so the Dry Reach Model inputs for those parameters are protective.

For NH3-N, the limit can be back-calculated using the equation: $C_t = (C_o)e^{-(kt)}$, where

$$C_t = 4.81 \text{ mg/l}$$

$$k = 0.7 \text{ days}^{-1} = \text{constant for NH}_3\text{-N}$$

$$t = 0.166 \text{ days} = \text{Dry Reach Model travel time}$$

$$\text{Therefore, } 4.81 \text{ mg/l} = (C_t)e^{-(0.7 \text{ days}^{-1})(0.166 \text{ days})}$$

$$C_t = 5.4$$

$$\text{NH}_3\text{-N} = 5.4 \text{ mg/l}$$

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	35275	STONY RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
4.260	0.037	25.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
5.656	0.381	14.854	0.076	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
7.71	1.001	1.69	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
5.117	25.889	Owens	5	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.911	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.091	6.87	1.54	7.34
	0.182	6.13	1.40	7.54
	0.273	5.46	1.27	7.54
	0.364	4.87	1.16	7.54
	0.456	4.34	1.06	7.54
	0.547	3.87	0.96	7.54
	0.638	3.45	0.88	7.54
	0.729	3.08	0.80	7.54
	0.820	2.74	0.73	7.54
	0.911	2.45	0.66	7.54

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	35275	STONY RUN	4.260	1164.00	1.06	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Perennial Reach	PA0102580b	0.0370	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	18.27	2.00	0.00	1.50
Dissolved Oxygen	0.63	7.54	0.00	0.00
NH3-N	21.07	0.00	0.00	0.70

(from Dry Reach model)

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	35275	STONY RUN	3.130	1131.00	2.73	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
20C 35275 STONY RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.260	Perennial Reach	11.07	24.2	11.07	24.2	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.260	Perennial Reach	1.37	4.81	1.37	4.81	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
4.26	Perennial Reach	18.27	18.27	4.81	4.81	.63	.63	0	0

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		35275				STONY RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
4.260	0.11	0.00	0.11	.0572	0.00553	.381	5.66	14.85	0.08	0.911	25.00	7.00
Q1-10 Flow												
4.260	0.07	0.00	0.07	.0572	0.00553	NA	NA	NA	0.07	1.058	25.00	7.00
Q30-10 Flow												
4.260	0.14	0.00	0.14	.0572	0.00553	NA	NA	NA	0.09	0.810	25.00	7.00

Attachment 2

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	35293	Trib 35293 to Stony Run		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.620	0.037	25.000		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
0.389	0.647	0.601		0.228
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
25.00	1.500	25.00		1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
4.000	20.316	Owens		2
<u>Reach Travel Time (days)</u>	Subreach Results			
0.166	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.017	24.23	24.58	2.00
	0.033	23.48	24.16	1.71
	0.050	22.75	23.75	1.11
	0.067	22.05	23.35	0.74
	0.083	21.37	22.95	0.53
	0.100	20.71	22.56	0.43
	0.116	20.07	22.18	0.41
	0.133	19.45	21.80	0.45
	0.150	18.85	21.43	0.52
	0.166	18.27	21.07	0.63

- Input into Perennial Reach Model

WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Simulation	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	35293	Trib 35293 to Stony Run	0.620	1284.00	0.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Dry Reach	PA0102580a	0.0370	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	0.00	0.00	1.50
Dissolved Oxygen	4.00	2.00	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	35293	Trib 35293 to Stony Run	0.000	1167.00	0.75	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		35293				Trib 35293 to Stony Run						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
0.620	0.00	0.00	0.00	NA	0.03574	.647	.39	.6	0.23	0.166	25.00	7.00
Q1-10 Flow												
0.620	0.00	0.00	0.00	NA	0.03574	NA	NA	NA	0.00	0.000	0.00	0.00
Q30-10 Flow												
0.620	0.00	0.00	0.00	NA	0.03574	NA	NA	NA	0.00	0.000	0.00	0.00

Attachment 3

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.106	= Q stream (cfs)		0.5	= CV Daily
0.037	= Q discharge (MGD)		0.5	= CV Hourly
30	= no. samples		1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		0	=Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA afc = 0.610		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc= 0.227		5.1d
				WLA cfc = 0.587
				LTAMULT cfc = 0.581
				LTA_cfc = 0.341
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.280		AFC
		INST MAX LIMIT (mg/l) = 0.915		
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots$ $\dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots$ $\dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$			
AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST_MAX_LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)			