



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0102822

APS ID

1142504

Authorization ID

1535871

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	Jones Estates Rolling Valley PA LLC	Facility Name	Rolling Valley Estates
Applicant Address	2310 S Miami Boulevard	Facility Address	369 Eagle Mill Road
	Durham, NC 27703-5798		Butler, PA 16001-8789
Applicant Contact	Kellen Buss	Facility Contact	Kellen Buss
Applicant Phone	(419) 357-9091	Facility Phone	(419) 357-9091
Client ID	373254	Site ID	244074
Ch 94 Load Status	Not Overloaded	Municipality	Connoquenessing Township
Connection Status		County	Butler
Date Application Received	August 1, 2025	EPA Waived?	Yes
Date Application Accepted		If No, Reason	--
Purpose of Application	Renewal application for a Minor Sewage Facility		

Summary of Review

On August 1, 2025, the Department received a renewal application for Rolling Valley Estates' Individual Permit No. PA0102822 that is set to expire on January 31, 2026. Rolling Valley Estates is a mobile home park with a design flow of 0.025 MGD. There is one outfall (Outfall 001) which discharges to Little Connoquenessing Creek (CWF).

Act 14 notifications were submitted and received.

The facility is currently in the eDMR system.

An inspection summary has been provided below (Table 1).

There are 24 open violations in WMS for the subject Client ID (373254) as of October 2, 2025. (Table 1)

Notes:

- Total Residual Chlorine effluent violations are considered chronic and significant.

Proposed Changes:

- Addition of E. Coli monitoring

Approve	Deny	Signatures	Date
X		Carlee Wilson Carlee Wilson / Environmental Engineering Trainee	October 2, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	October 3, 2025

NPDES Permit Fact Sheet
Rolling Valley Estates

NPDES Permit No. PA0102822

Discharge, Receiving Waters and Water Supply Information

Outfall No. 001
Latitude 40° 51' 44.63"
Quad Name -
Wastewater Description: Sewage Effluent

Design Flow (MGD) .025
Longitude -79° 58' 34.46"
Quad Code -

Receiving Waters	<u>Little Connoquenessing Creek (CWF)</u>	Stream Code	<u>34918</u>
NHD Com ID	<u>126217465</u>	RMI	<u>---</u>
Drainage Area	<u>11.5 (first point of perennial conditions)</u>	Yield (cfs/mi ²)	<u>0.015</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.173</u>	Q ₇₋₁₀ Basis	<u>USGS - StreamStats</u>
Elevation (ft)	<u>1038</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>20-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>Aluminum, Iron, and Manganese</u>		
Source(s) of Impairment	<u>Abandoned Mine Drainage (AMD)</u>		
TMDL Status	<u>Final</u>	Name	<u>Little Connoquenessing Creek Watershed</u>

Background/Ambient Data
pH (SU) 7.0
Temperature (°F) 68
Hardness (mg/L) 100
Other: -

Data Source

default
default
default
-

Nearest Downstream Public Water Supply Intake
PWS Waters Little Connoquenessing Creek
PWS RMI 1.1

Harmony Borough Water Authority

Flow at Intake (cfs) 2.0
Distance from Outfall (mi) 7.0

Changes Since Last Permit Issuance: Q₇₋₁₀ Flow was changed using updated StreamStats data.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Treatment Facility Summary				
Treatment Facility Name: Rolling Valley Estates				
WQM Permit No.	Issuance Date			
1073410 T-1	6/25/2024			
1073410	9/10/1973			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage			Chlorine	0.025
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.025		Not Overloaded		

Changes Since Last Permit Issuance: None

1073410 T-1

Screening and comminution, alum for Phosphorus removal, two parallel 12,500-gallon aeration tanks, two parallel 2,000-gallon settling tanks, a 3,000-gallon aerated sludge storage tank, a dosing chamber with dual siphons, two 1,600 square foot (40' x 40') intermittent surface sand filters, and tablet chlorination with a 2,073-gallon contact tank.

The influent comes into the aeration basin for secondary treatment, then goes to the clarifier, and then to the chlorine contact tank for disinfection.

Table 1. Inspection Summary of the Last 5 Years for Rolling Valley Estates

Site Name	Inspection Date	Inspection Type	Inspection Result Description	Inspector	Number of Violations
ROLLING VALLEY ESTATES	04/02/2025	Administrative/File Review	Violation(s) Noted	RIOS MARTINEZ, WANDA	1
ROLLING VALLEY ESTATES	12/28/2023	Administrative/File Review	Violation(s) Noted	KING, WILLIAM	1
ROLLING VALLEY ESTATES	04/05/2023	Administrative/File Review	Violation(s) Noted	OPILA, TAMI	1
ROLLING VALLEY ESTATES	01/03/2023	Administrative/File Review	Violation(s) Noted	KING, WILLIAM	1
ROLLING VALLEY ESTATES	07/21/2025	Administrative/File Review	Violation(s) Noted	SINGER, SEAN	1
ROLLING VALLEY ESTATES	08/14/2025	Compliance Evaluation	Violation(s) Noted	CARVER, MELISSA	14
ROLLING VALLEY ESTATES	10/11/2024	Administrative/File Review	Violation(s) Noted	SINGER, SEAN	3
ROLLING VALLEY ESTATES	12/20/2021	Administrative/File Review	Violation(s) Noted	KING, WILLIAM	1
ROLLING VALLEY ESTATES	05/06/2022	Administrative/File Review	Violation(s) Noted	OPILA, TAMI	1

Compliance History

DMR Data for Outfall 001 (from August 1, 2024, to July 31, 2025)

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Flow (MGD) Average Monthly	0.0042	0.0039	0.0041	0.0043	0.0043	0.009	0.0041	0.004	0.0041	0.0041	0.0042	0.0041
Flow (MGD) Daily Maximum	0.0045	0.0042	0.0037	0.0045	0.0047	0.0095	0.0045	0.0044	0.0045	0.0045	0.0045	0.0045
pH (S.U.) Instantaneous Minimum	7.76	7.04	6.97	7.2	6.64	7.25	7.36	6.28	7.13	6.01	6.07	6.07
pH (S.U.) Instantaneous Maximum	8.81	8.21	7.98	8.43	7.98	7.65	7.84	7.97	8.82	8.91	7.08	6.93
DO (mg/L) Instantaneous Minimum	4.16	4.41	4.36	5.02	4.71	4.03	4.03	5.16	3.69	4.03	4.02	4.11
TRC (mg/L) Average Monthly	0.28	0.83	0.81	0.94	1.13	1.08	0.5	0.09	0.08	0.47	0.61	1.0
TRC (mg/L) Instantaneous Maximum	0.45	1.53	1.42	1.49	1.59	2.2	1.6	0.15	0.22	0.9	0.79	1.55
CBOD5 (mg/L) Average Monthly	< 2.0	3.28	2.14	< 2.0	3.23	< 2.0	2.0	2.0	23.05	6.055	< 2.0	2.0
TSS (mg/L) Average Monthly	< 5.0	< 5.0	6.5	< 5.0	< 5.0	< 5.0	5.0	6.5	5.0	5.0	5.0	5.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	1.0	1.0	14.83	1.0	1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	1.0	1.0	22	1.0	1.0
Total Nitrogen (mg/L) Average Monthly	31.05	22.59	10.18	12.06	17.95	22.65	1.66	29.3	29.3	46.7	12.93	1.05
Ammonia (mg/L) Average Monthly	1.765	0.328	0.27	< 0.15	7.3575	0.15	0.45	0.317	0.317	0.1015	0.55	0.65
Total Phosphorus (mg/L) Average Monthly	2.91	0.6	0.72	0.39	0.78	0.62	0.15	1.28	1.28	6.09	1.05	0.50
Total Aluminum (mg/L) Annual Average								0.249				
Total Iron (mg/L) Annual Average								< 0.03				
Total Manganese (mg/L) Annual Average								0.036				

Compliance History

Effluent Violations for Outfall 001, from: September 1, 2024, To: July 31, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
DO	11/30/24	Inst Min	3.69	mg/L	4.0	mg/L
DO	11/30/24	Inst Min	3.69	mg/L	4.0	mg/L
TRC	02/28/25	Avg Mo	1.08	mg/L	.5	mg/L
TRC	06/30/25	Avg Mo	0.83	mg/L	.5	mg/L
TRC	02/28/25	Avg Mo	1.08	mg/L	.5	mg/L
TRC	03/31/25	Avg Mo	1.13	mg/L	.5	mg/L
TRC	05/31/25	Avg Mo	0.81	mg/L	.5	mg/L
TRC	09/30/24	Avg Mo	0.61	mg/L	.5	mg/L
TRC	04/30/25	Avg Mo	0.94	mg/L	.5	mg/L
TRC	03/31/25	Avg Mo	1.13	mg/L	.5	mg/L
TRC	04/30/25	Avg Mo	0.94	mg/L	.5	mg/L
TRC	05/31/25	Avg Mo	0.81	mg/L	.5	mg/L
TRC	06/30/25	Avg Mo	0.83	mg/L	.5	mg/L
TRC	02/28/25	IMAX	2.2	mg/L	1.6	mg/L
TRC	02/28/25	IMAX	2.2	mg/L	1.6	mg/L
CBOD5	11/30/24	Avg Mo	23.05	mg/L	20.0	mg/L
CBOD5	11/30/24	Avg Mo	23.05	mg/L	20.0	mg/L
Total Phosphorus	07/31/25	Avg Mo	2.91	mg/L	2.0	mg/L
Total Phosphorus	10/31/24	Avg Mo	6.09	mg/L	2.0	mg/L

Table 2. Open Violations in WMS for Client ID (373254)

<i>Inspection Program</i>	<i>Violation Date</i>	<i>Violation</i>
Water Planning and Conservation	11/20/2024	Reporting for all water withdrawals and usage
Safe Drinking Water	04/13/2023	Failure to comply with permit condition
Safe Drinking Water	04/13/2023	Failure to comply with permit condition
Safe Drinking Water	04/13/2023	Failure to comply with permit condition
Safe Drinking Water	06/06/2023	FAILURE TO MEET DESIGN AND CONSTRUCTION STANDARDS
Safe Drinking Water	06/06/2023	FAILURE TO COMPLY WITH UNINTERRUPTED SYSTEM SERVICE PLAN REQUIREMENTS
WPC NPDES	10/11/2024	NPDES - Violation of effluent limits in Part A of permit
WPC NPDES	10/11/2024	NPDES - Failure to monitor pollutants as required by the NPDES permit
WPC NPDES	04/02/2025	NPDES - Failure to pay annual fee
WPC NPDES	07/21/2025	NPDES - Violation of effluent limits in Part A of permit
WPC NPDES	08/14/2025	NPDES - Failure to utilize an accredited environmental laboratory for testing or analysis of environmental samples
WPC NPDES	08/14/2025	NPDES - Failure to utilize approved analytical methods
WPC NPDES	08/14/2025	NPDES - Failure to properly document monitoring activities and results
WPC NPDES	08/14/2025	NPDES - Failure to properly document monitoring activities and results
WPC NPDES	08/14/2025	NPDES - Failure to properly document monitoring activities and results
WPC NPDES	08/14/2025	NPDES - Failure to submit monitoring report(s) or properly complete monitoring reports
WPC NPDES	08/14/2025	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance
WPC NPDES	08/14/2025	CSL - Failure to apply for and/or obtain a WQM permit for the construction of sewage or industrial waste facilities
WPC NPDES	08/14/2025	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance
WPC NPDES	08/14/2025	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance
WPC NPDES	08/14/2025	NPDES - Violation of Part C permit condition(s)
WPC NPDES	08/14/2025	Operator Certification - Owner failed to comply with the Act or Chapter 302 regulations
WPC NPDES	08/14/2025	Operator Certification - Operator failed to comply with the Act or Chapter 302 regulations
WPC NPDES	08/14/2025	Operator Certification - Owner failed to comply with the Act or Chapter 302 regulations

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 51' 58.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .025
Longitude -79° 58' 41.00"

Technology-Based Limitations

Table 3. Minimum Technology and BPJ Standards				
Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report	IMAX	-	92a.61
Total Phosphorous	Report	Average Monthly	-	92a.61
Total Nitrogen	Report	Average Monthly	-	92a.61

The above limits are minimum technology-based and BPJ standards for individual sewage permits which are found in the Department's "Establishing Effluent Limitations for Individual Sewage Permits" document (SOP. No. BCW-PMT-033). The limits for pH are technology-based on Chapter 93.7. The limits for Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus are based on Chapter 92a.61.

The site received the 2.0 mg/l Total Phosphorous limit based on Chapter 96.5 due to the discharge flowing to Connoquenessing Creek which is impaired for nutrients. The limit will be retained into this renewal.

Water Quality-Based Limitations

Table 4. Water Quality Modeling Results (WQM 7.0)		
Parameter	Limit (mg/l)	SBC
CBOD5	25	Average Monthly
NH3-N	12.77	Average Monthly
	25.54	IMAX
DO	4	Daily Minimum

The above parameters were evaluated using water quality modeling (Attachment 6). This model is used to determine and/or establish WQBELs to protect water quality. In this evaluation, the model provided the above limits for CBOD5, Ammonia-Nitrogen and Dissolved Oxygen. The CBOD5 and DO limits remained the same. Since the NH3-N limits recommended by the model are less stringent than the current permit, the current limits will be retained into this renewal.

Toxic Pollutants

The Toxics Management Spreadsheet was ran using the highest discharge concentration values from the facility's eDMR data (Attachment 7). No limits were recommended by the model. Since the current permit require monitoring, 1/year monitoring will be retained for Aluminum, Iron, and Manganese due to the Little Connoquenessing Creek Watershed TMDL that was made final on April 9, 2009, under the authority of Chapter 92a.61, and per the direction of the SOP for Establishing Effluent Limitations for Individual Sewage Permits.

Anti-Backsliding

Table 5. Current Permit Effluent Limitations for Outfall 001

Parameter	Effluent Limitations			
	Concentrations (mg/L)			
	Minimum	Average Monthly	Maximum	Instant. Maximum
Flow (MGD)	XXX	Report	XXX	XXX
pH (S.U.)	6.0 Inst Min	XXX	XXX	9.0
DO	4.0 Inst Min	XXX	XXX	XXX
TRC	XXX	0.5	XXX	1.6
CBOD5	XXX	20.0	XXX	40
TSS	XXX	30.0	XXX	60
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	2000 Geo Mean	XXX	10000
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	200 Geo Mean	XXX	1000
Total Nitrogen	XXX	Report	XXX	XXX
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	12.0	XXX	36
Ammonia-Nitrogen May 1 - Oct 31	XXX	4.0	XXX	12
Total Phosphorus	XXX	2.0	XXX	4
Total Aluminum	XXX	Report Annl Avg	XXX	XXX
Total Iron	XXX	Report Annl Avg	XXX	XXX
Total Manganese	XXX	Report Annl Avg	XXX	XXX

Comments: All permit limitations, monitoring, requirements, and conditions will be retained into the next permit with the addition of E. Coli monitoring.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	20.0	XXX	40	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	12.0	XXX	36	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	4.0	XXX	12	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Aluminum	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Iron	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Manganese	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite


Compliance Sampling Location: Outfall 001 – after disinfection

Other Comments: Flow and Total Nitrogen are monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The limits for Total Residual Chlorine (TRC), CBOD₅, Total Suspended Solids, and Fecal Coliform are technology based on Chapter 92a.47. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. The Total Phosphorus limits are technology-based on Chapter 96.5. Total Aluminum, Total Iron, and Total Manganese are monitor only based on Chapter 92a.61.

Attachment 1
eMapPA – Receiving Stream Location and Data



Attachment 2
Google Earth – Aerial Site View



Attachment 3
USGS StreamStats – Outfall 001

StreamStats Report

Region ID:

PA

Workspace ID:


PA20250930172607225000

Clicked Point (Latitude, Longitude):

40.86884, -79.98532

Time:

2025-09-30 13:26:28 -0400



➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	11.5	square miles	2.26	1400
ELEV	Mean Basin Elevation	1272	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.476	ft ³ /s	43	43
30 Day 2 Year Low Flow	0.823	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.173	ft ³ /s	66	66
30 Day 10 Year Low Flow	0.309	ft ³ /s	54	54
90 Day 10 Year Low Flow	0.569	ft ³ /s	41	41

Low-Flow Statistics Citations

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

Attachment 4
USGS StreamStats – Endpoint

StreamStats Report

Region ID:

PA

Workspace ID:


PA20250930173906270000

Clicked Point (Latitude, Longitude):

40.86788, -79.98985

Time:

2025-09-30 13:39:26 -0400



► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	11.7	square miles	2.26	1400
ELEV	Mean Basin Elevation	1271	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.485	ft ³ /s	43	43
30 Day 2 Year Low Flow	0.838	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.176	ft ³ /s	66	66
30 Day 10 Year Low Flow	0.315	ft ³ /s	54	54
90 Day 10 Year Low Flow	0.58	ft ³ /s	41	41

Low-Flow Statistics Citations

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

Attachment 5
TRC Spreadsheet

TRC EVALUATION

0.173	= Q stream (cfs)	0.5	= CV Daily
0.025	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
	= % Factor of Safety (FOS)		=Decay Coefficient (K)
Source	Reference	AFC Calculations	Reference
TRC	1.3.2.iii	WLA_afc = 1.446	1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c
PENTOXSD TRG	5.1b	LTA_afc= 0.539	5.1d
Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635	
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$		
LTAMULT_afc	$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$		
LTA_afc	wla_afc*LTAMULT_afc		
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$		
LTAMULT_cfc	$\text{EXP}((0.5*\text{LN}(cvd^2/no_samples+1))-2.326*\text{LN}(cvd^2/no_samples+1)^0.5)$		
LTA_cfc	wla_cfc*LTAMULT_cfc		
AML MULT	$\text{EXP}(2.326*\text{LN}((cvd^2/no_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no_samples+1))$		
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)		
INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$		

Attachment 6
WQM 7.0 Results

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
		20C	34918	LITTLE CONNOQUENESSING CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
13.000	Connoquenessing	PA0102822	0.025	CBOD5	25		
				NH3-N	12.77	25.54	
				Dissolved Oxygen			4

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC			
20C	34918	LITTLE CONNOQUENESSING CREE	13.000	1038.00	11.50	0.00000	0.00	<input checked="" type="checkbox"/>			
Stream Data											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)	Temp pH (°C)
Q7-10	0.015	0.00	0.17	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
Discharge Data											
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
Connoquenessing	PA0102822	0.0250	0.0000	0.0000	0.000	25.00	7.00				
Parameter Data											
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)							
CBOD5	25.00	2.00	0.00	1.50							
Dissolved Oxygen	4.00	8.24	0.00	0.00							
NH3-N	25.00	0.00	0.00	0.70							

WQM 7.0 Hydrodynamic Outputs

SWP Basin			Stream Code		Stream Name								
20C			34918		LITTLE CONNOUENESSING CREEK								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
Q7-10 Flow													
13.000	0.17	0.00	0.17	.0387	0.00227	.426	10.31	24.19	0.05	1.268	20.91	7.00	
Q1-10 Flow													
13.000	0.11	0.00	0.11	.0387	0.00227	NA	NA	NA	0.04	1.541	21.29	7.00	
Q30-10 Flow													
13.000	0.24	0.00	0.24	.0387	0.00227	NA	NA	NA	0.06	1.097	20.71	7.00	

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20C	34918	LITTLE CONNOQUENESSING CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
13.000	Connoquenessin	15.06	50	15.06	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
13.000	Connoquenessin	1.8	12.77	1.8	12.77	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
13.00	Connoquenessing	25	25	12.77	12.77	4	4	0	0

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
20C	34918	LITTLE CONNOQUENESSING CREEK			
RMI	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH		
13.000	0.025	20.914	7.000		
Reach Width (ft)	Reach Depth (ft)	Reach WDRatio	Reach Velocity (fps)		
10.307	0.426	24.188	0.048		
Reach CBOD5 (mg/L)	Reach Kc (1/days)	Reach NH3-N (mg/L)	Reach Kn (1/days)		
6.20	0.762	2.33	0.751		
Reach DO (mg/L)	Reach Kr (1/days)	Kr Equation	Reach DO Goal (mg/L)		
7.468	14.089	Owens	5		
Reach Travel Time (days)		Subreach Results			
1.268	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)	
		0.127	5.61	2.12	7.89
		0.254	5.07	1.93	8.04
		0.380	4.58	1.75	8.10
		0.507	4.14	1.59	8.10
		0.634	3.75	1.45	8.10
		0.761	3.39	1.32	8.10
		0.888	3.06	1.20	8.10
		1.014	2.77	1.09	8.10
		1.141	2.50	0.99	8.10
		1.268	2.26	0.90	8.10

Attachment 7
TMS Spreadsheet

Discharge Information

Instructions Discharge Stream

Facility: Connoquenessing STP

NPDES Permit No.: PA0102822

Outfall No.: 001

Evaluation Type:

Wastewater Description: Sewage

Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)
			AFC	CFC	THH	
0.025	100	7				

			0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L									
	Chloride (PWS)	mg/L									
	Bromide	mg/L									
	Sulfate (PWS)	mg/L									
	Fluoride (PWS)	mg/L									
Group 2	Total Aluminum	µg/L	0.249								
	Total Antimony	µg/L									
	Total Arsenic	µg/L									
	Total Barium	µg/L									
	Total Beryllium	µg/L									
	Total Boron	µg/L									
	Total Cadmium	µg/L									
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L									
	Total Cobalt	µg/L									
	Total Copper	µg/L									
	Free Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L									
	Total Iron	µg/L	0.036								
	Total Lead	µg/L									
	Total Manganese	µg/L	0.319								
	Total Mercury	µg/L									
	Total Nickel	µg/L									
	Total Phenols (Phenolics) (PWS)	µg/L									
	Total Selenium	µg/L									
	Total Silver	µg/L									
	Total Thallium	µg/L									
	Total Zinc	µg/L									
	Total Molybdenum	µg/L									
Group 3	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								



Stream / Surface Water Information

Connoquenessing STP, NPDES Permit No. PA0102822, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Little Connoquenessing Creek**

No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	034918	13.3	1038	11.5			Yes
End of Reach 1	034918	12	1026	11.7			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	13.3	0.015							100		7				
End of Reach 1	12	0.015													

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	13.3														
End of Reach 1	12														

Model Results

Connoquenessing STP, NPDES Permit No. PA0102822, Outfall 001

Instructions **Results** [RETURN TO INPUTS](#) [SAVE AS PDF](#) [PRINT](#) All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC CCT (min): **8.481** PMF: **1** Analysis Hardness (mg/l): **100** Analysis pH: **7.00**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Aluminum	0	0		0	750	750	4,095	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	

CFC CCT (min): **8.481** PMF: **1** Analysis Hardness (mg/l): **100** Analysis pH: **7.00**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	8,190	WQC = 30 day average; PMF = 1
Total Manganese	0	0		0	N/A	N/A	N/A	

THH CCT (min): **8.481** PMF: **1** Analysis Hardness (mg/l): **N/A** Analysis pH: **N/A**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	5,480	

CRL CCT (min): **3.128** PMF: **1** Analysis Hardness (mg/l): **N/A** Analysis pH: **N/A**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Aluminum	0	0		0	N/A	N/A	N/A	

Total Iron	0	0		0	N/A	N/A	N/A
Total Manganese	0	0		0	N/A	N/A	N/A

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Aluminum	2,625	µg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	8,190	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	5,480	µg/L	Discharge Conc ≤ 10% WQBEL

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment █)
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment █)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment █)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment █)
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: █
<input type="checkbox"/>	Other: █