

Application Type Renewal
 Wastewater Type Sewage
 Facility Type SFTF

NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP

Application No. PA0103047
 APS ID 1110192
 Authorization ID 1478198

Applicant, Facility and Project Information

Applicant Name	<u>Jerome M. Laughlin</u>	Facility Name	<u>Laughlin Builders SFTF</u>
Applicant Address	8333 Edinboro Road Erie, PA 16509-4248	Facility Address	8333 Edinboro Road Erie, PA 16509-4265
Applicant Contact	Jerome M. Laughlin (Laughlin.beth@gmail.com)	Facility Contact	Jerome M. Laughlin (Laughlin.beth@gmail.com)
Applicant Phone	<u>(814) 440-1969</u>	Facility Phone	<u>(814) 866-1277</u>
Client ID	<u>44990</u>	Site ID	<u>250298</u>
SIC Code	<u>4952</u>	Municipality	<u>McKean Township</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>	County	<u>Erie</u>
Date Application Received	<u>March 1, 2024</u>	WQM Required	<u>No</u>
Date Application Accepted	<u>March 26, 2024</u>	WQM App. No.	<u>-</u>
Project Description	<u>Renewal of NPDES Permit for an existing discharge of treated sanitary wastewater.</u>		

Summary of Review

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

A. AMRs	F. Stormwater into sewers
B. DMRs	G. Right of way
C. Depth of Septage and Scum Measurement	H. Solids handling
D. Septic Tank Pumping	I. Public Sewerage Availability
E. Effluent Chlorine Optimization and Minimization	

II. SPECIAL CONDITIONS: None.

Permitted treatment consists of: Two 1,500 gallon septic tanks, alum feed for phosphorus control, a 500 gallon dosing tank, two surface sand filters, and tablet chlorine disinfection with a 500 gallon chlorine contact tank. (WQM Permit no. 2573402)

There are no open violations in efacts associated with the subject Client ID (44990) as of 2/19/2025.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Project Manager	2/19/2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	2/25/2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0017
Latitude	42° 1' 22.50"	Longitude	80° 7' 15.10"
Quad Name	-	Quad Code	-
Wastewater Description:	treated sanitary wastewater		
Receiving Waters	Unnamed Tributary to the Elk Creek (CWF, MF)	Stream Code	N/A
NHD Com ID	134205237	RMI	N/A
Drainage Area	0.88	Yield (cfs/mi ²)	0.067
Q ₇₋₁₀ Flow (cfs)	0.058	Q ₇₋₁₀ Basis	calculated
Elevation (ft)	1066	Slope (ft/ft)	0.00965
Watershed No.	15-A	Chapter 93 Class.	CWF, MF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	-		
Source(s) of Impairment	-		
TMDL Status	-	Name	-
Background/Ambient Data	Data Source		
pH (SU)	-	-	
Temperature (°F)	-	-	
Hardness (mg/L)	-	-	
Other:	-	-	
Nearest Downstream Public Water Supply Intake	Pennsylvania - Canada Border		
PWS Waters	Lake Erie	Flow at Intake (cfs)	N/A
PWS RMI	N/A	Distance from Outfall (mi)	42.0

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

No modeling was performed for this NPDES Permit renewal as septic tank/sand filter systems are capable of meeting CBOD5 and TSS averages of 10 mg/l, which are less than the inputs of the WQ model.

The TRC limits are technology-based using the TRC_Calc Spreadsheet (see Attachment 1). These are new limits set based on the SOP for SFTFs.

Compliance History

DMR Data for Outfall 001 (from January 1, 2024 to December 31, 2024)

Parameter	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24
Flow (MGD) Average Monthly	0.001	0.001	0.0009	0.0009	0.0009	0.001	0.001	0.001	0.001	0.001	0.001	0.001
TRC (mg/L) Average Monthly	0.26	0.24	0.2	0.56	0.56	0.31	0.32	0.36	0.59	0.26	0.31	0.32
TRC (mg/L) Instantaneous Maximum	0.26	0.24	0.2	0.56	0.56	0.31	0.32	0.36	0.59	0.26	0.31	0.32
BOD5 (mg/L) Average Monthly	2.6	< 2.4	< 2.4	< 2.0	3.1	6.1	< 2.4	< 2.4	10.4	< 2.2	4.1	< 2.4
TSS (mg/L) Average Monthly	10.5	4.5	8.0	< 2.5	7.5	6.5	6.5	6.0	5.5	< 2.5	3	3.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1.0	307.6	2	14.4	< 1	2.0	< 1.0	< 1	16	135.4	1.0

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/year	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/month	Grab
BOD ₅	XXX	XXX	XXX	10.0	XXX	20	1/month	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/month	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200 Geo Mean	XXX	XXX	1/month	Grab
Total Phosphorus	XXX	XXX	XXX	1.0 Annl Avg	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Flow is monitor only. The limits for pH are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are technology-based on Chapter 92a.48. The limits for BOD₅ and Total Suspended Solids are technology-based on the SOP for SFTFs. The limits for Fecal Coliform are technology-based on Chapter 92a.47. The limits for Total Phosphorus are technology-based on the 1969 International Joint Committee (IJC) agreement for Lake Erie.

Attachment 1

TRC EVALUATION																
Input appropriate values in A3:A9 and D3:D9																
Source	Reference	AFC Calculations		Reference	CFC Calculations											
TRC	1.3.2.iii	WLA_afc = 7.171		1.3.2.iii	WLA_cfc = 6.983											
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581											
PENTOXSD TRG	5.1b	LTA_afc = 2.672		5.1d	LTA_cfc = 4.060											
Source																
Effluent Limit Calculations																
PENTOXSD TRG	5.1f	AML MULT = 1.231		BAT/BPJ												
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		INST MAX LIMIT (mg/l) = 1.635												
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$															
LTAMULT_afc	$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^{0.5})$															
LTA_afc	wla_afc*LTAMULT_afc															
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$															
LTAMULT_cfc	$\text{EXP}((0.5*\text{LN}(cvd^2/no_samples+1))-2.326*\text{LN}(cvd^2/no_samples+1)^{0.5})$															
LTA_cfc	wla_cfc*LTAMULT_cfc															
AML MULT	$\text{EXP}(2.326*\text{LN}((cvd^2/no_samples+1)^{0.5})-0.5*\text{LN}(cvd^2/no_samples+1))$															
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)															
INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$															