

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0103209
 APS ID 1079958
 Authorization ID 1425232

Applicant and Facility Information

Applicant Name	<u>Wattsburg Area School District</u>	Facility Name	<u>Wattsburg Area School District Campus</u>
Applicant Address	<u>10782 Wattsburg Road</u> <u>Erie, PA 16509-6422</u>	Facility Address	<u>10782 Wattsburg Road</u> <u>Erie, PA 16509-6422</u>
Applicant Contact	<u>Eric Schultz</u>	Facility Contact	<u>Eric Schultz</u>
Applicant Phone	<u>(814) 824-3400</u>	Facility Phone	<u>(814) 824-3400</u>
Client ID	<u>58287</u>	Site ID	<u>236741</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Greene Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Erie</u>
Date Application Received	<u>January 30, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES renewal of an existing sewage discharge.</u>		

Summary of Review

This is an existing discharge for a minor sewage treatment facility.

Act 14 – Proof of Notification was submitted and received.

Existing treatment consists of (WQM Permit No. 2596408): a grit chamber, an equalization/comminutor tank, an additional equalization tank, two aeration tanks in series, a clarifier, two digesters, a dosing tank, two upflow filters in parallel, a chlorine contact tank, a dechlorination tank, and outfall pipe.

There are no open violations in WMS for the subject Client ID (58287) as of 1/10/2023. *CWY 1/10/2024*

Annual monitoring for E. Coli, Total Nitrogen and Total Phosphorus has been added per Department SOP for new and reissued NPDES permits with design flows exceeding 2000 GPD.

Sludge is hauled offsite by Don Green Sanitation as-needed.

The EPA Waiver is in effect.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania*

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	January 10, 2024
X		Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	1/10/2024

Summary of Review

Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0296</u>
Latitude	<u>42° 3' 14.40"</u>	Longitude	<u>-79° 54' 29.37"</u>
Quad Name	<u>Hammett</u>	Quad Code	<u>42079A8</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary of East Branch LeBoeuf Creek (TSF)</u>	Stream Code	<u>53537</u>
NHD Com ID	<u>127349464</u>	RMI	<u>89.02 mi</u>
Drainage Area	<u>0.98 mi²</u>	Yield (cfs/mi ²)	<u>0.0826</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.081</u>	Q ₇₋₁₀ Basis	<u>French Ck near Union City gage</u>
Elevation (ft)	<u>1327</u>	Slope (ft/ft)	<u>0.0072</u>
Watershed No.	<u>16-A</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.6</u>		<u>Median value from stream surveys (same as previous eval.)</u>
Temperature (°F)	<u>25</u>		<u>Default temp for a TSF stream</u>
Hardness (mg/L)	<u>2.0</u>		<u>Default value</u>
Other:	<u>0.1</u>		<u>Default value</u>
Nearest Downstream Public Water Supply Intake	<u>Cambridge Springs Waterworks</u>		
PWS Waters	<u>French Creek</u>	Flow at Intake (cfs)	<u>49</u>
PWS RMI	<u>---</u>	Distance from Outfall	<u>+/- 20 mi</u>

Changes Since Last Permit Issuance: None

Other Comments: None.

Treatment Facility Summary				
Treatment Facility Name: Wattsburg Area School District Campus - STP				
WQM Permit No.		Issuance Date		
2571403		4/2/71		
2592417		3/18/93		
2596408-A1		1/22/15		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Chlorine With Dechlorination	
Hydraulic Capacity (MGD)				
0.0296	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
	91	Not Overloaded	Holding Tank	Other WWTP

Changes Since Last Permit Issuance: None.

Other Comments: None.

Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	.0296
Latitude	42° 3' 14.51"	Longitude	-79° 54' 29.11"
Wastewater Description: Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: None.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
NH ₃ -N (5/1-10/31)	2.5	Average Monthly	WQM 7.0 v1.0b
NH ₃ -N (11/1-4/30)	7.5	Average Monthly	WQM 7.0 v1.0b
Dissolved Oxygen	5.0	Min	WQM 7.0 v1.0b
Total Residual Chlorine	0.21	Average Monthly	TRC Spreadsheet
Total Residual Chlorine	0.87	IMAX	TRC Spreadsheet

Comments: Ammonia-Nitrogen and Dissolved Oxygen limits are carried over from previous permit cycles and verified by WQM 7.0 modeling. The Instantaneous Maximum limit for Total Residual Chlorine has been changed to 0.87mg/l from 1.2 mg/l in accordance with modeling results from the Department's TRC Spreadsheet. A review of the facility's DMRs suggest the facility can meet the new IMAX TRC limit. *The calculated average monthly limits for DO, TRC, and Ammonia are less stringent than the previous permit, but the previous limits are attainable and will be retained. CWY 1/10/2024*

Best Professional Judgment (BPJ) Limitations

Comments: Total Phosphorus, Total Nitrogen, and E. Coli monitoring were added as BPJ limits per Department policy.

Anti-Backsliding

TRC modeling gave an average monthly limit of 0.26 mg/l but the previous limit of 0.21 mg/l will be retained in accordance with the Department's Anti-Backsliding policy.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.21	XXX	0.87	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/6 months	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	7.5	XXX	15	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.5	XXX	5	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/6 months	8-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection and dechlorination.

Other Comments: None.

TRC Spreadsheet

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.081	= Q stream (cfs)		0.5	= CV Daily	
0.0296	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.583		1.3.2.iii	WLA_cfc = 0.561
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.217		5.1d	LTA_cfc = 0.326
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.268		AFC	
		INST_MAX_LIMIT (mg/l) = 0.875			
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...]$ $...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$				
LTA_afc	$wla_afc*LTAMULT_afc$				
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...]$ $...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$				
LTA_cfc	$wla_cfc*LTAMULT_cfc$				
AML_MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$				
AVG_MON_LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$				
INST_MAX_LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$				

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16A	53570	Trib 53570 of E Branch Le Boeuf Cr	89.020	1327.00	0.98	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.083	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.60	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Wattsburg Area	PA0103209	0.0180	0.0180	0.0180	0.000	20.00	6.90

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16A	53570	Trib 53570 of E Branch Le Boeuf Cr	87.980	1291.00	1.74	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.60	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
 16A 53570 Trib 53570 of E Branch Le Boeuf Cr

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	89.020 Wattsburg Area	6.4	18.17	6.4	18.17	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	89.020 Wattsburg Area	1.18	5.47	1.18	5.47	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	89.02 Wattsburg Area	25	25	5.47	5.47	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16A	53570	Trib 53570 of E Branch Le Boeuf Cr		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
89.020	0.018	23.725	7.294	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
4.914	0.356	13.808	0.062	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
7.87	0.939	1.47	0.932	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.637	25.000	Owens	6	
<u>Reach Travel Time (days)</u>	Subreach Results			
1.018	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.102	7.02	1.34	7.54
	0.204	6.27	1.22	7.54
	0.305	5.60	1.11	7.54
	0.407	5.00	1.00	7.54
	0.509	4.46	0.91	7.54
	0.611	3.98	0.83	7.54
	0.712	3.56	0.76	7.54
	0.814	3.18	0.69	7.54
	0.916	2.84	0.63	7.54
	1.018	2.53	0.57	7.54

RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
89.020	Wattsburg Area	PA0103209	0.018	CBOD5	25		
				NH3-N	5.47	10.94	
				Dissolved Oxygen			4

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16A		53570				Trib 53570 of E Branch Le Boeuf Cr						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
89.020	0.08	0.00	0.08	.0278	0.00656	.356	4.91	13.81	0.06	1.018	23.72	7.29
Q1-10 Flow												
89.020	0.05	0.00	0.05	.0278	0.00656	NA	NA	NA	0.05	1.212	23.26	7.22
Q30-10 Flow												
89.020	0.11	0.00	0.11	.0278	0.00656	NA	NA	NA	0.07	0.891	23.99	7.34