

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0103594  
 APS ID 1088344  
 Authorization ID 1439453

**Applicant and Facility Information**

Applicant Name	<u>Madhuri Gorrepati</u>	Facility Name	<u>Windsor MHP</u>
Applicant Address	<u>3824 Trythall Street</u> <u>Bethlehem, PA 18020-2925</u>	Facility Address	<u>2871 Us Route 6n East</u> <u>Edinboro, PA 16412-9801</u>
Applicant Contact	<u>Madhuri Gorrepati</u>	Facility Contact	<u>Madhuri Gorrepati</u>
Applicant Phone	<u></u>	Facility Phone	<u></u>
Client ID	<u>205841</u>	Site ID	<u>447204</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Washington Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Erie</u>
Date Application Received	<u>May 1, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal <i>and Transfer</i> of an NPDES Permit for a Non-Municipal Minor Sewage Treatment Facility.</u>		

**Summary of Review**

Proposed is the renewal *and transfer* of an NPDES Permit for an existing sewage treatment plant discharge from the Windsor Mobile Home Park.

Treatment consists of a Lagoon System; influent enters a solids settling tank, then the primary lagoon, passes through a bar screen on the way to the secondary lagoon, then passes over the calcium hypochlorite tablet feeder, enters the contact chamber, and then flows over a weir wall into discharge pipe and outfall.

There are currently 13 open violations in WMS for the subject Client ID (380336) as of 2/14/24. All of the open violations come from the Safe Drinking Water program.

There are currently 26 DMR violations within the permit term, 11 of those violations happened within the last two years and will be covered in depth further in the Compliance History section of this Fact Sheet.

Act 14 – Notification was submitted and received.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP’s discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Dustin Hargenrater Dustin Hargenrater / Civil Engineer Trainee	February 14, 2023
		Vacant / Environmental Engineer Manager	Okay to Draft JCD 3/4/2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0092</u>
Latitude NHD	<u>41° 53' 2.03"</u>	Longitude NHD	<u>-80° 4' 27.11"</u>
Latitude DP	<u>41° 53' 10.00"</u>	Longitude DP	<u>-80° 4' 35.53"</u>
Quad Name	<u>Cambridge Springs</u>	Quad Code	<u>41080H1</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary of Little Conneauttee Creek (CWF)</u>	Stream Code	<u>52965</u>
NHD Com ID	<u>127344700</u>	RMI	<u>2.23</u>
Drainage Area	<u>Dry - 0.04</u>	Yield (cfs/mi <sup>2</sup> )	<u>Dry - 0</u>
Q <sub>7-10</sub> Flow (cfs)	<u>Perennial - 0.39</u>	Q <sub>7-10</sub> Basis	<u>Perennial - 0.042</u>
Elevation (ft)	<u>Dry - 0</u>		<u>Dry Stream</u>
Watershed No.	<u>Perennial - 0.0162</u>		<u>USGS - StreamStats</u>
Existing Use	<u>Dry - 1425</u>	Slope (ft/ft)	<u>0.013319</u>
Exceptions to Use	<u>Perennial - 1406</u>	Chapter 93 Class.	<u>CWF</u>
Assessment Status	<u>Attaining Use(s)</u>	Existing Use Qualifier	<u></u>
Cause(s) of Impairment	<u></u>	Exceptions to Criteria	<u></u>
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	<u></u>
Temperature (°F)	<u>20</u>	Default - CWF	<u></u>
Hardness (mg/L)	<u>100</u>	Default	<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Aqua Pennsylvania Inc. - Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1,376</u>
PWS RMI	<u>90.0</u>	Distance from Outfall (mi)	<u>92.4</u>

Changes Since Last Permit Issuance: None

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Windsor Mobile Home Park				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
2570410		October 5, 1970		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Stabilization Lagoon	Hypochlorite	0.0092
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0092	15.3	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments:

Lagoon treatment with a design flow over 2000 gpd.

Treatment: screening, 43,700-square foot primary lagoon and 6,750-square foot secondary lagoon with chlorination.

30-unit mobile home park.

Compliance History

DMR Data for Outfall 001 (from April 1, 2022 to March 31, 2023)

Parameter	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22
Flow (MGD) Average Monthly	0.0031	0.0034	0.0032	0.00267 5	0.00267 5	0.00276 7	0.00282 5	0.0031	0.00262 5	0.00228 0	0.00252	0.00212 5
pH (S.U.) Daily Minimum	6.7	6.8	6.7	6.8	6.6	6.7	6.7	6.8	6.7	6.7	6.8	6.7
pH (S.U.) Daily Maximum	7.3	7.3	7.2	7.4	7.2	7.3	7.3	7.4	7.2	7.1	7.4	7.1
DO (mg/L) Daily Minimum	5.06	5.01	5.27	5.14	5.36	4.46	4.46	4.59	4.62	4.98	5.42	7.21
TRC (mg/L) Average Monthly	0.14	0.08	0.09	0.21	0.08	0.07	0.11	0.10	0.09	0.09	0.08	0.21
CBOD5 (mg/L) Average Monthly	13.7	12.6	2.0	2.0	3.23	8.905	8.9005	9.105	18.6	12.65	7.53	12.435
CBOD5 (mg/L) Instantaneous Maximum	18.0	16.1	2.0	2.0	4.46	9.36	9.36	12.3	23.5	14.2	12.0	18.3
TSS (mg/L) Average Monthly	17.0	22.0	5.0	5.0	7.0	17.5	17.5	24.5	64.5	34.0	8.5	15.0
TSS (mg/L) Instantaneous Maximum	17.0	26.0	5.0	5.0	9.0	21.0	21.0	26.0	66.0	38.0	12.0	21.0
Fecal Coliform (CFU/100 ml) Geometric Mean	12	1.5	1	1	6	21	21	3	377	116	64	2
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	23	2.0	1	1	31	43	43	5	725	119	411	3
Total Nitrogen (mg/L) Annual Average				0.729								
Ammonia (mg/L) Average Monthly	3.47	5.1	5.85	5.85	3.98	3.47	3.47	1.85	2.17	1.799	3.78	6.195
Ammonia (mg/L) Instantaneous Maximum	3.72	7.08	10.9	10.9	4.94	4.44	4.44	2.68	2.36	2.63	4.93	6.66
Total Phosphorus (mg/L) Annual Average				0.20								

**Compliance History**

**Effluent Violations for Outfall 001, from: May 1, 2022 To: March 31, 2023**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TSS	06/30/22	Avg Mo	34.0	mg/L	30.0	mg/L
TSS	07/31/22	Avg Mo	64.5	mg/L	30.0	mg/L
TSS	07/31/22	IMAX	66.0	mg/L	60.0	mg/L
Fecal Coliform	07/31/22	Geo Mean	377	CFU/100 ml	200	CFU/100 ml

Other Comments: High temperatures in the months of June and July expected to effect TSS and Fecal Coliform reporting. No external comments were made, and no corrective action was reported for these violations.

The permittee has demonstrated its ability to comply by meeting the proposed limits at least 75% of the time considering existing performance data, no compliance schedule will be established in the draft permit.

Based on the definition of chronic or significant violations stated in the SOP this facility only has 2 significant violations within the last two years. The first being in September of 2021, and the second being in July of 2022.

**Effluent Violation Summary from May 1, 2021 to May 1, 2023:**

**June 2021:** CBOD5 Average Monthly reported value **35 mg/L**, permit limit **25 mg/L**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported.

**July 2021:** CBOD5 Average Monthly reported value **27 mg/L**, permit limit **25 mg/L**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported.

**September 2021:** Fecal Coliform Geometric Mean reported value **739 CFU/100 ml**, permit limit **200 CFU/100 ml**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported.

**September 2021:** Fecal Coliform Instantaneous Maximum reported value **1120 CFU/100 ml**, permit limit **1000 CFU/100 ml**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported.

**October 2021:** Total Suspended Solids Average Monthly reported value **35 mg/L**, permit limit **30 mg/L**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported.

**November 2021:** Total Residual Chlorine Average Monthly reported value **.9 mg/L**, permit limit **.5 mg/L**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported.

**December 2021:** Total Suspended Solids Average Monthly reported value **31 mg/L**, permit limit **30 mg/L**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported.

**June 2022:** Total Suspended Solids Average Monthly reported value **34 mg/L**, permit limit **30 mg/L**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported.

**July 2022:** Total Suspended Solids Average Monthly reported value **64.5 mg/L**, permit limit **30 mg/L**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported.

**July 2022:** Fecal Coliform Geometric Mean reported value **377 CFU/100 ml**, permit limit **200 CFU/100 ml**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported.

**July 2022:** Total Suspended Solids Instantaneous Maximum reported value **66 mg/L**, permit limit **60 mg/L**. No Cause of Non-Compliance, Corrective Action, or External Comments were reported

**Inspection Summary:**

**Inspection ID:** 3005473  
**Inspected Date:** 03/03/2020  
**Inspection Type:** Administrative/File Review  
**Inspection Result:** Violations Noted  
**Inspector:** Tami Opila  
**Violations:** Failure to pay annual fee

**Inspection ID:** 3068914  
**Inspected Date:** 08/04/2020  
**Inspection Type:** Compliance Evaluation  
**Inspection Result:** No Violations Noted  
**Inspector:** Melissa Carver  
**Violations:** None

**Inspection ID:** 3082283  
**Inspected Date:** 09/04/2020  
**Inspection Type:** Follow-up Inspection  
**Inspection Result:** No Violations Noted  
**Inspector:** Melissa Carver  
**Violations:** None

**Inspection ID:** 3160997  
**Inspected Date:** 03/12/2021  
**Inspection Type:** Administrative/File Review  
**Inspection Result:** Violations Noted  
**Inspector:** Sean Singer  
**Violations:** Violation of Effluent limits in Part A of the Permit

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.0092</u>
<b>Latitude</b> <u>41° 53' 10.00"</u>	<b>Longitude</b> <u>-80° 4' 35.53"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

The discharge was modeled using WQM 7.0 to evaluate CBOD<sub>5</sub>, Ammonia-Nitrogen, and Dissolved Oxygen parameters. The modeling results show technology based effluent limitations for CBOD<sub>5</sub> are appropriate. The modeling results also confirm that Ammonia-Nitrogen and Dissolved Oxygen limitations are necessary to meet in-stream water quality criterion. Since this facility discharges to a dry stream the dry stream was modeled first. Dry stream conditions exist for about .1 miles before the discharge reaches perennial conditions at Tributary 52965 of Little Conneauttee Creek. The following modeling considerations were used when modeling the dry stream:

D.O. Goal: 2 mg/L for Dry Streams

CBOD<sub>5</sub>: In stream concentration of 0 for dry streams at confluence with Tributary 52965.

NH<sub>3</sub>-N: In stream concentration of 0 for dry streams at confluence with Tributary 52965.

Yield: 0.001 used for Dry Streams

Discharge pH: Calculated using averages of June-September (dry season) for the facility.

The conclusion that the dry stream model provided was that the concentration of the three modeled parameters was still declining. Using the data from the dry stream model D.O. Simulation, we can accurately represent the concentration of the parameters entering the stream at perennial conditions.

The perennial stream modeling suggested that more stringent limits were not required for CBOD<sub>5</sub> and Dissolved Oxygen. This determination was made because the inputted data from the D.O. Simulation did not change when modeling the stream for perennial conditions. However, the data did change for Ammonia-Nitrogen which suggests that a limit should be put in place for this parameter. The perennial stream modeling suggested a monthly average limit of 4.81 mg/L and a maximum concentration limit of 9.62 mg/L. Since this is not a POTW it will not be subject to monthly mass loading limits for CBOD<sub>5</sub>, Total Suspended Solids, and Ammonia-Nitrogen. Using the Round-Off Guidelines in the Technical Guidance for the Development and Specification of Effluent Limitations these values will translate to 4.8 mg/L monthly limit and 9.6 mg/L IMAX limit. The facility is able to meet this limitation over 75% of the time from the last 4 years of effluent data so a compliance schedule will not be developed.

The Total Suspended Solids, pH, Fecal Coliform, or Total Residual Chlorine parameters are not evaluated using WQM 7.0. The bases for the proposed technology-based limitations are listed in the table above. WQM 7.0 and TRC\_CALC output files are attached to this fact sheet.

**Best Professional Judgment (BPJ) Limitations**

A Dissolved Oxygen minimum limitation of 4.0 mg/L will be implemented based on the standard in 25 PA Code Chapter 93 and best professional judgement.

**Anti-Backsliding**

N/A

**Additional Considerations**

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). Sewage discharges with design flows > 2,000 gpd require monitoring, at a minimum, for Total Nitrogen and Total Phosphorous in new and reissued permits. A monitoring frequency of once per year is acceptable. The discharge is to water not impaired for nutrients.

Monitoring frequency for the proposed effluent limits are based on Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	3/week	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	3/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	3/week	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	14.4	XXX	28.8	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	4.8	XXX	9.6	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
E. Coli	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection

TRC\_CALC

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.12	= Q stream (cfs)		0.5	= CV Daily
0.009	= Q discharge (MGD)		0.5	= CV Hourly
24	= no. samples		1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)			= Decay Coefficient (K)
Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 2.768	1.3.2.iii	WLA_cfc = 2.691
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 1.032	5.1d	LTA_cfc = 1.565
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.261		
PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.500	BAT/BPJ	
		INST_MAX_LIMIT (mg/l) = 1.597		
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST_MAX_LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)			

**WQM 7.0 v1.1 – Dry Stream Model**

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16A		52960				Trib 52960 to Little Conneauttee Cr						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.100	0.00	0.00	0.00	.0139	0.05303	.293	.97	3.32	0.05	0.125	20.00	6.88
<b>Q1-10 Flow</b>												
0.100	0.00	0.00	0.00	.0139	0.05303	NA	NA	NA	0.00	0.000	0.00	0.00
<b>Q30-10 Flow</b>												
0.100	0.00	0.00	0.00	.0139	0.05303	NA	NA	NA	0.00	0.000	0.00	0.00

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16A	52960	Trib 52960 to Little Conneauttee Cr	0.100	1425.00	0.04	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	6.88	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Windsor MHP	PA0103594	0.0090	0.0090	0.0090	0.000	20.00	6.88

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	0.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16A	52960	Trib 52960 to Little Conneauttee Cr	0.000	1397.00	0.04	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	6.88	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	20.00	6.88
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	0.00	0.00	0.00	1.50			
Dissolved Oxygen	0.00	0.00	0.00	0.00			
NH3-N	0.00	0.00	0.00	0.70			

### WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16A	52960	Trib 52960 to Little Conneauttee Cr

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.10	Windsor MHP	25	25	25	25	4	4	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
16A	52960	Trib 52960 to Little Conneauttee Cr			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
0.100	0.009	20.000		6.880	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
0.975	0.293	3.322		0.049	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
24.94	1.500	24.94		0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
4.011	27.717	Owens		2	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>				
0.125	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.013	24.47	24.72	4.09	
	0.025	24.02	24.50	4.17	
	0.038	23.57	24.29	4.24	
	0.050	23.13	24.08	4.31	
	0.063	22.70	23.87	4.37	
	0.075	22.28	23.66	4.44	
	0.088	21.86	23.45	4.50	
	0.100	21.46	23.25	4.56	
	0.113	21.06	23.05	4.62	
	0.125	20.67	22.84	4.68	

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
16A		52960	Trib 52960 to Little Conneauttee Cr				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.100	Windsor MHP	PA0103594	0.009	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

**WQM 7.0 v1.1 – Perennial Conditions Modeling**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16A	52960	Trib 52960 to Little Conneauttee Cr	2.230	1406.00	0.39	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.042	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Windsor MHP	PA0103594	0.0090	0.0090	0.0090	0.000	20.00	6.88

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	20.67	2.00	0.00	1.50
Dissolved Oxygen	4.68	8.24	0.00	0.00
NH3-N	22.84	0.10	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16A	52960	Trib 52960 to Little Conneauttee Cr	1.774	1335.00	0.76	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.043	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16A		52960				Trib 52960 to Little Conneauttee Cr						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
2.230	0.02	0.00	0.02	.0139	0.02951	.292	2.45	8.39	0.04	0.661	20.00	6.94
<b>Q1-10 Flow</b>												
2.230	0.01	0.00	0.01	.0139	0.02951	NA	NA	NA	0.04	0.746	20.00	6.93
<b>Q30-10 Flow</b>												
2.230	0.02	0.00	0.02	.0139	0.02951	NA	NA	NA	0.05	0.599	20.00	6.95

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Wasteload Allocations**

SWP Basin      Stream Code      Stream Name  
16A                      52960                      Trib 52960 to Little Conneauttee Cr

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.230	Windsor MHP	17.81	30.99	17.81	30.99	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.230	Windsor MHP	1.92	4.81	1.92	4.81	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.23	Windsor MHP	20.67	20.67	4.81	4.81	4.68	4.68	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16A	52960	Trib 52960 to Little Conneauttee Cr		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
2.230	0.009	20.000		6.940
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
2.450	0.292	8.395		0.042
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
10.63	1.260	2.27		0.700
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
6.596	25.372	Owens		6
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.661	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.066	9.78	2.17	7.84
	0.132	9.00	2.07	8.13
	0.198	8.28	1.98	8.24
	0.264	7.62	1.89	8.24
	0.331	7.01	1.80	8.24
	0.397	6.45	1.72	8.24
	0.463	5.93	1.65	8.24
	0.529	5.46	1.57	8.24
	0.595	5.02	1.50	8.24
	0.661	4.62	1.43	8.24

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
16A		52960		Trib 52960 to Little Conneauttee Cr			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.230	Windsor MHP	PA0103594	0.009	CBOD5	20.67		
				NH3-N	4.81	9.62	
				Dissolved Oxygen			4.68