

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0103641
APS ID 1046876
Authorization ID 1368024

Applicant and Facility Information

Applicant Name	<u>Wilmington Township Sewer Authority</u>	Facility Name	<u>Wilmington Township Sewer Authority Orchard Terrace STP</u>
Applicant Address	<u>669 Wilson Mill Road</u> <u>New Castle, PA 16105</u>	Facility Address	<u>204 Orchard Terrace</u> <u>New Castle, PA 16105</u>
Applicant Contact	<u>Tracey Deal, Secretary</u> <u>wilmingtontwp@comcast.net</u>	Facility Contact	<u>Jim Schneider, Chairman</u> <u>wilmingtontwp@comcast.net</u>
Applicant Phone	<u>(724) 946-2560</u>	Facility Phone	<u>(724) 946-2560</u>
Client ID	<u>36348</u>	Site ID	<u>262274</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Wilmington Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lawrence County</u>
Date Application Received	<u>August 30, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 2, 2021</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of an existing NPDES Permit for an existing discharge of treated sanitary wastewater from a Publicly Owned Treatment Works (POTW).</u>		

Summary of Review

Act 14 - Proof of Notification was submitted and received.
A Part II Water Quality Management permit is not required at this time.
The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling
- D. Effluent Chlorine Optimization and Minimization

SPECIAL CONDITIONS:

- II. Solids Management

There is 1 open violation in EFACTS associated with the subject Client ID (36348) as of 8/2/2022 (see Attachment 1).

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	8/2/2022 AJP 8/2/2022
X		Vacant / Environmental Engineer Manager	Okay to Draft JCD 8/8/2022

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.042</u>
Latitude	<u>40° 05' 53.00"</u>	Longitude	<u>-80° 20' 56.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to the Little Neshannock Creek (TSF)</u>	Stream Code	<u>UNT to 35515</u>
NHD Com ID	<u>130032044</u>	RMI	<u>1.53</u>
Drainage Area	<u>0.75 mi²</u>	Yield (cfs/mi ²)	<u>0.032</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.024</u>	Q ₇₋₁₀ Basis	<u>previously calculated</u>
Elevation (ft)	<u>1140</u>	Slope (ft/ft)	<u>0.0251</u>
Watershed No.	<u>20-A</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Beaver Falls Municipal Authority - Eastvale</u>		
PWS Waters	<u>Beaver River</u>	Flow at Intake (cfs)	<u>561</u>
PWS RMI	<u>5.0</u>	Distance from Outfall (mi)	<u>30.0</u>

Sludge use and disposal description and location(s): Sludge is hauled to the Mahoning Township WWTP (PA0240095), where it ends up at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.042 MGD of treated sewage from an existing Publicly Owned Treatment Works (POTW) in Wilmington Township, Lawrence County.

Permitted treatment consists of: Two extended aeration tanks, two final clarifiers, two aerobic digesters, gas chlorine disinfection with two contact tanks, tablet sodium sulfite dechlorination, and post aeration.
(WQM Permit no. 3790401)

1. Streamflow:

Unnamed Tributary to the Little Neshannock Creek at Outfall 001:

Yieldrate: 0.032 cfsm previous WQPRs
Drainage Area: 0.75 sq. mi. previous WQPRs
% of stream allocated: 100% Basis: No nearby discharges
Q₇₋₁₀: 0.024 cfs calculated

2. Wasteflow:

Maximum discharge: 0.042 MGD = 0.065 cfs
Runoff flow period: 24 hours Basis: Runoff flow for a Municipal STP

There is less than 3 parts stream flow (Q7-10) to 1 part effluent (design flow) at the discharge point. However, since this is an existing discharge, the more stringent treatment requirements cannot be achieved, and the receiving stream is not impaired by the discharge, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, will not be implemented in this NPDES Permit renewal.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, Phosphorus, NH₃-N, CBOD₅, Dissolved Oxygen, and Total Residual Chlorine.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits

The measurement frequency was previously set to 3/day. It will be set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 mg/l as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows between 0.002 MGD and 0.05 MGD.

e. Total Phosphorus

Limit not necessary

Basis: Chapter 96.5 does not apply. However, the previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

Limit necessary due to:

Discharge to lake, pond, or impoundment

Discharge to stream

Basis N/A

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 7.2 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for TSF modeling)

Background NH₃-N concentration: 0.1 mg/l

Basis: Default value.

Calculated NH₃-N Summer limits: 1.9 mg/l (monthly average)

3.8 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 5.7 mg/l (monthly average)

11.4 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 2), which are less restrictive than the limits calculated in the previous NPDES Permit. The winter limits are calculated as three times the summer limits. The newly calculated limits are still less restrictive than the previous limits, which are attainable, so they will be retained.

h. CBOD₅

Median discharge pH to be used: 7.2 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for TSF modeling)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD₅ limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 1), which are the same as the previous NPDES Permit and will be retained.

i. Influent Total Suspended Solids and BOD₅

Monitoring for these two parameters will be retained as recommended in the SOP for POTWs, as authorized under Chapter 92a.61.

j. Dissolved Oxygen (DO)

- 4.0 mg/l - minimum desired in effluent to protect all aquatic life.
- 5.0 mg/l - required in effluent for CWF, WWF, or TSF based on WQ Model.
- 6.0 mg/l - minimum required due to discharge going to a drainage swale or ditch.
- 8.0 mg/l - required due to discharge going to a naturally reproducing salmonid stream

Discussion: A Dissolved Oxygen technology-based minimum of 5.0 mg/l is recommended by the WQ Model (see Attachment 2), and the SOP, based on Chapter 93.7, under the authority of Chapter 92a.61. The Dissolved Oxygen minimum of 5.0 mg/l is the same as in the previous permit so it will be retained with this renewal.

The measurement frequency was previously set to 3/day. It will be set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

k. Total Residual Chlorine (TRC)

- TRC limits: 0.063 mg/l (monthly average)
0.205 mg/l (instantaneous maximum)

Basis: The calculated TRC monthly average limit above (see Attachment 3) is more restrictive than in the previous permit and will be set with this renewal. The new limit should be attainable. The previous instantaneous maximum limit of 0.11 mg/l is more restrictive than the limit above so it will be retained.

The measurement frequency was previously set to 3/week. It will be set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

- No limit necessary

Basis: N/A

4. Reasonable Potential Analysis:

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 by the Department's Toxics Management Spreadsheet due to a lack of non-sewage data.

5. Reasonable Potential for Downstream Public Water Supply (PWS):

The Reasonable Potential Analysis above does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no non-sewage sample data was provided, no calculations were performed.

Nearest Downstream potable water supply (PWS): Beaver Falls Municipal Authority - Eastvale

Distance downstream from the point of discharge: 30.0 miles (approximate)

- No limits necessary
- Limits needed

Basis: Significant dilution available.

6. Anti-Backsliding:

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

7. Flow Information:

100% of the flow comes from the Wilmington Township, which is a 100% separate sewer system.

8. Attachment List:

- Attachment 1 - WMS Open Violations by Client
- Attachment 2 - WQ Modeling Printouts
- Attachment 3 - TRC_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from June 1, 2021 to May 31, 2022)

Parameter	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21
Flow (MGD) Average Monthly	0.0346	0.0356	0.0365	0.0378	0.0224	0.0241	0.0216	0.0192	0.0313	0.037	0.0327	0.021
Flow (MGD) Daily Maximum	0.0555	0.0586	0.0577	0.0673	0.0316	0.0389	0.0257	0.0263	0.036	0.056	0.074	0.0263
pH (S.U.) Minimum	7.3	7.5	7.2	6.7	6.9	6.9	6.9	7.1	6.9	6.9	6.9	7.1
pH (S.U.) Maximum	8.0	8.2	7.9	7.7	7.3	7.4	7.4	7.6	7.7	7.8	7.6	7.5
DO (mg/L) Minimum	6.1	8.1	8.6	8.6	9.0	9.1	8.5	7.78	6.38	5.07	6.2	7.19
TRC (mg/L) Average Monthly	0.05	0.05	0.05	0.05	0.06	0.05	0.05	< 0.05	0.04	0.05	0.07	< 0.04
TRC (mg/L) Instantaneous Maximum	0.10	0.09	0.09	0.09	0.23	0.10	0.07	0.09	0.10	0.07	0.10	0.09
CBOD5 (lbs/day) Average Monthly	4.0	2.0	2.0	1.0	0.8	0.6	0.6	0.6	0.9	0.8	0.6	< 0.4
CBOD5 (lbs/day) Weekly Average	5.0	2	2.0	1	0.9	0.7	0.6	0.8	1.0	0.8	0.6	< 0.4
CBOD5 (mg/L) Average Monthly	11.6	6.28	5.05	5.41	3.78	2.84	3.08	4.31	5.26	2.71	2.43	< 2
CBOD5 (mg/L) Weekly Average	11.7	6.64	5.09	7.3	4.53	3.04	3.13	5.45	7.94	2.75	2.7	< 2
BOD5 (lbs/day) Influent Average Monthly	44	34	41	29	27132	34	22	39	79	33	46	56
BOD5 (mg/L) Influent Average Monthly	131	140	106	167	132	161	118	292	395	186	122	304
TSS (lbs/day) Average Monthly	7.0	3.0	3.0	2.0	2.0	2.0	1.0	0.9	< 1.0	2.0	1.0	< 1.0
TSS (lbs/day) Influent Average Monthly	17	15	15	19	17	19	8	34	32	27	43	30
TSS (lbs/day) Weekly Average	9.0	4.0	3.0	2.0	3.0	2.0	2.0	1.0	< 1.0	2.0	2.0	1.0
TSS (mg/L) Average Monthly	19.2	11	8.1	8.8	10.6	7	7.4	< 7.2	< 5.8	6.1	6.2	< 5
TSS (mg/L) Influent Average Monthly	54	62	36	103	82	87	44	257	147	155	115	156
TSS (mg/L) Weekly Average	20.8	13.6	10	9.4	13.8	9	8.6	9.4	6.6	6.2	6.6	5

Fecal Coliform (No./100 ml) Geometric Mean	15	5	< 5	50	188	12	70	< 11	1	17	3	4
Fecal Coliform (No./100 ml) Instantaneous Maximum	20	6	30	500	645	14	86	120	1	143	4	5
Total Nitrogen (mg/L) Average Monthly	11.1	7.06	9.92	9.66	973	9.32	445.2	21.9	18.8	33.2	11.5	10.1
Ammonia (lbs/day) Average Monthly	< 0.40	< 0.2	< 0.2	0.09	< 0.1	< 0.1	< 0.1	0.50	< 0.60	< 0.10	< 0.10	< 0.30
Ammonia (mg/L) Average Monthly	< 1.5	< 0.95	< 0.5	< 0.5	< 0.5	< 0.56	< 0.5	3.69	< 3.62	< 0.5	< 0.5	< 1.62
Total Phosphorus (mg/L) Average Monthly	1.84	0.736	1.35	2.65	1.7	1.97	2.25	3.02	2.69	3.55	2.31	2.05

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.063	XXX	0.11	1/day	Grab
CBOD5	8.8	14.0	XXX	25.0	40.0	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	10.5	15.8	XXX	30.0	45.0	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	1.1	XXX	XXX	3.0	XXX	6	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	0.35	XXX	XXX	1.0	XXX	2	2/month	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are water quality-based on Chapter 93.7. The limits for CBOD₅, Total Suspended Solids, and Fecal Coliform are technology based on Chapter 92a.47. Monitoring for influent BOD₅ and influent Total Suspended Solids is based on Chapter 92a.61. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7.

Attachment 1



**WATER MANAGEMENT SYSTEM
 OPEN VIOLATIONS BY CLIENT**

Client ID: 36348
 Client: All

Open Violations: 1

CLIENT ID	CLIENT	PF ID	FACILITY	PF KIND	PF STATUS	INSP PROGRAM
36348	WILMINGTON TWP SEW AUTH	280884	WILMINGTON TWP SA ORCHARD TERR	Sewage Publicly Owned (Muni)	Active	WPC NPDES

PROGRAM SPECIFIC ID	INSP ID	VIOLATION ID	INSPECTION CATEGORY	VIOLATION DATE	VIOLATION CODE	VIOLATION	PF INSPECTOR	INSP REGION
PA0103641	3344534	950768	PF	04/08/2022	92A.44	NPDES - Violation of effluent limits in Part A of permit	PUDLICK,DAN	NWRO

Attachment 2

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
20A		35515		NESHANNOCK CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.530	Wilmington Twp	PA0103641	0.042	CBOD5	25		
				NH3-N	1.95	3.9	
				Dissolved Oxygen			5

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	35515	NESHANNOCK CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
1.530	0.042	25.000		7.136
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
3.888	0.347	11.217		0.066
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
18.80	1.257	1.42		1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
5.685	28.081	Owens		5
<u>Reach Travel Time (days)</u>	Subreach Results			
1.416	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.142	15.02	1.23	6.80
	0.283	12.01	1.06	7.12
	0.425	9.60	0.92	7.36
	0.566	7.67	0.79	7.54
	0.708	6.13	0.69	7.54
	0.850	4.90	0.59	7.54
	0.991	3.92	0.51	7.54
	1.133	3.13	0.44	7.54
	1.275	2.50	0.38	7.54
	1.416	2.00	0.33	7.54

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35515	NESHANNOCK CREEK	1.530	1140.00	0.75	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.032	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Wilmington Twp	PA0103641	0.0420	0.0000	0.0000	0.000	25.00	7.20

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35515	NESHANNOCK CREEK	0.000	937.00	1.64	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.032	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
 20A 35515 NESHANNOCK CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.530	Wilmington Twp	9.53	11.79	9.53	11.79	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.530	Wilmington Twp	1.3	1.95	1.3	1.95	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.53	Wilmington Twp	25	25	1.95	1.95	5	5	0	0

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20A		35515				NESHANNOCK CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
1.530	0.02	0.00	0.02	.065	0.02513	.347	3.89	11.22	0.07	1.416	25.00	7.14
Q1-10 Flow												
1.530	0.02	0.00	0.02	.065	0.02513	NA	NA	NA	0.06	1.500	25.00	7.15
Q30-10 Flow												
1.530	0.03	0.00	0.03	.065	0.02513	NA	NA	NA	0.07	1.345	25.00	7.12

Attachment 3

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.024	= Q stream (cfs)			0.5	= CV Daily
0.042	= Q discharge (MGD)			0.5	= CV Hourly
30	= no. samples			1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream			1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge			15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value			720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)			0	= Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.137		1.3.2.iii	WLA_cfc = 0.126
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.051		5.1d	LTA_cfc = 0.073
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.063		AFC	
		INST MAX LIMIT (mg/l) = 0.205			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$				