

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0103861
 APS ID 1094052
 Authorization ID 1449527

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|--|
| Applicant Name | <u>Steve Zoccoli</u> | Facility Name | <u>Zoccoli MHP</u> |
| Applicant Address | <u>2575 Ben Franklin Highway</u> <u>Edinburg, PA 16116</u> | Facility Address | <u>217 Stacie Lane</u> <u>Edinburg, PA 16116-9801</u> |
| Applicant Contact | <u>Steve Zoccoli</u> | Facility Contact | <u>Steve Zoccoli</u> |
| Applicant Phone | <u>(724) 656-2506</u> | Facility Phone | <u>(724) 656-2506</u> |
| Client ID | <u>36648</u> | Site ID | <u>269766</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Mahoning Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Lawrence</u> |
| Date Application Received | <u>July 3, 2023</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>August 4, 2023</u> | If No, Reason | <u>-</u> |
| Purpose of Application | <u>Renewal of an existing NPDES Permit for an existing discharge of treated sanitary wastewater from a non-municipal STP</u> | | |

Summary of Review

Act 14 - Proof of Notification was submitted and received.
 A Part II Water Quality Management permit is not required at this time.
 The applicant should be able to meet the limits of this permit, which will continue to protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling
- D. Public Sewerage Availability
- E. Effluent Chlorine Optimization and Minimization

SPECIAL CONDITIONS:

- II. Solids Management

There are no open violations in effects associated with the subject Client ID (36648) as of 5/30/2024.

| Approve | Deny | Signatures | Date |
|---------|------|---|-----------|
| X | | Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist | 5/30/2024 |
| X | | Jason T. Roessing Jason T. Roessing, P.E. / Environmental Engineer Manager | 6/3/2024 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|--|-----------------------|-------------------|------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>0.005</u> |
| Latitude | <u>41° 02' 41.37"</u> | Longitude | <u>-80° 25' 48.11"</u> |
| Quad Name | <u>-</u> | Quad Code | <u>-</u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |

| | | | |
|------------------------------|--|------------------------------|------------------------------|
| Receiving Waters | <u>Unnamed Tributary to the Shenango River (WWF)</u> | Stream Code | <u>N/A</u> |
| NHD Com ID | <u>130025487</u> | RMI | <u>N/A</u> |
| Drainage Area | <u>2.12</u> | Yield (cfs/mi ²) | <u>0.053 (previous WQPR)</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>0.11</u> | Q ₇₋₁₀ Basis | <u>calculated</u> |
| Elevation (ft) | <u>964</u> | Slope (ft/ft) | <u>0.01379</u> |
| Watershed No. | <u>20-A</u> | Chapter 93 Class. | <u>WWF</u> |
| Existing Use | <u>-</u> | Existing Use Qualifier | <u>-</u> |
| Exceptions to Use | <u>-</u> | Exceptions to Criteria | <u>-</u> |
| Assessment Status | <u>Impaired*</u> | | |
| Cause(s) of Impairment | <u>Nutrients</u> | | |
| Source(s) of Impairment | <u>Package plants or other permitted small flow discharges</u> | | |
| TMDL Status | <u>-</u> | Name | <u>-</u> |

| Background/Ambient Data | | Data Source |
|-------------------------|----------|-------------|
| pH (SU) | <u>-</u> | <u>-</u> |
| Temperature (°F) | <u>-</u> | <u>-</u> |
| Hardness (mg/L) | <u>-</u> | <u>-</u> |
| Other: | <u>-</u> | <u>-</u> |

| | | | |
|---|---|----------------------------|-------------|
| Nearest Downstream Public Water Supply Intake | <u>PA American Water Company - New Castle</u> | | |
| PWS Waters | <u>Shenango River</u> | Flow at Intake (cfs) | <u>16.2</u> |
| PWS RMI | <u>5.1</u> | Distance from Outfall (mi) | <u>5.0</u> |

* - The receiving stream is impaired by nutrients. Since Total Nitrogen and Total Phosphorus are already monitored, no further action will be taken with this renewal.

Sludge use and disposal description and location(s): Sludge is pumped and hauled to the Mahoning WWTP.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.005 MGD of treated sewage from an existing non-municipal STP in Mahoning Township, Lawrence County.

Treatment permitted under WQM Permit no. 3705403 consists of the following: Two 3,590 gallon septic tanks in series, a dosing tank in the second septic tank, two 1,680 square foot (40' x 42') subsurface sand filters, and tablet chlorine disinfection with a 250 gallon contact tank.

1. Streamflow:

Unnamed Tributary to the Shenango River @ Outfall 001:

Drainage Area: 2.12 sq. mi. (from previous WQPR)
Yieldrate: 0.053 cfsm (from previous WQPR)
% of stream allocated: 100% Basis: no nearby discharges
Q₇₋₁₀: 0.11 cfs (calculated)

2. Wasteflow:

Maximum discharge: 0.005 MGD = 0.0077 cfs
Runoff flow period: 16 hours Basis: Runoff flow for a MHP
24 hour flow: 0.005 MGD x 24/16 = 0.0075 MGD = 0.0116 cfs

The calculated stream flow (Q₇₋₁₀) is greater than 3 times the permitted discharge flow. In accordance with the SOP, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were not evaluated for this facility.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, Phosphorus, NH₃-N, CBOD₅, Dissolved Oxygen, and Disinfection.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency was previously set as 3/week at the request of the Permittee due to financial hardship. Based on eDMR data, this facility is achieving the limits so the monitoring frequency will not be changed with this renewal.

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a.47 technology-based limits

c. Fecal Coliform

05/01 - 09/30: 200 No./100ml (monthly average)
1,000 No./100ml (instantaneous maximum)
10/01 - 04/30: 2,000 No./100ml (monthly average)
10,000 No./100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows greater than 0.002 MGD and less than 0.05 MGD.

e. Total Phosphorus

Chapter 96.5 does not apply. Therefore, the previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 7.0 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (Default value used for modeling purposes)

Median stream pH to be used: 8.0 Standard Units (S.U.)

Basis: Value used in previous modeling

Stream Temperature: 25°C (Default value used for WWF modeling purposes)

Background NH₃-N concentration: 0.0 mg/l

Basis: Default value used for modeling purposes

Calculated summer NH₃-N limits: 19.3 mg/l (monthly average)
38.6 mg/l (instantaneous maximum)

Calculated winter NH₃-N limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 2). Per the SOP, the winter limits were set as three times the summer limits, but were capped at the technology-based limits of 25.0 mg/l monthly average and 50.0 mg/l instantaneous maximum. The calculated summer

limits are less restrictive than the previous NPDES Permit. Since the previous, more restrictive summer limits of 9.0 mg/l monthly average and 18.0 mg/l instantaneous maximum are attainable, they will be retained.

h. CBOD₅

Median discharge pH to be used: 7.0 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (Default value used for modeling purposes)

Median stream pH to be used: 8.0 Standard Units (S.U.)

Basis: Value used in previous modeling

Stream Temperature: 25°C (Default value used for WWF modeling purposes)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value used for modeling purposes

Calculated CBOD₅ limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Result WQ modeling resulted in the technology-based limits above (see Attachment 2), which are the same as the previous NPDES Permit, and will be retained.

i. Dissolved Oxygen (DO)

The technology-based minimum of 4.0 mg/l will be retained with this renewal as recommended by the SOP based on Chapter 93.7, and by the WQ modeling (see Attachment 2), under the authority of Chapter 92a.61.

The measurement frequency was previously set as 3/week at the request of the Permittee due to financial hardship. Based on eDMR data, this facility is achieving the limits so the monitoring frequency will not be changed with this renewal.

j. Disinfection

Ultraviolet (UV) light monitoring

Total Residual Chlorine (TRC) limits: 0.5 mg/l (monthly average)
1.6 mg/l (instantaneous maximum)

Basis: The technology-based TRC limits above were calculated using the Department's TRC Calculation Spreadsheet (see Attachment 1). These limits are the same as the previous permit and will be retained with this renewal.

The measurement frequency was previously set as 3/week at the request of the Permittee due to financial hardship. Based on eDMR data, this facility is achieving the limits so the monitoring frequency will not be changed with this renewal.

4. **Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was not performed in accordance with State practices using the Department's Toxics Management Spreadsheet since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

5. Reasonable Potential for Downstream Public Water Supply (PWS):

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). Since no relevant sampling was provided, mass-balance calculations were not performed.

Nearest Downstream potable water supply (PWS): Pennsylvania American Water Company - New Castle
Distance downstream from the point of discharge: 5.0 miles (approximate)

Result: No limits or monitoring are necessary as significant dilution is available.

6. Anti-Backsliding:

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

7. Attachment List:

Attachment 1 - TRC_Calc Spreadsheet

Attachment 2 - WQ Modeling Printouts

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

| Parameter | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 | OCT-23 | SEP-23 | AUG-23 | JUL-23 | JUN-23 | MAY-23 | APR-23 |
|--|--------|--------|--------|--------|--------|---------|---------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.0004 | 0.0004 | 0.0028 | 0.0006 | 0.0002 | 0.00015 | 0.00006 | 0.0004 | 0.0006 | 0.0004 | 0.0007 | 0.0008 |
| Flow (MGD) Daily Maximum | 0.0005 | 0.0005 | 0.009 | 0.0011 | 0.0003 | 0.0003 | 0.00018 | 0.0006 | 0.0009 | 0.0007 | 0.0009 | 0.0015 |
| pH (S.U.) Instantaneous Minimum | 7.0 | 6.8 | 6.9 | 6.7 | 7.0 | 6.9 | 6.7 | 6.8 | 6.8 | 6.6 | 6.7 | 6.8 |
| pH (S.U.) Instantaneous Maximum | 7.6 | 7.3 | 7.3 | 7.3 | 8.0 | 7.3 | 7.1 | 7.1 | 7.6 | 7.1 | 7.3 | 7.2 |
| DO (mg/L) Instantaneous Minimum | 7.6 | 8.0 | 7.4 | 7.6 | 7.4 | 7.0 | 6.9 | 6.0 | 7.5 | 6.6 | 6.9 | 9.0 |
| TRC (mg/L) Average Monthly | 0.2 | 0.15 | 0.21 | 0.19 | 0.21 | 0.18 | 0.13 | 0.21 | 0.16 | 0.31 | 0.29 | 0.22 |
| TRC (mg/L) Instantaneous Maximum | 0.39 | 0.21 | 0.31 | 0.41 | 0.29 | 0.24 | 0.29 | 0.47 | 0.29 | 0.61 | 0.43 | 0.46 |
| CBOD5 (mg/L) Average Monthly | < 4.8 | < 4 | 13.1 | < 4 | < 4 | < 4 | < 4 | < 3 | < 4 | < 4 | < 4 | < 4 |
| TSS (mg/L) Average Monthly | < 17 | 29.3 | 117.9 | < 7 | < 5 | < 5 | 40 | 9 | 11 | < 8 | < 6 | < 5.8 |
| Fecal Coliform (No./100 ml) Geometric Mean | < 3 | < 4 | > 456 | < 1 | < 1 | < 1 | < 1 | < 9 | < 1 | < 1 | < 1 | < 1 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | < 10 | < 10 | > 2420 | < 1 | < 1 | < 1 | 1 | 74 | < 1 | < 1 | < 1 | < 1 |
| Total Nitrogen (mg/L) Average Monthly | 2.16 | 3.11 | 6.31 | 2.7 | < 1.25 | 2.74 | 2.4 | 11.3 | 10.25 | 13.2 | 7.1 | 5.08 |
| Ammonia (mg/L) Average Monthly | 1.91 | 3.33 | 5.53 | 3.07 | < 0.3 | 3.24 | 2.33 | 12.7 | 10.68 | 14.8 | 5.73 | 6.38 |
| Total Phosphorus (mg/L) Average Monthly | 0.068 | 0.158 | 0.367 | < 0.02 | < 0.02 | < 0.02 | 0.1025 | 0.021 | 0.045 | 0.054 | 0.028 | 0.032 |

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|------------------|---------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | 1/week | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 3/week | Grab |
| DO | XXX | XXX | 4.0 Inst Min | XXX | XXX | XXX | 3/week | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 3/week | Grab |
| CBOD5 | XXX | XXX | XXX | 25.0 | XXX | 50 | 2/month | 8-Hr Composite |
| TSS | XXX | XXX | XXX | 30.0 | XXX | 60 | 2/month | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 2/month | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/year | Grab |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Ammonia Nov 1 - Apr 30 | XXX | XXX | XXX | 25.0 | XXX | 50 | 2/month | 8-Hr Composite |
| Ammonia May 1 - Oct 31 | XXX | XXX | XXX | 9.0 | XXX | 18 | 2/month | 8-Hr Composite |
| Total Phosphorus | XXX | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are technology-based on Chapter 92a.48. The limits for CBOD₅, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus are based on Chapter 92a.61.

Attachment 1

| TRC EVALUATION | | | | |
|---|---|-------------------------------|-----|--------------------------------------|
| Input appropriate values in A3:A9 and D3:D9 | | | | |
| 0.11 | = Q stream (cfs) | | 0.5 | = CV Daily |
| 0.0075 | = Q discharge (MGD) | | 0.5 | = CV Hourly |
| 30 | = no. samples | | 1 | = AFC_Partial Mix Factor |
| 0.3 | = Chlorine Demand of Stream | | 1 | = CFC_Partial Mix Factor |
| 0 | = Chlorine Demand of Discharge | | 15 | = AFC_Criteria Compliance Time (min) |
| 0.5 | = BAT/BPJ Value | | 720 | = CFC_Criteria Compliance Time (min) |
| 0 | = % Factor of Safety (FOS) | | 0 | = Decay Coefficient (K) |
| Source | Reference | AFC Calculations | | Reference |
| TRC | 1.3.2.iii | WLA_afc = 3.043 | | 1.3.2.iii |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | | 5.1c |
| PENTOXSD TRG | 5.1b | LTA_afc = 1.134 | | 5.1d |
| | | | | WLA_cfc = 2.960 |
| | | | | LTAMULT_cfc = 0.581 |
| | | | | LTA_cfc = 1.721 |
| Source | Effluent Limit Calculations | | | |
| PENTOXSD TRG | 5.1f | AML_MULT = 1.231 | | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | | BAT/BPJ |
| | | INST MAX LIMIT (mg/l) = 1.635 | | |
| WLA_afc | $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | |
| LTAMULT_afc | $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$ | | | |
| LTA_afc | $wla_afc \cdot LTAMULT_afc$ | | | |
| WLA_cfc | $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | |
| LTAMULT_cfc | $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$ | | | |
| LTA_cfc | $wla_cfc \cdot LTAMULT_cfc$ | | | |
| AML_MULT | $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$ | | | |
| AVG MON LIMIT | $MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$ | | | |
| INST MAX LIMIT | $1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$ | | | |

Attachment 2

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | |
|------------------|-------------|--------------------|-----------------|--------------------|--------------------------------|----------------------------|----------------------------|
| 20A | | 35482 | | SHENANGO RIVER | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 2.400 | Zoccoli MHP | PA0103861 | 0.007 | CBOD5 | 25 | | |
| | | | | NH3-N | 19.37 | 38.74 | |
| | | | | Dissolved Oxygen | | | 4 |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|---------------------|-----------------------------|
| 20A | 35482 | SHENANGO RIVER | | |
| <u>RM</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> |
| 2.400 | 0.007 | 25.000 | | 7.000 |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> |
| 5.687 | 0.362 | 15.700 | | 0.060 |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> |
| 4.15 | 0.408 | 1.81 | | 1.029 |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> |
| 7.209 | 24.328 | Owens | | 5 |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u> | | | |
| 1.422 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> |
| | 0.142 | 3.86 | 1.57 | 7.54 |
| | 0.284 | 3.59 | 1.35 | 7.54 |
| | 0.426 | 3.34 | 1.17 | 7.54 |
| | 0.569 | 3.10 | 1.01 | 7.54 |
| | 0.711 | 2.88 | 0.87 | 7.54 |
| | 0.853 | 2.68 | 0.75 | 7.54 |
| | 0.995 | 2.49 | 0.65 | 7.54 |
| | 1.137 | 2.31 | 0.56 | 7.54 |
| | 1.279 | 2.15 | 0.49 | 7.54 |
| | 1.422 | 2.00 | 0.42 | 7.54 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 5 | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|----------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 20A | 35482 | SHENANGO RIVER | 2.400 | 964.00 | 2.12 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary | | Stream | |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.053 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| Zoccoli MHP | PA0103861 | 0.0075 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

| Parameter Data | | | | |
|------------------|------------------|------------------|--------------------|--------------------|
| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 4.00 | 7.54 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|----------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 20A | 35482 | SHENANGO RIVER | 1.000 | 862.00 | 3.19 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.053 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 0.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | <u>Stream Name</u> | | | | | | | |
|--------------------|----------------------|--------------------|--------------------------|-----------------------------|------------------------|---------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| 20A | | 35482 | | | SHENANGO RIVER | | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 2.400 | 0.11 | 0.00 | 0.11 | .0116 | 0.01380 | .362 | 5.69 | 15.7 | 0.06 | 1.422 | 25.00 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 2.400 | 0.07 | 0.00 | 0.07 | .0116 | 0.01380 | NA | NA | NA | 0.05 | 1.774 | 25.00 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 2.400 | 0.15 | 0.00 | 0.15 | .0116 | 0.01380 | NA | NA | NA | 0.07 | 1.214 | 25.00 | 7.00 |

WQM 7.0 Wasteload Allocations

| | | |
|------------------|--------------------|--------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
| 20A | 35482 | SHENANGO RIVER |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 2.400 | Zoccoli MHP | 11.07 | 50 | 11.07 | 50 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 2.400 | Zoccoli MHP | 1.37 | 19.37 | 1.37 | 19.37 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|------|----------------|--------------------|--------------------|--------------------|--------------------|-------------------------|--------------------|-------------------|----------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 2.40 | Zoccoli MHP | 25 | 25 | 19.37 | 19.37 | 4 | 4 | 0 | 0 |