

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0104078  
 APS ID 1031351  
 Authorization ID 1341343

**Applicant and Facility Information**

Applicant Name	<u>Martha &amp; Nathan Palm</u>	Facility Name	<u>Anderson MHP</u>
Applicant Address	<u>134 N Maysville Road</u> <u>Greenville, PA 16125-8632</u>	Facility Address	<u>326 Vernon Road</u> <u>Greenville, PA 16125-8632</u>
Applicant Contact	<u>Nathan Palm</u>	Facility Contact	<u>Nathan Palm</u>
Applicant Phone	<u>(724) 866-9261</u>	Facility Phone	<u></u>
Applicant Email	<u><a href="mailto:nateheatherpalm@gmail.com">nateheatherpalm@gmail.com</a></u>		
Client ID	<u>281458</u>	Site ID	<u>257535</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>West Salem Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Mercer</u>
Date Application Received	<u>January 19, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 27, 2021</u>	If No, Reason	<u>---</u>
Purpose of Application	<u>NPDES renewal</u>		

**Summary of Review**

No current violations are reported.

Daily DO, pH and TRC monitoring is proposed. This was previously proposed and was later reduced to twice per week for the expiring permit term. For this facility no Shenango River Reservoir based requirements have been established.

Sludge use and disposal description and location(s): No cleaning reported (long term cell bottom storage in place)

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. / Environmental Engineering Specialist	January 5, 2022
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	January 5, 2022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.00315</u>
Latitude DP	<u>41° 23' 56.40"</u>	Longitude DP	<u>-80° 25' 27.20"</u>
Latitude NHD	<u>41° 23' 57.09"</u>	Longitude NHD	<u>-80° 25' 29.42"</u>
Quad Name	_____	Quad Code	<u>0702</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Big Run (WWF)</u>	Stream Code	<u>36121</u>
NHD Com ID	<u>130027468</u>	RMI	<u>0.7800</u>
Drainage Area	<u>0.07</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0555</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0</u>	Q <sub>7-10</sub> Basis	<u>L Shenango</u>
Elevation (ft)	<u>1163.44</u>	Slope (ft/ft)	<u>0.0231</u>
Watershed No.	<u>20-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>---</u>		
Source(s) of Impairment	<u>---</u>		
TMDL Status	<u>---</u>	Name	<u>---</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>---</u>		<u>---</u>
Temperature (°F)	<u>---</u>		<u>---</u>
Hardness (mg/L)	<u>---</u>		<u>---</u>
Other:	<u>---</u>		<u>---</u>
Nearest Downstream Public Water Supply Intake	<u>Reynolds Water Company</u>		
PWS Waters	<u>Big Run</u>	Flow at Intake (cfs)	<u>1.5</u>
PWS RMI	<u>0.13</u>	Distance from Outfall (mi)	<u>5.23</u>

Changes Since Last Permit Issuance: none

Other Comments: This discharge should not impact any downstream public water supplies

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Anderson MHP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
4368404	January 14, 1969	Tertiary treatment in a two-cell lagoon system with gas chlorination		
4305403	February 22, 2006	Conversion to tablet feed chlorination and three cell series operation		
4305403 A1	November 21, 2006	De-chlorination		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary With Ammonia Reduction	Stabilization Lagoon	Hypochlorite	0.0032
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0032	11.8	Not Overloaded	Anaerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: none

Other Comments: WQM 4368404 is part of the 4305403 application. WQM 4305403 is the operating permit and includes WQM 4368404 as part of the design.

Treatment is with a 3-cell lagoon with chlorination and de-chlorination. Lagoon cell bottoms are used for anaerobic sludge digestion and sludge storage.



Compliance History

DMR Data for Outfall 001 (from December 1, 2020 to November 30, 2021)

Parameter	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20
Flow (MGD) Average Monthly	0.00216	0.00169	0.00130	0.00292	0.00271	0.00237	0.00217	0.00212	0.00184	0.00166	0.00234	0.00243
pH (S.U.) Minimum	7.4	7.2	7.3	7.33	7.29	7.28	7.28	6.99	7.49	7.38	7.33	6.87
pH (S.U.) Maximum	7.7	7.4	7.4	7.43	7.51	7.58	7.81	7.62	7.78	7.81	7.83	7.63
DO (mg/L) Minimum	8.0	7.1	6.2	6.88	6.5	7.08	6.0	8.03	8.80	9.03	8.8	7.99
TRC (mg/L) Average Monthly	< 0.01	0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	0.01	0.01	0.01	0.01	0.01
TRC (mg/L) Instantaneous Maximum	< 0.01	0.01	< 0.01	< 0.01	< 0.01	0.01	< 0.01	0.01	0.01	0.01	0.01	0.01
CBOD5 (mg/L) Average Monthly	5	7	8	10	18	6	4	< 3.00	16.45	14.15	9.19	6.75
TSS (mg/L) Average Monthly	4	8	7	20	19	7	9	4.50	14.5	17.5	16	5.50
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 1	< 1	108	< 1	> 15	2	< 1	1	2	11.49	< 1.00
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 1	< 1	< 1	771	< 1	> 2420	4	< 1	1	4	12	< 1.00
Total Nitrogen (mg/L) Average Monthly	3.76	3.89	6.19	2.73	3.51	5.02	1.84	1.45	3.03	4.32	2.36	2.93
Ammonia (mg/L) Average Monthly	2.19	2.3	1.93	0.77	0.49	0.8	0.67	0.62	0.26	1.17	1.00	1.88
Total Phosphorus (mg/L) Average Monthly	0.38	0.39	0.38	0.29	0.35	0.34	0.26	0.20	0.30	0.21	0.21	0.25

**Compliance History**

**Effluent Violations for Outfall 001, from: January 1, 2021 To: November 30, 2021**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	06/30/21	Geo Mean	> 15	CFU/100 ml	200	CFU/100 ml
Fecal Coliform	06/30/21	IMAX	> 2420	CFU/100 ml	1000	CFU/100 ml

**Effluent Violations for Outfall 001, from: May 1, 2020 To: March 31, 2021**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
CBOD5	9/30/20	Avg Mo	27.8	Mg/L	25	mg/L

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.00315</u>
<b>Latitude</b> <u>41° 23' 56.40"</u>	<b>Longitude</b> <u>-80° 25' 27.20"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: secondary treatment is required

**Water Quality-Based Limitations**

A Sewerage Program “Reasonable Potential Analysis” determined the following parameters were candidates for limitations: BOD<sub>5</sub>, CBOD<sub>5</sub>, TSS, phosphorus, ammonia, chlorine, and pH.

Comments: secondary treatment should be adequate.

**Best Professional Judgment (BPJ) Limitations**

Parameter	Limit (mg/l)	SBC	Comments
DO	4.0	Daily Minimum	---
E. Coli (No./100 mL)	Report	IMAX	---
Total Phosphorus	Report	Avg. Mo.	---
Total Nitrogen	Report	Avg. Mo.	---

Comments: DO daily minimum requirement is being achieved.

E. Coli is based on Ch. 92a.61 and the Departments SOP for Establishing Effluent Limitations for Individual Sewage Permits (SOP No. BPNPSM-PMT-033). E. Coli monitoring of 1/year is a new addition to this permit renewal. JCD

**Anti-Backsliding**

No non-compliance issues.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001 after disinfection

Other Comments: daily DO, pH and TRC monitoring is proposed.

1A	B	C	D	E	F	G	H	I	J	K	L	M
	<b>Discharger Site</b>		Anderson MHP STP								Wednesday, December 1, 2021	
	<b>Municipality</b>		Anderson MHP STP					Revised			Wednesday, December 1, 2021	
	<b>County</b>		West Salem Township									
	<b>NPDES Permit</b>		Mercer									
	<b>0.5</b>		PA0104078									
<b>TRC EVALUATION</b>												
2	Input appropriate values in B4:B8 and E4:E7											
3	0.0472	= Q stream (cfs)					0.5	= CV Daily				
4	0.0032	= Q discharge (MGD)					0.5	= CV Hourly				
5	30	= no. samples					1	= AFC_Partial Mix Factor				
6	0.3	= Chlorine Demand of Stream					1	= CFC_Partial Mix Factor				
7	0	= Chlorine Demand of Discharge					15	= AFC_Criteria Compliance Time (min)				
8	0	= BAT/BPJ Value					720	= CFC_Criteria Compliance Time (min)				
9	0	= % Factor of Safety (FOS)						= Decay Coefficient (K)				
10	Source	Reference	AFC Calculations				Reference	CFC Calculations				
11	TRC	1.3.2.iii			WLA_afc = 3.106		1.3.2.iii		WLA_cfc = 3.021			
12	PENTOXSD TRG	5.1a			LTAMULT_afc = 0.373		5.1c		LTAMULT_cfc = 0.581			
13	PENTOXSD TRG	5.1b			LTA_afc = 1.157		5.1d		LTA_cfc = 1.756			
14												
15	Source		Effluent Limit Calculations									
16	PENTOXSD TRG	5.1f			AML_MULT = 1.231							
17	PENTOXSD TRG	5.1g			LIMIT (mg/l) = 0.500				BAT/BPJ			
18					X LIMIT (mg/l) = 1.635							
	WLA_afc		$(0.19/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot 0.19/Qd \cdot e^{-k \cdot AFC\_tc}) \dots]$ $\dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs/Qd)^{(1-FOS/100)}$									
	LTAMULT_afc		$EXP((0.5 \cdot LN(cvd^2 + 1)) - 2.326 \cdot LN(cvd^2 + 1)^{0.5})$									
	LTA_afc		$wla\_afc \cdot LTAMULT\_afc$									
	WLA_cfc		$(0.11/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot 0.11/Qd \cdot e^{-k \cdot CFC\_tc}) \dots]$ $\dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs/Qd)^{(1-FOS/100)}$									
	LTAMULT_cfc		$EXP((0.5 \cdot LN(cvd^2/2 + no\_samples + 1)) - 2.326 \cdot LN(cvd^2/2 + no\_samples + 1)^{0.5})$									
	LTA_cfc		$wla\_cfc \cdot LTAMULT\_cfc$									
	AML_MULT		$EXP(2.326 \cdot LN((cvd^2/2 + no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2/2 + no\_samples + 1))$									
	AVG MON LIMIT		$MIN(BAT\_BPJ, MIN(LTA\_afc, LTA\_cfc) \cdot AML\_MULT)$									
	INST MAX LIMIT		$1.5 \cdot ((av\_mon\_limit/AML\_MULT)/LTAMULT\_afc)$									
	$(0.011/EXP(-K \cdot CFC\_tc/1440)) + (((CFC\_Yc \cdot Qs \cdot 0.011)/(1.547 \cdot Qd)) \dots)$ $\dots \cdot EXP(-K \cdot CFC\_tc/1440)) + Xd + (CFC\_Yc \cdot Qs \cdot Xs/1.547 \cdot Qd)^{(1-FOS/100)}$											
	Stream	Chlorine Required	=	perennial	Chlorine Demand	+	Chlorine Residual					
	Stream	Reach/Node	2	1	2							
	Stream	Flow	Conditions	intermittent	perennial							
	Stream	Code		36121	36121							
	Stream	Function										
	Samples			30	30							
	reach	outfall	RMI	1.44	0.41							
	reach	Reach End	RMI	0.41	0							
	reach		feet	5459.52	2164.8							
	drainage		sq miles	0.07	0.85							
	TRC	limitation	average	mg/L	0.162	0.500						
			maximum	mg/L	0.529	1.600						
	elevation	modelled	feet	1163.44	1016.12							
	elevation	modelled	feet	1016.12	973.29							
	slope	modelled	foot/foot	0.027	0.020							
	low flow		cfs/sq mi	0.055	0.055							
	discharge		mgd	0.0032	0.0032							
	Runoff	Period	hours	24.000	24.000							
	Intermittent stream discharge. TRC revised at outfall and estimated perennial stream conditions. Stream chlorine is expected to naturally abated prior to reaching perennial flow conditions.											
	stream	flow		cfs	0.00388	0.04716						
	stream	flow		MGD	0.002510	0.030479						
	stream	flow	total	MGD	0.005660	0.033629						
	stream	chlorine	demand	mg/L	0.4	0.3						
	discharge	discharge	demand	mg/L								
	stream	Total Stream/Waste	ratio		1.8	10.7						
	permitted	TRC	mean	BAT	0.5	0.5						
	permitted	TRC	maximum	BAT	1.6	1.6						



**Input Data WQM 7.0**

Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
36121 Trib	36121 to Big Run	1.44C	1163.44	0.07	0.00000	0.00	<input type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.055	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.0C	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Anderson MHP	PA0104078	0.0032	0.0032	0.0032	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

**Input Data WQM 7.0**

Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC					
36121 Trib	36121 to Big Run	0.41C	1016.12	0.85	0.00000	0.00	<input checked="" type="checkbox"/>					
Stream Data												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.055	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.0C	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.10	0.00	0.70			

**Input Data WQM 7.0**

Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
36121 Trib	36121 to Big Run	0.00C	973.29	16.70	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.055	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.0C	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70



**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20A		36121				Trib 36121 to Big Run						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
1.440	0.00	0.00	0.00	.0049	0.02709	.251	1.14	4.54	0.03	2.064	22.79	7.00
0.410	0.05	0.00	0.05	.0049	0.01978	.314	3.54	11.28	0.05	0.540	20.47	7.00
<b>Q1-10 Flow</b>												
1.440	0.00	0.00	0.00	.0049	0.02709	NA	NA	NA	0.03	2.274	23.32	7.00
0.410	0.03	0.00	0.03	.0049	0.01978	NA	NA	NA	0.04	0.673	20.70	7.00
<b>Q30-10 Flow</b>												
1.440	0.01	0.00	0.01	.0049	0.02709	NA	NA	NA	0.03	1.901	22.41	7.00
0.410	0.06	0.00	0.06	.0049	0.01978	NA	NA	NA	0.05	0.461	20.36	7.00

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

SWP Basin      Stream Code                      Stream Name  
20A                      36121                      Trib 36121 to Big Run

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.440	Anderson MHP	NA	50	12.73	50	0	0
0.410		NA	NA	15.82	NA	NA	NA

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.440	Anderson MHP	NA	25	1.62	25	0	0
0.410		NA	NA	1.84	NA	NA	NA

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.44	Anderson MHP	25	25	25	25	4	4	0	0
0.41		NA	NA	NA	NA	NA	NA	NA	NA

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
20A	36121	Trib 36121 to Big Run			
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
1.440	0.003	22.793		7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
1.140	0.251	4.542		0.030	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
14.85	0.854	14.01		0.868	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
5.873	28.859	Owens		NA	
<u>Reach Travel Time (days)</u>					
2.064					
<b>Subreach Results</b>					
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.206	12.15	11.71	6.41	
	0.413	9.94	9.79	6.80	
	0.619	8.14	8.19	7.12	
	0.826	6.66	6.84	7.39	
	1.032	5.45	5.72	7.61	
	1.239	4.46	4.78	7.79	
	1.445	3.65	4.00	7.95	
	1.651	2.99	3.34	8.07	
	1.858	2.44	2.79	8.18	
	2.064	2.00	2.34	8.24	
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
0.410	0.003	20.472		7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
3.542	0.314	11.283		0.046	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
2.00	0.000	0.48		0.726	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
8.243	23.925	Owens		5	
<u>Reach Travel Time (days)</u>					
0.540					
<b>Subreach Results</b>					
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.054	2.00	0.46	8.24	
	0.108	2.00	0.44	8.24	
	0.162	2.00	0.42	8.24	
	0.216	2.00	0.41	8.24	
	0.270	2.00	0.39	8.24	
	0.324	2.00	0.38	8.24	
	0.378	2.00	0.36	8.24	
	0.432	2.00	0.35	8.24	
	0.486	2.00	0.34	8.24	
	0.540	2.00	0.32	8.24	



**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
20A		36121	Trib 36121 to Big Run				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.440	Anderson MHP	PA0104078	0.003	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4