

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0111201
APS ID 813980
Authorization ID 1267615

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|--|
| Applicant Name | <u>Carrolltown Borough Municipal Authority</u> | Facility Name | <u>Carrolltown Borough</u> |
| Applicant Address | <u>PO Box 307</u> <u>Carrolltown, PA 15722-0307</u> | Facility Address | <u>190 Mill Street Extension</u> <u>Carrolltown, PA 15722</u> |
| Applicant Contact | <u>Lonnie Batdorf</u> | Facility Contact | <u>Same as Applicant</u> |
| Applicant Phone | <u>(814) 344-6650</u> | Facility Phone | <u>Same as Applicant</u> |
| Client ID | <u>77904</u> | Site ID | <u>262099</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>East Carroll Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Cambria</u> |
| Date Application Received | <u>April 2, 2019</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>April 3, 2019</u> | If No, Reason | <u></u> |
| Purpose of Application | <u>Application for renewal of a NPDES Permit for discharge of sewage effluent</u> | | |

Summary of Review

The permittee has applied for a renewal of NPDES Permit No. PA0111201. NPDES Permit No. PA0111201 was previously issued by the PA Department of Environmental Protection (DEP) on September 5, 2014 and expired on September 30, 2019. The application was submitted in a timely manner, so the permit was granted an administrative extension.

Sewage from this facility is treated by extended aeration, final clarification, and chlorination.



The applicant is currently enrolled in and will continue to use eDMR.

Sludge produced at this facility is disposed of Cambria Township Sewer Authority's Revloc STP.

The applicant has complied with Act 14 Notifications and no comments were received.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania*

| Approve | Deny | Signatures | Date |
|---------|------|---|---------------|
| X | |  Stephanie Conrad / Environmental Engineering Specialist | April 8, 2022 |
| x | |  Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineer Manager | April 8, 2022 |

Summary of Review

Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|---|------------------------------|--|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>0.2</u> |
| Latitude | <u>40° 36' 34"</u> | Longitude | <u>-78° 42' 20"</u> |
| Quad Name | <u>Carrolltown</u> | Quad Code | <u>1416</u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |
| Receiving Waters | <u>Trib 26884 to Little Chest Creek (CWF)</u> | Stream Code | <u>26884</u> |
| NHD Com ID | <u>61837689</u> | RMI | <u>3.27</u> |
| Drainage Area | <u>0.46</u> | Yield (cfs/mi ²) | <u></u> |
| Q ₇₋₁₀ Flow (cfs) | <u>0.0222</u> | Q ₇₋₁₀ Basis | <u>0.04826</u> |
| Elevation (ft) | <u></u> | Slope (ft/ft) | <u></u> |
| Watershed No. | <u>8-B</u> | Chapter 93 Class. | <u>CWF</u> |
| Existing Use | <u></u> | Existing Use Qualifier | <u></u> |
| Exceptions to Use | <u></u> | Exceptions to Criteria | <u></u> |
| Assessment Status | <u>Attaining</u> | | |
| Cause(s) of Impairment | <u>Siltation, Total Suspended Solids (TSS), Turbidity</u> | | |
| Source(s) of Impairment | <u>Acid Mine Drainage</u> | | |
| TMDL Status | <u>Final</u> | Name | <u>Chest Creek Watershed Sediment TMDL West Branch Susquehanna River</u> |
| Background/Ambient Data | | Data Source | |
| pH (SU) | <u></u> | | <u></u> |
| Temperature (°F) | <u></u> | | <u></u> |
| Hardness (mg/L) | <u></u> | | <u></u> |
| Other: | <u></u> | | <u></u> |
| Nearest Downstream Public Water Supply Intake | <u>Shawville Power Plant</u> | | |
| PWS Waters | <u>Susquehanna</u> | Flow at Intake (MGD) | <u>1.953</u> |
| PWS RMI | <u></u> | Distance from Outfall (mi) | <u>73.7</u> |

Changes Since Last Permit Issuance: None

Other Comments: None.

| Treatment Facility Summary | | | | |
|---|-----------------------------------|----------------------|----------------------------|-------------------------------|
| Treatment Facility Name: Carrolltown Borough STP | | | | |
| WQM Permit No. | | Issuance Date | | |
| 566S019 | | May 23, 1966 | | |
| | | | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Tertiary | Extended Aeration | Gas Chlorine | 0.2 |
| | | | | |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.2 | 417 | Not Overloaded | Aerated Holding Tank | Other WWTP |

Changes Since Last Permit Issuance: None

Other Comments: None

Compliance History

Facility: Carrolltown Borough STP
NPDES Permit No.: PA0111201
Compliance Review Period: 10/2016 – 10/2021

Inspection Summary:

| INSP ID | INSPECTED DATE | INSP TYPE | AGENCY | INSPECTION RESULT DESC |
|---------|----------------|--|-------------------------------------|------------------------|
| 3155331 | 03/02/2021 | Incident-Response to Accident or Event | PA Dept of Environmental Protection | No Violations Noted |
| 3052142 | 05/04/2020 | Administrative/File Review | PA Dept of Environmental Protection | Violation(s) Noted |
| 2890725 | 03/13/2019 | Chapter 94 Inspection | PA Dept of Environmental Protection | No Violations Noted |
| 2853208 | 03/13/2019 | Chapter 94 Inspection | PA Dept of Environmental Protection | No Violations Noted |
| 2856397 | 02/08/2019 | Compliance Evaluation | PA Dept of Environmental Protection | No Violations Noted |
| 2767972 | 08/28/2018 | Chapter 94 Inspection | PA Dept of Environmental Protection | No Violations Noted |
| 2692017 | 02/08/2018 | Chapter 94 Inspection | PA Dept of Environmental Protection | No Violations Noted |

Violation Summary:

| VIOL ID | VIOLATION DATE | VIOLATION TYPE | VIOLATION TYPE DESC | RESOLVED DATE | INSP ID |
|---------|----------------|----------------|--|---------------|---------|
| 888112 | 05/04/2020 | 92A.44 | NPDES - Violation of effluent limits in Part A of permit | 05/04/2020 | 3052142 |

Open Violations by Client ID:

No CW violations for client ID 77904

Enforcement Summary:

| ENF ID | ENF TYPE | ENF TYPE DESC | ENF CREATION DATE | EXECUTED DATE | ENF FINALSTATUS | ENF CLOSED DATE |
|--------|----------|---------------------------|-------------------|---------------|--------------------------|-----------------|
| 386735 | FLNOV | Field Notice of Violation | 07/07/2020 | 05/04/2020 | Administrative Close Out | 04/08/2021 |

DMR Violation Summary:

| MONITORING START DATE | MONITORING END DATE | PARAMETER | SAMPLE VALUE | PERMIT VALUE | STATISTICAL BASE CODE |
|-----------------------|---------------------|-------------------------------|--------------|--------------|-----------------------|
| 09/01/2020 | 09/30/2020 | Fecal Coliform | 1725 | 1000 | Instantaneous Maximum |
| 02/01/2020 | 02/29/2020 | Total Suspended Solids | 53 | 45 | Weekly Average |
| 02/01/2020 | 02/29/2020 | Total Suspended Solids | 137.5 | 75.0 | Weekly Average |
| 12/01/2019 | 12/31/2019 | Ammonia-Nitrogen | 7.2 | 5.0 | Weekly Average |
| 12/01/2019 | 12/31/2019 | Total Suspended Solids | 52 | 45 | Weekly Average |
| 08/01/2019 | 08/31/2019 | Fecal Coliform | 4106 | 1000 | Instantaneous Maximum |
| 09/01/2018 | 09/30/2018 | Ammonia-Nitrogen | 5.1 | 3.0 | Weekly Average |
| 09/01/2018 | 09/30/2018 | Fecal Coliform | 1145 | 1000 | Instantaneous Maximum |
| 09/01/2018 | 09/30/2018 | Flow | 0.212 | 0.20 | Average Monthly |
| 09/01/2018 | 09/30/2018 | Ammonia-Nitrogen | 6.5 | 5.0 | Weekly Average |
| 02/01/2018 | 02/28/2018 | Fecal Coliform | 24200 | 10000 | Instantaneous Maximum |
| 02/01/2018 | 02/28/2018 | Flow | 0.217 | 0.20 | Average Monthly |
| 04/01/2017 | 04/30/2017 | Ammonia-Nitrogen | 5.2 | 5.0 | Weekly Average |
| 11/01/2016 | 11/30/2016 | Total Residual Chlorine (TRC) | 0.080 | 0.076 | Instantaneous Maximum |

Compliance Status:

Permittee has had some DMR exceedances. Will monitor and issue CACP as necessary.

Completed by: John Murphy

Completed date: 10/8/2021

Compliance History

DMR Data for Outfall 001 (from August 1, 2020 to July 31, 2021)

| Parameter | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 | SEP-20 | AUG-20 |
|---|--------|--------|--------|--------|---------|--------|---------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.054 | 0.075 | 0.111 | 0.080 | 0.206 | 0.091 | 0.119 | 0.128 | 0.078 | 0.063 | 0.064 | 0.059 |
| Flow (MGD) Daily Maximum | 0.08 | 0.134 | 0.557 | 0.129 | 0.885 | 0.242 | 0.394 | 0.507 | 0.141 | 0.130 | 0.091 | 0.110 |
| pH (S.U.) Minimum | 6.72 | 6.51 | 6.66 | 6.60 | 6.57 | 6.71 | 6.60 | 6.66 | 6.71 | 6.67 | 6.57 | 6.66 |
| pH (S.U.) Maximum | 7.27 | 7.26 | 7.4 | 7.17 | 7.16 | 7.25 | 7.10 | 7.17 | 7.28 | 7.27 | 7.7 | 7.20 |
| DO (mg/L) Minimum | 6.32 | 6.06 | 6.06 | 6.25 | 6.17 | 6.25 | 6.95 | 6.47 | 6.74 | 6.03 | 6.14 | 6.07 |
| TRC (mg/L) Average Monthly | 0.001 | 0.010 | 0.001 | 0.010 | 0.001 | 0.001 | 0.010 | 0.010 | 0.010 | 0.010 | 0.001 | 0.010 |
| TRC (mg/L) Instantaneous Maximum | 0.050 | 0.020 | 0.040 | 0.060 | 0.040 | 0.050 | 0.050 | 0.040 | 0.020 | 0.030 | 0.020 | 0.040 |
| CBOD5 (lbs/day) Average Monthly | 2.9 | 3.8 | 7.6 | 2.8 | 19.0 | < 4.5 | 7.6 | 6.4 | 4.2 | < 2.8 | 3.4 | < 2.7 |
| CBOD5 (lbs/day) Weekly Average | 3.9 | 4.9 | 13.8 | 3.3 | 41.7 | 6.6 | 12.4 | 8.1 | 6.2 | 5.0 | 4.9 | 3.3 |
| CBOD5 (mg/L) Average Monthly | 7 | 7 | 8 | 5 | 13 | < 7 | 8 | 7 | 7 | < 6 | 6 | < 6 |
| CBOD5 (mg/L) Weekly Average | 8 | 9 | 9 | 5 | 19 | 9 | 11 | 9 | 7 | 9 | 7 | 7 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 63 | 87 | 145 | 107 | < 178 | 130 | < 114 | 162 | 90 | 97 | 89 | 71 |
| BOD5 (lbs/day) Raw Sewage Influent Daily Maximum | 84 | 138 | 261 | 170 | 341 | 146 | 135 | 198 | 112 | 190 | 103 | 89 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 163.9 | 150.3 | 156.1 | 191 | < 141.1 | 195 | < 139.2 | 183 | 148.3 | 207 | 154 | 157 |
| TSS (lbs/day) Average Monthly | < 3.5 | 4.7 | 8.5 | 3.6 | 35.0 | 8.2 | 13.5 | 8.8 | 4.1 | < 3.4 | < 4.6 | < 2.8 |

**NPDES Permit Fact Sheet
Carrolltown Borough Cambria County**

NPDES Permit No. PA0111201

| | | | | | | | | | | | | |
|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 42 | 46 | 72 | 54 | 78 | 74 | 84 | 100 | 50 | 76 | 78 | 55 |
| TSS (lbs/day) Raw Sewage Influent Daily Maximum | 57 | 66 | 159 | 113 | 93 | 92 | 100 | 147 | 116 | 162 | 102 | 72 |
| TSS (lbs/day) Weekly Average | 7.7 | 5.7 | 15.9 | 4.1 | 60.8 | 9.9 | 17.9 | 14.4 | 5.2 | 6.4 | 7.6 | 3.9 |
| TSS (mg/L) Average Monthly | < 9 | 8 | 9 | 7 | 26 | 12 | 15 | 10 | 7 | < 8 | < 8 | < 6 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 109 | 81 | 77 | 97 | 65 | 111 | 104 | 118 | 83 | 160 | 136 | 121 |
| TSS (mg/L) Weekly Average | 20 | 10 | 14 | 8 | 37 | 16 | 19 | 14 | 9 | 11 | 14 | 8 |
| Fecal Coliform (CFU/100 ml) Geometric Mean | < 12 | 47 | < 77 | < 14 | < 133 | < 55 | 24 | < 18 | < 37 | < 62 | < 24 | < 4 |
| Fecal Coliform (CFU/100 ml) Instantaneous Maximum | 20 | 75 | 554 | 41 | 1935 | 2247 | 86 | 52 | 121 | 441 | 1725 | 10 |
| Total Nitrogen (mg/L) Daily Maximum | | | | | | | | 30.5 | | | | |
| Ammonia (lbs/day) Average Monthly | < 0.3 | < 0.5 | < 0.7 | < 0.5 | < 1.1 | < 0.5 | < 0.7 | < 0.7 | < 0.5 | < 0.4 | < 0.5 | < 0.4 |
| Ammonia (lbs/day) Weekly Average | < 0.4 | < 0.5 | < 1.2 | < 0.5 | < 2.3 | < 0.6 | < 1.2 | < 1.0 | < 0.7 | < 0.5 | < 0.6 | < 0.4 |
| Ammonia (mg/L) Average Monthly | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 |
| Ammonia (mg/L) Weekly Average | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 | < 0.8 |
| Total Phosphorus (mg/L) Daily Maximum | | | | | | | | 3.2 | | | | |
| Total Copper (lbs/day) Average Monthly | 0.010 | 0.020 | 0.030 | 0.020 | 0.040 | 0.030 | 0.030 | 0.030 | 0.020 | 0.020 | 0.030 | 0.020 |
| Total Copper (lbs/day) Weekly Average | 0.020 | 0.020 | 0.050 | 0.020 | 0.060 | 0.040 | 0.040 | 0.050 | 0.040 | 0.030 | 0.040 | 0.020 |
| Total Copper (mg/L) Average Monthly | 0.03 | 0.04 | 0.04 | 0.04 | 0.03 | 0.05 | 0.04 | 0.04 | 0.04 | 0.04 | 0.05 | 0.04 |
| Total Copper (mg/L) Weekly Average | 0.04 | 0.04 | 0.05 | 0.040 | 0.03 | 0.057 | 0.05 | 0.05 | 0.05 | 0.05 | 0.052 | 0.04 |

Compliance History

Effluent Violations for Outfall 001, from: September 1, 2020 To: July 31, 2021

| Parameter | Date | SBC | DMR Value | Units | Limit Value | Units |
|----------------|----------|--------|-----------|------------|-------------|------------|
| Flow | 03/31/21 | Avg Mo | 0.206 | MGD | 0.20 | MGD |
| Fecal Coliform | 09/30/20 | IMAX | 1725 | CFU/100 ml | 1000 | CFU/100 ml |

Summary of Inspections: The facility was last inspected by PADEP as a response to an incident on March 2, 2021. There were no violations.

Other Comments:

Permit No. PA0111201

Development of Effluent Limitations

| | |
|---|---|
| Outfall No. <u>001</u> | Design Flow (MGD) <u>0.2</u> |
| Latitude <u>40° 36' 34.00"</u> | Longitude <u>-78° 42' 20.00"</u> |
| Wastewater Description: <u>Sewage Effluent</u> | |

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Water Quality-Based Limitations

Pursuant to EPA’s approval of Pennsylvania’s 2017 Triennial Review of Water Quality Standards and corresponding regulatory changes published in the *Pennsylvania Bulletin* on July 11, 2020, new water quality criteria for ammonia-nitrogen apply to waters of the commonwealth. Therefore, WQBELs for Outfall 001 are re-evaluated even though there have been no changes to the STP.

The effluent was modeled using WQM 7.0 to evaluate the CBOD₅, Ammonia Nitrogen, and Dissolved Oxygen parameters. Modeling confirmed that technology based effluent limitations are appropriate for CBOD₅. The modeling also confirmed that Dissolved Oxygen and Ammonia-Nitrogen limits are necessary to meet in-stream water quality criterion. These limits are not changing from the last permit.

Total Residual Chlorine (TRC) was modeled with PADEP’s TRC Spreadsheet, and it was determined that a stricter limit should be imposed. Based on eDMR data, the facility as operating should be able to meet the new, more restrictive TRC limit.

| Parameter | Limit (mg/l) | SBC | Model |
|---------------------------|--------------|-----------------------|-----------------|
| Total Residual Chlorine | 0.019 | Average Monthly | TRC Spreadsheet |
| Dissolved Oxygen | 6.0 | Instantaneous Minimum | WQM 7.0 |
| Ammonia-Nitrogen (winter) | 3.3 | Average Monthly | WQM 7.0 |
| Ammonia-Nitrogen (summer) | 2.0 | Average Monthly | WQM 7.0 |

Permit No. PA0111201

A “Reasonable Potential Analysis” was conducted using PADEP’s Toxic Management Spreadsheet Version 1.3.

The following limitations were determined through water quality modeling (output files attached):

| Parameter | Limit (µg/l) | SBC | Model |
|---------------------|---------------------|-----------------|-----------------|
| Total Copper (µg/L) | 9.9 | Average Monthly | TMS Version 1.3 |

A WQBEL for total copper (mass and concentration) was previously imposed on this facility based upon output data from PENTOXSD Version 1.03. DMR data for total copper was reviewed and the Department’s TMS Model, Version 1.3 was used to develop an updated WQBEL (mass and concentration) for total copper based upon a design flow of 0.2 MGD. The output files are included in Attachment C. Based on eDMR data, the facility as currently operating is not able to meet the new limit.

In accordance with department policy, a pre-draft survey was sent to the authority on November 10, 2021. The authority returned a copy of the survey on December 13, 2022, and a copy of their response is included in Attachment E. The Authority stated copper is suspected to be coming from corrosion within the public drinking water system. The authority incorporates polyphosphate into their drinking water system to control corrosion. The new limits will require the authority to install additional treatment and the authority estimates that they can achieve the new limits in 2027. A compliance schedule of five years is therefore being implemented. The existing permit limits will expire one month prior to the permit expiration date.

Default stream parameter values were used for modeling the new Copper limits. Because of this, the permittee must collect the site-specific data and a special condition Part C. III. B. was added to the Permit. Additionally, because the facility is receiving a WQBEL for Copper and the source is suspected to be corrosion of drinking water lines, the permittee is required to complete a Toxics Reduction Evaluation (TRE) and a special condition Part B. III. C. was added to the Permit.

The Toxic Management Spreadsheet Version 1.3 modeling results recommends Monitoring for Total Zinc. This monitoring requirement was not part of the previous permit.

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA’s anti-backsliding regulation 40 CFR 122.44 **(I) Reissued permits. (1) Except as provided in paragraph (I)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.**

The facility is not seeking to revise the previously permitted effluent limits.

Additional Considerations

Sewage discharges will include monitoring, at a minimum, for E. coli, in new and reissued permits, with a monitoring frequency of 1/quarter for design flows ≥ 0.05 and < 1 MGD.

Permit No. PA011201

For pH, Dissolved Oxygen (DO) and TRC, a monitoring frequency 1/day has been imposed. In general, less frequent monitoring may be established only when the permittee demonstrates that there will be no discharge on days where monitoring is not required.

The receiving stream is not impaired for nutrients, therefore, annual sampling for nitrogen and phosphorus will be imposed per 25 PA Code §92a.61.

For POTWs with design flows greater than 2,000 GPD, influent BOD₅ and TSS monitoring must be established in the permit and the monitoring should be consistent with the same frequency and sample type as used for other effluent parameters.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations. Please note that Monitoring Requirements were changed for Flow to 1/week Metered to be consistent with the guidance.

When the source of a toxic pollutant is unknown, or suspected, department policy stipulates that the facility conducts a Toxicity Reduction Evaluation (TRE). Additionally, when the pollutant is copper or lead and the source is suspected to be corrosion of water lines, the facility is required to conduct a Corrosion Control Feasibility Study as part of the TRE. Part C.III, Water Quality-Based Effluent Limitations for Toxic Pollutants, and C.IV, Corrosion Control Feasibility Study, have been added to the permit.

Mass Loading

Mass loading limits are applicable for publicly owned treatment works. Current policy requires average monthly mass loading units be established for CBOD₅, TSS, and NH₃-N. Average monthly mass loading limits (lbs./day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion factor (8.34).

Chest Creek Watershed Sediment TMDL West Branch

Section 303(d) of the Clean Water Act and the U.S. Environmental Protection Agency's Water Quality Planning and Management Regulations (codified at Title 40 of the Code of Federal Regulations Part 130) require states to develop a TMDL for impaired water bodies. A TMDL establishes the amount of a pollutant that a water body can assimilate without exceeding water quality criteria for the pollutant. TMDLs also provide a scientific bases for states to establish water quality-based controls for reducing pollution from both point and non-point sources in order to restore and maintain the quality of the state's water resources (USEPA 1991a). Stream reaches within the Chest Creek Watershed are included in the state's 2008 Section 303(d) because of various impairments including siltation, Total Suspended Solids (TSS), and turbidity. A TMDL for this watershed was finalized in August 2011 to address siltation, TSS, and turbidity impairments associated with abandoned mine drainage discharge.

In accordance with 40 CFR § 122.44(d)(1)(vii)(B), when developing WQBELs, the permitting authority shall ensure that effluent limits developed to protect a narrative water criterion, a numeric water quality criterion, or both, are consistent with the assumptions and requirements of any available wasteload allocation (WLA) for the discharge.

The facility permit, PA011201, was identified in the TMDL. The facility was assigned a WLA that was derived from the permit limit which existed at the time the TMDL was finalized. The WLA is based on a TSS concentration of 30 mg/L and a design flow of 0.2 MGD. The WLA for this facility was adjusted up to 18,275.6 lbs./yr. An instantaneous maximum limit of 60 mg/L was calculated by using a multiplier of two times the average monthly limit in accordance with the Department's Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (Doc. No. 362-0400-001, Chapter 3, pp. 15 – 16). A weekly average limit of 45 mg/L was imposed to be consistent with 40 CFT 133.102(b)(2) and 25 PA Code §92a.47(a)(b).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Beginning of Sixtieth (60th) Month Following Permit Issuance through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---------------------|-------------------------------------|--------------------|-----------------------|--------------------|-------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (ug/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Total Copper (ug/L) | 0.017 | 0.025 Daily Max | XXX | 9.9 | 15.0 Daily Max | 15 | 1/week | 24-Hr Composite |

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through End of Fifty-Ninth (59th) Month Following Permit Issuance.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--------------|-------------------------------------|-------------------|-----------------------|-----------------|------------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (µg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Total Copper | 0.083 | 0.166 Wkly Avg | XXX | 0.05 | 0.10 Wkly Avg | 0.125 | 1/week | 8-Hr Composite |

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--|-------------------------------------|------------------|-----------------------|-----------------|------------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | 0.20 | Report Daily Max | XXX | XXX | XXX | XXX | 1/week | Metered |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 6.0 Inst Min | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.019 | XXX | 0.063 | 1/day | Grab |
| CBOD ₅ | 41.7 | 62.5 | XXX | 25 | 38 | 50 | 1/week | 8-Hr Composite |
| BOD ₅ Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| TSS | 50.0 | 75.0 | XXX | 30 | 45 | 60 | 1/week | 8-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 1/week | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/quarter | Grab |
| Total Nitrogen | XXX | XXX | XXX | XXX | Report Daily Max | XXX | 1/year | 8-Hr Composite |
| Ammonia-Nitrogen Nov 1 - Apr 30 | 5.5 | 8.3 | XXX | 3.3 | 5.0 | 6.6 | 1/week | 8-Hr Composite |

Outfall001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------------------|-------------------------------------|---------------------|-----------------------|--------------------|---------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Ammonia-Nitrogen May 1 - Oct 31 | 3.3 | 5.0 | XXX | 2.0 | 3.0 | 4.0 | 1/week | 8-Hr Composite |
| Total Phosphorus | XXX | XXX | XXX | XXX | Report Daily Max | XXX | 1/year | 8-Hr Composite |
| Total Zinc (ug/L) | Report | Report Daily Max | XXX | Report | Report Daily Max | XXX | 1/week | 24-Hr Composite |

Compliance Sampling Location:

Other Comments:

ATTACHMENT A

WQM 7.0 Modeling Results

Permit No. PA0111201

Summer

Permit No. PA0111201

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|----------------------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 08B | 26884 | Trib 26884 to Little Chest Creek | 3.270 | 2600.00 | 0.46 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.048 | 0.00 | 0.00 | 0.000 | 0.000 | 10.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|-----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| Carrolltown Bor | PA0111201 | 0.2000 | 0.0000 | 0.0000 | 0.000 | 20.00 | 7.00 |

| Parameter Data | | | | |
|------------------|------------------|------------------|--------------------|--------------------|
| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 6.00 | 9.01 | 0.00 | 0.00 |
| NH3-N | 2.00 | 0.00 | 0.00 | 0.70 |

Permit No. PA0111201

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|----------------------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 08B | 26884 | Trib 26884 to Little Chest Creek | 0.001 | 1800.00 | 2.88 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.048 | 0.00 | 0.00 | 0.000 | 0.000 | 10.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Permit No. PA0111201

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | <u>Stream Name</u> | | | | | | | |
|--------------------|----------------------|--------------------|--------------------------|-----------------------------|----------------------------------|---------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| 08B | | 26884 | | | Trib 26884 to Little Chest Creek | | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 3.270 | 0.02 | 0.00 | 0.02 | .3094 | 0.04635 | .457 | 4.49 | 9.82 | 0.16 | 1.236 | 20.00 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 3.270 | 0.01 | 0.00 | 0.01 | .3094 | 0.04635 | NA | NA | NA | 0.16 | 1.253 | 20.00 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 3.270 | 0.03 | 0.00 | 0.03 | .3094 | 0.04635 | NA | NA | NA | 0.16 | 1.220 | 20.00 | 7.00 |

Permit No. PA0111201

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

Permit No. PA0111201

WQM 7.0 Wasteload Allocations

| | | |
|------------------|--------------------|----------------------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
| 08B | 26884 | Trib 26884 to Little Chest Creek |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|-----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 3.270 | Carrolltown Bor | 16.76 | 4 | 16.76 | 4 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|-----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 3.270 | Carrolltown Bor | 1.89 | 2 | 1.89 | 2 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|------|-----------------|--------------------|--------------------|--------------------|--------------------|-------------------------|--------------------|-------------------|----------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 3.27 | Carrolltown Bor | 25 | 25 | 2 | 2 | 6 | 6 | 0 | 0 |

Permit No. PA0111201

WQM 7.0 D.O. Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | |
|---------------------------------|-----------------------------------|----------------------------------|--------------|-----------------------------|--|
| 08B | 26884 | Trib 26884 to Little Chest Creek | | | |
| <hr/> | | | | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> | |
| 3.270 | 0.200 | 20.000 | | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> | |
| 4.488 | 0.457 | 9.815 | | 0.162 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> | |
| 23.46 | 1.476 | 1.87 | | 0.700 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> | |
| 6.202 | 27.217 | Owens | | 6 | |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u> | | | | |
| 1.236 | <u>TravTime</u> | <u>CBOD5</u> | <u>NH3-N</u> | <u>D.O.</u> | |
| | (days) | (mg/L) | (mg/L) | (mg/L) | |
| | 0.124 | 19.55 | 1.71 | 7.25 | |
| | 0.247 | 16.29 | 1.57 | 7.57 | |
| | 0.371 | 13.57 | 1.44 | 7.82 | |
| | 0.495 | 11.31 | 1.32 | 8.03 | |
| | 0.618 | 9.42 | 1.21 | 8.20 | |
| | 0.742 | 7.85 | 1.11 | 8.24 | |
| | 0.865 | 6.54 | 1.02 | 8.24 | |
| | 0.989 | 5.45 | 0.93 | 8.24 | |
| | 1.113 | 4.54 | 0.86 | 8.24 | |
| | 1.236 | 3.79 | 0.79 | 8.24 | |

Permit No. PA0111201

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | | <u>Stream Code</u> | <u>Stream Name</u> | | | | |
|------------------|-----------------|--------------------|----------------------------------|------------------|-------------------------------|---------------------------|---------------------------|
| 08B | | 26884 | Trib 26884 to Little Chest Creek | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Eff. Limit 30-day Ave. (mg/L) | Eff. Limit Maximum (mg/L) | Eff. Limit Minimum (mg/L) |
| 3.270 | Carrolltown Bor | PA0111201 | 0.200 | CBOD5 | 25 | | |
| | | | | NH3-N | 2 | 4 | |
| | | | | Dissolved Oxygen | | | 6 |

Permit No. PA0111201

Winter

Permit No. PA0111201

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|----------------------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 08B | 26884 | Trib 26884 to Little Chest Creek | 3.270 | 2600.00 | 0.46 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfs) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary | | Stream | |
|--------------|-----------|-----------------|-------------------|----------------------|--------------------|----------|----------------|----------------|-----------|------|-----------|------|
| | | | | | | | | | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.097 | 0.00 | 0.00 | 0.000 | 0.000 | 10.0 | 0.00 | 0.00 | 5.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing | Permitted | Design | Reserve Factor | Disc | Disc |
|-----------------|---------------|-----------------|-----------------|-----------------|----------------|-----------|------|
| | | Disc Flow (mgd) | Disc Flow (mgd) | Disc Flow (mgd) | | Temp (°C) | pH |
| Carrolltown Bor | PA0111201 | 0.2000 | 0.0000 | 0.0000 | 0.000 | 15.00 | 7.00 |

Parameter Data

| Parameter Name | Disc | Trib | Stream | Fate |
|------------------|-------------|-------------|-------------|---------------|
| | Conc (mg/L) | Conc (mg/L) | Conc (mg/L) | Coef (1/days) |
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 6.00 | 12.51 | 0.00 | 0.00 |
| NH3-N | 3.30 | 0.00 | 0.00 | 0.70 |

Permit No. PA0111201

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|----------------------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 08B | 26884 | Trib 26884 to Little Chest Creek | 0.001 | 1800.00 | 2.88 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary | | Stream | |
|--------------|-------|-----------------|-------------------|----------------------|--------------------|----------|----------------|----------------|-----------|------|-----------|------|
| | | | | | | | | | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.097 | 0.00 | 0.00 | 0.000 | 0.000 | 10.0 | 0.00 | 0.00 | 5.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|------------------|---------------|-----------------|-----------------|-----------------|----------------|-----------|------|
| Name | Permit Number | Existing | Permitted | Design | Reserve Factor | Disc | Disc |
| | | Disc Flow (mgd) | Disc Flow (mgd) | Disc Flow (mgd) | | Temp (°C) | pH |
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 0.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | Disc | Trib | Stream | Fate | | | |
| | Conc (mg/L) | Conc (mg/L) | Conc (mg/L) | Coef (1/days) | | | |
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 | | | |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 | | | |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 | | | |

Permit No. PA0111201

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | | <u>Stream Name</u> | | | | | | |
|--------------------|-------------|--------------------|-----------------|--------------------|-------------|----------------------------------|-------|-----------|----------|-----------------|---------------|-------------|
| 08B | | 26884 | | | | Trib 26884 to Little Chest Creek | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | (cfs) | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 3.270 | 0.04 | 0.00 | 0.04 | .3094 | 0.04635 | .463 | 4.56 | 9.87 | 0.17 | 1.192 | 13.75 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 3.270 | 0.03 | 0.00 | 0.03 | .3094 | 0.04635 | NA | NA | NA | 0.16 | 1.223 | 14.16 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 3.270 | 0.06 | 0.00 | 0.06 | .3094 | 0.04635 | NA | NA | NA | 0.17 | 1.163 | 13.37 | 7.00 |

Permit No. PA0111201

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

Permit No. PA0111201

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
 08B 26884 Trib 26884 to Little Chest Creek

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|-----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 3.270 | Carrolltown Bor | 24.1 | 6.6 | 24.1 | 6.6 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|-----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 3.270 | Carrolltown Bor | 2.89 | 3.3 | 2.89 | 3.3 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|------|-----------------|-----------------|-----------------|-----------------|-----------------|-------------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 3.27 | Carrolltown Bor | 25 | 25 | 3.3 | 3.3 | 6 | 6 | 0 | 0 |

Permit No. PA0111201

WQM 7.0 D.O. Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | |
|---------------------------------|-----------------------------------|----------------------------------|---------------------|-----------------------------|--|
| 08B | 26884 | Trib 26884 to Little Chest Creek | | | |
| <u>RM</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> | |
| 3.270 | 0.200 | 13.745 | | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> | |
| 4.565 | 0.463 | 9.869 | | 0.168 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> | |
| 22.11 | 1.465 | 2.89 | | 0.433 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> | |
| 6.817 | 23.534 | Owens | | 6 | |
| <u>Reach Travel Time (days)</u> | Subreach Results | | | | |
| 1.192 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> | |
| | 0.119 | 19.40 | 2.74 | 8.61 | |
| | 0.238 | 17.02 | 2.60 | 8.89 | |
| | 0.358 | 14.93 | 2.47 | 9.06 | |
| | 0.477 | 13.09 | 2.35 | 9.21 | |
| | 0.596 | 11.49 | 2.23 | 9.33 | |
| | 0.715 | 10.08 | 2.12 | 9.33 | |
| | 0.835 | 8.84 | 2.01 | 9.33 | |
| | 0.954 | 7.75 | 1.91 | 9.33 | |
| | 1.073 | 6.80 | 1.81 | 9.33 | |
| | 1.192 | 5.97 | 1.72 | 9.33 | |

Permit No. PA0111201

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | |
|------------------|-----------------|--------------------|-----------------|----------------------------------|--------------------------------|----------------------------|----------------------------|
| 08B | | 26884 | | Trib 26884 to Little Chest Creek | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 3.270 | Carrolltown Bor | PA0111201 | 0.200 | CBOD5 | 25 | | |
| | | | | NH3-N | 3.3 | 6.6 | |
| | | | | Dissolved Oxygen | | | 6 |

ATTACHMENT B

TRC Modeling Results

Permit No. PA0111201

| TRC EVALUATION | | | | |
|---|---|-------------------------------|-----|--------------------------------------|
| Input appropriate values in A3:A9 and D3:D9 | | | | |
| 0.0222 | = Q stream (cfs) | | 0.5 | = CV Daily |
| 0.2 | = Q discharge (MGD) | | 0.5 | = CV Hourly |
| 30 | = no. samples | | 1 | = AFC_Partial Mix Factor |
| 0.3 | = Chlorine Demand of Stream | | 1 | = CFC_Partial Mix Factor |
| 0 | = Chlorine Demand of Discharge | | 15 | = AFC_Criteria Compliance Time (min) |
| 0.5 | = BAT/BJ Value | | 720 | = CFC_Criteria Compliance Time (min) |
| 0 | = % Factor of Safety (FOS) | | | = Decay Coefficient (K) |
| Source | Reference | AFC Calculations | | Reference |
| TRC | 1.3.2.iii | WLA_afc = 0.042 | | 1.3.2.iii |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | | 5.1c |
| PENTOXSD TRG | 5.1b | LTA_afc = 0.016 | | 5.1d |
| | | | | WLA_cfc = 0.033 |
| | | | | LTAMULT_cfc = 0.581 |
| | | | | LTA_cfc = 0.019 |
| Source | Effluent Limit Calculations | | | |
| PENTOXSD TRG | 5.1f | AML_MULT = 1.231 | | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.019 | | AFC |
| | | INST MAX LIMIT (mg/l) = 0.063 | | |
| WLA_afc | $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)]^{(1-FOS/100)}$ | | | |
| LTAMULT_afc | $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$ | | | |
| LTA_afc | $wla_afc \cdot LTAMULT_afc$ | | | |
| WLA_cfc | $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)]^{(1-FOS/100)}$ | | | |
| LTAMULT_cfc | $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$ | | | |
| LTA_cfc | $wla_cfc \cdot LTAMULT_cfc$ | | | |
| AML_MULT | $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$ | | | |
| AVG MON LIMIT | $MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$ | | | |
| INST MAX LIMIT | $1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$ | | | |

ATTACHMENT C

TMS Spreadsheet Output

Permit No. PA0111201



Discharge Information

Instructions Discharge Stream

Facility: Carrolltown Borough NPDES Permit No.: PA0111201 Outfall No.: 001
 Evaluation Type: _____ Wastewater Description: _____

| Discharge Characteristics | | | | | | | | |
|---------------------------|------------------|----------|----------------------------|-----|-----|-----|--------------------------|----------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | | Complete Mix Times (min) | |
| | | | AFC | CFC | THH | CRL | Q ₇₋₁₀ | Q _h |
| 0.2 | 100 | 7 | | | | | | |

| Discharge Pollutant | Units | Max Discharge Conc | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | | 1 if left blank | | |
|---------------------|---------------------------------|--------------------|-----------------|-------------|-------------------|-----------|-----------------|------------|-----|-----------------|-------------|--|
| | | | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteria Mod | Chem Transl | |
| Group 1 | Total Dissolved Solids (PWS) | mg/L | 449 | | | | | | | | | |
| | Chloride (PWS) | mg/L | 114 | | | | | | | | | |
| | Bromide | mg/L | 0.06 | | | | | | | | | |
| | Sulfate (PWS) | mg/L | 27.5 | | | | | | | | | |
| | Fluoride (PWS) | mg/L | | | | | | | | | | |
| Group 2 | Total Aluminum | µg/L | | | | | | | | | | |
| | Total Antimony | µg/L | | | | | | | | | | |
| | Total Arsenic | µg/L | | | | | | | | | | |
| | Total Barium | µg/L | | | | | | | | | | |
| | Total Beryllium | µg/L | | | | | | | | | | |
| | Total Boron | µg/L | | | | | | | | | | |
| | Total Cadmium | µg/L | | | | | | | | | | |
| | Total Chromium (III) | µg/L | | | | | | | | | | |
| | Hexavalent Chromium | µg/L | | | | | | | | | | |
| | Total Cobalt | µg/L | | | | | | | | | | |
| | Total Copper | µg/L | 47 | | | | | | | | | |
| | Free Cyanide | µg/L | | | | | | | | | | |
| | Total Cyanide | µg/L | | | | | | | | | | |
| | Dissolved Iron | µg/L | | | | | | | | | | |
| | Total Iron | µg/L | | | | | | | | | | |
| | Total Lead | µg/L | < 0.33 | | | | | | | | | |
| | Total Manganese | µg/L | | | | | | | | | | |
| | Total Mercury | µg/L | | | | | | | | | | |
| | Total Nickel | µg/L | | | | | | | | | | |
| | Total Phenols (Phenolics) (PWS) | µg/L | | | | | | | | | | |
| | Total Selenium | µg/L | | | | | | | | | | |
| | Total Silver | µg/L | | | | | | | | | | |
| | Total Thallium | µg/L | | | | | | | | | | |
| Total Zinc | µg/L | 47 | | | | | | | | | | |
| Total Molybdenum | µg/L | | | | | | | | | | | |
| Acrolein | µg/L | < | | | | | | | | | | |
| Acrylamide | µg/L | < | | | | | | | | | | |
| Acrylonitrile | µg/L | < | | | | | | | | | | |
| Benzene | µg/L | < | | | | | | | | | | |
| Bromofom | µg/L | < | | | | | | | | | | |

Permit No. PA0111201

| | | | | | | | | | | | | | |
|----------------------------|-----------------------------|----------------|------|---|--|--|--|--|--|--|--|--|--|
| Group 3 | Carbon Tetrachloride | µg/L | < | | | | | | | | | | |
| | Chlorobenzene | µg/L | | | | | | | | | | | |
| | Chlorodibromomethane | µg/L | < | | | | | | | | | | |
| | Chloroethane | µg/L | < | | | | | | | | | | |
| | 2-Chloroethyl Vinyl Ether | µg/L | < | | | | | | | | | | |
| | Chloroform | µg/L | < | | | | | | | | | | |
| | Dichlorobromomethane | µg/L | < | | | | | | | | | | |
| | 1,1-Dichloroethane | µg/L | < | | | | | | | | | | |
| | 1,2-Dichloroethane | µg/L | < | | | | | | | | | | |
| | 1,1-Dichloroethylene | µg/L | < | | | | | | | | | | |
| | 1,2-Dichloropropane | µg/L | < | | | | | | | | | | |
| | 1,3-Dichloropropylene | µg/L | < | | | | | | | | | | |
| | 1,4-Dioxane | µg/L | < | | | | | | | | | | |
| | Ethylbenzene | µg/L | < | | | | | | | | | | |
| | Group 4 | Methyl Bromide | µg/L | < | | | | | | | | | |
| Methyl Chloride | | µg/L | < | | | | | | | | | | |
| Methylene Chloride | | µg/L | < | | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | | µg/L | < | | | | | | | | | | |
| Tetrachloroethylene | | µg/L | < | | | | | | | | | | |
| Toluene | | µg/L | < | | | | | | | | | | |
| 1,2-trans-Dichloroethylene | | µg/L | < | | | | | | | | | | |
| 1,1,1-Trichloroethane | | µg/L | < | | | | | | | | | | |
| 1,1,2-Trichloroethane | | µg/L | < | | | | | | | | | | |
| Trichloroethylene | | µg/L | < | | | | | | | | | | |
| Vinyl Chloride | | µg/L | < | | | | | | | | | | |
| 2-Chlorophenol | | µg/L | < | | | | | | | | | | |
| 2,4-Dichlorophenol | | µg/L | < | | | | | | | | | | |
| 2,4-Dimethylphenol | | µg/L | < | | | | | | | | | | |
| 4,6-Dinitro-o-Cresol | µg/L | < | | | | | | | | | | | |
| 2,4-Dinitrophenol | µg/L | < | | | | | | | | | | | |
| 2-Nitrophenol | µg/L | < | | | | | | | | | | | |
| 4-Nitrophenol | µg/L | < | | | | | | | | | | | |
| p-Chloro-m-Cresol | µg/L | < | | | | | | | | | | | |
| Pentachlorophenol | µg/L | < | | | | | | | | | | | |
| Phenol | µg/L | < | | | | | | | | | | | |
| 2,4,6-Trichlorophenol | µg/L | < | | | | | | | | | | | |
| Group 5 | Acenaphthene | µg/L | < | | | | | | | | | | |
| | Acenaphthylene | µg/L | < | | | | | | | | | | |
| | Anthracene | µg/L | < | | | | | | | | | | |
| | Benzidine | µg/L | < | | | | | | | | | | |
| | Benzo(a)Anthracene | µg/L | < | | | | | | | | | | |
| | Benzo(a)Pyrene | µg/L | < | | | | | | | | | | |
| | 3,4-Benzofluoranthene | µg/L | < | | | | | | | | | | |
| | Benzo(ghi)Perylene | µg/L | < | | | | | | | | | | |
| | Benzo(k)Fluoranthene | µg/L | < | | | | | | | | | | |
| | Bis(2-Chloroethoxy)Methane | µg/L | < | | | | | | | | | | |
| | Bis(2-Chloroethyl)Ether | µg/L | < | | | | | | | | | | |
| | Bis(2-Chloroisopropyl)Ether | µg/L | < | | | | | | | | | | |
| | Bis(2-Ethylhexyl)Phthalate | µg/L | < | | | | | | | | | | |
| | 4-Bromophenyl Phenyl Ether | µg/L | < | | | | | | | | | | |
| | Butyl Benzyl Phthalate | µg/L | < | | | | | | | | | | |
| | 2-Chloronaphthalene | µg/L | < | | | | | | | | | | |
| | 4-Chlorophenyl Phenyl Ether | µg/L | < | | | | | | | | | | |
| | Chrysene | µg/L | < | | | | | | | | | | |
| | Dibenzo(a,h)Anthracene | µg/L | < | | | | | | | | | | |
| | 1,2-Dichlorobenzene | µg/L | < | | | | | | | | | | |
| | 1,3-Dichlorobenzene | µg/L | < | | | | | | | | | | |
| | 1,4-Dichlorobenzene | µg/L | < | | | | | | | | | | |
| | 3,3-Dichlorobenzidine | µg/L | < | | | | | | | | | | |
| | Diethyl Phthalate | µg/L | < | | | | | | | | | | |
| Dimethyl Phthalate | µg/L | < | | | | | | | | | | | |
| Di-n-Butyl Phthalate | µg/L | < | | | | | | | | | | | |
| 2,4-Dinitrotoluene | µg/L | < | | | | | | | | | | | |

Permit No. PA0111201

| | | | | | | | | | | | | | | | | |
|--------------|---------------------------|--------|---|--|--|--|--|--|--|--|--|--|--|--|--|--|
| | 2,6-Dinitrotoluene | µg/L | < | | | | | | | | | | | | | |
| | Di-n-Octyl Phthalate | µg/L | < | | | | | | | | | | | | | |
| | 1,2-Diphenylhydrazine | µg/L | < | | | | | | | | | | | | | |
| | Fluoranthene | µg/L | < | | | | | | | | | | | | | |
| | Fluorene | µg/L | < | | | | | | | | | | | | | |
| | Hexachlorobenzene | µg/L | < | | | | | | | | | | | | | |
| | Hexachlorobutadiene | µg/L | < | | | | | | | | | | | | | |
| | Hexachlorocyclopentadiene | µg/L | < | | | | | | | | | | | | | |
| | Hexachloroethane | µg/L | < | | | | | | | | | | | | | |
| | Indeno(1,2,3-cd)Pyrene | µg/L | < | | | | | | | | | | | | | |
| | Isophorone | µg/L | < | | | | | | | | | | | | | |
| | Naphthalene | µg/L | < | | | | | | | | | | | | | |
| | Nitrobenzene | µg/L | < | | | | | | | | | | | | | |
| | n-Nitrosodimethylamine | µg/L | < | | | | | | | | | | | | | |
| | n-Nitrosod-n-Propylamine | µg/L | < | | | | | | | | | | | | | |
| | n-Nitrosodphenylamine | µg/L | < | | | | | | | | | | | | | |
| | Phenanthrene | µg/L | < | | | | | | | | | | | | | |
| | Pyrene | µg/L | < | | | | | | | | | | | | | |
| | 1,2,4-Trichlorobenzene | µg/L | < | | | | | | | | | | | | | |
| Group 6 | Aldrin | µg/L | < | | | | | | | | | | | | | |
| | alpha-BHC | µg/L | < | | | | | | | | | | | | | |
| | beta-BHC | µg/L | < | | | | | | | | | | | | | |
| | gamma-BHC | µg/L | < | | | | | | | | | | | | | |
| | delta BHC | µg/L | < | | | | | | | | | | | | | |
| | Chlordane | µg/L | < | | | | | | | | | | | | | |
| | 4,4-DDT | µg/L | < | | | | | | | | | | | | | |
| | 4,4-DDE | µg/L | < | | | | | | | | | | | | | |
| | 4,4-DDD | µg/L | < | | | | | | | | | | | | | |
| | Dieldrin | µg/L | < | | | | | | | | | | | | | |
| | alpha-Endosulfan | µg/L | < | | | | | | | | | | | | | |
| | beta-Endosulfan | µg/L | < | | | | | | | | | | | | | |
| | Endosulfan Sulfate | µg/L | < | | | | | | | | | | | | | |
| | Endrin | µg/L | < | | | | | | | | | | | | | |
| | Endrin Aldehyde | µg/L | < | | | | | | | | | | | | | |
| | Heptachlor | µg/L | < | | | | | | | | | | | | | |
| | Heptachlor Epoxide | µg/L | < | | | | | | | | | | | | | |
| | PCB-1016 | µg/L | < | | | | | | | | | | | | | |
| | PCB-1221 | µg/L | < | | | | | | | | | | | | | |
| | PCB-1232 | µg/L | < | | | | | | | | | | | | | |
| PCB-1242 | µg/L | < | | | | | | | | | | | | | | |
| PCB-1248 | µg/L | < | | | | | | | | | | | | | | |
| PCB-1254 | µg/L | < | | | | | | | | | | | | | | |
| PCB-1260 | µg/L | < | | | | | | | | | | | | | | |
| PCBs, Total | µg/L | < | | | | | | | | | | | | | | |
| Toxaphene | µg/L | < | | | | | | | | | | | | | | |
| 2,3,7,8-TCDD | ng/L | < | | | | | | | | | | | | | | |
| Group 7 | Gross Alpha | pCi/L | < | | | | | | | | | | | | | |
| | Total Beta | pCi/L | < | | | | | | | | | | | | | |
| | Radium 226/228 | pCi/L | < | | | | | | | | | | | | | |
| | Total Strontium | µg/L | < | | | | | | | | | | | | | |
| | Total Uranium | µg/L | < | | | | | | | | | | | | | |
| | Osmotic Pressure | mOs/kg | < | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |



Stream / Surface Water Information

Carrolltown Borough, NPDES Permit No. PA0111201, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: UNT of Little Chest Creek

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 026884 | 3.27 | 2600 | 0.46 | | | Yes |
| End of Reach 1 | 026884 | 0.01 | 1800 | 2.88 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 3.27 | 0.048 | | | | | | | | | | 100 | 7 | | |
| End of Reach 1 | 0.01 | 0.048 | | | | | | | | | | | | | |

Q_n

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|----------|----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness | pH | Hardness | pH |
| Point of Discharge | 3.27 | | | | | | | | | | | | | | |
| End of Reach 1 | 0.01 | | | | | | | | | | | | | | |



Model Results

Carrolltown Borough, NPDES Permit No. PA0111201, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | 13.439 | 14.0 | 15.0 | Chem Translator of 0.96 applied |
| Total Lead | 0 | 0 | | 0 | 64.581 | 81.6 | 87.5 | Chem Translator of 0.791 applied |
| Total Zinc | 0 | 0 | | 0 | 117.180 | 120 | 128 | Chem Translator of 0.978 applied |

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | 8.956 | 9.33 | 9.99 | Chem Translator of 0.96 applied |
| Total Lead | 0 | 0 | | 0 | 2.517 | 3.18 | 3.41 | Chem Translator of 0.791 applied |
| Total Zinc | 0 | 0 | | 0 | 118.139 | 120 | 128 | Chem Translator of 0.986 applied |

THH

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | 500,000 | 500,000 | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |

| | | | | | | | |
|--------------|---|---|--|---|-----|-----|-----|
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A |

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|--------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Copper | 0.017 | 0.025 | 9.99 | 15.0 | 15.0 | µg/L | 9.99 | CFC | Discharge Conc ≥ 50% WQBEL (RP) |
| Total Zinc | Report | Report | Report | Report | Report | µg/L | 120 | AFC | Discharge Conc > 10% WQBEL (no RP) |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., ≤ Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|------------------------------|-----------------|-------|----------------------|
| Total Dissolved Solids (PWS) | N/A | N/A | PWS Not Applicable |
| Chloride (PWS) | N/A | N/A | PWS Not Applicable |
| Bromide | N/A | N/A | No WQS |
| Sulfate (PWS) | N/A | N/A | PWS Not Applicable |
| Total Lead | N/A | N/A | Discharge Conc < TQL |
| | | | |

ATTACHMENT D


USGS Stream Stats Output

Permit No. PA0111201

At Discharge Point

StreamStats Report

Region ID: PA
Workspace ID: PA20211001125026276000
Clicked Point (Latitude, Longitude): 40.60927, -78.70556
Time: 2021-10-01 08:50:45 -0400



Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|---|-------|--------------|
| DRNAREA | Area that drains to a point on a stream | 0.46 | square miles |
| ELEV | Mean Basin Elevation | 2157 | feet |
| PRECIP | Mean Annual Precipitation | 43 | inches |

Permit No. PA0111201

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 0.46 | square miles | 2.33 | 1720 |
| ELEV | Mean Basin Elevation | 2157 | feet | 898 | 2700 |
| PRECIP | Mean Annual Precipitation | 43 | inches | 38.7 | 47.9 |

Low-Flow Statistics Disclaimers [Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [Low Flow Region 3]

| Statistic | Value | Unit |
|-------------------------|--------|--------------------|
| 7 Day 2 Year Low Flow | 0.0583 | ft ³ /s |
| 30 Day 2 Year Low Flow | 0.0855 | ft ³ /s |
| 7 Day 10 Year Low Flow | 0.0222 | ft ³ /s |
| 30 Day 10 Year Low Flow | 0.0312 | ft ³ /s |
| 90 Day 10 Year Low Flow | 0.0474 | ft ³ /s |

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

Permit No. PA0111201

Downstream of Discharge


StreamStats Report

Region ID: PA

Workspace ID: PA20211001125946385000

Clicked Point (Latitude, Longitude): 40.62916, -78.66222

Time: 2021-10-01 09:00:05 -0400



Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|---|-------|--------------|
| DRNAREA | Area that drains to a point on a stream | 2.88 | square miles |
| ELEV | Mean Basin Elevation | 2039 | feet |
| PRECIP | Mean Annual Precipitation | 43 | inches |

ATTACHMENT E

Carrolltown Borough Municipal Authority Pre-Draft Survey Response

Permit No. PA0111201



**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
PRE-DRAFT PERMIT SURVEY FOR TOXIC POLLUTANTS**

| | | | |
|---|--|------------------------------------|------------------|
| Permittee Name: | Carrolltown Borough Municipal Authority | Permit No.: | PA0111201 |
| | Cambridia County | | |
| Pollutant(s) identified by DEP that may require QBELs: | Copper | | |
| Is the permittee aware of the source(s) of the pollutant(s)? | <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Suspected | | |
| If Yes or Suspected, describe the known or suspected source(s) of pollutant(s) in the effluent. The primary source of copper is suspected to be corrosion of piping (including institutional boilers) within the public drinking water system, 2019 Lead/Copper Testing resulted in a 90th percentile copper concentration of 0.413 mg/l. That level meets drinking water standards but is well in excess of the proposed QBEL. | | | |
| Has the permittee completed any studies in the past to control or treat the pollutant(s)? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | |
| If Yes, describe prior studies and results: The Authority has incorporated polyphosphate treatment into the drinking water system to control corrosion, Occasional exceedances of the existing copper effluent limit still occur. | | | |
| Does the permittee believe it can achieve the proposed QBELs now? | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Uncertain | | |
| If No, describe the activities, upgrades or process changes that would be necessary to achieve the QBELs, if known. More stringent copper effluent limits will require the installation of tertiary treatment, likely in the form of adsorption or filtration units. | | | |
| Estimated date by which the permittee could achieve the proposed QBELs: | 2027 | <input type="checkbox"/> Uncertain | |
| Will the permittee conduct additional sampling for the pollutant(s) to supplement the application? | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | |
| Check the appropriate box(es) below to indicate site-specific data that have been collected by the permittee in the past. If any of these data have <u>not</u> been submitted to DEP, please attach to this survey. | | | |
| <input checked="" type="checkbox"/> Discharge pollutant concentration coefficient(s) of variability | Year(s) Studied: | 2021 to date | |
| <input type="checkbox"/> Discharge and background Total Hardness concentrations (metals) | Year(s) Studied: | | |
| <input type="checkbox"/> Background / ambient pollutant concentrations | Year(s) Studied: | | |
| <input type="checkbox"/> Chemical translator(s) (metals) | Year(s) Studied: | | |
| <input type="checkbox"/> Slope and width of receiving waters | Year(s) Studied: | | |
| <input type="checkbox"/> Velocity of receiving waters at design conditions | Year(s) Studied: | | |
| <input type="checkbox"/> Acute and/or chronic partial mix factors (mixing at design conditions) | Year(s) Studied: | | |
| <input type="checkbox"/> Volatilization rates (highly volatile organics) | Year(s) Studied: | | |
| <input checked="" type="checkbox"/> Site-specific criteria (e.g., Water Effect Ratio or related study) | Year(s) Studied: | 2008 | |

Please submit this survey to the DEP regional office that is reviewing the permit application within 30 days of receipt.