

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES/WQM PERMITS FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0111422 &
3412401 A-1
APS ID 147
Authorization ID 1311566 &
1335039 WQM

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|---|
| Applicant Name | <u>Thompstontown Borough Municipal Authority Juniata County</u> | Facility Name | <u>Thompstontown STP</u> |
| Applicant Address | <u>PO Box 154 Thompstontown, PA 17094-0154</u> | Facility Address | <u>281 South Mill Street Thompstontown, PA 17094-0154</u> |
| Applicant Contact | <u>Roger Stutts</u> | Facility Contact | <u>Roger Stutts</u> |
| Applicant Phone | <u>(717) 535-5292</u> | Facility Phone | <u>(717) 535-5292</u> |
| Client ID | <u>87479</u> | Site ID | <u>252191</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Delaware Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Juniata</u> |
| Date Application Received | <u>April 7, 2020</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>May 26, 2020</u> | If No, Reason | <u></u> |
| Purpose of Application | <u>NPDES Renewal and WQM amendment permits.</u> | | |

Summary of Review

cb³ Solutions, LLC, on behalf of Thompstontown Municipal Authority, has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit on April 7, 2020. The permit was last reissued on September 22, 2015 and became effective on October 1, 2015. The permit expired on September 30, 2020 but the terms and conditions of the permit have been extended since that time.

Thompstontown Municipal Authority owns, operates, and maintains the wastewater treatment plant located in Delaware Township, Juniata County. The aeration secondary treatment plant discharges treated municipal wastewater to Delaware Creek, which is classified for Trout Stocking Fishes (TSF). The collection system has 75% sewers from Thompstontown Borough and 30% sewers from Delaware Township. The facility has proposed a change of design, from the average annual design flow / hydraulic capacity flow of 0.205 MGD, to 0.250 MGD due to a few consecutive months of overflow in 2019.

At the request of DEP, WQM No. 3412401 (originally issued on September 28, 2012), a permit amendment application was also submitted by cb³ Solutions, LLC on December 1, 2020, to increase average annual design flow / hydraulic capacity flow to 0.250 MGD. This rerate, according to the cb³ Solutions, LLC, will not require any construction. Accordingly, DEP has decided to review both WQM amendment permit and NPDES permit renewal applications simultaneously.

Changes from the previous permit: Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml. The average annual flow / hydraulic capacity flow changed from 0.205 MGD to 0.250 MGD. Organic capacity changed from 367 lbs/day to 448 lbs/day.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

| Approve | Deny | Signatures | Date |
|---------|------|--|------------------|
| X | | <i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist | December 9, 2020 |
| | | Daniel W. Martin, P.E. / Environmental Engineer Manager | |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|-------------------------|------------------------------|----------------------|
| Outfall No. | 001 | Design Flow (MGD) | 0.25 |
| Latitude | 40° 33' 20.24" | Longitude | -77° 14' 4.33" |
| Quad Name | Millerstown | Quad Code | |
| Wastewater Description: Sewage Effluent | | | |
| Receiving Waters | Delaware Creek (TSF) | Stream Code | 11754 |
| NHD Com ID | 66204937 | RMI | 0.24 mile |
| Drainage Area | 12.6 mi. ² | Yield (cfs/mi ²) | 0.12 |
| Q ₇₋₁₀ Flow (cfs) | 1.5 | Q ₇₋₁₀ Basis | USGS StreamStats |
| Elevation (ft) | 390.0 | Slope (ft/ft) | |
| Watershed No. | 12-B | Chapter 93 Class. | TSF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Attaining Use(s) | | |
| Cause(s) of Impairment | | | |
| Source(s) of Impairment | | | |
| TMDL Status | | Name | |
| Nearest Downstream Public Water Supply Intake | Newport Water Authority | | |
| PWS Waters | Juniata River | Flow at Intake (cfs) | |
| PWS RMI | 12 miles | Distance from Outfall (mi) | Approximate 13 miles |

Changes Since Last Permit Issuance: increase average annual design flow from 0.205 MGD to 0.25 MGD

Drainage Area

The discharge is to Delaware Creek at RMI 0.24 mile. A drainage area upstream of the discharge is estimated to be 12.6 mi.², according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

Since there is no gage station near the outfall, a downstream gage station on the Juniata River was used to determine design stream flows (Gage No. 01567000). The gage is located near Newport, PA. The Q_{7,10} flow at the gage station is 403 cfs, with a drainage area of 3,350 mi.² (according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>) which results in a Q₇₋₁₀ low flow yield of 0.12 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned} \text{Low Flow Yield} &= 403 \text{ cfs} / 3,350 \text{ mi.}^2 \approx 0.12 \text{ cfs/mi.}^2 \\ \text{Q}_{7-10} \text{ discharge} &= 0.12 \text{ cfs/mi.}^2 \times \text{D.A discharge} = 0.12 \text{ cfs/mi.}^2 \times 12.6 \text{ mi.}^2 = 1.5 \text{ cfs} \\ \text{Q}_{30-10} &= 1.36 * 1.5 \text{ cfs} \approx 2.04 \text{ cfs} \\ \text{Q}_{1-10} &= 0.64 * 1.5 \text{ cfs} \approx 0.96 \text{ cfs} \end{aligned}$$

The resulting dilution ratio (under Q₇₋₁₀ conditions) is: Q_{stream} / Q_{discharge} = 1.5 cfs / [0.25 MGD * (1.55 cfs/MGD)] = 3.9:1

Delaware Creek

25 Pa. Code § 93.9n classifies Delaware Creek as Trout Stocking Fishes (TSF) surface water. Based on the 2018 Integrated Report, Delaware Creek, assessment unit ID 9589, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Public Water Supply

The nearest downstream public water supply intake is the Newport Water Authority on Juniata River in Perry County, approximately 13 miles downstream of this discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

| Treatment Facility Summary | | | | |
|---|-----------------------------------|----------------------|----------------------------|-------------------------------|
| Treatment Facility Name: Thompstontown STP | | | | |
| WQM Permit No. | | Issuance Date | | |
| 3412401 | | 9/28/2012 | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Extended Aeration | Gas Chlorine | 0.205 to 0.25 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.205 to 0.25 | 367 to 448 | Not Overloaded | Aerobic Digestion | Landfill |

Changes Since Last Permit Issuance: Yes, the facility flow changed to 0.250 MGD of average daily, 0.04 MGD of minimum daily, 0.50 MGD of maximum daily, and 1.00 MGD of instantaneous peak.

Other Comments: The facility is a 250,000 GPD system with the following treatment units:

- One (1), Comminutor
- One (1), Influent Pump Station
- Two (2), Sequencing Batch Reactors
- One (1), Chlorine Contact Tank
- One (1), Post Aeration Tank
- One (1), Aerobic Sludge Digester

The chemical used chlorine for disinfection.

| Compliance History | |
|--------------------------------|--|
| Summary of DMRs: | DMRs reported last 12 months from November 1, 2019 to October 31, 2020 are summarized in the Table below (Pages 5, 6, & 7). |
| Summary of Inspections: | <p>4/4/2019: Mr. Michael Benham, DEP WQS, conducted compliance evaluation inspection. There were recommendations such as calibrating the influent flowmeter which was due by 3/31/2019, restraining all chlorine gas cylinders, developing logs for the emergency generator maintenance and daily treatment plant activities, having the SCBA unit inspected regularly and developing a logbook for SCBA maintenance and training, and developing SOP for non-certified operators which should include a section on Chlorine gas emergency. The field test results were within permit limit.</p> <p>2/14/2017: Mr. Patrick Bowen, DEP WQS, conducted compliance evaluation inspection. There were violations noted during inspection due to failure to submit discharge monitoring reports for water years 2014-2015 and 2015-2016. Field test results were within permit limit.</p> |
| Other Comments: | There are no open violations associated with the permittee or the facility. |

Other Comments:

**NPDES Permit Fact Sheet
Thompstontown STP**

NPDES Permit No. PA0111422

The table below summarizes the influent/effluent testing results submitted along with the application.

| <i>Influent Testing Results</i> | | | <i>Effluent Testing Results</i> | | |
|---|----------------------|----------------------|---|----------------------|----------------------|
| Parameter | Min/Max Value | Average Value | Parameter | Min/Max Value | Average Value |
| BOD ₅ (mg/L) | 83/151 mg/L | 165 mg/L | pH (minimum) | 6.8 S.U. | |
| BOD ₅ (lbs/day) | 77/181 lbs/day | 275 lbs/day | pH (maximum) | 7.3 S.U. | |
| TSS (mg/L) | 75/322 mg/L | 180 mg/L | D.O (minimum) | 6.2 mg/L | 6.8 mg/L |
| TSS (lbs/day) | 95/268 lbs/day | 300 lbs/day | TRC | 0.3 mg/L | 0.6 mg/L |
| TN (mg/L) | 42/63 mg/L | 50 mg/L | Fecal Coliform | 2 No./100mL | 22 No./100 mL |
| TN (lbs/day) | 35/117 lbs/day | 84 lbs/day | CBOD ₅ | 2 mg/L | 3.6 mg/L |
| TP (mg/L) | 4.5/6.6 mg/L | 6.0 mg/L | TSS | 5 mg/L | 6.5 mg/L |
| TP (lbs/day) | 4/11 lbs/day | 10.0 lbs/day | NH ₃ -N | 0.1 mg/L | 3.6 mg/L |
| NH ₃ -N (mg/L) | 17.2/25 mg/L | 22.0 mg/L | TN | 2.0 mg/L | 4.5 mg/L |
| NH ₃ -N (lbs/day) | 25/52 lbs/day | 37.0 lbs/day | TP | 1.0 mg/L | 1.3 mg/L |
| TDS (mg/L) | 200 mg/L | 350 mg/L | Temp | 50 F | 62 F |
| TDS (lbs/day) | 333 lbs/day | 500 lbs/day | TKN | 1.4 mg/L | 4.0 mg/L |
| TKN | 25/45 mg/L | 35 mg/L | NO ₂ -N + NO ₃ -N | 2.6 mg/L | 2.6 mg/L |
| NO ₂ -N + NO ₃ -N | 12/22 mg/L | 15 mg/L | TDS | 200 mg/L | 350 mg/L |
| | | | Chloride | mg/L | mg/L |
| | | | Bromide | mg/L | mg/L |
| | | | Sulfate | mg/L | mg/L |
| | | | Oil and Grease | 10 mg/L | 15 mg/L |
| | | | Total Copper | 0.0025 mg/L | 0.02 mg/L |
| | | | Total Lead | 0.001 mg/L | 0.0011 mg/L |
| | | | Total Zinc | 0.0025 mg/L | 0.036 mg/L |

Compliance History

DMR Data for Outfall 001 (from November 1, 2019 to October 31, 2020)

| Parameter | OCT-20 | SEP-20 | AUG-20 | JUL-20 | JUN-20 | MAY-20 | APR-20 | MAR-20 | FEB-20 | JAN-20 | DEC-19 | NOV-19 |
|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.108 | 0.094 | 0.091 | 0.089 | 0.116 | 0.221 | 0.174 | 0.168 | 0.136 | 0.133 | 0.110 | 0.115 |
| Flow (MGD) Daily Maximum | 0.300 | 0.126 | 0.118 | 0.120 | 0.200 | 1.307 | 0.306 | 0.949 | 0.435 | 0.601 | 0.227 | 0.492 |
| pH (S.U.) Minimum | 7.1 | 7.1 | 7.0 | 6.9 | 6.8 | 7.0 | 6.8 | 7.0 | 7.0 | 6.9 | 6.8 | 7.0 |
| pH (S.U.) Maximum | 7.4 | 7.4 | 7.3 | 7.7 | 7.2 | 7.4 | 7.4 | 7.3 | 7.5 | 7.3 | 7.3 | 7.3 |
| DO (mg/L) Minimum | 7.4 | 7.5 | 7.2 | 7.3 | 6.9 | 6.8 | 6.8 | 6.9 | 7.0 | 7.0 | 7.0 | 6.8 |
| TRC (mg/L) Average Monthly | 0.5 | 0.5 | 0.4 | 0.4 | 0.4 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.4 | 0.4 |
| TRC (mg/L) Instantaneous Maximum | 0.7 | 0.7 | 0.6 | 0.9 | 0.8 | 0.7 | 0.6 | 0.6 | 0.3 | 0.7 | 0.7 | 0.6 |
| CBOD5 (lbs/day) Average Monthly | < 2.0 | < 2.2 | 2.2 | 2.3 | < 2.5 | < 2.5 | < 3.4 | < 2.8 | < 2.5 | < 3.0 | < 2.4 | < 2.2 |
| CBOD5 (lbs/day) Weekly Average | 2.8 | 4.0 | 2.7 | 2.8 | 2.8 | < 3.8 | < 5.0 | 3.8 | 4.0 | 5.0 | 4.0 | 3.8 |
| CBOD5 (mg/L) Average Monthly | < 2.5 | < 2.8 | 3.0 | 3.1 | < 2.6 | < 2.0 | < 2.2 | < 2.7 | 2.3 | < 3.1 | < 2.6 | < 2.8 |
| CBOD5 (mg/L) Weekly Average | 3.4 | 5.1 | 3.6 | 3.4 | 3.3 | < 2.0 | 2.7 | 4.7 | 3.2 | 4.7 | 3.7 | 4.7 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 183 | 125 | 113 | 115 | 205 | 174 | 155 | 128 | 141 | 90 | 91 | 91 |
| BOD5 (lbs/day) Raw Sewage Influent Daily Maximum | 267 | 200 | 141 | 142 | 286 | 204 | 224 | 196 | 174 | 137 | 120 | 123 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 217 | 153 | 152 | 152 | 225 | 163 | 111 | 109 | 134 | 107 | 101 | 122 |
| TSS (lbs/day) Average Monthly | < 4.3 | < 5.0 | < 3.7 | < 3.8 | < 4.8 | < 6.3 | < 7.7 | < 5.7 | < 4.4 | < 6.2 | < 4.5 | 7.0 |
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 261 | 117 | 183 | 172 | 238 | 166 | 195 | 119 | 80 | 110 | 144 | 100 |

**NPDES Permit Fact Sheet
Thompsonstown STP**

NPDES Permit No. PA0111422

| | | | | | | | | | | | | |
|--|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| TSS (lbs/day) Raw Sewage Influent Daily Maximum | 460 | 259 | 282 | 212 | 335 | 227 | 255 | 210 | 121 | 193 | 347 | 124 |
| TSS (lbs/day) Weekly Average | 4.9 | 7.7 | < 3.8 | < 4.0 | 6.7 | < 9.4 | < 12.5 | 8.2 | 6.3 | 7.0 | 5.3 | 16.0 |
| TSS (mg/L) Average Monthly | < 5.0 | < 6.3 | < 5.0 | < 5 | < 5.0 | < 5 | < 5 | < 5 | < 5 | < 7.0 | < 5 | 9.0 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 310 | 142 | 113 | 228 | 254 | 148 | 137 | 102 | 79 | 131 | 163 | 133 |
| TSS (mg/L) Weekly Average | 6.0 | 10 | < 5.0 | < 5 | < 5.0 | < 5 | < 5 | 5 | < 5 | 13.0 | < 5 | 20.0 |
| Fecal Coliform (CFU/100 ml) Geometric Mean | < 6 | 1.0 | < 3.0 | < 21 | 17 | < 1 | < 1 | < 2 | < 1 | < 34 | < 3.0 | < 2.0 |
| Fecal Coliform (CFU/100 ml) Instantaneous Maximum | 2100 | 27500 | 57 | 23900 | 2100 | 1 | < 1 | 25 | 2 | 5000 | 68.0 | 12.0 |
| Nitrate-Nitrite (mg/L) Average Monthly | 3.0 | 2.28 | 1.88 | 1.83 | 2.12 | 3.7 | 3.64 | 4.73 | 2.28 | 4.24 | 2.05 | < 6.9 |
| Nitrate-Nitrite (lbs) Total Monthly | 74.4 | 54 | 43.4 | 43.4 | 48 | 152 | 180 | 173.6 | 69.6 | 18.1 | 57.7 | < 154.4 |
| Total Nitrogen (mg/L) Average Monthly | < 4.0 | < 4.13 | < 2.9 | < 2.95 | < 3.24 | < 4.7 | < 4.64 | < 6.15 | 3.60 | < 5.84 | 3.93 | < 8.01 |
| Total Nitrogen (lbs) Effluent Net Total Monthly | < 102.3 | < 102 | < 65.1 | < 68.2 | < 72 | < 192.2 | < 225 | < 217 | 110 | < 25.1 | 109.9 | < 181.2 |
| Total Nitrogen (lbs) Total Monthly | 102.3 | < 102 | < 65.1 | < 68.2 | < 72 | < 192.2 | < 225 | < 217 | 110 | < 25.1 | 109.9 | < 181.2 |
| Total Nitrogen (lbs) Effluent Net Total Annual | | < 229 | | | | | | | | | | |
| Total Nitrogen (lbs) Total Annual | | < 229 | | | | | | | | | | |
| Ammonia (lbs/day) Average Monthly | < 0.1 | < 0.75 | 0.15 | < 0.1 | < 0.08 | < 1.3 | < 0.16 | < 0.13 | < 0.15 | < 0.022 | < 0.6 | < 4.9 |
| Ammonia (mg/L) Average Monthly | < 0.118 | < 0.805 | < 0.185 | < 0.136 | < 0.109 | < 0.1 | < 0.113 | < 0.113 | < 0.132 | < 0.153 | < 0.638 | < 6.508 |
| Ammonia (lbs) Total Monthly | < 3.1 | < 22.5 | < 4.7 | < 3.1 | < 2.4 | < 40.3 | < 4.8 | < 4.0 | < 4.4 | < 0.7 | < 18.5 | < 146.5 |
| Ammonia (lbs) Total Annual | | < 30 | | | | | | | | | | |
| TKN (mg/L) Average Monthly | < 1.0 | < 1.9 | < 1.0 | < 1.1 | < 1.1 | < 1.0 | < 1.0 | < 1.4 | 1.3 | < 1.6 | 1.9 | < 6.9 |

**NPDES Permit Fact Sheet
Thompstontown STP**

NPDES Permit No. PA0111422

| | | | | | | | | | | | | |
|---|--------|------|--------|--------|------|--------|--------|--------|------|-------|------|---------|
| TKN (lbs) Total Monthly | < 25.4 | < 48 | < 23.3 | < 26.4 | < 33 | < 40.3 | < 45 | < 46.5 | 42 | < 7.0 | 52.2 | < 154.4 |
| Total Phosphorus (mg/L) Average Monthly | 2.4 | 2.8 | 2.05 | 2.63 | 1.9 | < 1.2 | < 0.52 | 2.2 | 1.14 | 1.1 | 0.62 | 0.59 |
| Total Phosphorus (lbs) Effluent Net Total Monthly | 59 | 72 | 46.5 | 62 | < 39 | < 40.3 | < 21.6 | 70 | 34.8 | 4.5 | 15.6 | 13.5 |
| Total Phosphorus (lbs) Total Monthly | 59 | 72 | 46.5 | 62 | 39 | 40.3 | < 21.6 | 70 | 34.8 | 4.5 | 15.6 | 13.5 |
| Total Phosphorus (lbs) Effluent Net Total Annual | | < 67 | | | | | | | | | | |
| Total Phosphorus (lbs) Total Annual | | < 67 | | | | | | | | | | |

Development of Effluent Limitations

| | |
|---|--|
| Outfall No. <u>001</u> | Design Flow (MGD) <u>0.25</u> |
| Latitude <u>40° 33' 20.25"</u> | Longitude <u>-77° 14' 4.33"</u> |
| Wastewater Description: <u>Sewage Effluent</u> | |

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Comments:

Water Quality-Based Limitations

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model indicates that a monthly average limit of 25 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing limits of 25 mg/L monthly average (AML), 40mg/l average weekly limit (AWL), and 50 mg/L instantaneous maximum will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 25 \text{ mg/L} \times 0.250 \text{ MGD} \times 8.34 = 52.1 \text{ (52.0) lbs/day} \\ \text{Average weekly mass limit: } & 40 \text{ mg/L} \times 0.250 \text{ MGD} \times 8.34 = 83.4 \text{ (83.0) lbs/day} \end{aligned}$$

Ammonia (NH₃-N):

NH₃N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

| | | | | |
|---|-------------------------------|---|--------|-----------|
| * | Discharge pH | = | 7.0 | (Default) |
| * | Discharge Temperature | = | 20°C | (Default) |
| * | Stream pH | = | 7.0 | (Default) |
| * | Stream Temperature | = | 25°C | (Default) |
| * | Background NH ₃ -N | = | 0 mg/L | (Default) |

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model indicates that a limit of 11.44 mg/L as a monthly average and 22.88 mg/L IMAX are necessary to protect the aquatic life from toxicity effects at the point of discharge. However, the existing limits of 10.0 mg/L monthly average & 20 mg/L IMAX will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\text{Average monthly mass limit: } 10.0 \text{ mg/L} \times 0.250 \text{ MGD} \times 8.34 = 20.85 \text{ (21.0) lbs/day}$$

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

pH:
The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa. Code § 95.2(1).

Total Suspended Solids (TSS):
The existing technology-based limits of 30 mg/L average monthly, 45 mg/L average weekly, and 60 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 30 \text{ mg/L} \times 0.250 \text{ MGD} \times 8.34 = 62.55 \text{ (63.0) lbs/day} \\ \text{Average weekly mass limit: } & 45 \text{ mg/L} \times 0.250 \text{ MGD} \times 8.34 = 93.8 \text{ (94.0) lbs/day} \end{aligned}$$

Fecal Coliform:
The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

Total Residual Chlorine (TRC):
Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), the facility's discharge must meet a monthly average limit of 0.5 mg/L and an instantaneous maximum limit of 1.6 mg/L. These limits are the same as those in the existing permit. The facility has been meeting the limits consistently.

Chesapeake Bay Strategy:
The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase 4 (0.2 -0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase 5 (below 0.2 MGD) will monitor during current permit renewal once a year unless two years of monitoring completed and documented. Any facility in Phases 4 and 5 that undergoes expansion is subjected to cap load right away.

This plant is classified as a phase 4 and is currently undergoing an expansion as allowed under a Part II permit issued on September 28, 2012. For Phase 4 sewage facilities (average annual design flow on August 29, 2005 \geq 0.2 MGD and $<$ 0.4 MGD), renewed or amended permits that include an increase in design flow will contain Cap Loads based on the lesser of a) existing TN and TP concentrations at current design average annual flow or b) 7,306 lbs./yr. TN and 974 lbs./yr. TP (Phase 3 WIP Wastewater Supplement revised 12/17/2019, page #19). Therefore, the existing cap loads of 7,306 lbs./yr. TN and 974 lbs./yr. TP will be continuing to be utilized.

Influent BOD₅ and TSS Monitoring:
The permit will include influent BOD₅ and TSS monitoring at the same frequency as is done for effluent in order to implement 25 Pa. Code § 94.12 and assess percent removal requirements, per DEP policy.

Biosolids Management:
Digested Sludge is sent out periodically to the drying beds.

Stormwater:
There is no stormwater outfall associated with this facility.

Antidegradation (93.4):
The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Thompstontown STP

303d Listed Streams:

The discharge is not located on a 303d listed stream segment. The stream segment that receive the discharge is listed as attaining its uses for aquatic life and fish consumption.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

WQM 7.0

Node 1: Outfall 001 on Delaware Creek (11754)

- Elevation: 390 ft (USGS National Map Viewer)
- Drainage Area: 12.6 mi.² (USGS PA StreamStats)
- River Mile Index: 0.240 (PA DEP eMapPA)
- Low Flow Yield: 0.12 cfs/mi.²
- Discharge Flow: 0.250 MGD (NPDES Application)

Node 2: Just before confluence with Delaware Creek to Juniata River

- Elevation: 381 ft (USGS National Map Viewer)
- Drainage Area: 12.7 mi.² (USGS PA StreamStats)
- River Mile Index: 0.01 (PA DEP eMapPA)
- Low Flow Yield: 0.12 cfs/mi.²
- Discharge Flow: 0.000 MGD

USGS StreamStats

Low-Flow Statistics Parameters (Low Flow Region 2)

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| DRNAREA | Drainage Area | 12.6 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 41 | inches | 35 | 50.4 |
| STRDEN | Stream Density | 2.03 | miles per square mile | 0.51 | 3.1 |
| ROCKDEP | Depth to Rock | 5 | feet | 3.32 | 5.65 |
| CARBON | Percent Carbonate | 22 | percent | 0 | 99 |

Low-Flow Statistics Flow Report (Low Flow Region 2)

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

| Statistic | Value | Unit | SE | SEp |
|-------------------------|-------|--------------------|----|-----|
| 7 Day 2 Year Low Flow | 1.89 | ft ³ /s | 38 | 38 |
| 30 Day 2 Year Low Flow | 2.36 | ft ³ /s | 33 | 33 |
| 7 Day 10 Year Low Flow | 1.05 | ft ³ /s | 51 | 51 |
| 30 Day 10 Year Low Flow | 1.29 | ft ³ /s | 46 | 46 |
| 90 Day 10 Year Low Flow | 1.74 | ft ³ /s | 36 | 36 |

USGS StreamStats

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

[Continue](#)

POWERED BY **WIM**

[USGS Home](#) [Contact USGS](#) [Search USGS](#)
[Accessibility](#) [FOIA](#) [Privacy](#) [Policy & Notices](#)

Low-Flow Statistics Parameters^[Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| DRNAREA | Drainage Area | 12.7 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 41 | inches | 35 | 50.4 |
| STRDEN | Stream Density | 2.03 | miles per square mile | 0.51 | 3.1 |
| ROCKDEP | Depth to Rock | 5 | feet | 3.32 | 5.65 |
| CARBON | Percent Carbonate | 22 | percent | 0 | 99 |

Low-Flow Statistics Flow Report^[Low Flow Region 2]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

| Statistic | Value | Unit | SE | SEp |
|-------------------------|-------|--------------------|----|-----|
| 7 Day 2 Year Low Flow | 1.9 | ft ³ /s | 38 | 38 |
| 30 Day 2 Year Low Flow | 2.38 | ft ³ /s | 33 | 33 |
| 7 Day 10 Year Low Flow | 1.06 | ft ³ /s | 51 | 51 |
| 30 Day 10 Year Low Flow | 1.3 | ft ³ /s | 46 | 46 |
| 90 Day 10 Year Low Flow | 1.75 | ft ³ /s | 36 | 36 |

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Millerstown

Leaflet

USGS StreamStats

BUILD A REPORT report built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

[Continue](#)

POWERED BY **WIM**

[USGS Home](#) [Contact USGS](#) [Search USGS](#)
[Accessibility](#) [FOIA](#) [Privacy](#) [Policy & Notices](#)

Low-Flow Statistics Parameters^[100 Percent (3350 square miles) Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| DRNAREA | Drainage Area | 3350 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 39.2 | inches | 35 | 50.4 |
| STRDEN | Stream Density | 1.94 | miles per square mile | 0.51 | 3.1 |
| ROCKDEP | Depth to Rock | 4.5 | feet | 3.32 | 5.65 |
| CARBON | Percent Carbonate | 16.6 | percent | 0 | 99 |

Low-Flow Statistics Disclaimers^[100 Percent (3350 square miles) Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report^[100 Percent (3350 square miles) Low Flow Region 2]

| Statistic | Value | Unit |
|-------------------------|-------|--------------------|
| 7 Day 2 Year Low Flow | 601 | ft ³ /s |
| 30 Day 2 Year Low Flow | 726 | ft ³ /s |
| 7 Day 10 Year Low Flow | 403 | ft ³ /s |
| 30 Day 10 Year Low Flow | 488 | ft ³ /s |
| 90 Day 10 Year Low Flow | 625 | ft ³ /s |

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Carlisle

Leaflet

| TRC EVALUATION | | | | | |
|---|---|-------------------------------|-----|--------------------------------------|---------------------|
| Input appropriate values in A3:A9 and D3:D9 | | | | | |
| 1.5 | = Q stream (cfs) | | 0.5 | = CV Daily | |
| 0.25 | = Q discharge (MGD) | | 0.5 | = CV Hourly | |
| 30 | = no. samples | | 1 | = AFC_Partial Mix Factor | |
| 0.3 | = Chlorine Demand of Stream | | 1 | = CFC_Partial Mix Factor | |
| 0 | = Chlorine Demand of Discharge | | 15 | = AFC_Criteria Compliance Time (min) | |
| 0.5 | = BAT/BPJ Value | | 720 | = CFC_Criteria Compliance Time (min) | |
| 0 | = % Factor of Safety (FOS) | | | =Decay Coefficient (K) | |
| Source | Reference | AFC Calculations | | Reference | CFC Calculations |
| TRC | 1.3.2.iii | WLA_afc = 1.256 | | 1.3.2.iii | WLA_cfc = 1.217 |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | | 5.1c | LTAMULT_cfc = 0.581 |
| PENTOXSD TRG | 5.1b | LTA_afc = 0.468 | | 5.1d | LTA_cfc = 0.708 |
| Source | Effluent Limit Calculations | | | | |
| PENTOXSD TRG | 5.1f | AML_MULT = 1.231 | | | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | | BAT/BPJ | |
| | | INST MAX LIMIT (mg/l) = 1.635 | | | |
| WLA_afc | $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | | |
| LTAMULT_afc | $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$ | | | | |
| LTA_afc | wla_afc * LTAMULT_afc | | | | |
| WLA_cfc | $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | | |
| LTAMULT_cfc | $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$ | | | | |
| LTA_cfc | wla_cfc * LTAMULT_cfc | | | | |
| AML_MULT | $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$ | | | | |
| AVG MON LIMIT | MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT) | | | | |
| INST MAX LIMIT | 1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc) | | | | |

Analysis Results WQM 7.0

Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | Effluent Limitations

| RMI | Discharge Name | Permit Number | Disc Flow (mgd) |
|------|----------------|---------------|-----------------|
| 0.24 | Thompsontown | PA0111422 | 0.2500 |

| Parameter | Effluent Limit 30 Day Average (mg/L) | Effluent Limit Maximum (mg/L) | Effluent Limit Minimum (mg/L) |
|------------------|--------------------------------------|-------------------------------|-------------------------------|
| CBOD5 | 25 | | |
| NH3-N | 11.44 | 22.88 | |
| Dissolved Oxygen | | | 5 |

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

WQM 7.0 Effluent Limits

| WQM 7.0 | Discharge | Permit | Parameter | Eff. Limit 30 Day Avg. (mg/L) | Eff. Limit Maximum (mg/L) | Eff. Limit Minimum (mg/L) |
|---------|--------------|-----------|------------------|-------------------------------|---------------------------|---------------------------|
| 0.24 | Thompsontown | PA0111422 | NH3-N | 11.44 | 22.88 | |
| | | | Dissolved Oxygen | | | 5 |

Wednesday, June 17, 2020 | View in PDF | Page 1 of 1

WQM 7.0 Wasteload Allocations

| WQM 7.0 | Discharge | Permit | Parameter | Eff. Limit 30 Day Avg. (mg/L) | Eff. Limit Maximum (mg/L) | Eff. Limit Minimum (mg/L) | Col. Res. | Percent Reduction |
|-------------------------------------|--------------|--------|------------------|-------------------------------|---------------------------|---------------------------|-----------|-------------------|
| NH3-N Acute Allocations | | | | | | | | |
| 0.24 | Thompsontown | | NH3-N | 11.44 | 22.88 | | 0 | 0 |
| NH3-N Chronic Allocations | | | | | | | | |
| 0.24 | Thompsontown | | NH3-N | 11.44 | 22.88 | | 0 | 0 |
| Dissolved Oxygen Allocations | | | | | | | | |
| 0.24 | Thompsontown | | Dissolved Oxygen | | | 5 | 0 | 0 |

Wednesday, June 17, 2020 | View in PDF | Page 1 of 1

WQM 7.0 D.O. Simulation

| WQM Results | | Station Code | | Station Name | |
|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| OR | 1 CWA | OR | 1 CWA | OR | 1 CWA |
| DO | WQM 7.0 (mg/L) | DO | WQM 7.0 (mg/L) | DO | WQM 7.0 (mg/L) |
| 6.30 | 6.30 | 6.30 | 6.30 | 6.30 | 6.30 |
| Flow (MGD) | Flow (MGD) | Flow (MGD) | Flow (MGD) | Flow (MGD) | Flow (MGD) |
| 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 |
| WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) |
| 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) |
| 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) |
| 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) |
| 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) |
| 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) | WSSR (ft) |
| 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |

WQM 7.0 Modeling Specifications

Parameters: DO, BOD, Use Specified (C) 10 and (C) 20: TTPhen
 WLA Method: SMPN Use Specified BOD Rate
 (C) 10: (C) 20 Ratio: 0.80 Use Specified Wash-Tank Stoic
 (C) 10: (C) 20: TTPhen: 1.30 Temperature Adjustment
 (C) 10: Reduction: 80.00% Use Selected Technology
 (C) 10: Grad: 0

WSSR (ft) vs Time (hr)

| Time (hr) | WSSR (ft) | DO (mg/L) | Flow (MGD) |
|-----------|-----------|-----------|------------|
| 0.00 | 1.00 | 6.30 | 1.50 |
| 0.25 | 1.00 | 6.30 | 1.50 |
| 0.50 | 1.00 | 6.30 | 1.50 |
| 0.75 | 1.00 | 6.30 | 1.50 |
| 1.00 | 1.00 | 6.30 | 1.50 |
| 1.25 | 1.00 | 6.30 | 1.50 |
| 1.50 | 1.00 | 6.30 | 1.50 |
| 1.75 | 1.00 | 6.30 | 1.50 |
| 2.00 | 1.00 | 6.30 | 1.50 |
| 2.25 | 1.00 | 6.30 | 1.50 |
| 2.50 | 1.00 | 6.30 | 1.50 |
| 2.75 | 1.00 | 6.30 | 1.50 |
| 3.00 | 1.00 | 6.30 | 1.50 |

Wednesday, June 17, 2020 Version 1.0a Page 1 of 1

Page: 1 No Filter

WQM 7.0 Modeling Specifications

Parameters: DO, BOD, Use Specified (C) 10 and (C) 20: TTPhen
 WLA Method: SMPN Use Specified BOD Rate
 (C) 10: (C) 20 Ratio: 0.80 Use Specified Wash-Tank Stoic
 (C) 10: (C) 20: TTPhen: 1.30 Temperature Adjustment
 (C) 10: Reduction: 80.00% Use Selected Technology
 (C) 10: Grad: 0

WSSR (ft) vs Time (hr)

| Time (hr) | WSSR (ft) | DO (mg/L) | Flow (MGD) |
|-----------|-----------|-----------|------------|
| 0.00 | 1.00 | 6.30 | 1.50 |
| 0.25 | 1.00 | 6.30 | 1.50 |
| 0.50 | 1.00 | 6.30 | 1.50 |
| 0.75 | 1.00 | 6.30 | 1.50 |
| 1.00 | 1.00 | 6.30 | 1.50 |
| 1.25 | 1.00 | 6.30 | 1.50 |
| 1.50 | 1.00 | 6.30 | 1.50 |
| 1.75 | 1.00 | 6.30 | 1.50 |
| 2.00 | 1.00 | 6.30 | 1.50 |
| 2.25 | 1.00 | 6.30 | 1.50 |
| 2.50 | 1.00 | 6.30 | 1.50 |
| 2.75 | 1.00 | 6.30 | 1.50 |
| 3.00 | 1.00 | 6.30 | 1.50 |

Wednesday, June 17, 2020 Version 1.0a Page 1 of 1

Page: 1 No Filter

rptHydro

WQM 7.0 Hydrodynamic Output

| WQM 7.0 | | Station Data | | Station Name | | | | | | | | | | | | | | | | |
|--------------------|---------|--------------|-------|-----------------|-------|------|-------|------|-------|------|-------|------|-------|------|-------|------|-------|------|-------|------|
| Code | Station | Flow | Depth | DR. JAMES CRANE | | | | | | | | | | | | | | | | |
| Flow | W/S | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | |
| (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) |
| Q7-10 Flow | | | | | | | | | | | | | | | | | | | | |
| 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 |
| Q1-10 Flow | | | | | | | | | | | | | | | | | | | | |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Q30-10 Flow | | | | | | | | | | | | | | | | | | | | |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

Wednesday, June 17, 2020 Version 1.0.0 Page 1 of 1

rptGeneral

Input Data WQM 7.0

| Code | Station | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | Flow | Depth | |
|------|---------|------|-------|------|-------|------|-------|------|-------|------|-------|------|-------|------|-------|------|-------|------|-------|------|
| (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) | (MG) |
| 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 | 1.01 | 0.00 |

Wednesday, June 17, 2020 Version 1.0.0 Page 1 of 2

rptGeneral
— □ ×

Input Data WQM 7.0

| SSP Basin | Station | Station Name | MSB | Station | Change | Station | MSB | Apply |
|-----------|---------|---------------|-----|---------|--------|----------|------|-------------------------------------|
| Basin | Code | | (1) | Code | Rate | (2) | MSB | PC |
| 000 | 1175.0 | COLLEGE CREEK | 600 | 38.000 | 00.70 | 0.000000 | 0.00 | <input checked="" type="checkbox"/> |

Screen Data

| Design | LFY | Tds | SS | Oil | Vel | WV | Temp | pH | Temp | pH | | |
|--------|-------|------|------|-------|--------|------|------|-----|-------|------|------|------|
| Code | (mgd) | (mg) | (mg) | (mg) | (ft/s) | (ft) | (°C) | | (°C) | | | |
| Q710 | 0.00 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.0 | 0.0 | 0.000 | 7.00 | 0.00 | 0.00 |
| Q710 | 0.00 | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q3010 | 0.00 | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Site Usage Data

| Name | Permit Number | Flow | Flow | Flow | Flow | Flow | Flow | Flow | Temp | pH |
|--------------|---------------|--------|--------|--------|--------|--------|--------|--------|-------|------|
| | | (mgd) | (mgd) | (mgd) | (mgd) | (mgd) | (mgd) | (mgd) | (°C) | |
| Thompsontown | PA011142 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 20.00 | 7.00 |

Parameter Data

| Parameter Name | Obs | Tds | SS | Oil | Vel | WV | Temp | pH |
|------------------|--------|--------|--------|--------|--------|------|------|------|
| | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (ft/s) | (ft) | (°C) | |
| CHLOR | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Dissolved Oxygen | 0.00 | 8.34 | 0.00 | 0.00 | | | | |
| NH3-N | 0.00 | 0.00 | 0.00 | 0.00 | 0.70 | | | |

Modeling: June 17, 2009 Version: 10.0 Page 2 of 2

Page: 14 2 No Filter

Existing Effluent Limitations and Monitoring Requirements

The annual design flow & hydraulic capacity flow are 0.205 MGD.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|--------------------|-------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD ₅ | 42 | 67 Wkly Avg | XXX | 25 | 40 | 50 | 1/week | 24-Hr Composite |
| TSS | 50 | 75 Wkly Avg | XXX | 30 | 45 | 60 | 1/week | 24-Hr Composite |
| BOD ₅ Raw Sewage Influent | Report | Report | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| TSS Raw Sewage Influent | Report | Report | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 1/week | Grab |
| Ammonia May 1 - Oct 31 | 17 | XXX | XXX | 10 | XXX | 20 | 1/week | 24-Hr Composite |
| Ammonia Nov 1 - Apr 30 | Report | XXX | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |

Existing Effluent Limitations and Monitoring Requirements

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------------|-------------------------------------|--------|-----------------------|--------------------|---------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Monthly | Annual | Minimum | Monthly Average | Maximum | Instant. Maximum | | |
| Ammonia---N | Report | Report | XXX | Report | XXX | XXX | 1/week | 24-hr Composite |
| Kjeldahl---N | Report | Report | XXX | Report | XXX | XXX | 1/week | 24-hr Composite |
| Nitrate-Nitrite as N | Report | XXX | XXX | Report | XXX | XXX | 1/week | 24-hr Composite |
| Total Nitrogen | Report | Report | XXX | Report | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | Report | Report | XXX | Report | XXX | XXX | 1/week | 24-hr Composite |
| Net Total Nitrogen | Report | 7,032 | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Net Total Phosphorus | Report | 974 | XXX | XXX | XXX | XXX | 1/month | Calculation |

Proposed Effluent Limitations and Monitoring Requirements

The annual design flow & hydraulic capacity flow are 0.25 MGD.

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|-------------------|----------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD ₅ | 52.0 | 83.0 Wkly Avg | XXX | 25.0 | 40.0 | 50.0 | 1/week | 24-Hr Composite |
| TSS | 63.0 | 94.0 Wkly Avg | XXX | 30.0 | 45.0 | 60.0 | 1/week | 24-Hr Composite |
| BOD ₅ Raw Sewage Influent | Report | Report | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| TSS Raw Sewage Influent | Report | Report | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 1/week | Grab |
| Ammonia May 1 - Oct 31 | 21.0 | XXX | XXX | 10.0 | XXX | 20.0 | 1/week | 24-Hr Composite |
| Ammonia Nov 1 - Apr 30 | Report | XXX | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------------|-------------------------------------|--------|-----------------------|-----------------|---------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Monthly | Annual | Minimum | Monthly Average | Maximum | Instant. Maximum | | |
| Ammonia---N | Report | Report | XXX | Report | XXX | XXX | 1/week | 24-hr Composite |
| Kjeldahl---N | Report | Report | XXX | Report | XXX | XXX | 1/week | 24-hr Composite |
| Nitrate-Nitrite as N | Report | XXX | XXX | Report | XXX | XXX | 1/week | 24-hr Composite |
| Total Nitrogen | Report | Report | XXX | Report | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | Report | Report | XXX | Report | XXX | XXX | 1/week | 24-hr Composite |
| Net Total Nitrogen | Report | 7,032 | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Net Total Phosphorus | Report | 974 | XXX | XXX | XXX | XXX | 1/month | Calculation |

Compliance Sampling Location:

Other Comments:

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment [redacted]) |
| <input type="checkbox"/> | PENTOXSD for Windows Model (see Attachment [redacted]) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Toxics Screening Analysis Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 385-2000-011, 9/08. |
| <input checked="" type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 391-2000-006, 9/97. |
| <input checked="" type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004. |
| <input checked="" type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008. |
| <input checked="" type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09. |
| <input checked="" type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 391-2000-023, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97. |
| <input checked="" type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: [redacted] |
| <input type="checkbox"/> | Other: [redacted] |