

Application Type Renewal
 Facility Type Industrial
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**


Application No. PA0111635
 APS ID 1097477
 Authorization ID 1456054

Applicant and Facility Information

Applicant Name	<u>Spring Township Municipal Authority</u>	Facility Name	<u>Spring Township Municipal Authority</u>
Applicant Address	<u>PO Box 133</u>	Facility Address	<u>732 Brick Plant Road</u>
	<u>Beaver Springs, PA 17812-0133</u>		<u>Beavertown, PA 17813</u>
Applicant Contact	<u>Steven Aumiller</u>	Facility Contact	<u>Steven Aumiller</u>
Applicant Phone	<u>(570) 658-9505</u>	Facility Phone	<u>(570) 658-9505</u>
Client ID	<u>82854</u>	Site ID	<u>4659</u>
SIC Code	<u>4941</u>	Municipality	<u>Beaver Township</u>
SIC Description	<u>Trans. & Utilities - Water Supply</u>	County	<u>Snyder</u>
Date Application Received	<u>September 25, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 28, 2023</u>	If No, Reason	
Purpose of Application	<u>Renewal of an existing NPDES permit for the discharge of water treatment plant backwash.</u>		

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		 Derek S. Garner / Project Manager	May 23, 2024
X		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	May 27, 2024

Facility Description

The Spring Township Municipal Authority Water Treatment Plant treats surface water from a reservoir source for potable water distribution in Beaver Springs in Spring Township, Snyder County. The wastewater from the filter backwash cycles enters two settling lagoons. Overflow from the lagoons is collected in a discharge box and is discharged to Kern Run via Outfall 001. Original construction and continued operation of the treatment units are covered under WQM Permit No. 5572202, originally issued March 30, 1973.

Discharge, Receiving Waters and Water Supply Information

Outfall No. 001
Latitude 40° 44' 25.46"
Quad Name Beaver Springs
Wastewater Description: Water Treatment Effluent

Design Flow (MGD) 0.040
Longitude -77° 10' 44.63"
Quad Code 1328

Receiving Waters Kern Run
NHD Com ID 54969973
Drainage Area (mi²) 5.08
Q₇₋₁₀ Flow (cfs) 0.635
Elevation (ft) 680
Watershed No. 6-A
Existing Use n/a
Exceptions to Use n/a
Assessment Status Impaired
Cause(s) of Impairment pH
Source(s) of Impairment Atmospheric Deposition
TMDL Status n/a

Stream Code 17873
RMI 2.97
Yield (cfs/mi²) 0.125
Q₇₋₁₀ Basis Streamgage No. 01555000
Slope (ft/ft) 0.00893
Chapter 93 Class. CWF
Existing Use Qualifier n/a
Exceptions to Criteria n/a

Nearest Downstream Public Water Supply Intake SUEZ Water
PWS Waters Susquehanna River
PWS RMI 10.64

Flow at Intake (cfs) 688
Distance from Outfall (mi) 64

Compliance History

The facility was most recently inspected by DEP on November 20, 2023. No violations were noted during the inspection and no impacts were noted downstream of the outfall in Kern Run.

The following effluent violations occurred during the existing permit's term:

Noncompliance Date	Noncompliance Description	Parameter	Sample Value	Violation Condition	Permit Value	Units	SBC
10/19/2020	Violation of permit condition	Manganese, Total	1.7	>	1	mg/L	Avg Mo

There are no open violations associated with the permittee.

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 44' 25.46"
Wastewater Description: Water Treatment Effluent

Design Flow (MGD) 0.040
Longitude -77° 10' 44.63"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	State Regulation
pH	6.0 – 9.0 S.U.	IMIN - IMAX	95.2(1)
Iron, Dissolved ⁽¹⁾	7.0	IMAX	95.2(4)
Oil and Grease ⁽¹⁾	15	Average Monthly	95.2(2)(ii)
	30	IMAX	95.2(2)(ii)
Total Residual Chlorine	0.5	IMAX	92a.48(b)(2)

⁽¹⁾ Sample results for dissolved iron and oil and grease submitted with the application indicate that neither of the pollutants approach the above technology limits. Since effluent concentrations do not approach the technology-based standards it is not appropriate to establish limits or monitoring requirements for dissolved iron or oil and grease in the permit.

Water Quality-Based Limitations

A “Reasonable Potential Analysis” was conducted in the Toxics Management Spreadsheet v1.4 (“TMS”) to determine if WQBELs are necessary to protect the receiving surface water. Input values were taken from existing permit limits, when applicable, or the application’s pollutant groups. The spreadsheet’s recommendations are as follows:

Pollutants	Mass Limits		Concentration Limits					Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units				
Total Aluminum	1.81	2.82	5.41	8.45	13.5	mg/l	5.41	AFC		Discharge Conc ≥ 50% WQBEL (RP)
Total Iron	Report	Report	Report	Report	Report	mg/l	16.9	CFC		Discharge Conc > 10% WQBEL (no RP)

Existing total residual chlorine limits were evaluated using the TRC Evaluation spreadsheet. The spreadsheet’s results indicate that the existing limits are protective of Kern Run. Accordingly, DEP recommends that the existing limits remain in the permit.

Best Professional Judgment (BPJ) Limitations

Parameter	Limit (mg/l)	SBC	Guidance
Total Suspended Solids	30	Average Monthly	Technology-Based Control Requirements for Water Treatment Plant Wastes (362-2183-003, 10/1/97)
	60	Daily Maximum	
pH	6.0 – 9.0 S.U.	Min – Max	
	2.0	Average Monthly	
Iron, Total	4.0	Daily Maximum	
	4.0	Average Monthly	
Aluminum, Total	8.0	Daily Maximum	
	1.0	Average Monthly	
Manganese, Total	2.0	Daily Maximum	

The above effluent limits are recommended best practicable control technology currently available (BPT) for water treatment plant wastewater by DEP guidance “Technology-Based Control Requirements for Water Treatment Plant

Wastes" (362-2183-003, 10/1/97). These effluent limits reflect lagoon or settling tank treatment of different types of sludges (e.g., presettling, coagulant settling, softening sludge) and filter backwash wastewater. A higher degree of treatment such as best conventional pollutant control technology (BCT) or best available technology economically achievable (BAT) is only appropriate when recycle and/or reuse is employed by the permittee. The BPT limits are both existing and more stringent than the abovementioned recommended TMS requirements. DEP recommends the BPT limits remain in the permit.

Chesapeake Bay Requirements

The discharge is not anticipated to contribute to the net loading of total nitrogen or total phosphorus in the watershed. Accordingly, per the Phase 3 Wastewater Supplemental to Pennsylvania's Chesapeake Bay Watershed Implementation Plan, no cap loads or reporting requirements are necessary.

Anti-Backsliding

No limitations in this proposed draft permit have been made less stringent consistent with the anti-back-sliding requirements of the Clean Water Act and 40 CFR 122.44(l).

Existing Effluent Limitations and Monitoring Requirements

The existing effluent limitations and monitoring requirements are as follows:

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	1.0	XXX	1/day	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	XXX	1/month	Grab
Aluminum, Total	XXX	XXX	XXX	4.0	8.0	XXX	1/month	Grab
Iron, Total	XXX	XXX	XXX	2.0	4.0	XXX	1/month	Grab
Manganese, Total	XXX	XXX	XXX	1.0	2.0	XXX	1/month	Grab

Compliance Sampling Location: Outfall 001

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
TRC	XXX	XXX	XXX	0.5	1.0	XXX	1/day	Grab
TSS	XXX	XXX	XXX	30	60	XXX	1/month	Grab
Total Aluminum	XXX	XXX	XXX	4.0	8.0	XXX	1/month	Grab
Total Iron	XXX	XXX	XXX	2.0	4.0	XXX	1/month	Grab
Total Manganese	XXX	XXX	XXX	1.0	2.0	XXX	1/month	Grab

Compliance Sampling Location: Outfall 001

Discharge Information

Instructions Discharge Stream

Facility: Spring Township Municipal Authority WTP NPDES Permit No.: PA0111635 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Water treatment plant filter backwash

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.04	10.1	7						

	Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
				Trib Conc	Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	Criteri a Mod
Group 1	Total Dissolved Solids (PWS)	mg/L	84								
	Chloride (PWS)	mg/L	7.2								
	Bromide	mg/L	< 0.04								
	Sulfate (PWS)	mg/L	4.7								
	Fluoride (PWS)	mg/L	0.2								
Group 2	Total Aluminum	µg/L	685								
	Total Antimony	µg/L	< 0.07								
	Total Arsenic	µg/L	< 2.5								
	Total Barium	µg/L	20								
	Total Beryllium	µg/L	< 0.67								
	Total Boron	µg/L	< 0.06								
	Total Cadmium	µg/L	< 0.025								
	Total Chromium (III)	µg/L	< 0.0002								
	Hexavalent Chromium	µg/L	< 0.0003								
	Total Cobalt	µg/L	0.074								
	Total Copper	µg/L	1								
	Free Cyanide	µg/L	< 0.006								
	Total Cyanide	µg/L	<								
	Dissolved Iron	µg/L	32.9								
	Total Iron	µg/L	34.4								
	Total Lead	µg/L	0.13								
	Total Manganese	µg/L	236								
	Total Mercury	µg/L	< 0.0000932								
	Total Nickel	µg/L	0.331								
	Total Phenols (Phenolics) (PWS)	µg/L	0.005								
	Total Selenium	µg/L	< 2.5								
	Total Silver	µg/L	< 0.274								
	Total Thallium	µg/L	< 0.014								
	Total Zinc	µg/L	< 0.708								
	Total Molybdenum	µg/L	< 0.04								
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								

	Benzene	µg/L	<									
	Bromoform	µg/L	<									
Group 3	Carbon Tetrachloride	µg/L	<									
	Chlorobenzene	µg/L										
	Chlorodibromomethane	µg/L	<									
	Chloroethane	µg/L	<									
	2-Chloroethyl Vinyl Ether	µg/L	<									
	Chloroform	µg/L	<									
	Dichlorobromomethane	µg/L	<									
	1,1-Dichloroethane	µg/L	<									
	1,2-Dichloroethane	µg/L	<									
	1,1-Dichloroethylene	µg/L	<									
	1,2-Dichloropropane	µg/L	<									
	1,3-Dichloropropylene	µg/L	<									
	1,4-Dioxane	µg/L	<									
	Ethylbenzene	µg/L	<									
	Methyl Bromide	µg/L	<									
	Methyl Chloride	µg/L	<									
	Methylene Chloride	µg/L	<									
	1,1,2,2-Tetrachloroethane	µg/L	<									
	Tetrachloroethylene	µg/L	<									
	Toluene	µg/L	<									
	1,2-trans-Dichloroethylene	µg/L	<									
	1,1,1-Trichloroethane	µg/L	<									
	1,1,2-Trichloroethane	µg/L	<									
	Trichloroethylene	µg/L	<									
	Vinyl Chloride	µg/L	<									
Group 4	2-Chlorophenol	µg/L	<									
	2,4-Dichlorophenol	µg/L	<									
	2,4-Dimethylphenol	µg/L	<									
	4,6-Dinitro-o-Cresol	µg/L	<									
	2,4-Dinitrophenol	µg/L	<									
	2-Nitrophenol	µg/L	<									
	4-Nitrophenol	µg/L	<									
	p-Chloro-m-Cresol	µg/L	<									
	Pentachlorophenol	µg/L	<									
	Phenol	µg/L	<									
	2,4,6-Trichlorophenol	µg/L	<									
Group 5	Acenaphthene	µg/L	<									
	Acenaphthylene	µg/L	<									
	Anthracene	µg/L	<									
	Benzidine	µg/L	<									
	Benzo(a)Anthracene	µg/L	<									
	Benzo(a)Pyrene	µg/L	<									
	3,4-Benzofluoranthene	µg/L	<									
	Benzo(ghi)Perylene	µg/L	<									
	Benzo(k)Fluoranthene	µg/L	<									
	Bis(2-Chloroethoxy)Methane	µg/L	<									
	Bis(2-Chloroethyl)Ether	µg/L	<									
	Bis(2-Chloroisopropyl)Ether	µg/L	<									
	Bis(2-Ethylhexyl)Phthalate	µg/L	<									
	4-Bromophenyl Phenyl Ether	µg/L	<									
	Butyl Benzyl Phthalate	µg/L	<									
	2-Chloronaphthalene	µg/L	<									
	4-Chlorophenyl Phenyl Ether	µg/L	<									
	Chrysene	µg/L	<									
	Dibenzo(a,h)Anthracene	µg/L	<									
	1,2-Dichlorobenzene	µg/L	<									
	1,3-Dichlorobenzene	µg/L	<									
	1,4-Dichlorobenzene	µg/L	<									
	3,3-Dichlorobenzidine	µg/L	<									
	Diethyl Phthalate	µg/L	<									
	Dimethyl Phthalate	µg/L	<									
	Di-n-Butyl Phthalate	µg/L	<									

Stream / Surface Water Information

Spring Township Municipal Authority WTP, NPDES Permit No. PA0111635, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Kern Run**

No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	017873	2.97	670	5.08			Yes
End of Reach 1	017873	0	640	12.3			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	2.97	0.125										100	7		
End of Reach 1	0	0.125										100	7		

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	2.97														
End of Reach 1	0														

Model Results

Spring Township Municipal Authority WTP, NPDES Permit No. PA0111635, Outfall 001

[Instructions](#)

[Results](#)

[RETURN TO INPUTS](#)

[SAVE AS PDF](#)

[PRINT](#)

All

Inputs

Results

Limits

Hydrodynamics

Q₇₋₁₀

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
2.97	0.64		0.64	0.062	0.002	0.492	12.786	25.999	0.111	1.638	12.334
0	1.54		1.5375								

Q_h

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
2.97	5.00		5.00	0.062	0.002	1.176	12.786	10.87	0.336	0.54	3.918
0	10.821		10.82								

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	8,446	
Total Antimony	0	0		0	1,100	1,100	12,388	
Total Arsenic	0	0		0	340	340	3,829	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	236,498	
Total Boron	0	0		0	8,100	8,100	91,221	
Total Cadmium	0	0		0	1.857	1.96	22.1	Chem Translator of 0.947 applied
Total Chromium (III)	0	0		0	532.235	1,684	18,968	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	183	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	1,070	

Total Copper	0	0		0	12.426	12.9	146	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	22	22.0	248	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	58.982	73.4	827	Chem Translator of 0.803 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1.400	1.65	18.5	Chem Translator of 0.85 applied
Total Nickel	0	0		0	436.413	437	4,925	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	2.788	3.28	36.9	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	732	
Total Zinc	0	0		0	109.205	112	1,258	Chem Translator of 0.978 applied

CFC

CCT (min): 12.334

PMF: 1

Analysis Hardness (mg/l): 92.017

Analysis pH: 7.00

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	2,478	
Total Arsenic	0	0		0	150	150	1,689	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	46,173	
Total Boron	0	0		0	1,600	1,600	18,019	
Total Cadmium	0	0		0	0.232	0.25	2.87	Chem Translator of 0.912 applied
Total Chromium (III)	0	0		0	69.233	80.5	907	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	117	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	214	
Total Copper	0	0		0	8.341	8.69	97.9	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	5.2	5.2	58.6	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	16,893	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2.298	2.86	32.2	Chem Translator of 0.803 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	10.2	Chem Translator of 0.85 applied
Total Nickel	0	0		0	48.472	48.6	548	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.600	4.99	56.2	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	146	
Total Zinc	0	0		0	110.098	112	1,258	Chem Translator of 0.986 applied

THH

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc ($\mu\text{g/L}$)	Stream CV	Trib Conc ($\mu\text{g/L}$)	Fate Coef	WQC ($\mu\text{g/L}$)	WQ Obj ($\mu\text{g/L}$)	WLA ($\mu\text{g/L}$)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	63.1	
Total Arsenic	0	0		0	10	10.0	113	
Total Barium	0	0		0	2,400	2,400	27,028	
Total Boron	0	0		0	3,100	3,100	34,912	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Free Cyanide	0	0		0	4	4.0	45.0	
Dissolved Iron	0	0		0	300	300	3,379	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	11,262	
Total Mercury	0	0		0	0.050	0.05	0.56	
Total Nickel	0	0		0	610	610	6,870	
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	0.24	0.24	2.7	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL

CCT (min): 3.918

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc ($\mu\text{g/L}$)	Stream CV	Trib Conc ($\mu\text{g/L}$)	Fate Coef	WQC ($\mu\text{g/L}$)	WQ Obj ($\mu\text{g/L}$)	WLA ($\mu\text{g/L}$)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	

Total Cobalt	0	0		0	N/A	N/A	N/A
Total Copper	0	0		0	N/A	N/A	N/A
Free Cyanide	0	0		0	N/A	N/A	N/A
Dissolved Iron	0	0		0	N/A	N/A	N/A
Total Iron	0	0		0	N/A	N/A	N/A
Total Lead	0	0		0	N/A	N/A	N/A
Total Manganese	0	0		0	N/A	N/A	N/A
Total Mercury	0	0		0	N/A	N/A	N/A
Total Nickel	0	0		0	N/A	N/A	N/A
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A
Total Selenium	0	0		0	N/A	N/A	N/A
Total Silver	0	0		0	N/A	N/A	N/A
Total Thallium	0	0		0	N/A	N/A	N/A
Total Zinc	0	0		0	N/A	N/A	N/A

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Aluminum	Report	Report	Report	Report	Report	µg/L	5,414	AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	27,028	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	18,019	µg/L	Discharge Conc < TQL
Total Cadmium	2.87	µg/L	Discharge Conc < TQL
Total Chromium (III)	907	µg/L	Discharge Conc < TQL
Hexavalent Chromium	117	µg/L	Discharge Conc < TQL

Total Cobalt	214	µg/L	Discharge Conc ≤ 10% WQBEL
Total Copper	93.4	µg/L	Discharge Conc ≤ 10% WQBEL
Free Cyanide	45.0	µg/L	Discharge Conc < TQL
Dissolved Iron	3,379	µg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	16,893	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	32.2	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	11,262	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	0.56	µg/L	Discharge Conc < TQL
Total Nickel	548	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	56.2	µg/L	Discharge Conc < TQL
Total Silver	23.7	µg/L	Discharge Conc < TQL
Total Thallium	2.7	µg/L	Discharge Conc < TQL
Total Zinc	806	µg/L	Discharge Conc < TQL
Total Molybdenum	N/A	N/A	No WQS

1A	B	C	D	E	F	G
----	---	---	---	---	---	---

2 TRC EVALUATION

3 Input appropriate values in B4:B8 and E4:E7

4	0.635	= Q stream (cfs)	0.5	= CV Daily
5	0.04	= Q discharge (MGD)	0.5	= CV Hourly
6	30	= no. samples	1	= AFC_Partial Mix Factor
7	0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
8	0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
9	0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
	0	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)

10	Source	Reference	AFC Calculations	Reference	CFC Calculations
11	TRC	1.3.2.iii	WLA_afc = 3.293	1.3.2.iii	WLA_cfc = 3.202
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
13	PENTOXSD TRG	5.1b	LTA_afc = 1.227	5.1d	LTA_cfc = 1.862

15 Source Effluent Limit Calculations

16	PENTOXSD TRG	5.1f	AML MULT = 1.231	
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ

WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$
LTA_afc	wla_afc*LTAMULT_afc
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$
LTA_cfc	wla_cfc*LTAMULT_cfc
AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$
AVG MON LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$
INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$