

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0112381
 APS ID 1090258
 Authorization ID 1442960

Applicant and Facility Information

Applicant Name	<u>Columbia Investment Corp.</u>	Facility Name	<u>Madison Estates MHP</u>
Applicant Address	<u>6009 Columbia Boulevard</u> <u>Bloomsburg, PA 17815-8800</u>	Facility Address	<u>1947 Millville Road</u> <u>Bloomsburg, PA 17815-6579</u>
Applicant Contact	<u>Frank Baker</u>	Facility Contact	<u>Frank Baker</u>
Applicant Phone	<u>(570) 387-0902</u>	Facility Phone	<u>(570) 387-0902</u>
Client ID	<u>6750</u>	Site ID	<u>4447</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Madison Township</u>
Connection Status	<u>N/A</u>	County	<u>Columbia</u>
Date Application Received	<u>June 6, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 12, 2023</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit for a discharge of treated sewage</u>		



Summary of Review

This subject facility is a non-municipal sewage treatment plant serving a mobile home park in Madison Township, Columbia County. A map of the discharge location is attached.

Sludge use and disposal description and location(s): The facility's wasted sludge is transferred to other WWTPs for further processing.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
<input checked="" type="checkbox"/>	<input type="checkbox"/>	 Keith C. Allison / Project Manager	April 16, 2024
<input checked="" type="checkbox"/>	<input type="checkbox"/>	 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	April 17, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0045</u>
Latitude	<u>41° 4' 9.33"</u>	Longitude	<u>-76° 30' 26.16"</u>
Quad Name	<u>Millville, PA</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Little Fishing Creek (CWF)</u>	Stream Code	<u>27657</u>
NHD Com ID	<u>65639703</u>	RMI	<u>4.56 (@ L. Fishing Ck.)</u>
Drainage Area	<u>58.6 mi² (@ L. Fishing Ck)</u>	Yield (cfs/mi ²)	<u>0.1087</u>
Q ₇₋₁₀ Flow (cfs)	<u>6.37</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>548</u>	Slope (ft/ft)	<u>0.00261</u>
Watershed No.	<u>5-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Nearest Downstream Public Water Supply Intake	<u>United Water Pennsylvania</u>		
PWS Waters	<u>Fishing Creek</u>	Distance from Outfall (mi)	<u>Approx. 6 miles.</u>

Changes Since Last Permit Issuance: None. Stream flow and drainage area were updated using the USGS StreamStats web application. Other stream characteristics are based on interpolation of USGS topographic maps.

Other Comments: Discharge is to a storm swale that drains to Little Fishing Creek. The first point of aquatic life use has previously been determined to be at the discharge into Little Fishing Creek. Inspections of the facility have not noted any problems in the receiving waters.

No downstream water supply is expected to be affected by this discharge with the limitations and monitoring proposed.

Treatment Facility Summary				
Treatment Facility Name: Madison Estates MHP Sewer System				
WQM Permit No.	Issuance Date			
1997404	06/05/1997			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.0045
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0045	21	Not Overloaded	Holding Tank	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The treatment plant, as approved under WQM Permit No. 1997404 includes screening, equalization, aeration, clarification, disinfection (tablet chlorinator), and sludge holding.

Compliance History

DMR Data for Outfall 001 (from March 1, 2023 to February 29, 2024)

Parameter	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23
Flow (MGD) Average Monthly	0.00089	0.0012	0.0009	0.001	0.0010	0.0011	0.0010	0.0010	0.0011	0.0010	0.0008	0.0012
Flow (MGD) Daily Maximum	0.0014	0.0014	0.0014	0.0014	0.0014	0.0014	0.0014	0.0014	0.0014	0.0014	0.0014	0.0014
pH (S.U.) Instantaneous Minimum	6.2	6.0	6.2	6.4	6.4	6.3	6.5	6.1	6.4	6.1	6.2	6.9
pH (S.U.) Instantaneous Maximum	8.3	8.5	7.7	7.2	7.5	7.7	8.8	6.8	6.8	6.7	6.7	7.4
DO (mg/L) Instantaneous Minimum	3.9	1.8	3.3	1.2	1.0	0.89	0.57	0.57	0.37	0.28	0.57	0.52
TRC (mg/L) Average Monthly	0.13	0.13	0.12	0.12	0.10	0.23	0.20	0.14	0.19	0.15	0.18	0.16
TRC (mg/L) Instantaneous Maximum	0.67	0.42	0.21	0.24	0.26	0.89	0.52	0.36	0.63	0.46	0.49	0.47
CBOD5 (mg/L) Average Monthly	3.7	3.3	< 1.3	6	2.6	2	< 2	< 1.8	< 1	3.2	1	< 1.6
TSS (mg/L) Average Monthly	6	5.5	5	7.5	< 4	< 4	4	7.5	4	< 4	5	4
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	1	< 1	< 1	17.9	1.4	< 1	< 1	< 1	< 1	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	< 1	1	< 1	< 1	322.3	2.0	< 1	< 1	< 1	< 1	< 1
Ammonia (mg/L) Average Monthly	15.7	9.8	0.6	1.0	2.6	0.28	0.98	4.0	1.5	6.3	0.57	2.0
Ammonia (mg/L) Instantaneous Maximum	25.5	16.6	1.1	1.9	2.6	0.35	1.7	5.2	2.1	10.4	0.87	4.0

Compliance History

Summary of Inspections:	The facility has been inspected approximately annually by the Department over the past permit term. The most recent inspection on March 3, 2024 noted no violations at the time of inspection.
Other Comments:	There are no open violations in eFACTS for Columbia Investment Corp.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	5/week	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	5/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	5/week	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	Report Annl Avg	Report Daily Max	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Ammonia	XXX	XXX	XXX	Report	XXX	Report	2/month	Grab
Total Phosphorus	Report Annl Avg	Report Daily Max	XXX	Report Annl Avg	XXX	XXX	1/year	Grab

Development of Effluent Limitations

<p>Outfall No. <u>001</u></p> <p>Latitude <u>41° 4' 10.00"</u></p> <p>Wastewater Description: <u>Sewage Effluent</u></p>	<p>Design Flow (MGD) <u>0.0045</u></p> <p>Longitude <u>-76° 30' 27.00"</u></p>
---	---

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limits are included in the existing permit and remain appropriate.

Water Quality-Based Limitations

CBOD5, DO, and NH3-N

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. WQM7.0 modeling was performed for the previous review for the discharge in the receiving dry swale and in Little Fishing Creek and showed that the secondary treatment limits listed above are adequate to protect the receiving waters. See Attachment B.

TRC

The Department uses a modeling spreadsheet to determine necessary WQBELs for TRC toxicity based on instream dilution. The attached modeling results (See attachment C) show that the BAT limit of 0.5 mg/l is adequate to protect the receiving stream.

Toxics Management

No further "Reasonable Potential Analysis" was performed to determine additional toxic parameters as candidates for limitations for this 0.0045 MGD facility sewage treatment facility receiving no industrial influent.

Dry Stream Discharge

Because the discharge is existing and there have been no noted effects on the storm swale directly receiving the discharge or Little Fishing Creek, the additional discharge requirements from the Department's *Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers* including the Advanced Treatment Requirements will not be required at this time.

Chesapeake Bay Requirements

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. The Madison Estates treatment plant is considered an existing Phase 5, insignificant Chesapeake Bay discharger per the Phase III Watershed Implementation Plan (WIP) and thus has not received Cap Loads. Monitoring

under the current permit found the Total Nitrogen and Total Phosphorus to average 21.8 and 3.1 mg/L, respectively. Because the current nutrient load from the discharge has adequately been characterized no further nutrient monitoring will be required at this time.

e. Coli

Annual e. coli monitoring will be required at this time due to recent changes to Chapter 93 of the Departments regulations and Department policy.

Best Professional Judgment (BPJ) Limitations

No additional BPJ limits are needed beyond the water quality and technology-based limits noted above.

Anti-Backsliding

No water quality based or BPJ limits were made less stringent consistent with the anti-backsliding requirements of 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	5/week	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	5/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	5/week	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia	XXX	XXX	XXX	Report	XXX	Report	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab


Compliance Sampling Location: Outfall 001

Other Comments: Monitoring for Total Nitrogen and Total Phosphorus have been removed as mentioned above. E. coli monitoring has now been included as noted above. The Department's permit writer's manual recommends daily monitoring for pH, DO, and TRC for discharges with design flows greater than 2000 gpd. Given the size of the discharge and the consistent quality of the discharge the sampling frequencies for pH, DO, and TRC above are unchanged.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment)
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 03/24/2021
<input type="checkbox"/>	Other:

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Model



Discharge to Roadside ditch

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05C	27664	Trib 27664 to Little Fishing Creek	0.170	574.00	0.03	0.00000	0.00	

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Reh Trav Time	Reh Velocity	WD Ratio	Reh Width	Reh Depth	Tributary		Stream	
	(efsm)	(efs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.109	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Madison Est	PA0112381a	0.0045	0.0000	0.0000	0.000	25.00	7.00

Parameter Data				
Parameter Name	Disc Cone (mg/L)	Trib Cone (mg/L)	Stream Cone (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05C	27664	Trib 27664 to Little Fishing Creek	0.001	548.00	0.05	0.00000	0.00	

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Reh Trav Time	Reh Velocity	WD Ratio	Reh Width	Reh Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(els)	(els)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.109	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Cone	Trib Cone	Stream Cone	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code			Stream Name							
05C		27664			Trib 27664 to Little Fishing Creek							
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
0.170	0.00	0.00	0.00	NA	0.02914	.278	.91	3.28	0.04	0.256	23.40	7.00
Q1-10 Flow												
0.170	0.00	0.00	0.00	NA	0.02914	NA	NA	NA	0.00	0.000	0.00	0.00
Q30-10 Flow												
0.170	0.00	0.00	0.00	NA	0.02914	NA	NA	NA	0.00	0.000	0.00	0.00

WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	
WLA Method	Simulation	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	
D. O. Saturation	90.00%	Use Balanced Technology	
D.O. Goal	6		

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
OSC	27664	Trib 27664 to Little Fishing Creek		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.170	0.004	23.405	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
0.911	0.278	3.277	0.040	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
17.66	1.432	17.02	0.910	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
4.673	29.285	Owens	6	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.256	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>
	(days)	(mg/L)	(mg/L)	(mg/L)
	0.026	16.92	16.63	4.71
	0.051	16.21	16.25	4.79
	0.077	15.53	15.88	4.89
	0.102	14.88	15.51	4.99
	0.128	14.26	15.16	5.10
	0.153	13.66	14.81	5.20
	0.179	13.09	14.47	5.30
	0.205	12.54	14.13	5.40
	0.230	12.01	13.81	5.49
	0.256	11.51	13.49	5.59

lev'1-'1.) ,..t ll_r.Jof f12, c'1

Discharge into Little Fishing Creek

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05C	27657	LITTLE FISHING CREEK	4.560	548.00	58.60	0.00000	0.00	

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Reh Trav Time	Reh Velocity	WO Ratio	Reh Width	Reh Depth	Tributary		Stream	
	(efsm)	(efs)	(cfs)	(days)	(fps)		(ft)	(fl)	Temp ('C)	pH	Temp ('C)	pH
Q7-10	0.109	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp ('C)	Disc pH
Madison Estates	PA0112381	0.0045	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Coric (mg/L)	Trib Cone (mg/L)	Stream Cone (mg/L)	Fate Coef (1/days)			
CBOD5	11.51	2.00	0.00	1.50			
Dissolved Oxygen	5.59	8.24	0.00	0.00			
NH3-N	13.49	0.00	0.00	0.70			

Outputs from dry reach

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05C	27657	LITTLE FISHING CREEK	3.970	540.00	60.00	0.00000	0.00	

Stream Data

Design Cond.	LFY (efsm)	Trib Flow (els)	Stream Flow (els)	Reh Trav Time (days)	Reh Velocity (fps)	WD Ratio	Reh Width (ft)	Reh Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.109	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Cone (mg/L)	Trib Cone (mg/L)	Stream Cone (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 H)t'.drod)t'.namic Out uts

SWP Basin		Stream Code				Stream Name						
OSC		27657				LITTLE FISHING CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (els)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
4.560	6.37	0.00	6.37	.007	0.00257	.713	39.05	54.8	0.23	0.157	20.01	7.00
Q1-10 Flow												
4.560	4.08	0.00	4.08	.007	0.00257	NA	NA	NA	0.18	0.202	20.01	7.00
Q30-10 Flow												
4.560	8.66	0.00	8.66	.007	0.00257	NA	NA	NA	0.27	0.133	20.00	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	
D.O. Saturation	90.00%	Use Balanced Technology	
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
05C	27657	LITTLE FISHING CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.560	Madison Estates	9.67	26.98	9.67	26.98	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.560	Madison Estates	1.92	13.49	1.92	13.49	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
4.56	Madison Estates	11.51	11.51	13.49	13.49	5.59	5.59	0	0

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
DSC	27657	LITTLE FISHING CREEK

<u>RM</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
4.560	0.004	20.005	7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
39.053	0.713	54.795	0.229
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.01	0.008	0.01	0.700
<u>Reach DO (mg/l)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.240	5.591	Tsvoglou	6
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>		
0.157	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>
	(days)	(mg/L)	(mg/L)
			<u>D.O.</u>
			(mg/L)
	0.016	2.01	0.01
	0.031	2.01	0.01
	0.047	2.01	0.01
	0.063	2.01	0.01
	0.079	2.01	0.01
	0.094	2.01	0.01
	0.110	2.01	0.01
	0.126	2.01	0.01
	0.142	2.01	0.01
	0.157	2.01	0.01

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
05C	27657	LITTLE FISHING CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
4.560	Madison Estates	PA0112381	0.004	CBODS	11.51		
				NH3-N	13.49	26.98	
				Dissolved Oxygen			5.59

Input levels are protective

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.0528	= Q stream (cfs)		0.5	= CV Daily	
0.01	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 1.108		1.3.2.iii	WLA_cfc = 1.072
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.413		5.1d	LTA_cfc = 0.623
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				