



Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

Application No. **PA0112488**  
APS ID **1081676**  
Authorization ID **1428210**

## NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE


### Applicant and Facility Information

Applicant Name	<u>Ralpho Township Municipal Authority</u>	Facility Name	<u>Bear Gap STP</u>
Applicant Address	<u>206 S Market Street Suite 1</u>	Facility Address	<u>Fredricks Road</u>
	<u>Elysburg, PA 17824-9782</u>		<u>Bear Gap, PA 17842</u>
Applicant Contact	<u>Ted Yeager</u>	Facility Contact	<u>Ted Yeager</u>
Applicant Phone	<u>(570) 672-9792</u>	Facility Phone	<u>(570) 672-9792</u>
Client ID	<u>25371</u>	Site ID	<u>245444</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Ralpho Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Northumberland</u>
Date Application Received	<u>February 17, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>February 28, 2023</u>	If No, Reason	
Purpose of Application	<u>Application for the renewal of the existing individual NPDES permit.</u>		

### Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

This facility serves the Bear Gap Area of the township and was originally designed to treat a total of 20 residences. The collection system consists of approximately 2,200 linear feet of 4" diameter PVC gravity sewer piping. Each residence has individual septic tanks and the primary treated effluent from the tanks is gravity fed to the treatment plant.

Approve	Deny	Signatures	Date
X		 Jonathan P. Peterman / Project Manager	December 27, 2024
X		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	December 27, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.006
Latitude	40° 49' 49.29"	Longitude	-76° 32' 31.00"
Quad Name	Shamokin	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Miller's Run (CWF)	Stream Code	18626
NHD Com ID	54961435	RMI	2.65
Drainage Area	1.07	Yield (cfs/mi <sup>2</sup> )	0.3
Q <sub>7-10</sub> Flow (cfs)	0.35	Q <sub>7-10</sub> Basis	Stream Gage No. 1468500
Elevation (ft)	740	Slope (ft/ft)	0.008
Watershed No.	6-B	Chapter 93 Class.	CWF
Existing Use	CWF	Existing Use Qualifier	N/A
Exceptions to Use	None.	Exceptions to Criteria	None.
Assessment Status	Impaired		
Cause(s) of Impairment	Metals; pH		
Source(s) of Impairment	Abandoned Mine Drainage		
TMDL Status	Final 4/9/2001	Name	Shamokin Creek Watershed
Nearest Downstream Public Water Supply Intake		Capital Region Water	
PWS Waters	Susquehanna River	Flow at Intake (cfs)	2610
PWS RMI	74	Distance from Outfall (mi)	70

Changes Since Last Permit Issuance: None.

**Other Comments:** In order to determine the Q<sub>7-10</sub> low flow for Miller's Run, a comparative stream analysis was previously conducted and the results of which are attached in Appendix A. This stream gage was used in the analysis and indicates that the Q<sub>7-10</sub> for Miller's Run is 0.3564 cfs (0.2303 MGD).

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Bear Gap STP				
WQM Permit No.	Issuance Date	Notes:		
488409	1/12/89	Initial construction.		
Waste Type	Degree of Treatment	Process Type	Disinfection	Design Flow (MGD)
Sewage	Primary	Septic Tanks	Hypochlorite	0.006
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.006	10	Not Overloaded	None.	Other WWTP.

**Treatment System Components for Outfall 001:**

- Note: Individual septic tanks at each residence and effluent is sent to plant.

- One (1) settling/receiving tank.
- One (1) dosing tank.
- Two (2) sand filter beds (5,264 sq. ft. total).
- One (1) erosion chlorinator.
- One (1) chlorine contact tank.
- One (1) carbonate tank. (pH adjustment using limestone)
- One (1) Outfall.

Changes Since Last Permit Issuance: None.

Other Comments: None.

**TMDL Impairment**

The Department's Geographic Information System (GIS) shows that the Miller's Run (Shamokin Creek Watershed) is impaired and a TMDL does exist for the stream segment. High levels of metals caused these impairments (iron, manganese, aluminum) as well as pH. All impairments resulted from acid mine drainage. The TMDL addresses the three primary metals associated with acid mine drainage (iron, manganese, aluminum). There is currently no industrial waste being discharged into the treatment plant and this discharge is not expected to contribute to the level of metals in the stream. Given the regulations contained in 40 CFR §122.44(d)(1)(ii)&(iii), it can be determined that the type of effluent from this facility has no "Reasonable potential to cause, or contributes to an in-stream excursion above the allowable ambient concentration of a State numeric criteria within a State water quality standard for an individual pollutant." However, monitoring requirements for metals (iron, manganese and aluminum) will be placed in the permit because point sources in the segment where the TMDL does not assign any wasteload allocations are not authorized to discharge these metals of concern. The result from the monitoring that was conducted over the previous permit cycles demonstrates that the facility is not contributing to this impairment and no further monitoring is required. The monitoring requirements will be removed. The monitoring results for these metals are attached in the Appendix E.

**Chesapeake Bay Requirements**

Previously, the permittee was required to monitor and report TN and TP throughout the permit term at a frequency no less than annually in accordance with the Phase III WIP Chesapeake Bay Strategy for Phase V facilities (0.002 MGD to 0.2 MGD) since it did not have at least two of years of monitoring completed. Monitoring for these parameters was conducted over the previous permit term and the yearly monitoring requirements for nutrients will be removed accordingly. No further monitoring is required at this time. The monitoring results are attached in the Appendix E.

**Existing Effluent Limitations and Monitoring Requirements**

**Existing Limits – Outfall 001**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	5/week	Grab
Dissolved Oxygen	XXX	XXX	Report Daily Min	XXX	XXX	XXX	5/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	5/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	1.3	2.0	XXX	25.0	40.0	50	1/month	Grab
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/month	Grab
Total Suspended Solids	1.5	2.3	XXX	30.0	45.0	60	1/month	Grab
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/month	Grab
Ammonia-Nitrogen	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
Total Nitrogen (lbs/year)	Report Annl Avg	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Phosphorus (lbs/year)	Report Annl Avg	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Aluminum, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Iron, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Manganese, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab

\*The existing effluent limits for Outfall 001 were based on a design flow of 0.006 MGD.

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 40° 49' 49.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.006  
Longitude -76° 32' 31.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: None.

**Water Quality-Based Limitations**

To establish whether or not water-quality based effluent limitations (WQBELs) are required, the Department models in-stream conditions. In order to determine limitations for CBOD<sub>5</sub>, ammonia-N and dissolved oxygen, the Department utilizes the WQM 7.0 v1.0b model and in order to determine limitations for toxics, the Department utilizes the Toxics Management Spreadsheet (TMS). The TMS was not utilized for this review.

**WQM 7.0 for Windows, Version 1.0b, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen**  
Since there have been no changes to the watershed or the facility and there is sufficient dilution, the previous modeling results shall be utilized. The model was previously run using the Q7-10 stream flow, background water quality, average annual design flow, and other discharge characteristics. The existing technology-based effluent limits for CBOD<sub>5</sub> (25 mg/l) and NH<sub>3</sub>-N (25.0 mg/l) were used as inputs for the modeling. The DO minimum daily average criterion from §93.7 (5.0 mg/L for CWF) was used for the in-stream objective for the model. The summary of the output is as follows:

Parameter	Effluent Limit		
	30 Day Average	Maximum	Minimum
CBOD <sub>5</sub>	25	N/A	N/A
Ammonia-N	25	50	N/A
Dissolved Oxygen	N/A	N/A	3

The previous model did not recommend water-quality based effluent limitations with regards to CBOD<sub>5</sub>, ammonia-nitrogen, and dissolved oxygen. Refer to the Appendix B for the previous WQM 7.0 inputs and results. The existing effluent limits will remain.

**Best Professional Judgment (BPJ) Limitations**

See the D.O. and Ammonia-Nitrogen sections below.

Comments: None.

**Anti-Backsliding**

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

**Proposed Limits - Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	5/week	Grab
Dissolved Oxygen	XXX	XXX	Report Daily Min	XXX	XXX	XXX	5/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	5/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	1.3	2.0	XXX	25.0	40.0	50	1/month	Grab
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/month	Grab
Total Suspended Solids	1.5	2.3	XXX	30.0	45.0	60	1/month	Grab
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/month	Grab
Ammonia-Nitrogen	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

\*The proposed effluent limits for Outfall 001 were based on a design flow of 0.006 MGD.

**Effluent Limit Determination for Outfall 001**

**General Information**

All of the limits proposed above are consistent with other permits issued for wastewater treatment plants in the region. The associated mass-based limits (lbs/day) for all parameters were based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34). All effluent limits were then rounded down in accordance with the rounding rules established in the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001), Chapter 5 - Specifying Effluent Limitations in NPDES Permits.

**Flow**

Reporting of the average monthly and daily maximum flow is consistent with monitoring requirements for other treatment plants of this size.

**Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>)**

The results of the WQM 7.0 model show that the previously applied secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for CBOD<sub>5</sub> are protective of water quality.

**Total Suspended Solids (TSS)**

The previously applied technology based secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for TSS will remain as well.

**pH**

CFR Title 40 §133.102(c) and 25 PA Code §95.2(1) provide the basis of effluent limitations for pH. The existing limits will remain.

**TRC**

In accordance with 25 Pa. Code 92a.48(b)(2), a best available technology (BAT) value of 0.5 mg/l was used in lieu of the existing effluent limit (1.0 mg/L) in the TRC Spreadsheet. The attached TRC model indicates that the technology-based effluent limits of 0.5 mg/L (Average Monthly) and 1.6 mg/L (Instantaneous Maximum) are protective of water quality and will remain.

**Fecal Coliforms**

The existing fecal coliform limits with I-max limits were previously updated from the previous Chapter 92 code to correspond with what is specified in the updated 25 PA Code § 92a.47 (a)(4)&(5).

**Ammonia-Nitrogen (NH3-N)**

The results of the WQM 7.0 model show that a discharge of ammonia-nitrogen at the technology-based effluent limit (25 mg/L) would be protective of water quality. It is anticipated that the influent NH3-N concentration would be 25 mg/L and the effluent concentration would be significantly lower. Therefore, the permittee will only be required to monitor for ammonia-nitrogen.

**Dissolved Oxygen (DO)**

Based on BPJ, monitoring of the minimum Dissolved Oxygen (DO) standard found in Chapter 93 for cold water fishes will remain. This will ensure that the discharge does not contribute to an in-stream excursion above the allowable ambient concentration of State numeric criteria within a State water quality standard for an individual pollutant.

**Influent BOD<sub>5</sub> and TSS**

The Department requires the reporting of raw sewage influent monitoring for BOD<sub>5</sub> and TSS in all POTW permits. This provides the Department with the ability to monitor the percent removal of each parameter as stipulated in section 2 of the Part A conditions and maintain records of the BOD<sub>5</sub> loading as required by 25 Pa. Code Chapter 94. The monitoring frequencies and sample types are identical to the effluent sampling.

**E. Coli**

25 PA Code § 92a.61 provide the basis of monitoring requirements for E. Coli. Yearly monitoring will be required going forward.

**Monitoring Frequencies (TRC, pH, CBOD<sub>5</sub>, TSS, and Fecal Coliforms)**

Previous reviews established a monitoring frequency of 5/ Week for pH, D.O., and TRC and 1/ Month for CBOD<sub>5</sub>, TSS, and Fecal Coliforms. However, these monitoring frequencies do not correspond with the *Technical Guidance for the*

*Development and Specification of Effluent Limitations* (362-0400-001) Table 6-3 which calls for daily monitoring and 2/month samples accordingly. Based on BPJ and given that there is no history of significant non-compliance with effluent limitations over the past two years of DMR data, the existing frequencies will be continued in the renewed permit. Given that this facility utilizes a septic / sand filter system in lieu of a traditional aeration system, a 5/ week sampling frequency is acceptable. It is expected that the effluent quality would not differ drastically on days when monitoring is not conducted given that there is a lesser potential for a system malfunction with a sand filter system.

### Compliance History

**Summary of Inspections** -The last inspection of the facilities was conducted on 12/13/24 by the Department which reveals the facility was operating normally. No major issues were noted.

**WMS Query Summary** - A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed that there were no unresolved violations.

**DMRs Summary** - Upon review of the last year of DMR's, the facility appears to be generally operating within the given concentration limits. See DMR data in continued Compliance History below.

Compliance History

DMR Data for Outfall 001 (from November 1, 2023 to October 31, 2024)

Parameter	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23
Flow (MGD) Average Monthly	0.002	0.002	0.0021	0.0023	0.0020	0.0027	0.0038	0.004	0.0027	0.00444 2	0.0066	0.0020
Flow (MGD) Daily Maximum	0.003	0.003	0.0032	0.0035	0.0034	0.0101	0.0143	0.014	0.0070	0.01484	0.0158	0.0045
pH (S.U.) Instantaneous Minimum	6.1	6.1	6.1	6.0	6.1	6.0	6.1	6.0	6.0	6.0	5.8	6.0
pH (S.U.) Instantaneous Maximum	6.8	6.9	6.7	6.5	6.5	6.7	7.1	6.9	7.4	7.0	9.0	7.0
DO (mg/L) Daily Minimum	5.68	6.12	0.33	4.17	6.07	4.32	7.01	7.88	8.36	7.36	7.67	0.65
TRC (mg/L) Average Monthly	0.4	0.4	0.2	0.1	0.1	0.1	0.2	0.4	0.3	0.03	0.4	0.5
TRC (mg/L) Instantaneous Maximum	1.37	1.15	0.62	0.43	0.42	0.45	0.86	2.2	1.09	1.57	1.26	1.67
CBOD5 (lbs/day) Average Monthly	< 0.05	< 0.04	< 0.05	< 0.06	0.1	< 0.04	1.8	< 0.1	0.08	< 0.05	< 0.05	0.1
CBOD5 (lbs/day) Weekly Average	< 0.05	< 0.04	< 0.05	< 0.06	0.1	< 0.04	1.8	< 0.1	0.08	< 0.05	< 0.05	0.1
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.0	< 3.0	7.1	< 3.0	15.3	< 3.0	4.6	< 3.0	< 3.0	7.5
CBOD5 (mg/L) Weekly Average	< 3.0	< 3.0	< 3.0	< 3.0	7.1	< 3.0	15.3	< 3.0	4.6	< 3.0	< 3.0	7.5
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	1	1	3	1	< 1	1	18	3	2	2	3	1
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	1	1	3	1	< 1	1	18	3	2	2	3	1
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	60	57	167	49	28	103	154	57	144	124	177	81

NPDES Permit Fact Sheet  
Bear Gap STP

NPDES Permit No. PA0112488

TSS (lbs/day) Average Monthly	0.04	< 0.02	0.05	< 0.03	< 0.02	< 0.02	1.1	0.2	< 0.03	< 0.03	0.05	< 0.02
TSS (lbs/day) Raw Sewage Influent   Average Monthly	< 1	< 1	1	1	1	< 1	7	1	< 1	1	< 1	< 1
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	< 1	< 1	1	1	1	< 1	7	1	< 1	1	< 1	< 1
TSS (lbs/day) Weekly Average	0.04	< 0.02	0.05	< 0.03	< 0.02	< 0.02	1.1	0.2	< 0.03	< 0.03	0.05	< 0.02
TSS (mg/L) Average Monthly	2.8	< 1.6	2.8	< 1.6	< 1.6	< 1.6	9.6	5.2	< 1.6	< 1.6	3.2	< 1.6
TSS (mg/L) Raw Sewage Influent   Average Monthly	20	28	48	34	42	33	62	30	27.0	44	86	34
TSS (mg/L) Weekly Average	2.8	< 1.6	2.8	< 1.6	< 1.6	< 1.6	9.6	5.2	< 1.6	< 1.6	3.2	< 1.6
Fecal Coliform (No./100 ml) Geometric Mean	< 1	2	1	< 10	2	< 1	> 49	1553	< 1	< 1	< 1	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	2	1	< 10	2	< 1	> 2419.6	1553.1	< 1	< 1	< 1	< 1
Total Nitrogen (lbs/day) Annual Average				< 0.7								
Total Nitrogen (mg/L) Annual Average				< 48.14								
Total Nitrogen (lbs) Total Annual				< 254								
Ammonia (lbs/day) Average Quarterly		0.06			1			0.01			0.004	
Ammonia (mg/L) Average Quarterly		3.284			10.61			0.5633			0.277	
Total Phosphorus (lbs/day) Annual Average			0.005									
Total Phosphorus (mg/L) Annual Average			0.36									
Total Phosphorus (lbs) Total Annual			2									

Total Aluminum (mg/L) Daily Maximum											0.525	
Total Iron (mg/L) Daily Maximum											< 0.2	
Total Manganese (mg/L) Daily Maximum											0.175	

### Compliance History

#### Effluent Violations for Outfall 001, from: December 1, 2023 To: October 31, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
pH	12/31/23	Inst Min	5.8	S.U.	6.0	S.U.
pH	12/31/23	Inst Min	5.8	S.U.	6.0	S.U.
TRC	03/31/24	IMAX	2.2	mg/L	1.6	mg/L
CBOD5	04/30/24	Avg Mo	1.8	lbs/day	1.3	lbs/day
Fecal Coliform	04/30/24	Geo Mean	> 49	No./100 ml	2000	No./100 ml
Fecal Coliform	04/30/24	IMAX	> 2419.6	No./100 ml	10000	No./100 ml

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment <b>B</b> )
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment <b>C</b> )
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

# **APPENDIX A**

## **Q7-10 ANALYSIS AND STREAM DATA**

**Q<sub>7-10</sub> Calculations**

Comparative Analysis

Stream Name	Schuylkill River
Reference Gage	1468500
Station Name	Schuylkill River at Landingsville, PA
Gage Drainage Area (sq. mi.)	133
Q <sub>7-10</sub> at gage (cfs)	44.3
Drainage Area at site (sq. mi.)	1.07
Q <sub>7-10</sub> at discharge site (cfs)	0.3564
Q <sub>7-10</sub> at discharge site (mgd)	0.2303

Low flow Yield Ratio of 0.1 cfs/mi<sup>2</sup>

Q <sub>7-10</sub> at discharge site (cfs)	0.3570
Q <sub>7-10</sub> at discharge site (mgd)	0.0692

**Ralpho Twp. - Bear Gap STP**

Correlation
0.964

Check Dilution Ratio		
	sf (cfs)	wf (cfs)
Dilution Ratio = sf/wf	0.3564	0.03547229
Dilution Ratio = 23.03463 to 1		

**Basin Characteristics Report**

Date: Wed Sep 26 2012 14:18:47 Mountain Daylight Time

NAD27 Latitude: 40.8304 (40 49 49)

NAD27 Longitude: -76.5431 (-76 32 35)

NAD83 Latitude: 40.8305 (40 49 50)

NAD83 Longitude: -76.5428 (-76 32 34)

Parameter	Value
Area in square miles	1.68
Mean Basin Elevation In feet	997.5
Unadjusted basin slope, in degrees	9.1
Adjusted basin slope, in degrees	9.2
Total stream length in miles	1.44
Stream density (miles/square mile)	1.31
Percent of area covered by lakes, ponds, reservoirs and wetlands	0.1
Percent of area covered by carbonates to rock	0.0
Percent of area covered by glacial activity	0.0
Depth to rock in feet	4.9
Mean annual precipitation in inches	41.0
Maximum Daily Temperature in degrees F	57.3
Percent of area covered by forest	73.6
Percentage of impervious area determined from NLCD 2001 Impervious dataset	0.7
Percent of area covered by urban land according to an enhanced version of NLCD 1992	0.0
Percentage of urban land cover determined from NLCD 2001 land cover dataset	6.7
Drainage quality Index from STATSGO	3.1
X coordinate of the centroid, in map projection, meters	124178.5
Y coordinate of the centroid, in map projection, meters	204175.3
X coordinate of the outlet, in map projection, meters	122895.0
Y coordinate of the outlet, in map projection, meters	204255.0

# **APPENDIX B**

## **PREVIOUS WQM 7.0 MODEL INPUT/OUTPUT**

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RML	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC	Stream Data	
									2,650	740.00
QGB	18621 MILLERS RUN								1.07	0.00000
<b>Stream Data</b>										
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (ips)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
	(cfsn)	(cfs)	(cfs)							
Q7-10	0.100	0.00	0.38	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10			0.00	0.000	0.000					
Q30-10			0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Ralpho Twp Bear	PA0112488	0.0000	0.0060	0.0000	0.000	26.00	7.00		
<b>Parameter Data</b>										
	Parameter Name		Disc Concentration (mg/L)	Trib Concentration (mg/L)	Stream Concentration (mg/L)	Fate Coef				
	CBOD5		26.00	2.00	0.00	1.60				
	Dissolved Oxygen		3.00	8.24	0.00	0.00				
	NH3-N		26.00	0.00	0.00	0.70				

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
06B	18621 MILLERS RUN		2.520	734.00	2.34	0.00000	0.00	M

**Stream Data**

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.100	0.00	0.78	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

**Parameter Data**

Parameter Name	Disc Cone (mg/L)	Trib Cone (mg/L)	Stream Cone (mg/L)	Fate Coef (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	26.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin			Stream Code			Stream Name						
06B			18621			MILLERS RUN						
RM#	Stream Flow	PWS Wth	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	WD Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
2,660	0.36	0.00	0.36	.0093	0.00874	.43	6.88	16.00	0.12	0.064	20.13	7.00
<b>Q1-10 Flow</b>												
2,660	0.36	0.00	0.36	.0093	0.00874	NA	NA	NA	0.12	0.065	20.13	7.00
<b>Q30-10 Flow</b>												
2,660	0.43	0.00	0.43	.0093	0.00874	NA	NA	NA	0.14	0.058	20.11	7.00

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted WID Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.97	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.2	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
00B	18621	MILLERS RUN

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	2.650 Ralpho Twp Bear	9.68	50	9.58	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	2.650 Ralpho Twp Bear	1.9	25	1.9	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	2.65 Ralpho Twp Bear	25	25	25	25	3	3	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
06B	18621	MILLERS RUN		
<u>RM</u> 2,650	<u>Total Discharge Flow (mgd)</u> 0.006	<u>Analysis Temperature (°C)</u> 20.127	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 0.883	<u>Reach Depth (ft)</u> 0.430	<u>Reach WD Ratio</u> 15.991	<u>Reach Velocity (fps)</u> 0.123	
<u>Reach CBOO5 (mg/L)</u> 2.58	<u>Reach Kc (1/days)</u> 0.355	<u>Reach NH3-N (mg/L)</u> 0.63	<u>Reach Kn (1/days)</u> 0.707	
<u>Reach DO (mg/L)</u> 8.110	<u>Reach Kr (1/days)</u> 25.486	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 8	
<u>Reach Travel Time (days)</u> 0.064	<u>Subreach Results</u>			
	<u>TravTime</u> (days)	<u>CBOD5</u> (mg/L)	<u>NH3-N</u> (mg/L)	<u>D.O.</u> (mg/L)
	0.006	2.68	0.63	8.22
	0.013	2.57	0.63	8.22
	0.019	2.67	0.63	8.22
	0.026	2.66	0.62	8.22
	0.032	2.55	0.62	8.22
	0.039	2.55	0.62	8.22
	0.045	2.54	0.61	8.22
	0.051	2.54	0.61	8.22
	0.058	2.53	0.61	8.22
	0.064	2.63	0.61	8.22

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
06B	18821	MILLERS RUN					
RM#	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
2,650	Ralpho Twp Bear	PA0112488	0.008	CBOD5	26		
				NH3-N	26	50	
				Dissolved Oxygen			3


# **APPENDIX C**

## **TRC ANALYSIS**

1A	B	C	D	E	F	G
2	<b>TRC EVALUATION</b> Ralpbo Twp PA0112488					
3	Input appropriate values in B4:B8 and E4:E7					
4	0.35	= Q stream (cfs)	0.5	= CV Daily		
5	0.006	= Q discharge (MGD)	0.5	= CV Hourly		
6	30	= no. samples	1	= AFC_Partial Mix Factor		
7	0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
8	0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
9	0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		
	0	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)		
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 12.048	1.3.2.iii	WLA_cfc = 11.738	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc= 4.489	5.1d	LTA_cfc = 6.824	
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
18			INST MAX LIMIT (mg/l) = 1.635			
	WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd)*e(-k*AFC_tc)]... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
	LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$				
	LTA_afc	wla_afc*LTAMULT_afc				
	WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd)*e(-k*CFC_tc)]... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
	LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$				
	LTA_cfc	wla_cfc*LTAMULT_cfc				
	AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$				
	AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
	INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)				

# **APPENDIX D**

## **FACILITY MAP**



# **APPENDIX E**

## **TN, TP, AND METALS SAMPLING RESULTS**

PERMIT	PF	NAME	REPORT FR	DUE DATE	OUTFALL	MONITORI	PARAMETE	PARAMETER	LOADUNIT: LOAD 1VAL LOAD 1LIM LOAD 1SBC LOAD 2VAL LOAD 2LIM LOAD 2SBC CONCUNITS		CONC 2VAI	CONC 2LIM	CONC 2SBC	CONC 3VAL	SAMPLE FR	SAMPLE TY
									mg/L	mg/L						
PA011248E	RALPH0	Tv	Annually	01/28/2020	001	Final Efflue	01105	Aluminum, Total			0.126	Monitor an Daily Maximum	1/year	Grab		
PA011248E	RALPH0	Tv	Annually	01/28/2021	001	Final Efflue	01105	Aluminum, Total			0.856	Monitor an Daily Maximum	1/year	Grab		
PA011248E	RALPH0	Tv	Annually	01/28/2022	001	Final Efflue	01105	Aluminum, Total			0.519	Monitor an Daily Maximum	1/year	Grab		
PA011248E	RALPH0	Tv	Annually	01/28/2023	001	Final Efflue	01105	Aluminum, Total			0.814	Monitor an Daily Maximum	1/year	Grab		
PA011248E	RALPH0	Tv	Annually	01/28/2024	001	Final Efflue	01105	Aluminum, Total			0.525	Monitor an Daily Maximum	1/year	Grab		
PA011248E	RALPH0	Tv	Annually	01/28/2020	001	Final Efflue	01045	Iron, Total			<	0.3	Monitor an Daily Maximum	1/year	Grab	
PA011248E	RALPH0	Tv	Annually	01/28/2021	001	Final Efflue	01045	Iron, Total			<	0.2	Monitor an Daily Maximum	1/year	Grab	
PA011248E	RALPH0	Tv	Annually	01/28/2022	001	Final Efflue	01045	Iron, Total			<	0.2	Monitor an Daily Maximum	1/year	Grab	
PA011248E	RALPH0	Tv	Annually	01/28/2023	001	Final Efflue	01045	Iron, Total			<	0.2	Monitor an Daily Maximum	1/year	Grab	
PA011248E	RALPH0	Tv	Annually	01/28/2024	001	Final Efflue	01045	Iron, Total			<	0.2	Monitor an Daily Maximum	1/year	Grab	
PA011248E	RALPH0	Tv	Annually	01/28/2020	001	Final Efflue	01055	Manganese, Total			0.539	Monitor an Daily Maximum	1/year	Grab		
PA011248E	RALPH0	Tv	Annually	01/28/2021	001	Final Efflue	01055	Manganese, Total			0.315	Monitor an Daily Maximum	1/year	Grab		
PA011248E	RALPH0	Tv	Annually	01/28/2022	001	Final Efflue	01055	Manganese, Total			0.0963	Monitor an Daily Maximum	1/year	Grab		
PA011248E	RALPH0	Tv	Annually	01/28/2023	001	Final Efflue	01055	Manganese, Total			0.195	Monitor an Daily Maximum	1/year	Grab		
PA011248E	RALPH0	Tv	Annually	01/28/2024	001	Final Efflue	01055	Manganese, Total			0.175	Monitor an Daily Maximum	1/year	Grab		
PA011248E	RALPH0	Tv	Annually	11/28/2020	001	Final Efflue	00600	Total Nitrogen			<	38.78	Monitor an Annual Average	1/year	Grab	
PA011248E	RALPH0	Tv	Annually	11/28/2021	001	Final Efflue	00600	Total Nitrogen	lbs/day	0.8	Monitor an Annual Average		21.81	Monitor an Annual Average	1/year	Calculation
PA011248E	RALPH0	Tv	Annually	11/28/2022	001	Final Efflue	00600	Total Nitrogen	lbs/day	3	Monitor an Annual Average		62.55	Monitor an Annual Average	1/year	Calculation
PA011248E	RALPH0	Tv	Annually	11/28/2023	001	Final Efflue	00600	Total Nitrogen	lbs/day	0.9	Monitor an Annual Average		23.8	Monitor an Annual Average	1/year	Calculation
PA011248E	RALPH0	Tv	Annually	11/28/2024	001	Final Efflue	00600	Total Nitrogen	lbs/day	< 0.7	Monitor an Annual Average		48.14	Monitor an Annual Average	1/year	Calculation
PA011248E	RALPH0	Tv	Annually	11/28/2020	001	Final Efflue	51445	Total Nitrogen (Total Lbs)		< 0.8	Monitor an Annual Avg < 26	Monitor ar Total Annual				Grab
PA011248E	RALPH0	Tv	Annually	11/28/2021	001	Final Efflue	51445	Total Nitrogen (Total Lbs)			24	Monitor ar Total Annual				Calculation
PA011248E	RALPH0	Tv	Annually	11/28/2022	001	Final Efflue	51445	Total Nitrogen (Total Lbs)			< 99	Monitor ar Total Annual				Calculation
PA011248E	RALPH0	Tv	Annually	11/28/2023	001	Final Efflue	51445	Total Nitrogen (Total Lbs)			29	Monitor ar Total Annual				Calculation
PA011248E	RALPH0	Tv	Annually	11/28/2024	001	Final Efflue	51445	Total Nitrogen (Total Lbs)			< 254	Monitor ar Total Annual				Calculation
PA011248E	RALPH0	Tv	Annually	11/28/2020	001	Final Efflue	00665	Total Phosphorus				mg/L	2.09	Monitor an Annual Average	1/year	Grab
PA011248E	RALPH0	Tv	Annually	11/28/2021	001	Final Efflue	00665	Total Phosphorus	lbs/day	0.08	Monitor an Annual Average		2.29	Monitor an Annual Average	1/year	Grab
PA011248E	RALPH0	Tv	Annually	11/28/2022	001	Final Efflue	00665	Total Phosphorus	lbs/day	0.01	Monitor an Annual Average		0.27	Monitor an Annual Average	1/year	Grab
PA011248E	RALPH0	Tv	Annually	11/28/2023	001	Final Efflue	00665	Total Phosphorus	lbs/day	0.04	Monitor an Annual Average		0.962	Monitor an Annual Average	1/year	Grab
PA011248E	RALPH0	Tv	Annually	11/28/2024	001	Final Efflue	00665	Total Phosphorus	lbs/day	0.005	Monitor an Annual Average		0.36	Monitor an Annual Average	1/year	Grab
PA011248E	RALPH0	Tv	Annually	11/28/2020	001	Final Efflue	51451	Total Phosphorus (Tot lbs)		0.04	Monitor an Annual Ave 1	Monitor ar Total Annual				Grab
PA011248E	RALPH0	Tv	Annually	11/28/2021	001	Final Efflue	51451	Total Phosphorus (Tot lbs)			3	Monitor ar Total Annual				Grab
PA011248E	RALPH0	Tv	Annually	11/28/2022	001	Final Efflue	51451	Total Phosphorus (Tot lbs)			0.4	Monitor ar Total Annual				Grab
PA011248E	RALPH0	Tv	Annually	11/28/2023	001	Final Efflue	51451	Total Phosphorus (Tot lbs)			1	Monitor ar Total Annual				Grab
PA011248E	RALPH0	Tv	Annually	11/28/2024	001	Final Efflue	51451	Total Phosphorus (Tot lbs)			2	Monitor ar Total Annual				Grab

Averages	
Total Aluminum	0.568 mg/L
Total Iron	0.22 mg/L
Total Manganese	0.26406 mg/L
Total Nitrogen	39.016 mg/L
Total Phosphorus	1.1944 mg/L