

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0113069  
APS ID 1062786  
Authorization ID 1395296

**Applicant and Facility Information**

Applicant Name	<u>Greenwood Township Municipal Authority Columbia County</u>	Facility Name	<u>Greenwood Township Municipal Authority Sewer System</u>
Applicant Address	<u>90 Shed Road Millville, PA 17846-9148</u>	Facility Address	<u>Rohrsburg Road Rohrsburg, PA 17859</u>
Applicant Contact	<u>Joe Farr, Secretary</u>	Facility Contact	<u>Joe Farr, Secretary</u>
Applicant Phone	<u>(570) 458-0212</u>	Facility Phone	<u>(570) 458-0212</u>
Client ID	<u>43854</u>	Site ID	<u>254151</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Greenwood Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Columbia</u>
Date Application Received	<u>May 3, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 12, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit</u>		

**Summary of Review**

The subject facility is a municipal sewage treatment plant serving the area of the Village of Rohrsburg in Greenwood Township, Columbia County. A map indicating the discharge location is attached (See Attachment A).

Sludge use and disposal description and location(s): The facility's sludge is trucked to other treatment facilities for further processing. Per the application 6.206 dry tons were removed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	September 13, 2022
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	September XX, 2022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0075</u>
Latitude	<u>41° 7' 48.95"</u>	Longitude	<u>-76° 25' 21.58"</u>
Quad Name	<u>Benton, PA</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Green Creek (TSF)</u>	Stream Code	<u>27783</u>
NHD Com ID	<u>65638251</u>	RMI	<u>0.4</u>
Drainage Area	<u>2.11 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0613</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.129</u>	Q <sub>7-10</sub> Basis	<u>Gage 01539000 - Fishing Creek @ Bloomsburg, PA (1940-2008)</u>
Elevation (ft)	<u>625</u>	Slope (ft/ft)	<u>0.0095</u>
Watershed No.	<u>5-C</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Nearest Downstream Public Water Supply Intake	<u>Suez Water Pennsylvania - Bloomsburg</u>		
PWS Waters	<u>Fishing Creek</u>	Distance from Outfall (mi)	<u>Approx. 12</u>

Changes Since Last Permit Issuance: None. The existing stream and discharge characteristics were determined for the previous review and remain adequate.

Other Comments: The receiving stream is an unnamed according to Chapter 93 but is known locally and listed on USGS topographic maps as "Rickard Hollow".

The discharge is not expected to affect any downstream water supply at this time with the limitations and monitoring proposed.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Greenwood Township Municipal Authority Sewer System STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>	<b>Permit For:</b>		
1987401	7/23/87	0.0075 MGD Cromaglass Plant with 35 septic tanks		
1988409	2/2/88	Allowed for an "approved equal" to the plant under 1987401		
1990405	4/4/90	Sewer Extension with pump station		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Activated Sludge	Hypochlorite	0.0075
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0075	25	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The treatment facility as permitted under WQM Permit No. 1987401 consists of a pump station with grinder pumps receiving septic tank effluent, bar screen, aeration tank, clarifier, equalization, tablet chlorinator, and contact tank.

Compliance History

DMR Data for Outfall 001 (from August 1, 2021 to July 31, 2022)

Parameter	JUL-22	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21
Flow (MGD) Average Monthly	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005
Flow (MGD) Daily Maximum	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005
pH (S.U.) Minimum	6.98	7.11	7.24	7.06	6.89	7.25	7.23	7.47	7.39	7.44	7.12	7.03
pH (S.U.) Maximum	7.63	7.56	7.63	7.54	7.81	7.94	8.12	7.99	8.06	8.07	7.76	7.63
DO (mg/L) Minimum	2.85	4.13	4.27	3.24	4.2	4.29	1.8	2.76	2.12	2.95	2.6	3.4
TRC (mg/L) Average Monthly	0.91	0.93	1.18	0.83	0.92	0.97	0.77	0.48	0.95	0.83	0.77	0.7
TRC (mg/L) Instantaneous Maximum	1.12	1.25	1.49	1.46	1.55	1.27	1.19	1.21	1.1	1.08	1.1	1.18
CBOD5 (lbs/day) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.03	< 0.2	< 0.1	0.6	0.1	< 0.1	< 0.02	< 0.1	< 0.1
CBOD5 (lbs/day) Weekly Average	< 0.1	< 0.1	< 0.1	0.4	< 0.3	< 0.1	0.6	0.1	< 0.1	< 0.02	< 0.1	< 0.1
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.0	< 6.8	< 3.0	< 3.0	5.01	< 3.0	< 3.0	< 3.76	< 3.0	< 3.0
CBOD5 (mg/L) Weekly Average	< 3.0	< 3.0	< 3.0	10.6	< 3.0	< 3.0	8.48	< 3.0	< 3.0	4.52	< 3.0	< 3.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	2.0	5.0	1.0	10.0	5.0	10	5.0	4.0	2	4.0	6.0	< 4.0
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	2.0	7.0	2.0	7.0	7.0	12	5.0	5.0	2	5.0	5.0	7.0
BOD5 (mg/L) Raw Sewage Influent Average Monthly	73.5	120.0	118.6	176	120.7	231.0	103.2	101.5	58.3	88.1	108.9	< 100.0
TSS (lbs/day) Average Monthly	< 0.07	0.08	0.3	1.0	< 0.07	0.2	0.3	0.2	0.2	0.1	0.2	0.2
TSS (lbs/day) Raw Sewage Influent Average Monthly	0.9	0.2	1.0	2.0	1	2.0	2.0	2.0	2.0	2	3.0	< 1.0

**NPDES Permit Fact Sheet  
Greenwood Township Municipal Authority Sewer System**

**NPDES Permit No. PA0113069**

TSS (lbs/day) Raw Sewage Influent Daily Maximum	0.9	0.2	2.0	2.0	1	3.0	2.0	2.0	2.0	1	6.0	2.0
TSS (lbs/day) Weekly Average	< 0.07	0.08	0.2	0.6	< 0.07	0.2	0.3	0.3	0.2	0.1	0.4	0.2
TSS (mg/L) Average Monthly	< 3.4	1.8	3.0	13.6	< 1.6	4.4	7.6	5.1	2.8	2.6	5.8	4.2
TSS (mg/L) Raw Sewage Influent Average Monthly	61.0	38	118.6	37.0	30	59.0	27.0	42.0	41	34	63	< 33
TSS (mg/L) Weekly Average	5.2	2.0	4.0	25.6	< 1.6	5.2	7.6	8.0	3.6	2.8	8.8	4.4
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1.0	5.4	< 1.0	19.2	< 1.0	< 1.0	3.0	< 1.0	< 1.0	< 1210.3	1.0	1.0
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 1.0	9.8	< 1.0	36.4	2.0	< 1.0	3.1	< 1.0	1.0	2419.6	3.1	2.0

**Compliance History**

<b>Summary of Inspections:</b>		The facility has been inspected at least annually over the past permit term. The most recent inspection by the Department on November 2, 2021 identified no violations at the time of inspection.
<b>Other:</b>		A WMS query found no open violations for Greenwood Township Municipal Authority in eFACTS.

**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	1.0	XXX	2.3	1/day	Grab
CBOD5	1.5	2.5	XXX	25.0	40.0	50	2/month	Grab
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	Grab
TSS	1.5	2.5	XXX	30.0	45.0	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Phosphorus	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.0075</u>
<b>Latitude</b> <u>41° 7' 49.50"</u>	<b>Longitude</b> <u>-76° 25' 22.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limits are applicable and are included in the NPDES Permit with the exception of TRC. This facility has an existing site-specific BAT limit of 1.0 mg/L for tablet chlorinators consistent with 25 Pa Code 92a.48(b)(1) and the Domestic Wastewater Facilities Manual which supports tablet chlorinators for facilities under 0.01 MGD.

**Water Quality-Based Limitations**

**DO, CBOD<sub>5</sub> and NH<sub>3</sub>-N**

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. WQM7.0 modeling was performed for the discharge to Rickard Hollow for the previous review and showed that no limitations are necessary beyond the technology-based secondary treatment limits listed above (see Attachment C).

**Total Residual Chlorine**

The facility has an existing site-specific BAT limit for Total Residual Chlorine (TRC) of 1.0 mg/l which will remain. The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's TRC in a receiving stream, accounting for available dilution. The attached results of the TRC spreadsheet (see Attachment C) show that the technology-based limit of 1.0 mg/l is adequate to protect the receiving stream.

**Toxics Management**

No further "Reasonable Potential Analysis" was performed to determine additional parameters as candidates for limitations or monitoring for this minor municipal WWTP with no industrial influent.

**Chesapeake Bay/Nutrient Requirements**

According to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is an existing Phase 5 Chesapeake Bay sewage discharger that is not expanding, and as such requires no nutrient loading limits. Annual nutrient monitoring was included in the existing permit. The average Total Nitrogen concentration over the past permit term was 8.7 mg/L and the Average Phosphorus concentration was 2.4 mg/L. Because the nutrient load has been adequately characterized no additional nutrient monitoring will be required at this time consistent with the Phase III WIP Wastewater Supplement.

**Best Professional Judgment (BPJ) Limitations**

Comments: None need beyond the Technology and Water Quality-Based limits noted above.

**e. Coli**

Due to recent changes to Chapter 93 of the Departments regulations and Department policy annual e. coli monitoring will be required at this time.

**Anti-Backsliding**

No proposed limitations are less stringent than the existing consistent with anti-backsliding provisions of the Clean Water Act and 40 CFR 122.44(l).



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	1.0	XXX	2.3	1/day	Grab
CBOD5	1.5	2.5	XXX	25.0	40.0	50	2/month	Grab
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	Grab
TSS	1.5	2.5	XXX	30.0	45.0	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments: E. Coli monitoring is new consistent with as mentioned above. Total Nitrogen and Total Phosphorus monitoring have been removed as also mentioned above.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 03/24/2021
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Model