

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0113093  
 APS ID 1056176  
 Authorization ID 1384126

**Applicant and Facility Information**

Applicant Name	<u>Christ Wesleyan Church</u>	Facility Name	<u>Christ Wesleyan Church Sewer System</u>
Applicant Address	<u>363 Stamm Road</u> <u>Milton, PA 17847-7569</u>	Facility Address	<u>363 Stamm Road</u> <u>Milton, PA 17847-7569</u>
Applicant Contact	<u>Ken Paulhamus</u>	Facility Contact	<u>Keith Pfleeger</u>
Applicant Phone	<u>(570) 742-8987</u>	Facility Phone	<u>(570) 742-8987</u>
Client ID	<u>43867</u>	Site ID	<u>480713</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Turbot Township</u>
Connection Status	<u>No Exceptions Allowed</u>	County	<u>Northumberland</u>
Date Application Received	<u>February 7, 2022</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>February 10, 2022</u>	If No, Reason	<u>Chesapeake Bay Discharger, DEP Discretion</u>
Purpose of Application	<u>Renewal of a NPDES Permit</u>		

**Summary of Review**

The subject facility is a sewage treatment plant serving the church, Meadowbrook Christian School, coffee shop, wellness gym, and other community facilities in Turbot Township, Northumberland County.

A map of the discharge location is attached.

Sludge use and disposal description and location(s): The facility's sludge is disposed at other WWTPs for further processing. Per the application, 0.55 dry tons were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	August 11, 2022
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	August 12, 2022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0035</u>
Latitude	<u>41° 1' 25.25"</u>	Longitude	<u>-76° 49' 19.11"</u>
Quad Name	<u>Milton, PA</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Limestone Run (WWF)</u>	Stream Code	<u>19095</u>
NHD Com ID	<u>66919589</u>	RMI	<u>0.85</u>
Drainage Area	<u>0.7</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.125</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.088</u>	Q <sub>7-10</sub> Basis	<u>USGS Gage 01555000 (Penns Creek, 1931-2008)</u>
Elevation (ft)	<u>500</u>	Slope (ft/ft)	<u>0.007</u>
Watershed No.	<u>10-D</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>N/A</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>SILTATION</u>		
Source(s) of Impairment	<u>AGRICULTURE</u>		
TMDL Status	<u>Final</u>	Name	<u>Limestone Run TMDL</u>
Nearest Downstream Public Water Supply Intake	<u>PA American White Deer @ Milton, PA</u>		
PWS Waters	<u>West Branch Susquehanna River</u>	Flow at Intake (cfs)	<u>680</u>
PWS RMI	<u>10.66</u>	Distance from Outfall (mi)	<u>Approx. 3</u>

Changes Since Last Permit Issuance: None. The above stream and drainage characteristics were determined for the previous review and remain adequate.

Other Comments: The facility has received no Wasteload Allocation (WLA) under the Limestone Run TMDL. The TMDL included a 1% bulk reserve allocation for TSS or 29,142 pounds of sediment per year. The discharge is typically below detection for TSS. Assuming an average concentration of 5 mg/L at the maximum annual average flow rate of 0.0035 MGD the facility would discharge 0.15 lbs/day or 53.3 lbs/yr TSS which is well within the sediment bulk reserve allocation.

No downstream water supply is expected to be affected by the discharge at this time with the limitations and monitoring proposed.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Christ Wesleyan Church Sewer System				
<b>WQM Permit No.</b>	<b>Issuance Date</b>	<b>Permit Covered:</b>		
4986404	July 28, 1986	Original permitting for Cromaglass system		
4986404 A-1	September 1990	Incorporation of anoxic cycles		
4986404 A-3	June 20, 2018	Plant upgrade and expansion		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Activated Sludge	Hypochlorite	0.0035
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.005	45.9	Not Overloaded		Other WWTP

Changes Since Last Permit Issuance: Upgrades under WQM Permit No. 4986404 Amendment No. 3 were completed 2019.

Other Comments: The treatment consists of influent pump station, 5,000-gallon equalization tank, 15,000-gallon Cromag CF150 unit including aeration and sedimentation, NetaFim disc filters, tablet chlorinator, 750-gallon chlorine contact tank, 1,300-gallon sludge holding tank, and 3,000-gallon sludge holding tank.

Compliance History

DMR Data for Outfall 001 (from July 1, 2021 to June 30, 2022)

Parameter	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21
Flow (MGD) Average Monthly	0.001532	0.002524	0.002375	0.00243	0.002472	0.002158	0.001647	0.001882	0.002466	0.002561	0.001426	0.001109
Flow (MGD) Daily Maximum	0.001909	0.002774	0.002641	0.002819	0.002613	0.002506	0.002384	0.002433	0.002742	0.003062	0.001959	0.0011263
pH (S.U.) Minimum	6.3	6.2	6.4	6.3	6.3	6.1	6.3	6.3	6.1	6.2	6.2	6.3
pH (S.U.) Maximum	7.5	7.1	7.1	7.0	7.5	7.4	7.4	7.1	7.0	6.9	7.2	7.1
DO (mg/L) Minimum	4.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	3.0	3.0	3.0	3.0
TRC (mg/L) Average Monthly	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
TRC (mg/L) Instantaneous Maximum	0.8	0.6	0.8	0.9	0.7	0.6	0.6	0.7	0.8	0.6	0.6	0.5
CBOD5 (mg/L) Average Monthly	< 2.0	< 2.0	< 2.0	3.0	6.0	3.0	3.0	< 2.0	< 2.0	< 3.0	< 2.0	< 2.0
TSS (mg/L) Average Monthly	6.0	< 4.0	< 8.0	5.0	7.0	< 4.0	< 5.0	< 4.0	< 4.0	< 6.0	< 8.0	< 5.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 1.0	< 1.0	< 7.0	2.0	< 11	< 1.0	< 2.0	< 1.0	< 6.0	< 1.0	< 1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	1.0	< 1.0	1.0	55.4	4.1	129.6	1.0	3.1	2.0	41.4	1.0	1.0
Nitrate-Nitrite (mg/L) Average Monthly	39.4	88.6	102.0	36.6	76.7	102.0	117.0	114	34.7	14.7	72.4	60.4
Nitrate-Nitrite (lbs) Total Monthly	13.9	63.5	67.4	21.3	45.7	38.3	35.6	69.4	20.4	7.6	26.0	15.4
Total Nitrogen (mg/L) Average Monthly	40.8	90.7	104.8	39.8	94.8	109.0	126.6	< 115	< 35.7	< 15.7	76.1	< 61.4
Total Nitrogen (lbs) Total Monthly	14.4	65.0	69.2	23.1	56.5	40.9	38.5	< 70	< 21	< 8.2	27.4	< 15.7
Total Nitrogen (lbs) Effluent Net Total Annual										151		

**NPDES Permit Fact Sheet  
Christ Wesleyan Church Sewer System**

**NPDES Permit No. PA0113093**

Total Nitrogen (lbs) Total Annual										< 268		
Ammonia (mg/L) Average Monthly	< 0.1	0.91	< 0.1	1.4	15.5	4.9	9.6	0.94	< 0.12	0.41	3.0	< 0.1
Ammonia (lbs) Total Monthly	< 0.04	0.7	< 0.07	0.8	9.2	1.8	2.9	0.6	< 0.1	0.2	1.1	< 0.03
Ammonia (lbs) Total Annual										< 4		
TKN (mg/L) Average Monthly	1.4	2.1	2.8	3.2	18.1	7.0	3.4	< 1.0	< 1.0	< 1.0	3.7	< 1.0
TKN (lbs) Total Monthly	0.5	1.5	1.9	1.9	10.8	2.6	1.0	< 0.6	< 0.6	< 0.5	1.3	< 0.03
Total Phosphorus (lbs/day) Average Monthly	0.1	0.2	0.2	0.2	0.2	0.2	0.1	0.3	0.2	0.2	0.1	0.1
Total Phosphorus (mg/L) Average Monthly	10.9	7.9	10.1	9.4	8.2	13.1	11.9	13.1	10.7	11.1	9.4	12.7
Total Phosphorus (lbs) Total Monthly	3.8	5.7	6.7	5.5	4.9	4.9	3.6	8	6.3	5.8	3.4	3.2
Total Phosphorus (lbs) Effluent Net Total Annual										< 22		
Total Phosphorus (lbs) Total Annual										55		

**Compliance History, Cont'd**

<b>Summary of Inspections:</b>	The facility has been inspected annually over the past permit term. The most recent inspection on June 9, 2022 identified no violations at the time of inspection.
<b>Other Comments:</b>	A query in WMS found an open violation in eFACTS for Christ Wesleyan Church for effluent violations.

Existing Effluent Limitations and Monitoring Requirements – Outfall 001								
Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25.0	XXX	50	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30.0	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/month	Grab

Existing Effluent Limitations and Monitoring Requirements – Chesapeake Bay								
Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	1/month	Grab
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	1/month	Grab
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/month	Grab
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/month	Grab
Net Total Nitrogen	XXX	152	XXX	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	24	XXX	XXX	XXX	XXX	1/year	Calculation

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.0035</u>
<b>Latitude</b> <u>41° 1' 25.20"</u>	<b>Longitude</b> <u>-76° 49' 19.10"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and included in the existing permit.

**Water Quality-Based Limitations**

**DO, CBOD<sub>5</sub> and NH<sub>3</sub>-N**

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. WQM7.0 modeling was performed showing the CBOD<sub>5</sub> technology-based limits noted above and no necessary NH<sub>3</sub>-N limits are adequate to protect the receiving stream. The modeling run is attached (Attachment B).

**Total Residual Chlorine**

The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's TRC in a receiving stream, accounting for available dilution. TRC modeling was performed showing that the existing BAT limit of 0.5 mg/L is adequate to protect the receiving stream. See Attachment C.

**Toxics Management**

No further "Reasonable Potential Analysis" was conducted to determine additional toxic pollutants as candidates for limitations for this minor treatment facility.

**Chesapeake Bay/Nutrient Requirements**

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania in order to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. The Christ Wesleyan Church treatment facility is considered a Phase 5, Insignificant Chesapeake Bay discharger. Nutrient cap loadings were established in the previous review for this facility due to expansion.



The discharge's cap loadings as well as the Total Nitrogen and Total Phosphorus loadings for the past two cycle years are listed in the table below. The permittee has purchased credits for both Total Nitrogen and Total Phosphorus to meet cap loads.

<b>Nutrient</b>	<b>Total Nitrogen</b>	<b>Total Phosphorus</b>
<b>Nutrient Cap Loads for PA0113093</b>	152	24
<b>10/1/19 – 9/30/20 Total Loadings</b>	232	< 50
<b>Credits Purchased</b>	81	28
<b>10/1/19 – 9/30/20 Net Loadings</b>	151	< 22
<b>10/1/20 – 9/30/21 Total Loadings</b>	< 268	55
<b>Credits Purchased</b>	117	33
<b>10/1/20 – 9/30/21 Net Loadings</b>	< 151	22

**Best Professional Judgment (BPJ) Limitations**

Comments: No additional BPJ limitations are necessary at this time.

**Anti-Backsliding**

No limitations have been made less stringent consistent with the anti-backsliding requirements of the Clean Water Act and 40 CFR 122.44(l).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25.0	XXX	50	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30.0	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments: E. Coli monitoring is new consistent with changes to Chapter 93 of the Department's regulations and Department policy.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	1/month	Grab
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	1/month	Grab
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/month	Grab
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/month	Grab
Net Total Nitrogen	XXX	152	XXX	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	24	XXX	XXX	XXX	XXX	1/year	Calculation


Compliance Sampling Location: Outfall 001

The above Chesapeake Bay limits and monitoring is unchanged.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 8/23/13;
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Model



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10D	19094	LIME STONE RUN	0.850	575.40	0.70	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.125	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Christ Wesleyan	PA0113093	0.0035	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10D	19094	LIME STONE RUN	0.000	562.30	1.08	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.125	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
10D		19094		LIME STONE RUN								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	WD Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.850	0.09	0.00	0.09	.0054	0.00292	.356	4.54	12.74	0.06	0.904	20.29	7.00
<b>Q1-10 Flow</b>												
0.850	0.06	0.00	0.06	.0054	0.00292	NA	NA	NA	0.05	1.140	20.44	7.00
<b>Q30-10 Flow</b>												
0.850	0.12	0.00	0.12	.0054	0.00292	NA	NA	NA	0.07	0.768	20.22	7.00

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
10D	19094	LIME STONE RUN	
<u>RMI</u>	<u>Total Discharge Flow(mgd)</u>	<u>Analysis Temperature (°C)</u>	
0.850	0.004	20.291	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
4.539	0.356	12.738	0.057
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
3.34	0.430	1.46	0.716
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
7.937	21.736	Owens	6
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>		
0.904	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.090	3.21	1.37
	0.181	3.09	1.28
	0.271	2.97	1.20
	0.362	2.85	1.12
	0.452	2.74	1.05
	0.543	2.64	0.99
	0.633	2.53	0.93
	0.723	2.44	0.87
	0.814	2.34	0.81
	0.904	2.25	0.76



### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
10D	19094	LIME STONE RUN

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.850	Christ Wesleyan	16.16	50	16.16	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.850	Christ Wesleyan	1.86	25	1.86	25	0	0

**Disolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.85	Christ Wesleyan	25	25	25	25	3	3	0	0

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
10D	19094	LIME STONE RUN

RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	E fl. Limit 30-day Ave. (mg/L)	E fl. Limit Maximum (mg/L)	E fl. Limit Minimum (mg/L)
0.850	Christ Wesleyan	PA0113093	0.004	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

TRC\_CALC

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.088	= Q stream (cfs)			0.5	= CV Daily
0.0035	= Q discharge (MGD)			0.5	= CV Hourly
30	= no. samples			1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream			1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge			15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value			720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)				= Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 5.204		1.3.2.iii	WLA_cfc = 5.066
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 1.939		5.1d	LTA_cfc = 2.945
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1) \cdot 0.5)$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1) \cdot 0.5)$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1) \cdot 0.5) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * (av_mon_limit / AML_MULT) / LTAMULT_afc				