

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

 Application No. PA0113140
 APS ID 1126787
 Authorization ID 1508388

 NPDES PERMIT FACT SHEET
 INDIVIDUAL SEWAGE

Applicant and Facility Information

Applicant Name	Kress Holdings & Land Development, LLC	Facility Name	Hillside View MHP WWTP
Applicant Address	356 Roscoe Drive	Facility Address	15540 Route 6
	Gillett, PA 16925-9700		Mansfield, PA 16933
Applicant Contact	Daniel Kress	Facility Contact	Daniel Kress
Applicant Phone	(607) 426-3130	Facility Phone	(607) 426-3130
Client ID	294707	Site ID	3060
Ch 94 Load Status	Not Overloaded	Municipality	Richmond Township
Connection Status	No Limitations	County	Tioga
Date Application Received	<u>December 2, 2024</u>	EPA Waived?	Yes
Date Application Accepted	<u>December 4, 2024</u>	If No, Reason	
Purpose of Application	<u>Renewal of a NPDES Permit</u>		



Summary of Review

The subject sewage treatment plant discharge serves Hillside View MHP in Richmond Township, Tioga County.

Sludge use and disposal description and location(s): The facility's wasted sludge is transferred to other WWTPs for further processing.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		 Keith C. Allison / Project Manager	May 7, 2025
✓		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	May 7, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	0.026
Latitude	41° 47' 5.10"	Longitude	-77° 8' 6.96"
Quad Name	Crooked Creek, PA	Quad Code	0428
Wastewater Description:	Sewage Effluent		

Receiving Waters	Unnamed Tributary to North Elk Run (CWF, MF)	Stream Code	31365
NHD Com ID	57352117	RMI	1.12
Drainage Area	1.48 mi ²	Yield (cfs/mi ²)	0.0614
Q ₇₋₁₀ Flow (cfs)	0.091	Q ₇₋₁₀ Basis	Gage No. 1516350, Tioga River near Mansfield
Elevation (ft)	1414	Slope (ft/ft)	0.01693
Watershed No.	4-A	Chapter 93 Class.	CWF, MF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Attaining Use(s)		

Nearest Downstream Public Water Supply Intake	PA-NY Border		
PWS Waters	Tioga River	Flow at Intake (cfs)	28.8
PWS RMI	13	Distance from Outfall (mi)	29.2

Changes Since Last Permit Issuance: None. The above stream and drainage characteristics from previous reviews remain appropriate.

Other Comments: The Department considers the PA-NY border as public water intake where there is no nearer intake. No downstream water supply is expected to be affected by the discharge with the limitations and monitoring proposed.

Treatment Facility Summary				
Treatment Facility Name: Hillside View MHP				
WQM Permit No.	Issuance Date		Permit Coverage:	
5973404	9/28/1973		Original construction.	
5973404 T-1	8/26/1986		Transfer	
5973404 T-2	11/19/2008		Transfer	
5973404 T-3	10/11/2016		Transfer from Hillside View, LLC to Kress Holdings & Land Development, LLC.	
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration With Solids Removal	Hypochlorite	0.026
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.026	35.7	Not Overloaded	Holding Tank	Land Application

Changes Since Last Permit Issuance: None.

Other Comments: The treatment as permitted under WQM Permit 5973404 consists of comminutor, influent bar screen, one aeration tank, two sand filters, one clarifier, erosion chlorinator, chlorine contact tank, and sludge holding tank.

Compliance History

DMR Data for Outfall 001 (from April 1, 2024 to March 31, 2025)

Parameter	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24
Flow (MGD) Average Monthly	0.006	0.008	0.005	0.005	0.002	0.002	0.002	0.011	0.009	0.009	0.006	0.007
pH (S.U.) Instantaneous Minimum	7.5	7.6	7.6	7.6	7.5	7.7	7.6	7.0	7.6	7.5	7.6	7.3
pH (S.U.) Instantaneous Maximum	8.0	8.0	8.0	8.0	8.1	8.0	8.0	8.0	7.9	7.9	7.9	7.9
DO (mg/L) Minimum	7.4	7.6	6.8	6.8	6.8	8.2	6.7	7.4	6.9	6.2	6.0	6.1
TRC (mg/L) Average Monthly	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.3	0.30	0.3	0.2
TRC (mg/L) Instantaneous Maximum	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.38	0.3	0.3
CBOD5 (mg/L) Average Monthly	13.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 9.0	< 3.0	< 3.0	< 3.0
TSS (mg/L) Average Monthly	11.0	8.0	9.0	3.0	7.0	17.0	< 8.0	< 2.0	3.0	< 2.0	12.0	< 6.0
Fecal Coliform (No./100 ml) Geometric Mean	790	628	2	< 23	4	10	45	70	80	49	5	14
Fecal Coliform (No./100 ml) Instantaneous Maximum	2420	2420	3	517	4	16	1011	2419.6	579	1203	5	197
Ammonia (mg/L) Average Monthly	8.6	< 0.1	< 0.1	0.6	< 0.2	< 0.1	< 0.1	< 0.1325	< 0.3	< 0.3	0.3	1.3

Compliance History

Effluent Violations for Outfall 001, from: April 1, 2024 to March 31, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TSS	10/31/24	Avg Mo	31.6	mg/L	30.0	mg/L
Fecal Coliform	08/31/24	IMAX	2419.6	No./100 ml	1000	No./100 ml
Fecal Coliform	08/31/24	IMAX	2419.6	No./100 ml	1000	No./100 ml
Fecal Coliform	09/30/24	IMAX	1011	No./100 ml	1000	No./100 ml
Fecal Coliform	08/31/24	IMAX	2419.6	No./100 ml	1000	No./100 ml
Fecal Coliform	09/30/24	IMAX	1011	No./100 ml	1000	No./100 ml
Fecal Coliform	09/30/24	IMAX	1011	No./100 ml	1000	No./100 ml
Fecal Coliform	06/30/24	IMAX	1203	No./100 ml	1000	No./100 ml
Fecal Coliform	08/31/24	IMAX	2419.6	No./100 ml	1000	No./100 ml

Compliance History, Cont'd

Summary of Inspections:	The most recent inspection by the Department on May 3, 2024, noted no violations at the time of inspection. See Attachment B.
Other Comments:	A query in WMS found multiple open violations for Kress Holdings & Land Development, LLC in eFACTS as listed in the attached table.

Existing Effluent Limitations and Monitoring Requirements								
Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Weir
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	5/week	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	2/month	Grab
TRC	XXX	XXX	XXX	0.3	XXX	1.0	5/week	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15.0	XXX	30	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5.0	XXX	10	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	0.026
Latitude	41° 47' 5.06"	Longitude	-77° 8' 8.52"
Wastewater Description: Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD5	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and included in the existing permit except for a more stringent water quality-based limit for TRC as noted below.

Water Quality-Based Limitations

CBOD5, DO, and NH3-N

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N.

The discharge has existing water quality-based limits for NH₃-N and DO as listed on the previous page.

WQM7.0 modeling was performed for the discharge to the Unnamed Tributary to North Elk Run and showed that the secondary treatment limits listed above for CBOD5 and the existing limits for NH3-N and DO are adequate to protect the receiving waters. See Attachment C.

TRC

The Department uses a modeling spreadsheet to determine necessary WQBELs for TRC toxicity based on instream dilution. The attached modeling results (See attachment D) show that the existing average monthly limit of 0.3 mg/l and a slightly more stringent Instantaneous Maximum limit of 0.9 mg/L are adequate to protect the receiving stream.

Toxics Management

No further "Reasonable Potential Analysis" was performed to determine additional toxic parameters as candidates for limitations for this 0.026 MGD sewage treatment facility receiving no industrial influent.

Chesapeake Bay Requirements

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. The Hillside View MHP treatment plant is considered an existing Phase 5, insignificant Chesapeake Bay discharger per the Phase III Watershed Implementation Plan (WIP) and thus has not received Cap Loads. Monitoring under the current permit found the Total Nitrogen and Total Phosphorus to average <18.6 and 1.7 mg/L, respectively. Because the current nutrient load from the discharge has adequately been characterized no further nutrient monitoring will be required at this time.

e. Coli

Annual e. coli monitoring will be required at this time due to recent changes to Chapter 93 of the Departments regulations and Department policy.

Best Professional Judgment (BPJ) Limitations

No additional BPJ limits are needed beyond the water quality and technology-based limits noted above.

Anti-Backsliding

No water quality based or BPJ limits were made less stringent consistent with the anti-backsliding requirements of 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/day	Weir
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.3	XXX	0.9	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15.0	XXX	30	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5.0	XXX	10	2/month	8-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XX	1/year	Grab


Compliance Sampling Location: Outfall 001

Other Comments: The TRC IMax has become more stringent from 1.0 to 0.9 mg/L and Total Nitrogen and Total Phosphorus have been removed as mentioned above. E. Coli monitoring is new as also mentioned above. Consistent with the recommendations of the NPDES Permit Writer's Manual the Monitoring frequencies for Flow, pH, DO, and TRC have increased to daily.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment C)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment D)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Attachments:

- Discharge Location Map
- List of Open Violations for Kress Holdings & Land Development, LLC
- WQM7.0 Model
- TRC Model



Open Violations for Kress Holdings & Land Development, LLC

FACILITY	PF KIND	INSP PROGRAM	PROGRAM	VIOLATION		PF INSPECTOR
			SPECIFIC ID	DATE	VIOLATION	
HILLSIDE VIEW MHP	Community	Safe Drinking Water	2590013	12/20/2021	FAILURE OF AN OWNER TO SUBMIT ANNUAL OPERATOR CERTIFICATION SYSTEM FEE	BLANEY,ROBERT
HILLSIDE VIEW MHP	Community	Safe Drinking Water	2590013	12/16/2022	FAILURE OF AN OWNER TO SUBMIT ANNUAL OPERATOR CERTIFICATION SYSTEM FEE	BLANEY,ROBERT
HILLSIDE VIEW MHP	Community	Safe Drinking Water	2590013	12/19/2023	FAILURE OF AN OWNER TO SUBMIT ANNUAL OPERATOR CERTIFICATION SYSTEM FEE	BLANEY,ROBERT
HILLSIDE VIEW MHP	Community	Safe Drinking Water	2590013	1/23/2025	FAILURE OF AN OWNER TO SUBMIT ANNUAL OPERATOR CERTIFICATION SYSTEM FEE	BLANEY,ROBERT
HILLSIDE VIEW MHP	Sewage Non-Publicly Owned (Non-Muni)	WPC NPDES	PA0113140	3/26/2021	CERTIFICATION SYSTEM FEE	CROUTHAMEL,AUSTIN
HILLSIDE VIEW MHP	Sewage Non-Publicly Owned (Non-Muni)	WPC NPDES	PA0113140	8/31/2021	NPDES - Failure to pay annual fee	CROUTHAMEL,AUSTIN
HILLSIDE VIEW MHP	Sewage Non-Publicly Owned (Non-Muni)	WPC NPDES	PA0113140	6/7/2022	NPDES - Failure to pay annual fee	CROUTHAMEL,AUSTIN
HILLSIDE VIEW MHP	Sewage Non-Publicly Owned (Non-Muni)	WPC NPDES	PA0113140	9/6/2023	NPDES - Failure to pay annual fee	CROUTHAMEL,AUSTIN
HILLSIDE VIEW MHP	Sewage Non-Publicly Owned (Non-Muni)	WPC NPDES	PA0113140	9/5/2024	NPDES - Failure to pay annual fee Operator Certification - Failure to	CROUTHAMEL,AUSTIN
HILLSIDE VIEW MHP	Sewage Non-Publicly Owned (Non-Muni)	WPC NPDES	PA0113140	1/9/2025	submit annual system fee	CROUTHAMEL,AUSTIN

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	31365	Trib 31365 to North Elk Run			1.120	1420.00	1.49	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
Discharge Data										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Hillside View	PA0113140	0.0260	0.0000	0.0000	0.000	25.00	7.00		
Parameter Data										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	5.00	8.24	0.00	0.00					
	NH3-N	5.00	0.00	0.00	0.70					

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	31365	Trib 31365 to North Elk Run			0.001	1320.00	2.56	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
Discharge Data										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			0.0000	0.0000	0.0000	0.000	25.00	7.00		
Parameter Data										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		3.00	8.24	0.00	0.00				
	NH3-N		25.00	0.00	0.00	0.70				

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
04A			31365			Trib 31365 to North Elk Run						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
1.120	0.09	0.00	0.09	.0402	0.01693	.365	5.27	14.41	0.07	0.999	21.53	7.00
Q1-10 Flow												
1.120	0.06	0.00	0.06	.0402	0.01693	NA	NA	NA	0.06	1.174	22.04	7.00
Q30-10 Flow												
1.120	0.12	0.00	0.12	.0402	0.01693	NA	NA	NA	0.08	0.882	21.22	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
04A	31365	Trib 31365 to North Elk Run		
<u>RMI</u> 1.120	<u>Total Discharge Flow (mgd)</u> 0.026	<u>Analysis Temperature (°C)</u> 21.527	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 5.267	<u>Reach Depth (ft)</u> 0.365	<u>Reach WDRatio</u> 14.411	<u>Reach Velocity (fps)</u> 0.068	
<u>Reach CBOD5 (mg/L)</u> 9.02	<u>Reach Kc (1/days)</u> 1.053	<u>Reach NH3-N (mg/L)</u> 1.53	<u>Reach Kn (1/days)</u> 0.787	
<u>Reach DO (mg/L)</u> 7.253	<u>Reach Kr (1/days)</u> 24.020	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.999	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.100	8.06	1.41	8.01
	0.200	7.20	1.30	8.01
	0.300	6.43	1.21	8.01
	0.400	5.75	1.11	8.01
	0.500	5.13	1.03	8.01
	0.600	4.58	0.95	8.01
	0.700	4.09	0.88	8.01
	0.799	3.66	0.81	8.01
	0.899	3.27	0.75	8.01
	0.999	2.92	0.70	8.01

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>						
04A	31365	Trib 31365 to North Elk Run							
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
	1.120 Hillside View	14.16	10	14.16	10	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
	1.120 Hillside View	1.74	5	1.74	5	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
	1.12 Hillside View	25	25	5	5	5	5	0	0

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
04A	31365	Trib 31365 to North Elk Run					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.120	Hillside View	PA0113140	0.026	CBOD5	25		
				NH3-N	5	10	
				Dissolved Oxygen			5

TRC_CALC

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.091	= Q stream (cfs)		0.5	= CV Daily	
0.026	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.3	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
Source	Reference	AFC Calculations	Reference	CFC Calculations	
TRC	1.3.2.iii	WLA_afc = 0.741	1.3.2.iii	WLA_cfc = 0.715	
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
PENTOXSD TRG	5.1b	LTA_afc = 0.276	5.1d	LTA_cfc = 0.415	
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.300		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 0.981			
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_afc	$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$				
LTA_afc	wla_afc*LTAMULT_afc				
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_cfc	$\text{EXP}((0.5*\text{LN}(cvd^2/no_samples+1))-2.326*\text{LN}(cvd^2/no_samples+1)^0.5)$				
LTA_cfc	wla_cfc*LTAMULT_cfc				
AML MULT	$\text{EXP}(2.326*\text{LN}(cvd^2/no_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no_samples+1))$				
AVG MON LIMIT	$\text{MIN}(\text{BAT_BPJ},\text{MIN}(\text{LTA_afc},\text{LTA_cfc})*\text{AML_MULT})$				
INST MAX LIMIT	$1.5*((\text{av_mon_limit}/\text{AML_MULT})/\text{LTAMULT_afc})$				