

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0113484  
 APS ID 1128412  
 Authorization ID 1511445

**Applicant and Facility Information**

Applicant Name	<b>Robinson, William E., Jr</b>	Facility Name	<b>Robinson Home Park Development</b>
Applicant Address	16064 Route 6	Facility Address	16064 Route 6
Applicant Contact	Mansfield, PA 16933-9199	Facility Contact	Mansfield, PA 16933-9199
Applicant Phone	William Robinson	Facility Phone	Patrick Crowley
Client ID	570.659.5301	Site ID	570.439.0731
Ch 94 Load Status	36256	Municipality	262189
Connection Status	Not Overloaded	County	Richmond Township
Date Application Received	<u>January 6, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 15, 2025</u>	If No, Reason	
Purpose of Application	<u>Renewal of a NPDES Permit</u>		



**Summary of Review**

The subject facility is a Mobile Home Park in Richmond Township, Tioga County. A map of the discharge location is attached.

Sludge use and disposal description and location(s): The facility's wasted sludge is disposed by landfill.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		 Keith C. Allison / Project Manager	June 25, 2025
✓		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	June 25, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0078
Latitude	41° 46' 58.59"	Longitude	-77° 7' 41.54"
Quad Name	Crooked Creek, PA	Quad Code	0428
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to North Elk Run (CWF)	Stream Code	31365
NHD Com ID	57352117	RMI	1.02 (@ Discharge) 0.84 (@POFU)
Drainage Area	0.0933 mi <sup>2</sup> (@ Discharge) 1.91 mi <sup>2</sup> (@POFU)	Yield (cfs/mi <sup>2</sup> )	0.0614
Q <sub>7-10</sub> Flow (cfs)	0.0057 (@ Discharge) 0.117 (@POFU)	Q <sub>7-10</sub> Basis	Gage No. 1516350, Tioga River near Mansfield
Elevation (ft)	1540 (@ Discharge) 1405 (@POFU)	Slope (ft/ft)	0.0263
Watershed No.	4-A	Chapter 93 Class.	CWF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Attaining Use(s)		
Nearest Downstream Public Water Supply Intake		PA/NY State Line	
PWS Waters	Tioga River	Distance from Outfall (mi)	Approx. 25

Changes Since Last Permit Issuance: The drainage characteristics above have been updated. Drainage areas were determined using the USGS StreamStats web application.

Discharge is to a dry stream draining to an unnamed tributary to North Elk Run. The assumed point of first use (POFU) is the discharge into the unnamed tributary to North Elk Run, Stream Code 31365

Other Comments: No downstream water supply is expected to affect any downstream water supply at this time with the limits and monitoring proposed.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Robinsons MHP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
5975401		T-1 - 3/31/87		
		Original – 11/19/74		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	No Disinfection	0.0078
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0078	18	Not Overloaded	Holding	Landfill

Changes Since Last Permit Issuance: None

Other Comments: The treatment as permitted under WQM Permit No. 5975401 consists of comminutor, bar screen, aeration, clarifier, sand filter, tablet chlorinator, chlorine contact tank, and sludge holding.

Compliance History

DMR Data for Outfall 001 (from May 1, 2024 to April 30, 2025)

Parameter	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24
Flow (MGD) Average Monthly	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.002	0.001	0.001	0.001
Flow (MGD) Daily Maximum	0.001	0.002	0.001	0.002	0.002	0.001	0.001	0.003	0.005	0.002	0.001	0.007
pH (S.U.) Instantaneous Minimum	7.6	7.5	7.5	7.6	7.6	7.7	7.6	7.6	7.6	7.6	7.4	7.5
pH (S.U.) Instantaneous Maximum	8.0	8.0	8.3	8.0	8.1	8.2	8.2	8.0	7.9	7.9	7.8	7.8
TRC (mg/L) Average Monthly	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2
TRC (mg/L) Daily Maximum	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.3
CBOD5 (mg/L) Average Monthly	21	< 7	< 3.0	< 3	< 3	< 3	< 3	< 3	< 3	< 4	< 3	< 3.0
TSS (mg/L) Average Monthly	10	< 8	< 2	3	< 2	< 2	3	2	< 2	3	17	6
Fecal Coliform (No./100 ml) Geometric Mean	14	< 1	< 1	< 1	1	< 1	< 1	< 1	< 19	3	< 1	4
Fecal Coliform (No./100 ml) Instantaneous Maximum	102	< 1	< 1	< 1	1	1	< 1	2	2	4	1	6
Ammonia (mg/L) Average Monthly	12	2	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	2	< 1

Compliance History

Summary of Inspections:	The most recent inspection of the facility by the Department on May 2, 2024 noted no violations at the time of inspection. Inspections have noted no problems in the receiving waters.
Other Comments:	A query in WMS found no open violations in eFACTS for the permittee.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
TRC	XXX	XXX	XXX	0.5	1.6 Daily Max	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15	XXX	30	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5	XXX	10	2/month	8-Hr Composite

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	0.0078	
Latitude	41° 47' 34.30"	Longitude	-77° 7' 31.50"	
Wastewater Description:	Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limits are applicable and are included in the existing permit.

### Water Quality-Based Limitations

#### DO, CBOD<sub>5</sub> and NH<sub>3</sub>-N

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. The discharge has an existing water quality-based NH<sub>3</sub>-N limitation of 5 mg/L. WQM7.0 modeling was performed (see Attachment B) for the discharge in two reaches for the dry stream and then the unnamed tributary to Elk Run. The results verified that no limitations are necessary beyond the existing limits.

#### Total Residual Chlorine

The attached modeling shows that the technology-based limit of 0.5 mg/L is adequate to protect the receiving waters (See Attachment C).

#### Water Quality Toxics Management

No additional reasonable potential analysis has been performed to determine additional parameters for limitations or monitoring for this minor sewage treatment plant with no industrial flows.

#### Discharge to Intermittent/Dry Streams

Because the discharge is existing and there have been no noted effects on the dry stream directly receiving the discharge or the unnamed tributary to North Elk Run, the additional discharge requirements from the Department's *Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers* including the Advanced Treatment Requirements will not be required at this time.

#### Chesapeake Bay/Nutrient Requirements

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania to reduce the total nutrient load to the Bay and meet State of Maryland Water

Quality Standards. This facility is considered a Phase V, non-significant Chesapeake Bay discharger and as such no nutrient cap loadings have been established for the facility pursuant to the Phase III Watershed Implementation Plan. Nutrient data obtained for a previous permit term averaged 9.65 mg/L and 0.95 mg/L for Total Nitrogen and Total Phosphorus, respectively. Because the nutrient load from the facility has adequately been characterized no additional nutrient monitoring will be required at this time.

**Best Professional Judgment (BPJ) Limitations**

Comments: No additional BPJ limits are necessary at this time beyond the water quality and technology-based limits noted above.

**E. Coli**

Annual e. coli monitoring will be required at this time due to changes to Chapter 93 of the Department's regulations and Department policy.

**Anti-Backsliding**

No limitations in this proposed draft permit have been made less stringent consistent with the anti-backsliding requirements of the Clean Water Act and 40 CFR 122.44(l).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
TRC	XXX	XXX	XXX	0.5	1.6 Daily Max	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15	XXX	30	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5	XXX	10	2/month	8-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Dissolved Oxygen	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab


Compliance Sampling Location: Outfall 001

Other Comments: E. coli and dissolved oxygen monitoring are new as mentioned above.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Attachments:

- Discharge Location Map
- WQM7.0 Model
- TRC Model



# Google Earth

## Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	31366	Trib 31366 to North Elk Run	0.840	1540.00	0.09	0.00000	0.00	<input checked="" type="checkbox"/>

### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Robinson MHP	PA0113484	0.0078	0.0000	0.0000	0.000	25.00	7.00
<b>Parameter Data</b>							
Parameter Name							
		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		5.00	0.00	0.00	0.70		

## Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	31366	Trib 31366 to North Elk Run	0.010	1405.00	0.20	0.00000	0.00	<input checked="" type="checkbox"/>

### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	Stream pH	Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
<b>Parameter Data</b>							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
04A	31366	Trib 31366 to North Elk Run		
<u>RMI</u> 0.840	<u>Total Discharge Flow (mgd)</u> 0.008	<u>Analysis Temperature (°C)</u> 23.390	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 1.465	<u>Reach Depth (ft)</u> 0.282	<u>Reach WDRatio</u> 5.199	<u>Reach Velocity (fps)</u> 0.043	
<u>Reach CBOD5 (mg/L)</u> 17.60	<u>Reach Kc (1/days)</u> 1.337	<u>Reach NH3-N (mg/L)</u> 3.39	<u>Reach Kn (1/days)</u> 0.909	
<u>Reach DO (mg/L)</u> 4.688	<u>Reach Kr (1/days)</u> 29.818	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 1.176	<b>Subreach Results</b>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.118	14.64	3.05	6.90
	0.235	12.18	2.74	7.21
	0.353	10.14	2.46	7.42
	0.470	8.44	2.21	7.60
	0.588	7.02	1.99	7.75
	0.706	5.84	1.79	7.75
	0.823	4.86	1.60	7.75
	0.941	4.05	1.44	7.75
	1.058	3.37	1.30	7.75
	1.176	2.80	1.16	7.75

## Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	31365	Trib 31365 to North Elk Run	1.020	1405.00	1.91	0.00000	0.00	<input checked="" type="checkbox"/>

### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Robinson R2	Reach 2	0.0780	0.0000	0.0000	0.000	25.00	7.00
<b>Parameter Data</b>							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		2.80	2.00	0.00	1.50		
Dissolved Oxygen		7.75	8.24	0.00	0.00		
NH3-N		1.16	0.00	0.00	0.70		

## Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	31365	Trib 31365 to North Elk Run	0.840	1380.00	2.10	0.00000	0.00	<input checked="" type="checkbox"/>

### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
<b>Parameter Data</b>							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

## WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
04A			31365			Trib 31365 to North Elk Run						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
1.020	0.12	0.00	0.12	.1207	0.02630	.41	6.2	15.1	0.09	0.118	22.54	7.00
<b>Q1-10 Flow</b>												
1.020	0.08	0.00	0.08	.1207	0.02630	NA	NA	NA	0.08	0.131	23.08	7.00
<b>Q30-10 Flow</b>												
1.020	0.16	0.00	0.16	.1207	0.02630	NA	NA	NA	0.10	0.107	22.15	7.00

## **WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
04A	31365	Trib 31365 to North Elk Run		
<u>RMI</u> 1.020	<u>Total Discharge Flow (mgd)</u> 0.078	<u>Analysis Temperature (°C)</u> 22.536	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 6.197	<u>Reach Depth (ft)</u> 0.410	<u>Reach WDRatio</u> 15.105	<u>Reach Velocity (fps)</u> 0.094	
<u>Reach CBOD5 (mg/L)</u> 2.41	<u>Reach Kc (1/days)</u> 0.849	<u>Reach NH3-N (mg/L)</u> 0.59	<u>Reach Kn (1/days)</u> 0.851	
<u>Reach DO (mg/L)</u> 7.993	<u>Reach Kr (1/days)</u> 24.501	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.118	<b>Subreach Results</b>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.012	2.38	0.58	7.87
	0.024	2.35	0.58	7.87
	0.035	2.33	0.57	7.87
	0.047	2.30	0.57	7.87
	0.059	2.27	0.56	7.87
	0.071	2.25	0.55	7.87
	0.082	2.22	0.55	7.87
	0.094	2.20	0.54	7.87
	0.106	2.17	0.54	7.87
	0.118	2.15	0.53	7.87

## WQM 7.0 Wasteload Allocations

**SWP Basin**    **Stream Code**    **Stream Name**  
**04A**            **31365**            **Trib 31365 to North Elk Run**

---

### **NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.020	Robinson R2	12.98	2.32	12.98	2.32	0	0

### **NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.020	Robinson R2	1.64	1.16	1.64	1.16	0	0

### **Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.02	Robinson R2	2.8	2.8	1.16	1.16	7.75	7.75	0	0

## WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
04A		31365	Trib 31365 to North Elk Run				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.020	Robinson R2	Reach 2	0.078	CBOD5	2.8		
				NH3-N	1.16	2.32	
				Dissolved Oxygen			7.75

## TRC EVALUATION

Input appropriate values in A3:A9 and D3:D9

0.117	= Q stream (cfs)	0.5	= CV Daily
0.0078	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)
Source	Reference	AFC Calculations	Reference
TRC	1.3.2.iii	WLA_afc = 3.112	1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c
PENTOXSD TRG	5.1b	LTA_afc= 1.160	5.1d
Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635	
WLA_afc	(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)		
LTAMULT_afc	EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)		
LTA_afc	wla_afc*LTAMULT_afc		
WLA_cfc	(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc) )... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)		
LTAMULT_cfc	EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)		
LTA_cfc	wla_cfc*LTAMULT_cfc		
AML MULT	EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))		
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)		
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)		