

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0113956
APS ID 1024467
Authorization ID 1329146

Applicant and Facility Information

Applicant Name	<u>Locust Township Municipal Authority</u>	Facility Name	<u>Slabtown Wastewater Treatment Plant</u>
Applicant Address	<u>1223a Numidia Drive</u> <u>Catawissa, PA 17820-8632</u>	Facility Address	<u>E Lake Glory Road</u> <u>Catawissa, PA 17820</u>
Applicant Contact	<u>Susan Adam</u>	Facility Contact	<u>Thomas Runge</u>
Applicant Phone	<u>(570) 799-5710</u>	Facility Phone	<u>(570) 799-5710</u>
Client ID	<u>241299</u>	Site ID	<u>262380</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Locust Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Columbia</u>
Date Application Received	<u>October 1, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 14, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of an existing NPDES permit for the discharge of treated sewage.</u>		

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Derek S. Garner</i> Derek S. Garner / Project Manager	February 10, 2021
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	February 10, 2021

Discharge, Receiving Waters and Water Supply Information

Outfall No. 001 Design Flow (MGD) 0.01
 Latitude 40° 54' 22.33" Longitude -76° 24' 53.50"
 Quad Name Catawissa Quad Code 1134
 Wastewater Description: Sewage Effluent

Receiving Waters UNT of Roaring Creek Stream Code 27497
 NHD Com ID 65642311 RMI 0.12
 Drainage Area 3.01 Yield (cfs/mi²) 0.382
 Q₇₋₁₀ Flow (cfs) 1.15 Q₇₋₁₀ Basis Streamgage No. 01468500
 Elevation (ft) 750 Slope (ft/ft) n/a
 Watershed No. 5-E Chapter 93 Class. CWF
 Existing Use n/a Existing Use Qualifier n/a
 Exceptions to Use n/a Exceptions to Criteria n/a
 Assessment Status Attaining Use(s)
 Cause(s) of Impairment n/a
 Source(s) of Impairment n/a
 TMDL Status n/a Name n/a

Nearest Downstream Public Water Supply Intake Danville Municipal Water Authority
 PWS Waters Susquehanna River Flow at Intake (cfs) 1,120
 PWS RMI 138.06 Distance from Outfall (mi) 16.67

Treatment Facility Summary

The Slabtown Wastewater Treatment Plant has an annual average design flow and hydraulic capacity of 0.01 MGD. The organic capacity is 15 lbs/day. Treatment is provided by a Cromaglass sequencing batch reactor unit. Disinfection and dechlorination are provided by tablet feeders.

Digested sludge is hauled to another wastewater treatment plant, if necessary.

Compliance History

The following effluent violations occurred during the existing permit's term:

Noncompliance Date	Noncompliance Category	Parameter	Sample Value	Violation Condition	Permit Value	Units	SBC
8/24/2017	Concentration 3 Effluent Violation	Fecal Coliform	> 2420	>	1000	CFU/100 ml	IMAX
3/21/2018	Load 1 Effluent Violation	CBOD5	2.7	>	2.1	lbs/day	Avg Mo
3/21/2018	Load 1 Effluent Violation	TSS	2.7	>	2.5	lbs/day	Avg Mo

Since none of the above effluent violations are chronic or continuous, the compliance history should not impact the development of effluent limits.

There are no open violations associated with the permittee.

The facility was most recently inspected by DEP on March 12, 2020. All treatment units were operational and no impacts to the receiving stream were noted. No violations were identified during the inspection.

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 0.01
 Latitude 40° 54' 22.44" Longitude -76° 24' 53.27"
 Wastewater Description: Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

A “Reasonable Potential Analysis” was conducted in WQM 7.0 v1.0b (attached). The model indicates that, based on available data, water quality-based effluent limitations for CBOD₅, ammonia-n, and dissolved oxygen are not necessary.

TRC effluent limitations were evaluated using the TRC_CALC spreadsheet (attached). Due to a correction in the number of samples taken per month (20 samples, corrected from 30), a slightly more stringent instantaneous maximum limit of 1.5 mg/l is recommended. Since the permittee already dechlorinates the effluent, the new instantaneous maximum limit should not result in noncompliance.

Best Professional Judgment (BPJ) Limitations

DEP recommends the existing monitoring requirements for dissolved oxygen and ammonia-n remain in the permit to continue to help characterize the wastewater.

DEP also recommends that existing requirements for BOD₅ and TSS influent monitoring remain in the permit to continue to characterize the influent and help with Chapter 94 reporting requirements.

Chesapeake Bay Considerations

Per Phase 3 of Pennsylvania’s Chesapeake Bay Watershed Implementation Plan, the Slabtown Wastewater Treatment Plant is considered a Phase 5 facility (annual average design flow > 0.002 MGD and < 0.2 MGD). The WIP states that Phase 5 facilities that have completed at least two years of nutrient monitoring may have the monitoring requirements removed. Accordingly, DEP has proposed to remove the monitoring requirements for total nitrogen and total phosphorus. The summarized results are as follows:

Monitoring Period	Total N (mg/l)	Total P (mg/l)
2017	21.3	2.8
2018	< 1.7	0.5
2019	< 10	< 0.05
2020	5.325	1.74

Monitoring Frequencies

The existing permit established a 5/week monitoring frequency for pH, dissolved oxygen, and total residual chlorine; increases from 2/week. The 5/week frequency was a result of negotiations between DEP and Schlesinger & Kerstetter, LLP, acting on behalf of the Authority. Since there have been no effluent violations associated with these parameters under the increased monitoring frequency, DEP believes the existing frequencies are still appropriate.

Anti-Backsliding

No effluent limits have been proposed to be made less stringent. Monitoring requirements for total nitrogen and total phosphorus were removed per the Chesapeake Bay Watershed Implementation Plan's recommendations for Phase 5 facilities. Anti-backsliding is not applicable.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	5/week	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	5/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.5	5/week	Grab
CBOD5	2.1	3.3	XXX	25.0	40.0	50	2/month	Grab
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	Grab
TSS	2.5	3.8	XXX	30.0	45.0	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia	Report	Report	XXX	Report	Report	XXX	2/month	Grab

Compliance Sampling Location: Outfall 001

Locust Township - Slabtown Wastewater Treatment Plant

Region ID:
 Workspace ID:
 Clicked Point (Latitude, Longitude):
 Time:

PA
 PA20210209155215980000
 40.90620, -76.41487
 2021-02-09 10:52:35 -0500



Outfall 001 Drainage Area

Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	4.4617	degrees
BSLOPDRAW	Unadjusted basin slope, in degrees	4.6633	degrees
BSPDRPA20	Unadjusted basin slope, in degrees, from PA v1	4.8001	degrees
CARBON	Percentage of area of carbonate rock	0	percent
CENTROXA83	X coordinate of the centroid, in NAD_1983_Albers, meters	133640.242	meters
CENTROYA83	Basin centroid horizontal (y) location in NAD 1983 Albers	210601.859	meters
DRN	Drainage quality index from STATSGO	3	dimensionless
DRNAREA	Area that drains to a point on a stream	3.06	square miles
ELEV	Mean Basin Elevation	966	feet
ELEVMAX	Maximum basin elevation	1174	feet
FOREST	Percentage of area covered by forest	16.3012	percent
GLACIATED	Percentage of basin area that was historically covered by glaciers	0	percent
IMPNLCD01	Percentage of impervious area determined from NLCD 2001 impervious dataset	1.5543	percent
LC01DEV	Percentage of land-use from NLCD 2001 classes 21-24	11.0324	percent
LC11DEV	Percentage of developed (urban) land from NLCD 2011 classes 21-24	11.1044	percent
LC11IMP	Average percentage of impervious area determined from NLCD 2011 impervious dataset	1.5684	percent
LONG_OUT	Longitude of Basin Outlet	-76.414883	degrees
MAXTEMP	Mean annual maximum air temperature over basin area from PRISM 1971-2000 800-m grid	58.8	degrees F
OUTLETXA83	X coordinate of the outlet, in NAD_1983_Albers,meters	133525.566	meters
OUTLETYA83	Y coordinate of the outlet, in NAD_1983_Albers, meters	212852.4708	meters
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	4.4	feet

DFLOW Results

All available data from Apr 1, 1989 through Mar 31, 2019 are included in analysis.

Gage	Period	Days in Record	Zero/Missing	1B3	Percentile	Excur per 3 yr	1Q10	Percentile	Excur per 3 yr	1Qy Type	xQy	Percentile	Harmonic	Percentile
01468500 - Schuylkill River at Landingville, PA	1988/04/01 - 2019/04/01	11,322	0/0	49.5	0.24%	0.97	46.8	0.17%	0.77	1Q6	47.5	0.19%	1.67E+02	40.07%
Gage	Period	Days in Record	Zero/Missing	1B3	Percentile	Excur per 3 yr	7Q10	Percentile	Excur per 3 yr	7Qy Type	xQy	Percentile	Harmonic	Percentile
01468500 - Schuylkill River at Landingville, PA	1988/04/01 - 2019/04/01	11,322	0/0	49.5	0.24%	0.97	50.8	0.31%	0.97	7Q11	45.7	0.13%	1.67E+02	40.07%
Gage	Period	Days in Record	Zero/Missing	1B3	Percentile	Excur per 3 yr	30Q10	Percentile	Excur per 3 yr	30Qy Type	xQy	Percentile	Harmonic	Percentile
01468500 - Schuylkill River at Landingville, PA	1988/04/01 - 2019/04/01	11,322	0/0	49.5	0.24%	0.97	57.3	1.40%	3.29	30Q18	49.4	0.24%	1.67E+02	40.07%

Low-Flow (Q₇₋₁₀) Calculation

Facility: **Locust Twp Muni Auth Slabtown WWTP**

NPDES Permit No. **PA0113956**

Gage Information

Drainage Area: **133** mi²

Q₇₋₁₀: **50.8** cfs

LFY: **0.382** cfs/m

Outfall Information

Drainage Area: **3.01** mi²

Q₇₋₁₀: **1.15** cfs

Downstream Locations

RMI: **0**

Drainage Area: **3.06** mi²

Q₇₋₁₀: **1.169** cfs

RMI:

Drainage Area: mi²

Q₇₋₁₀: cfs

RMI:

Drainage Area: mi²

Q₇₋₁₀: cfs

RMI:

Drainage Area: mi²

Q₇₋₁₀: cfs

RMI:

Drainage Area: mi²

Q₇₋₁₀: cfs

RMI:

Drainage Area: mi²

Q₇₋₁₀: cfs

RMI:

Drainage Area: mi²

Q₇₋₁₀: cfs

RMI:

Drainage Area: mi²

Q₇₋₁₀: cfs

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05E	27497	Trib 27497 to Roaring Creek	0.120	750.00	3.01	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)	(ft)	(ft)	(°C)	(°C)	(°C)	(°C)	
Q7-10	0.382	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	6.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing	Permitted	Design	Reserve Factor	Disc Temp	Disc pH
		Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)		(°C)	
Slabtown WWTP	PA0113956	0.0100	0.0100	0.0100	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.10	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05E	27497	Trib 27497 to Roaring Creek	0.000	745.00	3.06	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
	Q7-10	0.382	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	6.50	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
05E		27497				Trib 27497 to Roaring Creek						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
0.120	1.15	0.00	1.15	.0155	0.00789	.512	12.21	23.87	0.19	0.039	20.07	6.50
Q1-10 Flow												
0.120	1.06	0.00	1.06	.0155	0.00789	NA	NA	NA	0.18	0.041	20.07	6.50
Q30-10 Flow												
0.120	1.30	0.00	1.30	.0155	0.00789	NA	NA	NA	0.20	0.037	20.06	6.50

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.92	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.13	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
05E	27497	Trib 27497 to Roaring Creek

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.120	Slabtown WWTP	11.9	50	11.9	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.120	Slabtown WWTP	2.56	25	2.56	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.12	Slabtown WWTP	25	25	25	25	3.1	3.1	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
05E	27497	Trib 27497 to Roaring Creek		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.120	0.010	20.066		6.504
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
12.210	0.512	23.866		0.187
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.31	0.211	0.33		0.704
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
8.175	14.010	Tsivoglou		5
<u>Reach Travel Time (days)</u>	Subreach Results			
0.039	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.004	2.30	0.33	8.22
	0.008	2.30	0.33	8.23
	0.012	2.30	0.33	8.23
	0.016	2.30	0.33	8.23
	0.020	2.30	0.33	8.23
	0.024	2.29	0.33	8.23
	0.028	2.29	0.33	8.23
	0.031	2.29	0.32	8.23
	0.035	2.29	0.32	8.23
	0.039	2.29	0.32	8.23

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
05E	27497	Trib 27497 to Roaring Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.120	Slabtown WWTP	PA0113956	0.010	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3.1

1A	B	C	D	E	F	G
2	TRC EVALUATION					
3	Input appropriate values in B4:B8 and E4:E7					
4	1.15	= Q stream (cfs)		0.5	= CV Daily	
5	0.01	= Q discharge (MGD)		0.5	= CV Hourly	
6	20	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	=Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 23.733	1.3.2.iii	WLA_cfc = 23.130	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 8.843	5.1d	LTA_cfc = 13.447	
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML_MULT = 1.288			
17	PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.500		BAT/BPJ	
18			INST_MAX_LIMIT (mg/l) = 1.563			
	WLA_afc	$(.019/e^{-k \cdot AFC_{tc}}) + [(AFC_{Yc} \cdot Q_s \cdot .019 / Q_d \cdot e^{-k \cdot AFC_{tc}}) \dots + X_d + (AFC_{Yc} \cdot Q_s \cdot X_s / Q_d)] \cdot (1 - FOS / 100)$				
	LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
	LTA_afc	wla_afc * LTAMULT_afc				
	WLA_cfc	$(.011/e^{-k \cdot CFC_{tc}}) + [(CFC_{Yc} \cdot Q_s \cdot .011 / Q_d \cdot e^{-k \cdot CFC_{tc}}) \dots + X_d + (CFC_{Yc} \cdot Q_s \cdot X_s / Q_d)] \cdot (1 - FOS / 100)$				
	LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
	LTA_cfc	wla_cfc * LTAMULT_cfc				
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
	AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
	INST_MAX_LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				