

Application Type Renewal
Facility Type Sewage
Major / Minor Minor

**NPDES PERMIT FACT SHEET
ADDENDUM No. 1**

Application No. PA0113956
APS ID 1024467
Authorization ID 1329146

Applicant and Facility Information

Applicant Name	<u>Locust Township Municipal Authority</u>	Facility Name	<u>Slabtown Wastewater Treatment Plant</u>
Applicant Address	<u>1223a Numidia Drive</u> <u>Catawissa, PA 17820-8632</u>	Facility Address	<u>E Lake Glory Road</u> <u>Catawissa, PA 17820</u>
Applicant Contact	<u>Susan Adam</u>	Facility Contact	<u>Thomas Runge</u>
Applicant Phone	<u>(570) 799-5710</u>	Facility Phone	<u>(570) 799-5710</u>
Client ID	<u>241299</u>	Site ID	<u>262380</u>
SIC Code	<u>4952</u>	Municipality	<u>Locust Township</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>	County	<u>Columbia</u>
Date Published in PA Bulletin	<u>February 27, 2021</u>	EPA Waived?	<u>Yes</u>
Comment Period End Date	<u>March 28, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for a renewal of an NPDES permit for discharge of treated sewage.</u>		

Internal Review and Recommendations

No comments were received from the permittee, public, or U.S. EPA.

Per an internal review of the permit, DEP has proposed to increase monitoring frequencies for pH, dissolved oxygen, and total residual chlorine from 5/week to 1/day.

Additionally, DEP has proposed an annual E. Coli monitoring requirement per the 2017 Triennial Review of Water Quality Standards, published in the PA Bulletin on July 11, 2020.

Based on the proposed increases to monitoring frequencies and the addition E. Coli sampling, DEP recommends that the permit is redrafted for an additional thirty day commenting period.

Approve	Return	Deny	Signatures	Date
X			<i>Derek S. Garner</i> Derek S. Garner / Project Manager	April 5, 2021
X			<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	April 5, 2021