

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0114081
 APS ID 1029892
 Authorization ID 1338699

Applicant and Facility Information

Applicant Name	<u>Orange Township, Columbia County</u>	Facility Name	<u>Woods Edge Estates STP</u>
Applicant Address	<u>2028 State Route 487</u> <u>Orangeville, PA 17859-9029</u>	Facility Address	<u>181 Draketown Road</u> <u>Bloomsburg, PA 17815-7708</u>
Applicant Contact	<u>Calvin Fox</u>	Facility Contact	<u>John Bauer, Operator</u>
Applicant Phone	<u>(570) 683-5836</u>	Facility Phone	<u>(570) 784-1653</u>
Client ID	<u>115590</u>	Site ID	<u>254209</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Orange Township</u>
Connection Status	<u>Dept. Imposed Connection Prohibitions</u>	County	<u>Columbia</u>
Date Application Received	<u>December 29, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 11, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit</u>		

Summary of Review

The subject permit is a Publicly Owned Treatment Works serving the Woods Edge subdivision in Orange Township, Columbia County.

A map of the discharge location is attached.

Sludge use and disposal description and location(s): The facility's sludge is transferred to other WWTPs for further processing.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	May 12, 2021
✓		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	May 13, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.021</u>
Latitude	<u>41° 2' 26.46"</u>	Longitude	<u>-76° 25' 38.85"</u>
Quad Name	<u>Bloomsburg, PA</u>	Quad Code	<u>1034</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Fishing Creek (WWF, MF)</u>	Stream Code	<u>27623 (Fishing Creek)</u>
NHD Com ID	<u>65639951</u>	RMI	<u>1.24 (UNT)</u>
Drainage Area	<u>0.0517 mi² (UNT)</u>	Yield (cfs/mi ²)	<u>7.9 (Fishing Creek)</u>
	<u>285 mi² (Fishing Creek)</u>		<u>0.0613</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.00317 (UNT)</u>	Q ₇₋₁₀ Basis	<u>USGS Gage 01539000, Fishing Creek @ Bloomsburg (1940-2008)</u>
Elevation (ft)	<u>17.5 (Fishing Creek)</u>	Slope (ft/ft)	<u>0.0454</u>
Watershed No.	<u>820</u>	Chapter 93 Class.	<u>WWF, MF</u>
Existing Use	<u>5-C</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>N/A</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>None</u>		
	<u>Attaining Use(s)</u>		
Nearest Downstream Public Water Supply Intake	<u>United Water Pennsylvania, Bloomsburg</u>		
PWS Waters	<u>Fishing Creek</u>	Distance from Outfall (mi)	<u>Approx. 6</u>

Changes Since Last Permit Issuance: None

Other Comments: The discharge is to a small stream that ultimately drains to Fishing Creek. An Aquatic Biological Investigation by the Department on May 6, 2014 found sufficient aquatic life in the Unnamed Tributary to consider it worthy of protection as a perennial stream. This assessment also found significant impact to the receiving waters below the discharge from the Woods Edge Estates treatment plant as compared to above the discharge. The stream degradation was still noticeable at a sample site approximately 0.8 miles below the discharge point. The presence of aquatic life in the receiving stream and the degradation to the stream will again be considered in the limits determination.

No downstream water supply is expected to be affected by this discharge with the monitoring and limitations proposed given the distance and ample dilution in Fishing Creek.

Treatment Facility Summary				
Treatment Facility Name: Woods Edge Estates				
WQM Permit No.	Issuance Date	Permit For:		
1988407	A-2 – 9/3/20	Installation of dechlorination and aeration		
	T-1 – 6/28/16	Transfer to Orange Township		
	A-1 – 6/11/93	Amended to modify language in special condition for connecting to municipal facilities		
	Original - 11/18/88	Original permit for treatment plant and sewer system		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration With Solids Removal	Hypochlorite	0.021
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.021	36.8	Not Overloaded		

Changes Since Last Permit Issuance: The WQM permit amendment issued in 2020 for the installation of a new two compartment chlorine contact tank. One compartment provides chlorine contact time and the other provides dechlorination utilizing a tablet feeder. Fine bubble diffusers were also installed to increase dissolved oxygen levels

Other Comments: The treatment facility is a package extended aeration plant followed by sand filters and consists of: bar screen, 21,000-gallon aeration tank, 4,300-gallon settling tank, siphon tank, two intermittent sand filters, erosion chlorinator, erosion dechlorinator, and two compartment chlorine contact tank.

Compliance History

DMR Data for Outfall 001 (from March 1, 2020 to February 28, 2021)

Parameter	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20
Flow (MGD) Average Monthly	0.0092	0.0106	0.0093	0.00978	0.0088	0.01	0.0131	0.0098	0.0084	0.0091	0.0088	0.0089
Flow (MGD) Daily Maximum	0.0159	0.0553	0.0062	0.0189	0.0127	0.07	0.0857	0.0312	0.0116	0.0137	0.0142	0.0104
pH (S.U.) Minimum	6.8	6.7	6.9	6.7	6.8	6.8	6.9	6.9	6.8	6.8	6.9	6.8
pH (S.U.) Maximum	7.3	7.3	7.2	7.1	7.3	7.3	7.4	7.3	7.4	7.3	7.3	7.2
DO (mg/L) Minimum	9.8	9.4	8.7	7.4	6.9	7.0	5.3	7.4	7.3	7.4	7.5	7.6
TRC (mg/L) Average Monthly	< 0.02	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	0.01	0.01	0.01	0.01	0.01
TRC (mg/L) Instantaneous Maximum	0.07	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
CBOD5 (lbs/day) Average Monthly	< 0.50	< 0.40	< 0.40	< 0.50	< 0.40	< 0.20	< 0.50	< 0.50	< 0.40	< 0.40	< 0.50	< 0.60
CBOD5 (mg/L) Average Monthly	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0
CBOD5 (mg/L) Instantaneous Maximum	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	9.0	28.0	5.0	10.0	8.0	6.0	23.0	21	9	21	12	18
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	9.0	39.0	6.0	13.0	13.0	6.0	37.0	21	10	27	17	18
BOD5 (mg/L) Raw Sewage Influent Average Monthly	109	385.0	65.0	113	136.0	86.0	302.0	280	138	297	150	187
TSS (lbs/day) Average Monthly	< 0.40	< 0.50	< 0.40	< 0.40	< 0.30	0.20	< 0.40	< 0.40	< 0.30	< 0.40	< 0.40	< 0.50
TSS (lbs/day) Raw Sewage Influent Average Monthly	8	27.0	5.0	11.0	6.0	9.0	19.0	12	3	13	7	9
TSS (lbs/day) Raw Sewage Influent Daily Maximum	10	42.0	6.0	19.0	6.0	10.0	27.0	13	6	15	7	10
TSS (mg/L) Average Monthly	< 5.0	< 7.0	< 5.0	< 5.0	< 5.0	5.0	< 5.0	< 5.0	< 5.0	< 5.1	< 5.0	< 5.0
TSS (mg/L) Raw Sewage Influent Average Monthly	97	367.0	62.0	131	92.0	140.0	250.0	155	46	180	89	99
TSS (mg/L) Instantaneous Maximum	< 5.0	8.3	< 5.0	< 5.0	< 5.0	5.0	< 5.0	< 5.0	< 5.0	5.2	< 5.0	< 5.0
Fecal Coliform (CFU/100 ml) Geometric Mean	< 2.0	< 4.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1	< 1	< 1	< 1	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	3.1	13.5	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1	< 1	< 1	< 1	< 1

**NPDES Permit Fact Sheet
Woods Edge Estates Clear Run STP**

NPDES Permit No. PA0114081

Ammonia (lbs/day) Average Monthly	0.10	< 0.020	1.00	0.30	0.02	0.02	0.03	< 0.02	< 0.30	< 0.04	< 0.20	0.20
Ammonia (mg/L) Average Monthly	1.2	< 0.30	11.6	3.0	0.4	0.3	0.3	< 0.2	< 4.08	< 0.52	2.716	1.678
Ammonia (mg/L) Instantaneous Maximum	1.65	< 0.40	21.0	3.68	0.423	0.493	0.373	< 0.2	7.77	0.83	4.44	2.91

Compliance History

Effluent Violations for Outfall 001, from: April 1, 2020 To: February 28, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
DO	09/30/20	Min	5.3	mg/L	6.0	mg/L
Ammonia	07/31/20	Avg Mo	< 0.30	lbs/day	0.28	lbs/day
Ammonia	01/31/21	Avg Mo	1.00	lbs/day	0.83	lbs/day
Ammonia	01/31/21	Avg Mo	11.6	mg/L	4.7	mg/L
Ammonia	07/31/20	Avg Mo	< 4.08	mg/L	1.6	mg/L
Ammonia	05/31/20	Avg Mo	2.716	mg/L	1.6	mg/L
Ammonia	05/31/20	IMAX	4.44	mg/L	3.2	mg/L
Ammonia	07/31/20	IMAX	7.77	mg/L	3.2	mg/L
Ammonia	01/31/21	IMAX	21.0	mg/L	9.5	mg/L

Compliance History

Summary of Inspections:	The facility has been inspected at least annually by the Department over the past permit term. The most recent inspection on January 29, 2021 identified NPDES effluent violations.
Other Comments:	A query in WMS found no open violations in eFACTS for Orange Township, Columbia County.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.02	XXX	0.07	1/day	Grab
CBOD5	1.75	XXX	XXX	10.0	XXX	20.0	2/month	Grab
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
TSS	1.75	XXX	XXX	10.0	XXX	20.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	0.83	XXX	XXX	4.7	XXX	9.5	2/month	Grab
Ammonia May 1 - Oct 31	0.28	XXX	XXX	1.6	XXX	3.2	2/week	Grab
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/year	Grab

Permit No. PA0114081

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.021</u>
Latitude <u>41° 3' 22.24"</u>	Longitude <u>-76° 24' 54.81"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The technology-based secondary treatment limits above for TSS and CBOD₅ are not as stringent as the facility's existing limits for the dry stream discharge as discussed below.

The TRC BAT limit from 92a applies to this facility. However, as noted below a more stringent water quality-based limitation has been applied to the discharge.

Water Quality-Based Limitations

The facility has existing limits of 10 mg/L for TSS and CBOD₅ to protect the receiving stream that were taken from the Department's Dry Stream's Guidance as well as existing water quality-based limits for NH₃-N and DO. These will be retained to address the minimal flow and potential nuisance conditions in the receiving stream with the exception of NH₃-N as noted below.

The WQM7.0 model allows the Department to evaluate point source discharges of Carbonaceous BOD (CBOD₅), ammonia-nitrogen (NH₃-N) and dissolved oxygen (DO) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. WQM7.0 modeling has been performed at this time which includes recent updates to the Department's NH₃-N criteria to address protection of the receiving stream. The results of the WQM7.0 modeling are attached (See Attachment B) showing the existing Ammonia-Nitrogen limit of 1.58 mg/L and Dissolved Oxygen limit of 6 mg/L are adequate.

The Department uses a spreadsheet to model the toxicity of Total Residual Chlorine in a receiving stream. Modeling of the unnamed tributary for the previous review produced a limit of 0.023 mg/L (See Attachment C).

Toxics Management

No further "Reasonable Potential Analysis" was performed to determine additional pollutants for monitoring or limitations for this minor municipal treatment plant with no industrial influent.

Best Professional Judgment (BPJ) Limitations

Comments: No BPJ limits are necessary beyond the technology and water quality-based limits noted above.

Permit No. PA0114081

Chesapeake Bay/Nutrient Requirements

According to the Pennsylvania Chesapeake Bay Tributary Implementation Plan for NPDES Permitting, this facility is considered an existing Phase 5 Chesapeake Bay sewage discharger. Under the previous permit annual monitoring was conducted and the average Total Nitrogen concentration for the past two years was 7.3 mg/L and the Total Phosphorus was 0.85 mg/L. Therefore, because the nutrient levels in the effluent have adequately been characterized no further nutrient monitoring will be required at this time.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.02	XXX	0.07	1/day	Grab
CBOD5	1.75	XXX	XXX	10.0	XXX	20.0	2/month	Grab
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
TSS	1.75	XXX	XXX	10.0	XXX	20.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	0.83	XXX	XXX	4.7	XXX	9.5	2/month	Grab
Ammonia May 1 - Oct 31	0.28	XXX	XXX	1.6	XXX	3.2	2/week	Grab
e. Coli Bacteria	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab



Compliance Sampling Location: Outfall 001

Other Comments: The above limitations and monitoring are unchanged from the existing permit except for the removal of nutrient as noted above. In addition, consistent with recent changes to Chapter 93 of the Department's regulations e. coli monitoring will be included in the permit at a frequency of once per quarter.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 3/22/21
<input type="checkbox"/>	Other: [redacted]

Attachments:

- Discharge Location Map
- WQM7.0 Model
- TRC Model



Permit No. PA0114081

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05C	27754	Trib 27754 to Fishing Creek	1,240	820.00	0.05	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Woods Edge	PA0114081	0.0210	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	10.00	2.00	0.00	1.50
Dissolved Oxygen	6.00	8.24	0.00	0.00
NH3-N	1.58	0.00	0.00	0.70

Permit No. PA0114081

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05C	27754	Trib 27754 to Fishing Creek	0.740	700.00	0.10	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.081	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

SWP Basin 05C **Stream Code** 27754 **Stream Name** Trib 27754 to Fishing Creek

RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Stream Flow (cfs)	Reach Analysis Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
1.240	0.00	0.00	0.00	.0325	0.04545	.34	1.39	4.09	0.08	0.408	24.57	7.00
Q1-10 Flow												
1.240	0.00	0.00	0.00	.0325	0.04545	NA	NA	NA	0.07	0.413	24.72	7.00
Q30-10 Flow												
1.240	0.00	0.00	0.00	.0325	0.04545	NA	NA	NA	0.08	0.399	24.43	7.00

Permit No. PA0114081

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
05C	27754	Trib 27754 to Fishing Creek

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.240	Woods Edge	11.34	3.16	11.34	3.16	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.240	Woods Edge	1.42	1.58	1.42	1.58	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.24	Woods Edge	10	10	1.58	1.58	6	6	0	0

Permit No. PA0114081

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
05C	27754	Trib 27754 to Fishing Creek		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
1.240	0.021	24.571		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
1.390	0.340	4.092		0.075
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
9.31	1.459	1.44		0.995
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
6.193	31.501	Owens		6
<u>Reach Travel Time (days)</u>				
0.408				
Subreach Results				
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.041	8.66	1.39	7.11
	0.081	8.05	1.33	7.42
	0.122	7.48	1.28	7.54
	0.162	6.95	1.23	7.59
	0.203	6.46	1.18	7.59
	0.244	6.01	1.13	7.59
	0.284	5.58	1.09	7.59
	0.325	5.19	1.05	7.59
	0.365	4.82	1.00	7.59
	0.406	4.48	0.96	7.59

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			<u>Eff. Limit 30-day Ave. (mg/L)</u>	<u>Eff. Limit Maximum (mg/L)</u>	<u>Eff. Limit Minimum (mg/L)</u>
05C	27754	Trib 27754 to Fishing Creek					
		<u>Permit Number</u>	<u>Disc Flow (mgd)</u>	<u>Parameter</u>			
1.240	Woods Edge	PA0114081	0.021	CBOD5	10		
				NH3-N	1.58	3.16	
				Dissolved Oxygen			6

Permit No. PA0114081

TRC EVALUATION						
Client			Date			
0.00317 = Q stream (cfs)			0.5 = CV Daily			
0.021 = Q discharge (MGD)			0.5 = CV Hourly			
30 = no. samples			0.972 = AFC_Partial Mix Factor			
0.3 = Chlorine Demand of Stream			1 = CFC_Partial Mix Factor			
0 = Chlorine Demand of Discharge			15 = AFC_Criteria Compliance Time (min)			
0.5 = BAT/BJ Value			720 = CFC_Criteria Compliance Time (min)			
= % Factor of Safety (FOS)			0 = Decay Coefficient (K)			
Source	Reference	AFC Calculations		Reference	CFC Calculations	
TRC	1.3.2.iii	WLA_afc = 0.049		1.3.2.iii	WLA_cfc = 0.041	
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581	
PENTOXSD TRG	5.1b	LTA_afc = 0.018		5.1d	LTA_cfc = 0.024	
		WQBEL_afc = 0.023			WQBEL_cfc = 0.030	
Source		Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231				
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.023		AFC		
		INST MAX LIMIT (mg/l) = 0.074				
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...]$ $...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$					
LTA_afc	wla_afc*LTAMULT_afc					
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...]$ $...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$					
LTA_cfc	wla_cfc*LTAMULT_cfc					
AML_MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$					
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)					
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)					