

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0114286
APS ID 1001474
Authorization ID 1288002

Applicant and Facility Information

Applicant Name	<u>New Albany Borough</u>	Facility Name	<u>New Albany Borough Sewer System STP</u>
Applicant Address	<u>PO Box 67</u> <u>New Albany, PA 18833-0067</u>	Facility Address	<u>401 Main Street</u> <u>New Albany, PA 18833</u>
Applicant Contact	<u>Rhonda McCarty, Secretary</u>	Facility Contact	<u>Shane Walker, Chief Operator</u>
Applicant Phone	<u>(570) 363-2300</u>	Facility Phone	<u>(570) 637-4302</u>
Client ID	<u>35452</u>	Site ID	<u>242240</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>New Albany Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Bradford</u>
Date Application Received	<u>September 10, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 12, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES permit</u>		

Summary of Review

This facility is a municipal wastewater treatment plant serving Albany Borough, Bradford County.

A map of the discharge location is attached.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Keith C. Allison / Project Manager	December 16, 2019
		Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.04</u>
Latitude	<u>41° 36' 23.45"</u>	Longitude	<u>-76° 26' 31.57"</u>
Quad Name	<u>Dushore, PA</u>	Quad Code	<u>0634</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>South Branch Towanda Creek (CWF, MF)</u>	Stream Code	<u>30251</u>
NHD Com ID	<u>66407625</u>	RMI	<u>8.5</u>
Drainage Area	<u>22.8</u>	Yield (cfs/mi ²)	<u>0.013</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.297</u>	Q ₇₋₁₀ Basis	<u>Gage 01532000, Towanda Creek near Monroeton, PA (1915-2008)</u>
Elevation (ft)	<u>1170</u>	Slope (ft/ft)	<u>0.00789</u>
Watershed No.	<u>4-C</u>	Chapter 93 Class.	<u>CWF, MF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Nearest Downstream Public Water Supply Intake	<u>Danville Municipal Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>6.5 MGD</u>
PWS RMI	<u>122.5</u>	Distance from Outfall (mi)	<u>Approx. 150</u>

Changes Since Last Permit Issuance: The above stream and discharge characteristics were determined in the previous review and remain adequate.

Other Comments: No downstream water supply is expected to be affected by the discharged with the limitations and monitoring proposed.

Treatment Facility Summary				
Treatment Facility Name: New Albany Borough Sewerage STP System				
WQM Permit No.	Issuance Date	Permit Approved:		
0889405	6/7/90	0.04 MGD treatment plant and associated sewers		
0893406	4/27/93	0.04 MGD Extended aeration treatment plant. A minor amendment approved in 2008 allowed the replacement of the existing tablet chlorinator with a liquid sodium hypochlorite feed. A minor amendment in 2019 approved the permanent use of a tablet dechlorinator.		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.04
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.04	80	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: The use of dechlorination is new since the last NPDES review.

Other Comments: The treatment facility, approved by WQM Permit No. 0893406, consists of a bar screen, influent tank, equalization tank with grinder pumps, three 16,000-gallon aeration tanks, one 8,750-gallon clarifier, tablet chlorinator, 1000-gallon chlorine contact tank, tablet dechlorination, and an 8,000-gallon aerated sludge holding tank. The permittee received three different WQM permit for different proposals for the treatment plant: 0889405, 0892403 and 0893406. Apparently, the option under 0893406 was constructed.

Hauled in Waste
Per the application, the permittee has not received any hauled in waste in the past three years and does not anticipate receiving any over the next permit term.

Sludge/Biosolids Disposal
The facility's sludge is sent to the Towanda Municipal Authority WWTP for further processing.

Compliance History

DMR Data for Outfall 001 (from November 1, 2018 to October 31, 2019)

Parameter	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18
Flow (MGD) Average Monthly	0.014	0.012	0.013	0.016	0.018	0.022	0.016	0.014	0.017	0.018	0.016	0.019
Flow (MGD) Daily Maximum	0.035	0.014	0.022	0.34	0.054	0.071	0.033	0.016	0.022	0.065	0.032	0.0227
pH (S.U.) Minimum	6.0	6.31	6.5	6.3	6.2	6.1	6.0	6.0	6.04	5.51	5.35	6.0
pH (S.U.) Maximum	6.75	7.29	7.1	6.75	8.05	7.0	6.93	6.8	6.77	7.17	7.02	7.08
DO (mg/L) Minimum	1.84	2.79	2.8	2.8	1.12	2.0	2.2	3.0	3.56	2.03	3.23	2.17
TRC (mg/L) Average Monthly	0.5	0.6	0.4	0.5	0.3	0.3	0.4	0.4	0.4	0.6	0.4	0.6
TRC (mg/L) Instantaneous Maximum	1.1	0.8	1.1	1.0	0.93	0.7	1.0	1.0	1.6	0.98	1.06	1.5
CBOD5 (lbs/day) Average Monthly	0.6	< 0.4	< 0.4	< 0.4	< 0.3	< 0.5	< 0.5	< 0.4	< 0.4	< 0.3	< 0.4	< 0.4
CBOD5 (lbs/day) Daily Maximum	0.8	0.5	< 0.4	< 0.4	< 0.4	< 0.6	0.6	< 0.4	< 0.4	< 0.4	< 0.4	< 0.4
CBOD5 (mg/L) Average Monthly	6	< 4	< 3	< 3	< 3	< 3	< 4	< 3.0	< 3	< 3	< 3	< 3
CBOD5 (mg/L) Daily Maximum	7.2	5	< 3	< 3	< 3	< 3	5	< 3.0	< 3	< 3	< 3	< 3
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	34	45	50	36	38	35	30	35	33	35	32	28
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	38	59	63	40	49	42	31	39	34	38	35	34
BOD5 (mg/L) Raw Sewage Influent Average Monthly	314	428	391	294	342	226	266	293	266	315	248	195
TSS (lbs/day) Average Monthly	0.9	< 0.3	0.4	0.5	0.5	< 1	0.7	1	< 0.2	< 0.3	0.3	< 0.5
TSS (lbs/day) Raw Sewage Influent Average Monthly	21	33	42	41	93	29	21	37	19	17	39	20

**NPDES Permit Fact Sheet
New Albany Borough Sewer System STP**

NPDES Permit No. PA0114286

TSS (lbs/day) Daily Maximum	1	0.6	0.5	0.6	0.7	2	0.7	1	0.2	0.5	0.3	0.8
TSS (lbs/day) Raw Sewage Influent Daily Maximum	22	48	68	55	115	36	21	64	20	18	60	28
TSS (mg/L) Average Monthly	8	< 3	3	4	5	< 4	6	12	< 2	< 2	2	< 4
TSS (mg/L) Raw Sewage Influent Average Monthly	199	310	313	350	912	186	190	314	150	155	310	138
TSS (mg/L) Daily Maximum	9	5.2	4	4.4	8	7	7	12.4	2	4	2.4	5.6
Fecal Coliform (No./100 ml) Geometric Mean	3	< 1	< 1	7	1	86	< 1	2	< 30	< 2	5	47
Fecal Coliform (No./100 ml) Instantaneous Maximum	8.5	< 1	1	25	1	157	< 1	< 4	875	3.1	5.2	1120
Total Nitrogen (lbs/day) Average Monthly											0.68	
Total Nitrogen (mg/L) Average Monthly											6.3	
Ammonia (lbs/day) Average Monthly	0.05	0.08	0.06	0.06	0.07	< 0.05	< 0.1	0.03	< 0.02	0.04	0.05	0.03
Ammonia (lbs/day) Daily Maximum	0.06	0.1	0.07	0.07	0.07	0.1	0.2	0.04	0.02	0.05	0.06	0.03
Ammonia (mg/L) Average Monthly	0.5	0.8	0.5	0.5	0.6	< 0.3	< 1.3	0.2	< 0.1	0.3	0.4	0.2
Ammonia (mg/L) Daily Maximum	0.6	1	0.5	0.6	0.73	0.4	2	0.33	0.176	0.42	0.5	0.228
Total Phosphorus (lbs/day) Average Monthly											0.32	
Total Phosphorus (mg/L) Average Monthly											2.99	

Compliance History, Cont'd

Effluent Violations for Outfall 001, from: November 1, 2018 To: October 31, 2019

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
pH	12/31/18	Min	5.35	S.U.	6.0	S.U.
pH	01/31/19	Min	5.51	S.U.	6.0	S.U.
TRC	09/30/19	Avg Mo	0.6	mg/L	0.5	mg/L
TRC	01/31/19	Avg Mo	0.6	mg/L	0.5	mg/L
TRC	02/28/19	IMAX	1.64	mg/L	1.6	mg/L
TRC	11/30/18	IMAX	0.6	mg/L	0.5	mg/L

Compliance History, Cont'd

Summary of Inspections:	The facility has been inspected approximately annually over the past permit term. The most recent inspection on June 26, 2019 by Stephen Puzio, WQS, identified effluent violations but no operational violations were noted at the time of inspection.
Other Comments:	A query in WMS found the following open violation in eFACTS for New Albany Borough from the Safe Drinking Water Program.

New Albany Borough Open Violations:

CLIENT ID	CLIENT	PF ID	FACILITY	PF KIND	INSP PROGRAM	PROGRAM SPECIFIC ID	VIOLATION ID	VIOLATION DATE	VIOLATION
35452	NEW ALBANY BORO BRADFORD CNTY	275369	NEW ALBANY WATER FUND	Community	Safe Drinking Water	2080010	865384	10/17/2019	FAILURE TO SUBMIT OR REVISE A COMPREHENSIVE MONITORING PLAN

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	8.3	13	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	10	15	XXX	30	45	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/year	8-Hr Composite
Ammonia Nov 1 - Apr 30	Report	Report	XXX	Report	Report	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	4.5	6.7	XXX	13.5	20	27	2/month	8-Hr Composite
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/year	8-Hr Composite

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.04</u>
Latitude <u>41° 36' 16.20"</u>	Longitude <u>-76° 26' 26.70"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable, are included in the existing permit, and will remain.

Water Quality-Based Limitations

CBOD₅, NH₃-N & DO

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. WQM7.0 modeling was performed at this time (see Attachment B) for the discharge to South Branch Towanda Creek and indicated that the existing limits for CBOD₅ and NH₃-N are adequate to protect the receiving stream.

Total Residual Chlorine

The Department uses a modeling spreadsheet to determine necessary WQBELs for TRC based on chlorine toxicity and available instream dilution. The attached modeling results (see attachment C) show that the BAT limit of 0.5 mg/l is adequate to protect the receiving stream.

Toxics Management

No further "Reasonable Potential Analysis" was conducted for this minor sewage treatment facility with no significant industrial users to determine additional parameters as candidates for limitations or monitoring.

Chesapeake Bay/Nutrient Requirements

According to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is an existing Phase 5 Chesapeake Bay sewage discharger that is not expanding, and as such requires no nutrient loading limits. The monitoring for the past permit term found the average Total Nitrogen concentration and loading to be 14.6 mg/L and 1.8 pounds per day and the average Total Phosphorus concentration and loading to be 3.7 mg/L and 0.48 pounds per day. Therefore, because the level of these nutrients in the discharge have been characterized no additional monitoring for TN and TP will be required at this time.

Best Professional Judgment (BPJ) Limitations

Comments: No additional BPJ limitations are necessary beyond the technology and water quality-based limitations noted above.

Anti-Backsliding

No limitations have been made less stringent consistent with the anti-degradation requirements of the Clean Water Act and 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	8.3	13	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	10	15	XXX	30	45	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	Report	Report	XXX	Report	Report	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	4.5	6.7	XXX	13.5	20	27	2/month	8-Hr Composite


Compliance Sampling Location: Outfall 001

Other Comments: The above limitations and monitoring requirements are unchanged from the existing permit except for the removal of monitoring for total nitrogen and total phosphorus as mentioned above.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 8/23/13
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Model



Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04C	30251	SOUTH BRANCH TOWANDA CREE	8.500	1170.00	22.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.013	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
New Albany	PA0114286	0.0400	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	13.50	0.00	0.00	0.70

Permit No. PA0114286

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04C	30251	SOUTH BRANCH TOWANDA CREE	7.780	1140.00	25.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.013	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Permit No. PA0114286

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
04C		30251		SOUTH BRANCH TOWANDA CREEK								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
8.500	0.30	0.00	0.30	.0619	0.00789	.465	12.48	26.84	0.06	0.713	20.86	7.00
Q1-10 Flow												
8.500	0.19	0.00	0.19	.0619	0.00789	NA	NA	NA	0.05	0.869	21.23	7.00
Q30-10 Flow												
8.500	0.40	0.00	0.40	.0619	0.00789	NA	NA	NA	0.07	0.616	20.67	7.00

Permit No. PA0114286

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
04C	30251	SOUTH BRANCH TOWANDA CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
8.500	New Albany	8.85	27	8.85	27	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
8.500	New Albany	1.83	13.5	1.83	13.5	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
8.50	New Albany	25	25	13.5	13.5	3	3	0	0

Permit No. PA0114286

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
04C	30251	SOUTH BRANCH TOWANDA CREEK		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
8.500	0.040	20.864	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
12.482	0.465	26.841	0.062	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
5.97	0.896	2.33	0.748	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.337	14.131	Owens	6	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.713	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.071	5.59	2.21	7.69
	0.143	5.23	2.10	7.86
	0.214	4.89	1.99	7.97
	0.285	4.58	1.88	8.04
	0.356	4.28	1.79	8.10
	0.428	4.01	1.69	8.11
	0.499	3.75	1.61	8.11
	0.570	3.51	1.52	8.11
	0.642	3.29	1.44	8.11
	0.713	3.07	1.37	8.11

Permit No. PA0114286

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
04C		30251		SOUTH BRANCH TOWANDA CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
8.500	New Albany	PA0114286	0.040	CBOD5	25		
				NH3-N	13.5	27	
				Dissolved Oxygen			3

Permit No. PA0114286

TRC EVALUATION				
Client		Date		
0.297	= Q stream (cfs)	0.5	= CV Daily	
0.04	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)	
Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 1.550	1.3.2.iii	WLA_cfc = 1.504
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.578	5.1d	LTA_cfc = 0.874
		WQBEL_afc = 0.711		WQBEL_cfc = 1.076
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	1.5 * (av_mon_limit / AML_MULT) / LTAMULT_afc			