

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0114545
APS ID 981985
Authorization ID 1253697

Applicant and Facility Information

Applicant Name	<u>Troy Schoenly</u>	Facility Name	<u>Troy's Suds Depot</u>
Applicant Address	<u>PO Box 153</u> <u>Sylvania, PA 16945-0153</u>	Facility Address	<u>Rt 14 S</u> <u>Troy, PA 16947</u>
Applicant Contact	<u>Troy Schoenly</u>	Facility Contact	<u>Troy Schoenly</u>
Applicant Phone	<u>570-297-4889</u>	Facility Phone	<u>570-297-4889</u>
Client ID	<u>44211</u>	Site ID	<u>1064</u>
SIC Code	<u>7542</u>	Municipality	<u>Troy Township</u>
SIC Description	<u>Services - Car Washes</u>	County	<u>Bradford</u>
Date Application Received	<u>November 27, 2018</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 14, 2018</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for the renewal of an individual NPDES permit for the discharge of industrial waste.</u>		

Summary of Review

Troy's Suds Depot has submitted an application for the renewal of the existing NPDES Permit PA114545 for the Department's review. DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jonathan P. Peterman / Project Manager	November 18, 2019
		Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0075 (Max Daily)</u>
Latitude	<u>41° 46' 9.51"</u>	Longitude	<u>-76° 47' 15.38"</u>
Quad Name	<u>Troy</u>	Quad Code	<u>0431</u>
Wastewater Description: <u>Laundromat, Washing/Cleaning Wastewater</u>			
Receiving Waters	<u>South Branch Sugar Creek (TSF)</u>	Stream Code	<u>30778</u>
NHD Com ID	<u>66402729</u>	RMI	<u>1.86</u>
Drainage Area	<u>5.66 mi²</u>	Yield (cfs/mi ²)	<u>0.013</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.0736</u>	Q ₇₋₁₀ Basis	<u>Gauge No. 01532000</u>
Elevation (ft)	<u>1150</u>	Slope (ft/ft)	<u>0.00927</u>
Watershed No.	<u>4-C</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u>TSF</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>N/A</u>		
Source(s) of Impairment	<u>N/A</u>		
TMDL Status	<u>N/A</u>	Name	<u>N/A</u>
Nearest Downstream Public Water Supply Intake	<u>Danville Municipal Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>1120</u>
PWS RMI	<u>138.06</u>	Distance from Outfall (mi)	<u>160</u>

Changes Since Last Permit Issuance: None.

Other Comments: In order to determine the Q₇₋₁₀ low flow for South Branch Sugar Creek, a comparative stream analysis was previously conducted and the results of which are attached in Appendix A. The Q₇₋₁₀ data was obtained from the updated stream gage information obtained from *Stuckey, M.H., and Roland, M.A., 2011, Selected Streamflow Statistics for Streamgage Locations In and Near Pennsylvania*. The analysis indicates that the Q₇₋₁₀ for South Branch Sugar Creek was 0.0736 cfs. This estimation of Q₇₋₁₀ is consistent with the previous review and seems appropriate given the size of the stream.

Treatment Facility Summary				
Treatment Facility Name: Troy's Suds Depot				
WQM Permit No.	Issuance Date	Comments		
0891201	8/8/91			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial	Physical (Industrial Waste)	Intermittent Sand Filters	Hypochlorite	

Treatment System Components:

Laundromat

- One (1) 10,000-gallon septic tank

Car Wash Wastewater

- One (1) grit chamber
- One (1) 1000-gallon oil/water separator

Combined flows are then further treated through the following:

- One (1) dosing tank
- Two (2) 40'x109' subsurface sand filters
- Two (2) erosion tablet chlorinators
- One (1) chlorine contact tank
- Outfall 001.

Changes Since Last Permit Issuance: None.

Other Comments: The owner has previously indicated that there are no sewage contributions to this system.

Chesapeake Bay Requirements

Troy's Suds Depot is considered a non-significant IW facility according to the Phase II Watershed Implementation Plan (WIP). For non-significant IW facilities, monitoring and reporting of TN and TP will be required throughout the permit term in renewed or amended permits anytime the facility has the potential to introduce a net TN or TP increase to the load contained within the intake water used in processing. One effluent sample was provided in the application. The results indicate that the discharge concentrations for nutrients are <2 mg/l Total Nitrogen (1.45 mg/l TKN and 0.469 mg/l Nitrate-Nitrite) and 1.30 mg/l Total Phosphorus. Given these results, the discharge doesn't appear to be introducing a net nutrient increase. Therefore, no further nutrient monitoring will be required for the facility at this time.

TMDL Impairment Discussion

The Department's Geographic Information System (GIS) shows that the South Branch Sugar Creek is not impaired and a no TMDL exists for the stream segment. No further review is required.

Existing Effluent Limitations and Monitoring Requirements

Existing Limits – Outfall 001

Discharge Parameter	Limitations							Monitoring Requirements	
	Mass (lb/day)		Concentration (mg/L)				Minimum Frequency	Sample Type	
	Monthly Average	Daily Maximum	Minimum	Average Monthly	Daily Max.	Instantaneous Maximum			
Flow (MGD)	Report	Report					1/ Week	Measured	
pH (Std. Units)			6.0			9.0	1/ Week	Grab	
CBOD5				22	44	55	1/ Quarter	Grab	
TSS				20	40	50	1/ Quarter	Grab	
TRC				0.5		1.6	1/ Week	Grab	
Oil and Grease				15	30	30	1/ Year	Grab	
Ammonia-Nitrogen				8.0	16	20	1/ Year	Grab	

*The existing effluent limits for Outfall 001 were based on a design flow of 0.0075 MGD.

Development of Effluent Limitations

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0075</u>
Latitude	<u>41° 46' 9.50"</u>	Longitude	<u>-76° 47' 14.60"</u>
Wastewater Description:	<u>Laundromat, Washing/Cleaning Wastewater</u>		

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

To establish whether or not water-quality based effluent limitations (WQBELs) are required, the Department models in-stream conditions. In order to determine limitations for toxics, the Department utilizes the PENTOXSD v2.0d model. The use of a PENTOXSD v2.0d analysis is not required given that there were no pollutant candidates for modeling.

WQM 7.0 for Windows, Version 1.0b, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen

The model was previously run using the Q7-10 stream flow, background water quality, max daily flow, and other discharge characteristics. The existing water quality-based effluent limits for CBOD₅ (22 mg/l) and NH₃-N (8 mg/l) were used as inputs for the modeling. The DO minimum daily average criterion from §93.7 (6.0 mg/L for TSF) was used for the in-stream objective for the model. The summary of the output is as follows:

Parameter	Effluent Limit		
	30 Day Average	Maximum	Minimum
CBOD5	22	N/A	N/A
Ammonia-N	8.0	16.0	N/A
Dissolved Oxygen	N/A	N/A	3

The model did not recommend more stringent water-quality based effluent limitations with regards to CBOD5, ammonia-nitrogen, and dissolved oxygen. The previously implemented effluent limits are still protective of water quality and will remain. Refer to Appendix B for the WQM 7.0 inputs and results.

Reasonable Potential Analysis

A formal "Reasonable Potential Analysis" was not conducted given the limited pollutant monitoring requirements required by the application. However, Emerging Pollutants (TDS, Chloride, Bromide, and Sulfate) have been sampled in the application. For discharges of 0.1 MGD or less, the Department's Policy is to establish a monitoring requirement for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L. The reported TDS effluent concentration (270 mg/L) is significantly below this value. Additionally, effluent concentrations for Chloride, Bromide, and Sulfate are significantly below the most stringent criterion and are not considered a pollutant of concern. This analysis has determined that there are no parameters that were candidates for monitoring or limitations. No further review is required.

Best Professional Judgement (BPJ) Limitations

Comments: None Required.

Anti-Backsliding

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

Proposed Limits - Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date

Discharge Parameter	Limitations							Monitoring Requirements	
	Mass (lb/day)		Concentration (mg/L)						
	Monthly Average	Daily Maximum	Minimum	Average Monthly	Daily Max.	Instantaneous Maximum	Minimum Frequency	Sample Type	
Flow (MGD)	Report	Report						1/ Week	Measured
pH (Std. Units)			6.0			9.0		1/ Week	Grab
CBOD5				22	44	55		1/ Quarter	Grab
TSS				20	40	50		1/ Quarter	Grab
TRC				0.5		1.6		1/ Week	Grab
Oil and Grease				15	30	30		1/ Year	Grab
Ammonia-Nitrogen				8.0	16	20		1/ Year	Grab

*The proposed effluent limits for Outfall 001 were based on a design flow of 0.0075 MGD.

pH

CFR Title 40 §133.102(c) and 25 PA Code §95.2(1) provide the basis of effluent limitations for pH.

Carbonaceous Biochemical Oxygen Demand (CBOD₅)

The results of the WQM 7.0 model show that the previously applied water quality-based effluent limit for CBOD₅ is protective of water quality and will remain.

Total Suspended Solids (TSS)

The previously applied technology based secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for TSS will remain as well.

Oil and Grease

The Oil and Grease treatment requirements, as stipulated in 25 Pa. Code § 95.2(2)(ii), were previously applied given that an oil-water separator is used to treat stormwater. The previous permits establish an effluent limitation for Oil and Grease of 15 mg/L as an average monthly limit and 30 mg/L as an IMAX limit which are appropriate and will remain.

Ammonia-Nitrogen (NH3-N)

The results of the WQM 7.0 model show that the previously applied water quality-based effluent requirements for NH3-N are still protective of water quality. These limits will be assigned in accordance with the *Implementation Guidance of Section 93.7 Ammonia Criteria* (391-2000-013) which states that a multiplier of 2.0 times the average monthly concentration limit (8.0 mg/L) was used to establish the I-max concentration limit (16.0 mg/L).

Total Residual Chlorine (TRC)

In accordance with 25 Pa. Code 92a.48(b)(2), a best available technology (BAT) value of 0.5 mg/l was used as an input in the TRC model (see Attachment D). The attached TRC model indicates that the existing water quality-based effluent limit of 0.5 mg/L (Average Monthly) and 1.6 mg/L (Instantaneous Maximum) are still protective of water quality and will remain.

The existing monitoring frequencies and sample types for the abovementioned parameters are consistent with other water treatment plant wastewater discharges and the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001) Table 6-3 and Table 6-4. The existing requirements will remain.

Compliance History

Summary of Inspections -The last inspection of the facility was conducted on 3/6/18 by the Department which reveals that there were no issues and the facility was operating normally.

WMS Query Summary - A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed that there are no open violations associated with this client.

DMRs Summary -Upon review of the DMR's for the past year, the facility has been operating within the given concentration limits.

Attachments



Appendices

Compliance History

DMR Data for Outfall 001 (from October 1, 2018 to September 30, 2019)

Parameter	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18	OCT-18
Flow (GPD) Average Monthly	2340	1534	2280	2734	2744	2005	4280	4550	3477	4288	2840	2734
Flow (GPD) Daily Maximum	4500	3000	4000	4000	4000	4500	6000	6000	6000	6000	5000	5000
pH (S.U.) Minimum	7.3	7.2	7.3	7.4	7.4	7.4	7.5	7.5	7.4	7.5	7.5	7.4
pH (S.U.) Instantaneous Maximum	7.5	7.4	7.4	7.5	7.6	7.5	7.7	7.6	7.6	7.6	7.6	7.7
TRC (mg/L) Average Monthly	0.32	0.43	0.28	0.22	0.23	0.25	0.2	0.23	0.33	0.2	0.23	0.2
TRC (mg/L) Instantaneous Maximum	0.4	0.5	0.3	0.3	0.3	0.3	0.2	0.3	0.3	0.2	0.3	0.2
CBOD5 (mg/L) Average Monthly	3			2.6			2.8			3		
CBOD5 (mg/L) Daily Maximum	3			2.6			2.8			3		
TSS (mg/L) Average Monthly	4			4.0			7			5		
TSS (mg/L) Daily Maximum	4			4.0			7			5		
Oil and Grease (mg/L) Average Monthly										5		
Oil and Grease (mg/L) Daily Maximum										5		
Ammonia (mg/L) Average Monthly										0.560		
Ammonia (mg/L) Daily Maximum										0.560		

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment D)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment)
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment)
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Industrial Permits, 1/10/2019
<input type="checkbox"/>	Other: