

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**


Application No. PA0114561
APS ID 1080170
Authorization ID 1425637

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|--|
| Applicant Name | <u>Herrick Township</u> | Facility Name | <u>Herrick Township Sewer System STP</u> |
| Applicant Address | <u>399 Leisure Lakes Road</u> | Facility Address | <u>399 Leisure Lakes Road</u> |
| Applicant Contact | <u>Wyalusing, PA 18853-8770</u> | Facility Contact | <u>Wyalusing, PA 18853-8770</u> |
| Applicant Phone | <u>(570) 746-3637</u> | Facility Phone | <u>(570) 746-3637</u> |
| Client ID | <u>74518</u> | Site ID | <u>255530</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Herrick Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Bradford</u> |
| Date Application Received | <u>January 27, 2023</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>February 7, 2023</u> | If No, Reason | |
| Purpose of Application | <u>Application for the renewal of the existing individual NPDES permit.</u> | | |

Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|---|----------------|
| X | |  Jonathan P. Peterman / Project Manager | March 24, 2025 |
| X | |  Nicholas W. Hartranft, P.E. / Environmental Engineer Manager | March 25, 2025 |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|-------------------|------------------------------------|---------------------|
| Outfall No. | 001 | Design Flow (MGD) | 0.01 |
| Latitude | 41° 48' 24.55" | Longitude | -76° 14' 59.62" |
| Quad Name | LeRaysville | Quad Code | 41076 |
| Wastewater Description: | Sewage Effluent | | |
| Receiving Waters | Cold Creek (WWF) | Stream Code | 29624 |
| NHD Com ID | 66397277 | RMI | 5.88 |
| Drainage Area | 0.97 | Yield (cfs/mi ²) | 0.035 |
| Q ₇₋₁₀ Flow (cfs) | 0.034 | Q ₇₋₁₀ Basis | USGS Gage #01532850 |
| Elevation (ft) | 1137 | Slope (ft/ft) | N/A |
| Watershed No. | 4-D | Chapter 93 Class. | WWF |
| Existing Use | None | Existing Use Qualifier | N/A |
| Exceptions to Use | None | Exceptions to Criteria | None |
| Assessment Status | Attaining Use(s) | | |
| Cause(s) of Impairment | N/A | | |
| Source(s) of Impairment | N/A | | |
| TMDL Status | N/A | Name | N/A |
| Nearest Downstream Public Water Supply Intake | | Danville Municipal Water Authority | |
| PWS Waters | Susquehanna River | Flow at Intake (cfs) | 1,100 |
| PWS RMI | 138.5 | Distance from Outfall (mi) | 130 |

Changes Since Last Permit Issuance: None.

Other Comments: Previously, the selected gage is "MB Wyalusing Creek near Birchardville, PA" (USGS #0532850) was selected as a reference gage. A Q_{7,10} flow for that gage was obtained from *Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania* (USGS Open Files Report 2011-1070) and a comparative analysis was conducted using this gage. There have been no changes to the discharge points and watershed, so the previous analysis will be utilized and attached in appendix A.

| Treatment Facility Summary | | | | |
|---|----------------------------|--|------------------------------|------------------------|
| Treatment Facility Name: Herrick Township WWTP | | | | |
| WQM Permit No. | Issuance Date | Comments | | |
| 0890407 A-1 | 10/27/92 | Includes the currently utilized aeration tanks | | |
| 0890407 | 1/30/91 | Original Construction | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Extended Aeration | Chlorine With Dechlorination | 0.01 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.01 | 30 | Not Overloaded | Aerobic Digestion | Other WWTP |

-The existing treatment system consists of the following:

- One (1) Influent bar screen
- One (1) 8,307 Gallon equalization tank
- Two (2) 8,307 Gallon aeration tanks.
- Three (3) Blowers.
- One (1) 5,547 Gallon clarifier.
- One (1) 7,386 Gallon sludge digester / holding tank.
- One (1) Erosion tablet chlorinator.
- One (1) 900 Gallon chlorine contact tank.
- One (1) Effluent flow meter.
- One (1) Post aeration.

Anti-Backsliding

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

Biosolids Use/Disposal

The facility's sludge is disposed at Towanda Municipal Authority at a quantity of 6,200 gallons.

Hauled in Waste

According to the application materials, the Herrick Township WWTF has not received hauled-in wastes during the past three years and does not anticipate receiving hauled-in wastes in the next five years.

Chesapeake Bay Requirements

Previously, the permittee was required to monitor and report TN and TP throughout the permit term at a frequency no less than annually in accordance with the Phase III WIP Chesapeake Bay Strategy for Phase V facilities (0.002 MGD to 0.2 MGD). Annual monitoring for these parameters will remain.

Existing Effluent Limitations and Monitoring Requirements

Existing Limits – Outfall 001

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|--|------------------|-----------------------|-----------------|---------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | 1/week | Weir |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| Dissolved Oxygen | XXX | XXX | 4.0 Inst Min | XXX | XXX | XXX | 1/day | Grab |
| Total Residual Chlorine (TRC) | XXX | XXX | XXX | 0.20 | XXX | 0.90 | 1/day | Grab |
| Biochemical Oxygen Demand (BOD5) Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 2/month | Grab |
| Carbonaceous Biochemical Oxygen Demand (CBOD5) | 2.1 | XXX | XXX | 25.0 | XXX | 50.0 | 2/month | Grab |
| Total Suspended Solids Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 2/month | Grab |
| Total Suspended Solids | 2.5 | XXX | XXX | 30.0 | XXX | 60.0 | 2/month | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX Geo Mean | XXX | 10000 | 2/month | Grab | |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX Geo Mean | XXX | 1000 | 2/month | Grab | |
| Ammonia-Nitrogen May 1 - Oct 31 | 0.25 | XXX | XXX | 3.0 | XXX | 6.0 | 2/month | Grab |
| Ammonia-Nitrogen Nov 1 - Apr 30 | 0.75 | XXX | XXX | 9.0 | XXX | 18.0 | 2/month | Grab |
| Total Nitrogen | Report Annl Avg | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |
| Total Phosphorus | Report Annl Avg | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |

*The existing effluent limits for Outfall 001 were based on a design flow of 0.01 MGD.

Development of Effluent Limitations

Outfall No. 001
Latitude 41° 48' 24.40"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .01
Longitude -76° 14' 58.50"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Water Quality-Based Limitations

To establish whether or not water-quality based effluent limitations (WQBELs) are required, the Department models in-stream conditions. In order to determine limitations for CBOD₅, ammonia-N and dissolved oxygen, the Department utilizes the WQM 7.0 v1.0b model and in order to determine limitations for toxics, the Department utilizes Toxics Management Spreadsheet (TMS). The TMS was not utilized or this review.

WQM 7.0 for Windows, Version 1.0b, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen
There have been no changes to the discharge or watershed, so the previous modeling is still valid and will be utilized for this review. The model was previously run using the Q7-10 stream flow, background water quality, average annual design flow, and other discharge characteristics. The technology-based effluent limits for CBOD₅ (25 mg/l) and the existing effluent limit for Ammonia-Nitrogen (3 mg/l) were used as inputs for the modeling. The DO minimum daily average criterion from §93.7 (5.0 mg/L for WWF) was used for the in-stream objective for the model. The summary of the output is as follows:

| Parameter | Effluent Limit | | |
|------------------|----------------|---------|---------|
| | 30 Day Average | Maximum | Minimum |
| CBOD5 | 25 | N/A | N/A |
| Ammonia-N | 3 | 6 | N/A |
| Dissolved Oxygen | N/A | N/A | 3 |

The model did not recommend more restrictive water-quality based effluent limitations with regards to CBOD₅, ammonia, and dissolved oxygen. Refer to the Appendix B for the previous WQM 7.0 inputs and results. The existing effluent limits will remain.

Best Professional Judgment (BPJ) Limitations

See the D.O. section below.

Comments: None.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

Proposed Limits - Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|-----------------|---------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | 1/week | Weir |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| Dissolved Oxygen | XXX | XXX | 4.0 Inst Min | XXX | XXX | XXX | 1/day | Grab |
| Total Residual Chlorine (TRC) | XXX | XXX | XXX | 0.20 | XXX | 0.90 | 1/day | Grab |
| Biochemical Oxygen Demand (BOD5) Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 2/month | Grab |
| Carbonaceous Biochemical Oxygen Demand (CBOD5) | 2.1 | XXX | XXX | 25.0 | XXX | 50.0 | 2/month | Grab |
| Total Suspended Solids Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 2/month | Grab |
| Total Suspended Solids | 2.5 | XXX | XXX | 30.0 | XXX | 60.0 | 2/month | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX Geo Mean | XXX | 10000 | 2/month | Grab | |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX Geo Mean | XXX | 1000 | 2/month | Grab | |
| Ammonia-Nitrogen May 1 - Oct 31 | 0.25 | XXX | XXX | 3.0 | XXX | 6.0 | 2/month | Grab |
| Ammonia-Nitrogen Nov 1 - Apr 30 | 0.75 | XXX | XXX | 9.0 | XXX | 18.0 | 2/month | Grab |
| Total Nitrogen | Report Annl Avg | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------------|--|----------------|-----------------------|-----------------|---------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Total Phosphorus | Report Annl Avg | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/year | Grab |

*The proposed effluent limits for Outfall 001 were based on a design flow of 0.01 MGD.

Effluent Limit Determination for Outfall 001

General Information

All of the limits proposed above are consistent with other permits issued for wastewater treatment plants in the region. The associated mass-based limits (lbs/day) for all parameters were based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34). All effluent limits were then rounded down in accordance with the rounding rules established in the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001), Chapter 5 - Specifying Effluent Limitations in NPDES Permits.

Flow

Reporting of the average monthly and daily maximum flow is consistent with monitoring requirements for other treatment plants of this size.

Carbonaceous Biochemical Oxygen Demand (CBOD₅)

The results of the WQM 7.0 model show that the previously applied secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for CBOD₅ are protective of water quality.

Total Suspended Solids (TSS)

The previously applied technology based secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for TSS will remain as well.

pH

CFR Title 40 §133.102(c) and 25 PA Code §95.2(1) provide the basis of effluent limitations for pH. The existing limits will remain.

TRC

In accordance with 25 Pa. Code 92a.48(b)(2), a best available technology (BAT) value of 0.5 mg/l was used in lieu of the existing effluent limit (0.2 mg/L) in the TRC Spreadsheet. The attached TRC model indicates that the existing effluent limits are more stringent than what the water quality model recommends. The existing effluent limits will remain.

Fecal Coliforms

The existing fecal coliform limits with I-max limits were previously updated from the previous Chapter 92 code to correspond with what is specified in the updated 25 PA Code § 92a.47 (a)(4)&(5).

Ammonia-Nitrogen (NH₃-N)

The results of the previous WQM 7.0 model showed that existing water quality-based effluent limits for ammonia-nitrogen are sufficient and a more stringent water quality-based limit would not be required. Seasonal limits were considered in accordance with the *Implementation Guidance of Section 93.7 Ammonia Criteria* (391-2000-013) which states that a multiplier of 2.0 times the average monthly concentration limit (3.0 mg/L) was used to establish the I-max concentration limit (6.0 mg/L). The Implementation Guidance also states that the winter seasonal limits shall be 3.0 times the summer limits.

Dissolved Oxygen (DO)

Based on BPJ, a minimum Dissolved Oxygen (DO) effluent limit of 4.0 mg/l was established. This will ensure that the discharge does not contributes to an in-stream excursion above the allowable ambient concentration of State numeric criteria within a State water quality standard for an individual pollutant.

Influent BOD₅ and TSS

The Department requires the reporting of raw sewage influent monitoring for BOD₅ and TSS in all POTW permits. This provides the Department with the ability to monitor the percent removal of each parameter as stipulated in section 2 of the Part A conditions and maintain records of the BOD₅ loading as required by 25 Pa. Code Chapter 94. The monitoring frequencies and sample types are identical to the effluent sampling.

E. Coli

25 PA Code § 92a.61 provide the basis of monitoring requirements for E. Coli. Yearly monitoring will be required going forward.

Compliance History

Summary of Inspections -The last inspection of the facilities was conducted by the Department on 6/27/2024 which reveals the facility was operating normally, but fecal coliform violations existed.

WMS Query Summary - A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed that there were no unresolved violations.

DMRs Summary - Upon review of the last year of DMR's, the facility appears to be generally operating within the given concentration limits with the exception a TSS and fecal coliform exceedance.

Compliance History

DMR Data for Outfall 001 (from February 1, 2024 to January 31, 2025)

| Parameter | JAN-25 | DEC-24 | NOV-24 | OCT-24 | SEP-24 | AUG-24 | JUL-24 | JUN-24 | MAY-24 | APR-24 | MAR-24 | FEB-24 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.003 | 0.005 | 0.003 | 0.002 | 0.002 | 0.003 | 0.003 | 0.002 | 0.004 | 0.002 | 0.004 | 0.003 |
| Flow (MGD) Daily Maximum | 0.007 | 0.014 | 0.007 | 0.003 | 0.004 | 0.015 | 0.009 | 0.006 | 0.006 | 0.010 | 0.012 | 0.009 |
| pH (S.U.) Instantaneous Minimum | 6.63 | 6.89 | 6.79 | 6.63 | 6.8 | 6.80 | 6.31 | 6.48 | 6.61 | 7.31 | 7.38 | 7.06 |
| pH (S.U.) Instantaneous Maximum | 7.67 | 7.29 | 7.10 | 7.28 | 7.2 | 7.56 | 7.46 | 7.89 | 7.59 | 7.98 | 7.67 | 7.98 |
| DO (mg/L) Instantaneous Minimum | 7.48 | 7.41 | 7.98 | 8.51 | 8.03 | 7.23 | 6.83 | 6.54 | 7.2 | 9.2 | 9.6 | 11.48 |
| TRC (mg/L) Average Monthly | < 0.01 | 0.02 | 0.01 | < 0.01 | < 0.02 | < 0.02 | 0.02 | < 0.03 | < 0.04 | 0.03 | < 0.03 | 0.03 |
| TRC (mg/L) Instantaneous Maximum | 0.04 | 0.04 | 0.03 | 0.05 | 0.09 | 0.08 | 0.06 | 0.09 | 0.20 | 0.15 | 0.25 | 0.24 |
| CBOD5 (lbs/day) Average Monthly | 0.1 | 0.2 | < 0.05 | < 0.04 | < 0.09 | < 0.06 | 0.3 | < 0.05 | < 0.08 | < 0.1 | < 0.2 | < 0.05 |
| CBOD5 (mg/L) Average Monthly | 5.86 | 5.15 | < 3.0 | < 3.0 | < 4.67 | < 3.0 | 5.6 | < 3.0 | < 3.0 | < 3.41 | < 4.1 | < 3.0 |
| CBOD5 (mg/L) Instantaneous Maximum | 6.36 | 5.53 | < 3.0 | < 3.0 | 6.33 | < 3.0 | 7.93 | < 3.0 | < 3.0 | 3.81 | 5.2 | < 3.0 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 3 | 10 | 2 | 2 | 5 | 1 | 6 | 5 | 4 | 3 | 3 | 3.0 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 104.0 | 232 | 141 | 143 | 245 | 74 | 132 | 294 | 165 | 74 | 53 | 178 |
| TSS (lbs/day) Average Monthly | 0.3 | < 0.3 | 4.8 | 0.04 | < 0.03 | < 0.05 | 0.6 | 0.08 | 0.2 | < 0.08 | 0.2 | 0.05 |

NPDES Permit Fact Sheet
Herrick Township Sewer System STP

NPDES Permit No. PA0114561

| | | | | | | | | | | | | |
|--|---------|---------|---------|--------|---------|---------|------|---------|---------|---------|---------|---------|
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 3 | 5 | 1 | 2 | 3 | 1 | 6 | 1 | 3 | 2 | 1 | 2 |
| TSS (mg/L) Average Monthly | 12.0 | < 7.4 | 0.8 | 3.4 | < 1.6 | < 2.2 | 13.6 | 4.6 | 7.1 | < 2.2 | 3.84 | 3.2 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 101.0 | 102 | 86 | 281 | 130 | 42 | 141 | 37 | 159 | 40 | 21 | 90 |
| TSS (mg/L) Instantaneous Maximum | 14.4 | 13.2 | 0.1 | 3.6 | < 1.6 | 2.4 | 14.4 | 4.8 | 8.5 | 2.8 | 4.4 | 3.6 |
| Fecal Coliform (No./100 ml) Geometric Mean | 112 | 12 | < 13 | 120 | 1 | < 1 | 476 | 2.0 | < 1 | < 1 | 98 | 3.0 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 2419.6 | 16.1 | 167 | 1011.2 | 1 | < 2 | 2419 | 3.1 | 1 | < 1 | 2419.6 | 3.1 |
| Total Nitrogen (lbs/day) Annual Average | | 0.8 | | | | | | | | | | |
| Total Nitrogen (mg/L) Annual Average | | 32.17 | | | | | | | | | | |
| Ammonia (lbs/day) Average Monthly | < 0.006 | < 0.004 | < 0.002 | 0.001 | < 0.002 | < 0.002 | 0.07 | < 0.002 | < 0.003 | < 0.004 | < 0.005 | < 0.002 |
| Ammonia (mg/L) Average Monthly | < 0.26 | < 0.1 | < 0.10 | 0.1 | < 0.10 | < 0.10 | 1.42 | < 0.1 | < 0.10 | < 0.1 | < 0.1 | < 0.1 |
| Ammonia (mg/L) Instantaneous Maximum | 0.41 | < 0.10 | < 0.10 | 0.1 | < 0.10 | < 0.10 | 2.7 | < 0.1 | < 0.10 | 0.1 | < 0.10 | < 0.1 |
| Total Phosphorus (lbs/day) Annual Average | | 0.08 | | | | | | | | | | |
| Total Phosphorus (mg/L) Annual Average | | 3.24 | | | | | | | | | | |

Compliance History

Effluent Violations for Outfall 001, from: March 1, 2024 To: January 31, 2025

| Parameter | Date | SBC | DMR Value | Units | Limit Value | Units |
|----------------|----------|----------|-----------|------------|-------------|------------|
| TSS | 11/30/24 | Avg Mo | 4.8 | lbs/day | 2.5 | lbs/day |
| Fecal Coliform | 07/31/24 | Geo Mean | 476 | No./100 ml | 200 | No./100 ml |
| Fecal Coliform | 07/31/24 | IMAX | 2419 | No./100 ml | 1000 | No./100 ml |

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment B) |
| <input type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [REDACTED]) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment C) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input checked="" type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input checked="" type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input checked="" type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input checked="" type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input checked="" type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input checked="" type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: [REDACTED] |
| <input type="checkbox"/> | Other: [REDACTED] |

APPENDIX A

PREVIOUS Q7-10 ANALYSIS AND STREAM DATA

Q₇₋₁₀ Analysis

| | |
|-----------|------------------|
| Facility: | Herrick Township |
| Outfall: | 001 |

| | |
|-------------------|-----------|
| NPDES Permit No.: | PA0114561 |
| RMI at 001: | 5.88 |

Reference Stream Gage Information

| | |
|------------------------------------|---|
| Stream Name | Cold Creek |
| Reference Gage | 01532850 |
| Station Name | MB Wyalusing Creek near Birchardville, PA |
| Gage Drainage Area (sq. mi.) | 5.67 |
| Q ₇₋₁₀ at gage (cfs) | 0.20 |
| Yield Ratio (cfs/mi ²) | 0.0353 |

Q₇₋₁₀ at 001

| | |
|--------------------------------|--------|
| Drainage Area at 001 (sq. mi.) | 0.97 |
| Q ₇₋₁₀ at 001 (cfs) | 0.034 |
| Q ₇₋₁₀ at 001 (mgd) | 0.0221 |

12 Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania

Table 1. List of U.S. Geological Survey streamgage locations in and near Pennsylvania with updated streamflow statistics.—Continued
[Latitude and Longitude in decimal degrees; mi², square miles]

| Streamgage number | Streamgage name | Latitude | Longitude | Drainage area (mi ²) | Regulated ¹ |
|-------------------|---|----------|-----------|----------------------------------|------------------------|
| 01508803 | West Branch Tioughnioga River at Homer, N.Y. | 42.638 | -76.176 | 71.5 | N |
| 01509000 | Tioughnioga River at Cortland, N.Y. | 42.603 | -76.159 | 292 | N |
| 01510000 | Otselic River at Cincinnatus, N.Y. | 42.541 | -75.900 | 147 | N |
| 01512500 | Chenango River near Chenango Forks, N.Y. | 42.218 | -75.848 | 1,483 | N |
| 01515000 | Susquehanna River near Waverly, N.Y. | 41.985 | -76.501 | 4,773 | N |
| 01516350 | Tioga River near Mansfield, Pa. | 41.797 | -77.080 | 153 | N |
| 01516500 | Corey Creek near Mainesburg, Pa. | 41.791 | -77.015 | 12.2 | N |
| 01518000 | Tioga River at Tioga, Pa. | 41.908 | -77.129 | 282 | Y |
| 01518700 | Tioga River at Tioga Junction, Pa. | 41.953 | -77.115 | 446 | Y |
| 01518862 | Cowanesque River at Westfield, Pa. | 41.923 | -77.532 | 90.6 | N |
| 01520000 | Cowanesque River near Lawrenceville, Pa. | 41.997 | -77.140 | 298 | Y |
| 01520500 | Tioga River at Lindley, N.Y. | 42.029 | -77.132 | 771 | Y |
| 01521500 | Canisteo River at Arkport, N.Y. | 42.396 | -77.711 | 30.6 | Y |
| 01523500 | Canacadea Creek near Hornell, N.Y. | 42.335 | -77.683 | 57.9 | Y |
| 01524500 | Canisteo River below Canacadea Creek at Hornell, N.Y. | 42.314 | -77.651 | 158 | Y |
| 01526500 | Tioga River near Erwins, N.Y. | 42.121 | -77.129 | 1,377 | Y |
| 01527000 | Cohocton River at Cohocton, N.Y. | 42.500 | -77.500 | 52.2 | N |
| 01527500 | Cohocton River at Avoca, N.Y. | 42.398 | -77.417 | 152 | N |
| 01528000 | Fivemile Creek near Kanona, N.Y. | 42.388 | -77.358 | 66.8 | N |
| 01529000 | Mud Creek near Savona, N.Y. | 42.308 | -77.197 | 76.6 | Y |
| 01529500 | Cohocton River near Campbell, N.Y. | 42.253 | -77.217 | 470 | N |
| 01529950 | Chemung River at Corning, N.Y. | 42.146 | -77.057 | 2,006 | Y |
| 01530332 | Chemung River at Elmira, N.Y. | 42.086 | -76.801 | 2,162 | Y |
| 01530500 | Newtown Creek at Elmira, N.Y. | 42.105 | -76.798 | 77.5 | Y |
| 01531000 | Chemung River at Chemung, N.Y. | 42.002 | -76.635 | 2,506 | Y |
| 01531500 | Susquehanna River at Towanda, Pa. | 41.765 | -76.441 | 7,797 | Y |
| 01532000 | Towanda Creek near Monroeton, Pa. | 41.707 | -76.485 | 215 | N |
| 01532850 | MB Wyalusing Creek near Birchardville, Pa. | 41.863 | -76.007 | 5.67 | N |
| 01533400 | Susquehanna River at Meshoppen, Pa. | 41.607 | -76.050 | 8,720 | Y |
| 01533500 | North Branch Mehoopany Creek near Lovelton, Pa. | 41.531 | -76.156 | 35.2 | N |
| 01533950 | SB Tunkhannock Creek near Montdale, Pa. | 41.575 | -75.642 | 12.6 | N |
| 01534000 | Tunkhannock Creek near Tunkhannock, Pa. | 41.558 | -75.895 | 383 | N |
| 01534300 | Lackawanna River near Forest City, Pa. | 41.680 | -75.472 | 38.8 | Y |
| 01534500 | Lackawanna River at Archbald, Pa. | 41.505 | -75.542 | 108 | Y |
| 01536000 | Lackawanna River at Old Forge, Pa. | 41.359 | -75.744 | 332 | Y |
| 01536500 | Susquehanna River at Wilkes-Barre, Pa. | 41.251 | -75.881 | 9,960 | Y |
| 01537000 | Toby Creek at Luzerne, Pa. | 41.281 | -75.896 | 32.4 | Y |
| 01537500 | Solomon Creek at Wilkes-Barre, Pa. | 41.228 | -75.904 | 15.7 | N |
| 01538000 | Wapwallopen Creek near Wapwallopen, Pa. | 41.059 | -76.094 | 43.8 | N |
| 01539000 | Fishing Creek near Bloomsburg, Pa. | 41.078 | -76.431 | 274 | N |
| 01539500 | Little Fishing Creek at Eyers Grove, Pa. | 41.080 | -76.511 | 56.5 | N |
| 01540200 | Trexler Run near Ringtown, Pa. | 40.853 | -76.280 | 1.77 | N |
| 01540500 | Susquehanna River at Danville, Pa. | 40.958 | -76.619 | 11,220 | Y |
| 01541000 | West Branch Susquehanna River at Bower, Pa. | 40.897 | -78.677 | 315 | N |
| 01541200 | West Branch Susquehanna River near Curwensville, Pa. | 40.961 | -78.519 | 367 | Y |

Table 2. Selected low-flow statistics for streamgage locations in and near Pennsylvania.—Continued

[ft³/s; cubic feet per second; —, statistic not computed; <, less than]

| Streamgage number | Period of record used in analysis ¹ | Number of years used in analysis | 1-day, 10-year (ft ³ /s) | 7-day, 10-year (ft ³ /s) | 7-day, 2-year (ft ³ /s) | 30-day, 10-year (ft ³ /s) | 30-day, 2-year (ft ³ /s) | 90-day, 10-year (ft ³ /s) |
|-------------------|--|----------------------------------|-------------------------------------|-------------------------------------|------------------------------------|--------------------------------------|-------------------------------------|--------------------------------------|
| 01530500 | 1940–2008 | 69 | 5.0 | 6.1 | 11.0 | 7.6 | 13 | 9.0 |
| 01531000 | ² 1981–2008 | 28 | 138 | 147 | 237 | 169 | 296 | 203 |
| 01531000 | ³ 1905–1979 | 68 | 86.3 | 97.0 | 175 | 116 | 219 | 161 |
| 01531500 | ² 1981–2008 | 28 | 550 | 592 | 1,030 | 733 | 1,340 | 952 |
| 01531500 | ³ 1915–1979 | 65 | 539 | 571 | 990 | 675 | 1,230 | 928 |
| 01532000 | 1915–2008 | 94 | 2.2 | 2.8 | 9.7 | 4.6 | 14.4 | 9.4 |
| 01532850 | 1967–1979 | 13 | .1 | .2 | .4 | .3 | .8 | .7 |
| 01533400 | ² 1981–2008 | 28 | 602 | 648 | 1,110 | 790 | 1,430 | 1,060 |
| 01533500 | 1942–1958 | 17 | .4 | .6 | 1.5 | .8 | 2.0 | 1.7 |
| 01533950 | 1962–1978 | 17 | .2 | .3 | 1.0 | .6 | 1.4 | 1.0 |
| 01534000 | 1915–2008 | 94 | 15.2 | 17.3 | 35.9 | 24.2 | 51.0 | 38.7 |
| 01534300 | 1960–2008 | 49 | 1.1 | 1.7 | 5.1 | 2.8 | 7.6 | 4.8 |
| 01534500 | ² 1961–2008 | 48 | 16.7 | 18.8 | 29.2 | 21.9 | 35.8 | 27.6 |
| 01534500 | ³ 1941–1959 | 19 | 18.8 | 23.0 | 33.3 | 25.6 | 39.2 | 34.9 |
| 01536000 | ² 1961–2008 | 48 | 28.7 | 32.7 | 51.7 | 40.8 | 68.1 | 54.3 |
| 01536000 | ³ 1940–1959 | 20 | 77.8 | 93.9 | 119 | 105 | 138 | 124 |
| 01536500 | ² 1981–2008 | 28 | 828 | 872 | 1,450 | 1,030 | 1,830 | 1,350 |
| 01536500 | ³ 1901–1979 | 79 | 778 | 811 | 1,350 | 927 | 1,640 | 1,260 |
| 01537000 | 1943–1993 | 51 | 1.3 | 2.0 | 4.9 | 3.1 | 6.4 | 4.7 |
| 01537500 | 1941–1990 | 50 | .2 | .3 | 1.9 | .5 | 3.1 | 1.6 |
| 01538000 | 1921–2008 | 88 | 3.1 | 3.6 | 7.1 | 5.0 | 9.3 | 7.5 |
| 01539000 | 1940–2008 | 69 | 15.4 | 16.8 | 36.8 | 21.1 | 51.1 | 36.8 |
| 01539500 | 1942–1958 | 17 | .1 | .3 | 1.4 | 1.0 | 3.3 | 2.3 |
| 01540200 | 1965–1981 | 17 | 0 | 0 | .3 | .1 | .3 | .1 |
| 01540500 | ² 1981–2008 | 28 | 1,080 | 1,120 | 1,870 | 1,320 | 2,330 | 1,690 |
| 01540500 | ³ 1906–1979 | 74 | 927 | 978 | 1,660 | 1,160 | 2,050 | 1,590 |
| 01541000 | 1915–2008 | 94 | 25.3 | 27.9 | 50.7 | 35.3 | 66.6 | 49.6 |
| 01541200 | ² 1967–2008 | 40 | 34.6 | 45.2 | 66.0 | 63.1 | 100 | 92.4 |
| 01541200 | ³ 1957–1965 | 9 | 22.9 | 24.7 | 44.7 | 27.7 | 58.2 | 36.4 |
| 01541303 | 1980–2008 | 29 | 53.4 | 58.5 | 94.0 | 74.4 | 123 | 102 |
| 01541308 | 1969–1979 | 11 | 1.3 | 1.3 | 1.9 | 1.6 | 2.4 | 2.1 |
| 01541500 | ² 1962–2008 | 47 | 39.0 | 41.9 | 66.5 | 51.9 | 86.3 | 70.6 |
| 01541500 | ³ 1915–1960 | 46 | 14.9 | 21.3 | 41.9 | 28.5 | 55.0 | 42.9 |
| 01542000 | 1942–1993 | 52 | 8.1 | 9.1 | 14.8 | 11.3 | 17.8 | 14.6 |
| 01542500 | ² 1967–2008 | 33 | 216 | 235 | 326 | 285 | 435 | 402 |
| 01542500 | ³ 1941–1965 | 20 | — | 131 | 189 | 152 | 243 | 221 |
| 01542810 | 1966–2008 | 43 | .1 | .1 | .3 | .2 | .5 | .3 |
| 01543000 | 1913–2008 | 94 | 2.9 | 4.2 | 16.0 | 9.6 | 27.4 | 19.2 |
| 01543500 | 1940–2008 | 69 | 10.7 | 14.5 | 44.9 | 26.6 | 74.9 | 50.5 |
| 01544000 | ² 1957–2008 | 52 | 3.3 | 6.9 | 19.0 | 11.2 | 31.1 | 19.0 |
| 01544500 | 1942–2008 | 67 | 4.2 | 4.9 | 12.5 | 7.5 | 17.4 | 11.7 |
| 01545000 | ² 1964–2008 | 45 | 6.8 | 8.2 | 21.2 | 12.0 | 32.7 | 20.7 |
| 01545500 | ² 1963–2008 | 46 | 217 | 238 | 446 | 306 | 629 | 428 |
| 01545500 | ³ 1909–1961 | 53 | 125 | 141 | 278 | 190 | 387 | 296 |
| 01545600 | 1966–2008 | 43 | 1.2 | 1.5 | 4.4 | 2.4 | 6.7 | 4.2 |

APPENDIX B

WQM 7.0 MODEL INPUT/OUTPUT

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--------------------|--------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 04D | 29624 | COLD CREEK | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 5.880 | Herrick Township | PA0114561 | 0.000 | CBOD5 | 25 | | |
| | | | | NH3-N | 3 | 6 | |
| | | | | Dissolved Oxygen | | | 4 |

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--------------------|--------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 04D | 29624 | COLD CREEK | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 5.880 | Herrick Township | PA0114561 | 0.000 | CBOD5 | 25 | | |
| | | | | NH3-N | 3 | 6 | |
| | | | | Dissolved Oxygen | | | 4 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------|-------|-------------------|--------------------------|------------------|-------------------------|-------------------------------------|
| 04D | 29624 | COLD CREEK | 0.100 | 803.00 | 12.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD | Rch Width | Rch Depth | Tributary Temp | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|-----|-----------|-----------|----------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | (°C) | (°C) |
| Q7-10 | 0.100 | 0.00 | 0.42 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow | Permitted Disc Flow | Design Disc Flow | Reserve Factor | Disc Temp | Disc pH |
|-----------------------|---------------|--------------------|---------------------|------------------|----------------|-----------|---------|
| | | (mgd) | (mgd) | (mgd) | | (°C) | |
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 0.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | | Disc Conc | Trib Conc | Stream Conc | Fate Coef | | |
| Parameter Name | | (mg/L) | (mg/L) | (mg/L) | (1/days) | | |
| CBOD5 | | 25.00 | 2.00 | 0.00 | 1.50 | | |
| Dissolved Oxygen | | 3.00 | 8.24 | 0.00 | 0.00 | | |
| NH3-N | | 25.00 | 0.00 | 0.00 | 0.70 | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------|-------|-------------------|--------------------------|------------------|-------------------------|-------------------------------------|
| 04D | 29624 | COLD CREEK | 0.100 | 803.00 | 12.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD | Rch Width | Rch Depth | Tributary Temp | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|-----|-----------|-----------|----------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | (°C) | (°C) |
| Q7-10 | 0.100 | 0.00 | 0.42 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow | Permitted Disc Flow | Design Disc Flow | Reserve Factor | Disc Temp | Disc pH |
|-----------------------|---------------|--------------------|---------------------|------------------|----------------|-----------|---------|
| | | (mgd) | (mgd) | (mgd) | | (°C) | |
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 0.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | | Disc Conc | Trib Conc | Stream Conc | Fate Coef | | |
| Parameter Name | | (mg/L) | (mg/L) | (mg/L) | (1/days) | | |
| CBOD5 | | 25.00 | 2.00 | 0.00 | 1.50 | | |
| Dissolved Oxygen | | 3.00 | 8.24 | 0.00 | 0.00 | | |
| NH3-N | | 25.00 | 0.00 | 0.00 | 0.70 | | |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

WQM 7.0 Wasteload Allocations

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
|------------------|--------------------|--------------------|
| 04D | 29624 | COLD CREEK |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-----------------------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 5.880 Herrick Townshi | | 8.32 | 6 | 8.32 | 6 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-----------------------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 5.880 Herrick Townshi | | 1.75 | 3 | 1.75 | 3 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | CBOD5 | | NH3-N | | Dissolved Oxygen | | Critical Reach | Percent Reduction |
|----------------------|----------------|-----------------|-----------------|-----------------|-----------------|------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 5.88 Herrick Townshi | | 25 | 25 | 3 | 3 | 4 | 4 | 0 | 0 |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|----------------|
| 04D | 29624 | COLD CREEK | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | |
| 5.880 | 0.010 | 21.564 | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | |
| 3.799 | 0.311 | 12.231 | 0.042 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | |
| 9.19 | 0.168 | 0.94 | 0.790 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | |
| 6.916 | 23.385 | Owens | 6 | |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u> | | | |
| 8.427 | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) |
| | 0.843 | 7.89 | 0.48 | 8.01 |
| | 1.685 | 6.78 | 0.25 | 8.01 |
| | 2.528 | 5.82 | 0.13 | 8.01 |
| | 3.371 | 4.99 | 0.07 | 8.01 |
| | 4.213 | 4.29 | 0.03 | 8.01 |
| | 5.056 | 3.68 | 0.02 | 8.01 |
| | 5.899 | 3.16 | 0.01 | 8.01 |
| | 6.741 | 2.71 | 0.00 | 8.01 |
| | 7.584 | 2.33 | 0.00 | 8.01 |
| | 8.427 | 2.00 | 0.00 | 8.01 |

APPENDIX C

TRC ANALYSIS

| 1A | B | C | D | E | F | G |
|----|---|---|-------------------------------|--------------------------------------|---------------------|---|
| 2 | TRC EVALUATION Herrick Twp PA0114561 | | | | | |
| 3 | Input appropriate values in B4:B8 and E4:E7 | | | | | |
| 4 | 0.034 | = Q stream (cfs) | 0.5 | = CV Daily | | |
| 5 | 0.01 | = Q discharge (MGD) | 0.5 | = CV Hourly | | |
| 6 | 30 | = no. samples | 1 | = AFC_Partial Mix Factor | | |
| 7 | 0.3 | = Chlorine Demand of Stream | 1 | = CFC_Partial Mix Factor | | |
| 8 | 0 | = Chlorine Demand of Discharge | 15 | = AFC_Criteria Compliance Time (min) | | |
| 9 | 0.5 | = BAT/BPJ Value | 720 | = CFC_Criteria Compliance Time (min) | | |
| | 0 | = % Factor of Safety (FOS) | 0 | = Decay Coefficient (K) | | |
| 10 | Source | Reference | AFC Calculations | Reference | CFC Calculations | |
| 11 | TRC | 1.3.2.iii | WLA_afc = 0.720 | 1.3.2.iii | WLA_cfc = 0.695 | |
| 12 | PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | 5.1c | LTAMULT_cfc = 0.581 | |
| 13 | PENTOXSD TRG | 5.1b | LTA_afc= 0.268 | 5.1d | LTA_cfc = 0.404 | |
| 14 | | | | | | |
| 15 | Source | Effluent Limit Calculations | | | | |
| 16 | PENTOXSD TRG | 5.1f | AML MULT = 1.231 | | | |
| 17 | PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.330 | AFC | | |
| 18 | | | INST MAX LIMIT (mg/l) = 1.080 | | | |
| | | | | | | |
| | WLA_afc | $(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)]^*(1-FOS/100)$ | | | | |
| | LTAMULT_afc | $\text{EXP}((0.5^{\text{LN}}(\text{cvh}^2+1))-2.326^{\text{LN}}(\text{cvh}^2+1)^{0.5})$ | | | | |
| | LTA_afc | wla_afc*LTAMULT_afc | | | | |
| | WLA_cfc | $(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)]^*(1-FOS/100)$ | | | | |
| | LTAMULT_cfc | $\text{EXP}((0.5^{\text{LN}}(\text{cvd}^2+1))-2.326^{\text{LN}}(\text{cvd}^2+1)^{0.5})$ | | | | |
| | LTA_cfc | wla_cfc*LTAMULT_cfc | | | | |
| | AML MULT | $\text{EXP}(2.326^{\text{LN}}((\text{cvd}^2/\text{no_samples}+1)^{0.5})-0.5^{\text{LN}}(\text{cvd}^2/\text{no_samples}+1))$ | | | | |
| | AVG MON LIMIT | $\text{MIN}(\text{BAT_BPJ},\text{MIN}(\text{LTA_afc},\text{LTA_cfc})*\text{AML_MULT})$ | | | | |
| | INST MAX LIMIT | $1.5^*((\text{av_mon_limit}/\text{AML_MULT})/\text{LTAMULT_afc})$ | | | | |

APPENDIX D

FACILITY MAP

