

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0114758  
 APS ID 1046525  
 Authorization ID 1366921

**Applicant and Facility Information**

Applicant Name	<u>GSP Management Co.</u>	Facility Name	<u>Bucknell View MHP</u>
Applicant Address	<u>PO Box 677</u> <u>Morgantown, PA 19543-0677</u>	Facility Address	<u>PA Route 405</u> <u>Milton, PA 17847, Regional Manager</u>
Applicant Contact	<u>Frank Perano, COO</u>	Facility Contact	<u>Leanne Miller</u>
Applicant Phone	<u>(610) 286-0490</u>	Facility Phone	<u>(717) 577-6240</u>
Client ID	<u>33789</u>	Site ID	<u>240925</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>West Chillisquaque Township</u>
Connection Status	<u>N/A</u>	County	<u>Northumberland</u>
Date Application Received	<u>August 23, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 30, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES permit</u>		

**Summary of Review**

The subject facility is a sewage treatment plant serving a mobile home park in West Chillisquaque Township, Northumberland County. A map indicating the discharge location is attached (Attachment A).

Sludge use and disposal description and location(s): Per the application the facility's sludge is sent to other WWTPs for further processing in the past year and approximately 0.9 tons of sludge were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	December 2, 2021
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	December 3, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0186</u>
Latitude	<u>40° 57' 26.33"</u>	Longitude	<u>-76° 52' 32.73"</u>
Quad Name	<u>Northumberland, PA</u>	Quad Code	<u>1131</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>West Branch Susquehanna River (WWF, MF)</u>	Stream Code	<u>18668</u>
NHD Com ID	<u>66920535</u>	RMI	<u>7.13</u>
Drainage Area	<u>6848 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.122</u>
Q <sub>7-10</sub> Flow (cfs)	<u>838</u>	Q <sub>7-10</sub> Basis	<u>USGS Gage 01553500, West Branch Susquehanna R. @ Lewisburg</u>
Elevation (ft)	<u>433</u>	Slope (ft/ft)	<u>0.00015</u>
Watershed No.	<u>10-C</u>	Chapter 93 Class.	<u>WWF, MF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>POLYCHLORINATED BIPHENYLS (PCBS)</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	<u>Final</u>	Name	<u>West Branch Susquehanna</u>
Nearest Downstream Public Water Supply Intake	<u>Sunbury Municipal Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>1740</u>
PWS RMI	<u>124</u>	Distance from Outfall (mi)	<u>Approx. 8</u>

Changes Since Last Permit Issuance: The above stream and drainage characteristics were determined in the previous review and remain adequate.

Other Comments: The discharge is not expected to be contributing to the impairment to the River by PCBs. The TMDL for the West Branch addresses AMD impairment upstream and this discharge is not identified as a contributor to the impairment in the TMDL.

The discharge is not expected to affect any downstream water supply at this time with the limitations and monitoring proposed.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Bucknell View Mobile Home Park				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
4992401		06/09/1992		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Hypochlorite	0.0186
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0186	38.7	Not Overloaded	Aerated Digester	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The treatment facility consists of an influent pump station, comminutor, equalization tank, two aeration tanks, clarifier, sodium hypochlorite feed, chlorine contact tank, dechlorination, and aerated sludge digester.

**Compliance History**

**DMR Data for Outfall 001 (from October 1, 2020 to September 30, 2021)**

Parameter	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20
Flow (MGD) Average Monthly	0.0083	0.0061	0.0061	0.005	0.0047	0.0053	0.0045	0.0038	0.0032	0.004	0.00341	0.0036
pH (S.U.) Minimum	7.1	7.1	7.1	7.1	7.0	7.1	7.1	7.1	7.2	7.1	7.2	7.1
pH (S.U.) Maximum	7.5	7.3	7.3	7.3	7.5	7.3	7.4	7.5	7.7	7.7	7.7	7.6
DO (mg/L) Minimum	2.2	3.0	2.4	4.5	2.3	2.9	5.5	5.5	5.8	7.7	8.3	7.0
TRC (mg/L) Average Monthly	< 0.02	< 0.03	0.04	< 0.1	< 0.01	< 0.02	0.02	0.01	< 0.01	< 0.01	< 0.01	< 0.01
TRC (mg/L) Instantaneous Maximum	0.05	0.13	0.43	0.38	0.05	0.07	0.09	0.03	0.05	0.04	0.02	0.02
CBOD5 (mg/L) Average Monthly	< 3	6.0	3	8	< 3	6	5	9.07	< 3.0	< 3.0	< 3.0	< 3.0
TSS (mg/L) Average Monthly	< 5	< 5.0	< 5	< 5	< 5	7	11	8.5	7.0	5.0	4.0	12
Fecal Coliform (CFU/100 ml) Geometric Mean	1	44	28	41	88	5	16	50	< 1.0	< 19.0	< 1.0	< 4
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	2	219	86	61	1553	7	1986	613	< 1.0	378.4	< 1.0	16
Ammonia (mg/L) Average Monthly	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 1	< 0.1	< 0.1	< 0.1	< 0.1

**Compliance History, Cont'd**

**Effluent Violations for Outfall 001, from: October 1, 2020 to September 30, 2021**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	05/31/21	IMAX	1553	CFU/100 ml	1000	CFU/100 ml

**Compliance History, Cont'd**

<b>Summary of Inspections:</b>	The facility has been inspected at least annually by the Department during the past permit term, most recently on March 30, 2021. This inspection identified no violations at the time of inspections.
<b>Other Comments:</b>	A WMS query found the open violations listed below in eFACTS for GSP Management Co.

**Open Violations for GSP Management Co.**

FACILITY	INSP_PROGRAM	PROGRAM SPECIFIC_ID	VIOLATION DATE	VIOLATION	REGION
MOUNTAIN VIEW TERRACE	Safe Drinking Water	7670025	11/17/2021	FAILURE OF A PUBLIC WATER SYSTEM TO OBTAIN A PERMIT	SCRO
MOUNTAIN VIEW TERRACE	Safe Drinking Water	7670025	11/17/2021	FAILURE TO MEET DESIGN AND CONSTRUCTION STANDARDS	SCRO
MOUNTAIN VIEW TERRACE	Safe Drinking Water	7670025	11/17/2021	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	SCRO
MOUNTAIN VIEW TERRACE	Safe Drinking Water	7670025	11/17/2021	FAILURE OF AN OWNER TO ENSURE THAT PROCESS CONTROL DECISIONS ARE MADE BY AN AVAILABLE OPERATOR	SCRO
SHADYBACK ACRES MHP	WPC NPDES	PA0087696	6/11/2020	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance	SCRO
SHADYBACK ACRES MHP	WPC NPDES	PA0087696	10/27/2021	NPDES - Violation of Part C permit condition(s)	SCRO

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.0186</u>
<b>Latitude</b> <u>40° 57' 30.50"</u>	<b>Longitude</b> <u>-76° 52' 20.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limits are applicable and are included in the existing permit.

**Water Quality-Based Limitations**

**DO, CBOD<sub>5</sub> and NH<sub>3</sub>-N**

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. Although significant dilution is available in the River (at a ratio of ~45,000:1 at low flow conditions) WQM7.0 modeling was performed at this time because it was not performed for the previous reviews. The modeling shows that the existing limitations are adequate to protect the receiving stream.

**Total Residual Chlorine**

The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's TRC in a receiving stream, accounting for available dilution. TRC modeling was performed at this time because it had not been performed in the previous reviews. The modeling shows that the existing BAT limit of 0.5 mg/L is adequate to protect the receiving stream.

**Chesapeake Bay/Nutrient Requirements**

According to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is an existing Phase 5 Chesapeake Bay sewage discharger that is not expanding, and therefore requires no nutrient loading limits but does require Total Nitrogen and Total Phosphorus monitoring. Annual nutrient monitoring was included in the current permit consistent with the Phase III Watershed Implementation Plan. The results of this monitoring from the eDMR system found the Total Nitrogen to average 24.6 mg/L and the Total Phosphorus to Average 2.6 mg/L. Because nutrient has been performed during the past permit term to characterize the discharge's nutrient load, no further monitoring for nutrients will be required in the proposed permit.

**Toxics Management**

No further "Reasonable Potential Analysis" was performed for this minor sewage facility with no industrial users to determine additional parameters as possible candidates for limitations or monitoring.

**Best Professional Judgment (BPJ) Limitations**

Comments: None needed beyond the limitations mentioned above.

**Anti-Backsliding**

No proposed limitations have been made less stringent consistent with the anti-backsliding provisions of the Clean Water Act and 40 CFR 122.44(l).



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab


Compliance Sampling Location: Outfall 001

Other Comments: The above limitations and monitoring are unchanged from the existing permit expect for the removal of annual Total Nitrogen and Total Phosphorus monitoring are mentioned above. Consistent with recent changes to Chapter 93 of the Department’s regulations and current Department policy E. Coli monitoring has now been included.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 3/24/21
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Model





**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10D	18668	WEST BRANCH SUSQUEHANNA RI	7.130	433.00	6848.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.122	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Bucknell View	PA0114758	0.0186	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Permit No. PA0114758

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10D	18668	WEST BRANCH SUSQUEHANNARI	4.560	431.00	7000.00	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.122	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
10D	18668	WEST BRANCH SUSQUEHANNA RIVER										
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
7.130	835.46	0.00	835.46	.0288	0.00015	1.166	629.73	539.87	1.14	0.138	20.00	7.00
<b>Q1-10 Flow</b>												
7.130	534.69	0.00	534.69	.0288	0.00015	NA	NA	NA	0.89	0.177	20.00	7.00
<b>Q30-10 Flow</b>												
7.130	1136.22	0.00	1136.22	.0288	0.00015	NA	NA	NA	1.35	0.116	20.00	7.00



Permit No. PA0114758

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
10D	18668	WEST BRANCH SUSQUEHANNA RIVER

#### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.130	Bucknell View	16.76	50	16.76	50	0	0

#### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.130	Bucknell View	1.89	25	1.89	25	0	0

#### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
7.130	Bucknell View	25	25	25	25	3	3	0	0

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
10D	18668	WEST BRANCH SUSQUEHANNA RIVER

RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	E fl. Limit 30-day Ave. (mg/L)	E fl. Limit Maximum (mg/L)	E fl. Limit Minimum (mg/L)
7.130	Bucknell View	PA0114758	0.019	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

TRC\_CALC

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
838	= Q stream (cfs)		0.5	= CV Daily
0.0186	= Q discharge (MGD)		0.5	= CV Hourly
30	= no. samples		1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)			= Decay Coefficient (K)
Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 9290.355	1.3.2.iii	WLA_cfc = 9057.361
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 3461.808	5.1d	LTA_cfc = 5265.525
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC\_tc})] \dots$			
	$\dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd) \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1) \cdot 0.5)$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC\_tc})] \dots$			
	$\dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd) \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1) \cdot 0.5)$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1) \cdot 0.5) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	$1.5 \cdot ((av\_mon\_limit / AML\_MULT) / LTAMULT\_afc)$			