

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0114766
 APS ID 1034590
 Authorization ID 1347041

Applicant and Facility Information

Applicant Name	<u>DTAC Diversified Treatment Alternative Center</u>	Facility Name	<u>DTAC Diversified Treatment Alternative Center</u>
Applicant Address	<u>40 Lawton Lane</u> <u>Milton, PA 17847-9756</u>	Facility Address	<u>184 E. Village Drive</u> <u>Williamsport, PA 17702-8023</u>
Applicant Contact	<u>Lisa Olander</u>	Facility Contact	<u>Lisa Olander</u>
Applicant Phone	<u>(412) 913-7343</u>	Facility Phone	<u>(412) 913-7343</u>
Client ID	<u>357203</u>	Site ID	<u>240935</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Susquehanna Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lycoming</u>
Date Application Received	<u>March 23, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>April 1, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of an existing NPDES permit for the discharge of treated sewage.</u>		

Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Additionally, there has been a change in ownership from Behavioral Specialist, Inc. to Diversified Treatment Alternative Center.

Approve	Deny	Signatures	Date
X		<i>Jonathan P. Peterman</i> Jonathan P. Peterman / Project Manager	August 19, 2021
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	August 30, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0032</u>
Latitude	<u>41° 13' 0.47"</u>	Longitude	<u>-77° 6' 43.89"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Bender Run (CWF, MF)</u>	Stream Code	<u>20955</u>
NHD Com ID	<u>66916703</u>	RMI	<u>0.5100</u>
Drainage Area	<u>4.29 mi²</u>	Yield (cfs/mi ²)	<u>0.0746</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.32</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>575</u>	Slope (ft/ft)	<u>0.231</u>
Watershed No.	<u>10-A</u>	Chapter 93 Class.	<u>CWF, MF</u>
Existing Use	<u>None</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>N/A</u>		
Source(s) of Impairment	<u>N/A</u>		
TMDL Status	<u>N/A</u>	Name	<u>N/A</u>
Nearest Downstream Public Water Supply Intake	<u>PA-American Water Company</u>		
	<u>West Branch of Susquehanna</u>		
PWS Waters	<u>River</u>	Flow at Intake (cfs)	<u>682</u>
PWS RMI	<u>10.5</u>	Distance from Outfall (mi)	<u>35</u>

Changes Since Last Permit Issuance: The updated Q₇₋₁₀ data was obtained from the updated stream gage information obtained from *Stuckey, M.H., and Roland, M.A., 2011, Selected Streamflow Statistics for Streamgage Locations In and Near Pennsylvania*. A comparative stream analysis was conducted using a comparative stream gage based on basin characteristics. The Q₇₋₁₀ calculations indicate that the Q₇₋₁₀ is 0.32 cfs.

Other Comments: None.

Treatment Facility Summary				
Treatment Facility Name: Diversified Treatment Alternative Center - Nisbet Elementary School				
WQM Permit No.		Issuance Date		
4191403		Original – 08/12/91		
4191403 T-1		Transfer – 07/11/11		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Sequencing Batch Reactor W/Sol Removal	Hypochlorite	0.0032
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0032	3.1	Not Overloaded	None	Other WWTP

Treatment System Components for Outfall 001:

- One (1) Sequencing Batch Reactor (SBR).
- One (1) Sand Filter.
- One (1) Erosion chlorinator.
- One (1) Chlorine contact tank.
- One (1) Outfall 001.

Sludge use and disposal description and location(s): None listed.

Changes Since Last Permit Issuance: None.

Other Comments: Typical flows from the facility average 600 gpd. Per facility inspection reports, the facility serves no more than 50 people for 5 days a week.

Anti-Backsliding

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

Chesapeake Bay Requirements

Since this facility’s annual average design flow is 0.0032 MGD, the permittee will be required to monitor and report TN and TP throughout the permit term at a frequency no less than annually in accordance with the Phase II WIP Chesapeake Bay Strategy for Phase V facilities (0.002 MGD to 0.2 MGD) unless 1) the facility has already conducted at least two years of nutrient monitoring and 2) a summary of the monitoring results are included in the next permit’s fact sheet. The previous permit contained the results from the Chesapeake Bay Monitoring requirements and removed the monitoring requirements. The summarized results for this monitoring are contained below and the full data set is contained in Appendix D. Since the permittee conducted this monitoring in the previous permit term and the data is summarized in the fact sheet below, the conditions have been met and Chesapeake Bay monitoring will not be required.

Existing Effluent Limitations and Monitoring Requirements

Existing Limits – Outfall 001

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	5/week	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	5/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	5/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25	XXX	50	1/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	1/month	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/month	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/month	Grab
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/year	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/year	Grab

*The existing effluent limits for Outfall 001 were based on a design flow of 0.0032 MGD.

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 0.0032
 Latitude 41° 13' 0.47" Longitude -77° 6' 43.89"
 Wastewater Description: Treated Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform	1,000 / 100 ml	IMAX	-	92a.47(a)(4)

(5/1 – 9/30)				
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

To establish whether or not water-quality based effluent limitations (WQBELs) are required, the Department models in-stream conditions. In order to determine limitations for CBOD5, ammonia-N and dissolved oxygen, the Department utilizes the WQM 7.0 v1.0b model and in order to determine limitations for toxics, the Department utilizes the Toxics Management Spreadsheet. The Toxics Management Spreadsheet was not utilized in this review.

WQM 7.0 for Windows, Version 1.0b, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen

The previous model was run using the latest information on Q7-10 stream flow, background water quality, average annual design flow, and other discharge characteristics. There have been no changes to the watershed or discharge characteristics, therefore the previous modeling is still valid. The existing technology-based effluent limits for CBOD₅ (25 mg/l) and for NH₃-N (25 mg/l) were used as inputs for the modeling. The DO minimum daily average criterion from §93.7 (5.0 mg/L for CWF) was used for the in-stream objective for the model. The summary of the output is as follows:

Parameter	Effluent Limit		
	30 Day Average	Maximum	Minimum
CBOD5	25	N/A	N/A
Ammonia-N	25	50	N/A
Dissolved Oxygen	N/A	N/A	3

The previous model did not recommend water-quality based effluent limitations with regards to CBOD5, ammonia-nitrogen, and dissolved oxygen. Refer to Appendix A for the WQM 7.0 inputs and results. The existing limits will remain.

Best Professional Judgment (BPJ) Limitations

See the Dissolved Oxygen section below.

Additional Considerations

None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

Proposed Limits - Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD ₅)	XXX	XXX	XXX	25	XXX	50	1/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
E. Coli	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

*The proposed effluent limits for Outfall 001 were based on a design flow of 0.0032 MGD.

Effluent Limit Determination for Outfall 001

General Information

All effluent limits were then rounded down in accordance with the rounding rules established in the *Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001)*, Chapter 5 - Specifying Effluent Limitations in NPDES Permits. The existing monitoring frequencies and sample types for these parameters generally correspond with the *Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001)* Table 6-3 and will remain.

Flow

Reporting of the weekly maximum flow is consistent with monitoring requirements for other treatment plants and will remain.

Carbonaceous Biochemical Oxygen Demand (CBOD₅)

The results of the WQM 7.0 model show that the previously applied secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for CBOD₅ are protective of water quality and will remain.

Total Suspended Solids (TSS)

The previously applied technology based secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for TSS will remain as well.

pH

CFR Title 40 §133.102(c) and 25 PA Code §95.2(1) provide the basis of effluent limitations for pH.

Total Residual Chlorine (TRC)

In accordance with 25 Pa. Code 92a.48(b)(2), a best available technology (BAT) value of 0.5 mg/l was used in the TRC Spreadsheet. The attached TRC model indicates that the technology-based effluent limit of 0.5 mg/L (Average Monthly) and 1.6 mg/L (Instantaneous Maximum) are protective of water quality. The existing limits will remain.

Fecal Coliforms

The existing fecal coliform limits with I-max limits were previously updated from the previous Chapter 92 code to correspond with what is specified in the updated 25 PA Code § 92a.47 (a)(4)&(5). The existing effluent limits will remain.

Ammonia-Nitrogen (NH3-N)

The results of the WQM 7.0 model show that the existing monitoring requirement for ammonia-nitrogen is appropriate and will remain.

Dissolved Oxygen (DO)

25 PA Code §93.7 provides specific water quality criteria for DO and monitoring for this parameter will ensure that the facility is not creating or contributing to an in-stream excursion below these water quality standards. Additionally, the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001) lists DO under the self-monitoring requirements for sewage discharges and monitoring of DO is consistent with other discharges of this size and type.

E. Coli

25 PA Code § 92a.61 provide the basis of monitoring requirements for E. Coli. Yearly monitoring will be required going forward.

Compliance History

Summary of Inspections -The most recent Clean Water Program onsite inspections for this facility were a Compliance Evaluation Inspection on 7/1/19. Some minor effluent exceedances were noted during this inspection.

WMS Query Summary - A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed no open violations.

eDMRs Summary - Upon review of the eDMR's, the facility has generally been in compliance with the existing effluent limits. There was a minor exceedance of TRC effluent limits in February of 2021. The issue was resolved by the next month.

Compliance History

DMR Data for Outfall 001 (from July 1, 2020 to June 30, 2021)

Parameter	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20
Flow (MGD) Average Monthly	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006
pH (S.U.) Minimum	7.3	7.3	7.4	7.5	7.6	7.6	7.8	7.0	7	6.8	6.9	6.6
pH (S.U.) Maximum	8.4	8.9	8.4	8.0	8.4	8	8.2	8.1	7.3	7.3	7.2	6.9
DO (mg/L) Minimum	7.3	6.0	6.2	8.6	7.8	8.6	10	8.6	7.6	6.2	6.4	6.2
TRC (mg/L) Average Monthly	0.4	0.3	0.3	0.5	0.7	0.1	0.5	0.4	0.5	0.2	0.1	0.1
TRC (mg/L) Instantaneous Maximum	0.6	0.5	0.9	0.8	1	0.8	0.7	0.6	0.6	0.5	0.6	0.6
CBOD5 (mg/L) Average Monthly	2	2.1	2.2	2	2	2.1	2	2.2	2	2	2	2
CBOD5 (mg/L) Instantaneous Maximum	2	2.1	2.2	2	2	2.1	2	2.2	2	2	2	2
TSS (mg/L) Average Monthly	4	4	4	4	4	4	4	4	4	4	4	4
TSS (mg/L) Instantaneous Maximum	4	4	4	4	4	4	4	4	4	4	4	4
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 8
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 8
Total Nitrogen (lbs/day) Average Monthly							0.03					
Total Nitrogen (mg/L) Average Monthly							6					
Ammonia (mg/L) Average Monthly	0.1	0.1	4	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1

**NPDES Permit Fact Sheet
DTAC Diversified Treatment Alternative Center**

NPDES Permit No. PA0114766

Total Phosphorus (lbs/day) Average Monthly							0.015					
Total Phosphorus (mg/L) Average Monthly							3					

Compliance History

Effluent Violations for Outfall 001, from: August 1, 2020 To: June 30, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	02/28/21	Avg Mo	0.7	mg/L	0.5	mg/L

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment A)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment B)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

APPENDIX A

WQM 7.0 MODEL RESULTS

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10A	20955	BENDER RUN	0.550	575.00	4.29	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.075	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
BSI, Inc	PA0114766	0.0032	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10A	20955	BENDER RUN	0.100	520.00	4.50	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.075	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
10A		20955				BENDER RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
0.550	0.32	0.00	0.32	.005	0.02315	.436	8.08	18.53	0.09	0.298	20.08	7.00
Q1-10 Flow												
0.550	0.20	0.00	0.20	.005	0.02315	NA	NA	NA	0.07	0.381	20.12	7.00
Q30-10 Flow												
0.550	0.44	0.00	0.44	.005	0.02315	NA	NA	NA	0.11	0.251	20.06	7.00

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
10A	20955	BENDER RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.550	BSI, Inc	9.59	50	9.59	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.550	BSI, Inc	1.91	25	1.91	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.55	BSI, Inc	25	25	25	25	3	3	0	0

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
10A		20955		BENDER RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.550	BSI, Inc	PA0114766	0.003	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
10A	20955	BENDER RUN			
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
0.550	0.003	20.076		7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
8.077	0.436	18.527		0.092	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
2.35	0.202	0.38		0.704	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
8.163	20.461	Owens		6	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>				
0.298	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.030	2.34	0.37	8.23	
	0.060	2.32	0.37	8.23	
	0.089	2.31	0.36	8.23	
	0.119	2.29	0.35	8.23	
	0.149	2.28	0.34	8.23	
	0.179	2.27	0.34	8.23	
	0.209	2.25	0.33	8.23	
	0.238	2.24	0.32	8.23	
	0.268	2.23	0.32	8.23	
	0.298	2.21	0.31	8.23	


APPENDIX B


TRC ANALYSIS SPREADSHEET

1A	B	C	D	E	F	G
2	TRC EVALUATION			DTAC		
3	Input appropriate values in B4:B8 and E4:E7					
4	0.32	= Q stream (cfs)		0.5	= CV Daily	
5	0.0032	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations		Reference	CFC Calculations
11	TRC	1.3.2.iii	WLA afc = 20.640		1.3.2.iii	WLA cfc = 20.114
12	PENTOXSD TRG	5.1a	LTAMULT afc = 0.373		5.1c	LTAMULT cfc = 0.581
13	PENTOXSD TRG	5.1b	LTA_afc = 7.691		5.1d	LTA_cfc = 11.694
14						
15	Source		Effluent Limit Calculations			
16	PENTOXSD TRG	5.1f	AML MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
18			INST MAX LIMIT (mg/l) = 1.635			
	WLA afc	(.019/e ^(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e ^(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
	LTAMULT afc	EXP((0.5*LN(cvh ² +1))-2.326*LN(cvh ² +1) ^{0.5})				
	LTA_afc	wla_afc*LTAMULT_afc				
	WLA_cfc	(.011/e ^(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e ^(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
	LTAMULT_cfc	EXP((0.5*LN(cvd ² /no_samples+1))-2.326*LN(cvd ² /no_samples+1) ^{0.5})				
	LTA_cfc	wla_cfc*LTAMULT_cfc				
	AML MULT	EXP(2.326*LN((cvd ² /no_samples+1) ^{0.5})-0.5*LN(cvd ² /no_samples+1))				
	AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
	INST MAX LIMIT	1.5*(av_mon_limit/AML_MULT)/LTAMULT_afc				

APPENDIX C

FACILITY MAP AND SCHEMATIC



		
--	--	---

APPENDIX D

eDMR NUTRIENT DATA

DMR RECEIVED DATE	REPORT STATUS	DMR VERSION 1 LATE IND	OUTFALL	DISCHARGE	MONITORING LOCATION	PARAMETER CODE	PARAMETER	LOAD UNITS	LOAD 1 VALUE	LOAD 1 LIMIT	LOAD 1 SBC	CONC UNITS	CONC 2 VALUE	CONC 2 LIMIT	CONC 2 SBC	SAMPLE FREQUENCY	SAMPLETYPE
04/10/2019	Submitted	Yes	001	Yes	Final Effluent	00600	Total Nitrogen	lbs/day	1.7	Monitor and Report	Average Monthly	mg/L	1.7	Monitor and Report	Average Monthly	1/year	Grab
01/06/2020	Submitted	No	001	Yes	Final Effluent	00600	Total Nitrogen	lbs/day	0.17	Monitor and Report	Average Monthly	mg/L	33	Monitor and Report	Average Monthly	1/year	Grab
12/21/2020	Submitted	No	001	Yes	Final Effluent	00600	Total Nitrogen	lbs/day	0.03	Monitor and Report	Average Monthly	mg/L	6	Monitor and Report	Average Monthly	1/year	Grab
04/10/2019	Submitted	Yes	001	Yes	Final Effluent	00665	Total Phosphorus	lbs/day	3.2	Monitor and Report	Average Monthly	mg/L	3.2	Monitor and Report	Average Monthly	1/year	Grab
01/06/2020	Submitted	No	001	Yes	Final Effluent	00665	Total Phosphorus	lbs/day	0.014	Monitor and Report	Average Monthly	mg/L	2.8	Monitor and Report	Average Monthly	1/year	Grab
12/21/2020	Submitted	No	001	Yes	Final Effluent	00665	Total Phosphorus	lbs/day	0.015	Monitor and Report	Average Monthly	mg/L	3	Monitor and Report	Average Monthly	1/year	Grab