

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0114936  
APS ID 1050595  
Authorization ID 1374385

**Applicant and Facility Information**

|                           |   |                  |  |
|---------------------------|---|------------------|--|
| Applicant Name            | <u>BCI Municipal Authority</u>                    | Facility Name    | <u>BCI Municipal Authority STP</u>                         |
| Applicant Address         | <u>PO Box 388</u><br><u>Irvona, PA 16656-0388</u> | Facility Address | <u>625 Cressview Street Ext</u><br><u>Irvona, PA 16656</u> |
| Applicant Contact         | <u>Jack Laing</u>                                 | Facility Contact | <u>Richard Hoover</u>                                      |
| Applicant Phone           | <u>(814) 672-4103</u>                             | Facility Phone   | <u>814-672-5745</u>  |
| Client ID                 | <u>44363</u>                                      | Site ID          | <u>255486</u>  |
| Ch 94 Load Status         | <u>Not Overloaded</u>                             | Municipality     | <u>Irvona Borough</u>                                      |
| Connection Status         | <u>No Limitations</u>                             | County           | <u>Clearfield</u>  |
| Date Application Received | <u>October 29, 2021</u>                           | EPA Waived?      | <u>Yes</u>   |
| Date Application Accepted | <u>11/15/2021</u>                                 | If No, Reason    | <u></u>  |
| Purpose of Application    | <u>Renewal of Existing NPDES Permit</u>           |                  |  |

**Summary of Review**

BCI Municipal Authority has submitted an NPDES renewal application for their existing outfall to Clearfield Creek from their Wastewater Treatment Plant (WWTP) in Clearfield County, PA. The 0.3 MGD treatment plant serves Irvona Borough, Coalport Borough, and Beccaria Township. There are 46 commercial connections within the sewer system, none of which are considered significant industrial users. The facility does not accept any hauled in wastes.

The treatment facility utilizes an extended aeration process. Treatment consists of a wet well, grinder pumps, two aeration tanks, two clarifiers, two chlorination units with contact tanks, two sludge digesters, and a belt filter press.

Unless otherwise noted, all of the Department's applicable Standard Operating Procedures (SOPs) were used in developing the following fact sheet.

Sludge use and disposal description and location(s): Laurel Highland Landfill in Johnstown, PA.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures   | Date              |
|---------|------|--|-------------------|
| X       |      | <i>Chad A. Fabian</i><br>Chad A. Fabian / Project Manager  | September 1, 2022 |
| X       |      | <i>Nicholas W. Hartranft, P.E.</i><br>Nicholas W. Hartranft, P.E. / Environmental Engineer Manager | September 6, 2022 |

| Discharge, Receiving Waters and Water Supply Information |  |                              |                   |
|--|--|------------------------------|-------------------|
| Outfall No.  | 001  | Design Flow (MGD)            | 0.3               |
| Latitude   | 40° 46' 31.58"   | Longitude                    | -78° 32' 50.64"   |
| Quad Name  | Irvona   | Quad Code                    |                   |
| Wastewater Description: Sewage Effluent                  |  |                              |                   |
| Receiving Waters   | Clearfield Creek   | Stream Code                  | 26107             |
| NHD Com ID   | 61834927   | RMI                          | 38.8              |
| Drainage Area  | 194 mi <sup>2</sup>  | Yield (cfs/mi <sup>2</sup> ) | 0.065             |
| Q <sub>7-10</sub> Flow (cfs)                             | 12.6   | Q <sub>7-10</sub> Basis      | USGS Stream Stats |
| Elevation (ft)   | 1380   | Slope (ft/ft)                | 0.0047            |
| Watershed No.  | 8-C  | Chapter 93 Class.            | WWF, MF           |
| Existing Use   | WWF, MF  | Existing Use Qualifier       | n/a               |
| Exceptions to Use  | None   | Exceptions to Criteria       | None              |
| Assessment Status  | Impaired   |                              |                   |
| Cause(s) of Impairment                                   | Metals   |                              |                   |
| Source(s) of Impairment                                  | Abandoned Mine Drainage  |                              |                   |
| TMDL Status  | Final  | Name                         | Clearfield Creek  |
| Nearest Downstream Public Water Supply Intake            | Shawville Power Generation Plant, approximately 41 miles downstream on the West Branch Susquehanna River |                              |                   |

Changes Since Last Permit Issuance: None

Other Comments: The TMDL does not list the above discharge as a cause of impairment nor does it allocate a waste load for metals.

| Compliance History             |  |
|--------------------------------|--|
| <b>Summary of eDMRs:</b>       | No effluent violations have been reported at the facility in the past 12 months. See below section regarding inspections.  |
| <b>Summary of Inspections:</b> | The latest inspection performed at the facility was done on 8/17/2022. A violation was noted for failure to monitor dissolved oxygen on some weekends during the months of April and June of 2022. This issue has been resolved. |

| Development of Effluent Limitations |                 |                   |                 |  |
|-------------------------------------|-----------------|-------------------|-----------------|--|
| Outfall No.                         | 001             | Design Flow (MGD) | 0.3             |  |
| Latitude                            | 40° 46' 35.50"  | Longitude         | -78° 32' 48.80" |  |
| Wastewater Description:             | Sewage Effluent |                   |                 |  |

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant                    | Limit (mg/l)    | SBC             | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD <sub>5</sub>            | 25              | Average Monthly | 133.102(a)(4)(i)   | 92a.47(a)(1)     |
|                              | 40              | Average Weekly  | 133.102(a)(4)(ii)  | 92a.47(a)(2)     |
| Total Suspended Solids       | 30              | Average Monthly | 133.102(b)(1)      | 92a.47(a)(1)     |
|                              | 45              | Average Weekly  | 133.102(b)(2)      | 92a.47(a)(2)     |
| pH                           | 6.0 – 9.0 S.U.  | Min – Max       | 133.102(c)         | 95.2(1)          |
| Fecal Coliform (5/1 – 9/30)  | 200 / 100 ml    | Geo Mean        | -                  | 92a.47(a)(4)     |
| Fecal Coliform (5/1 – 9/30)  | 1,000 / 100 ml  | IMAX            | -                  | 92a.47(a)(4)     |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml  | Geo Mean        | -                  | 92a.47(a)(5)     |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX            | -                  | 92a.47(a)(5)     |
| Total Residual Chlorine      | 0.5             | Average Monthly | -                  | 92a.48(b)(2)     |

Comments: None

**Water Quality-Based Limitations**

The Department's WQM 7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. WQM 7.0 modeling was previously performed for the discharge. The results of the previous modeling shows that the existing limitations are protective of water quality standards. Per the Department's SOP for reissuance of NPDES permits, additional modeling is not required since there has been no change to the wastewater characteristics or the receiving stream.

Previously, a "Reasonable Potential Analysis" using the Department's PENTOXSD 2.0 model determined no monitoring requirements or effluent limitations for toxics were needed to protect water quality. Due the size of the facility and lack of industrial users, no toxics are required to be monitored and reported within the renewal application. However, the applicant did report results for total copper, total lead, and total zinc. All reported levels of the respective parameters are less than the values evaluated during the previous reasonable potential analysis. Therefore, per the aforementioned SOP, no additional modeling is required at this time.

A chlorine spreadsheet analysis shows that the technology standard of 0.5 mg/l monthly average limitation is protective of water quality.

**Best Professional Judgment (BPJ) Limitations**

During the existing permit cycle, the facility has been required to monitor and report total aluminum, total manganese, and total iron due to the metals impairment listed in the TMDL. As previously stated, the discharge is not identified as a contributing factor, as acid mine drainage (AMD) is the cause of impairment. The following is a summary of the results of this monitoring:

| Parameter       | Maximum Result        |
|-----------------|-----------------------|
| Total Aluminum  | 0.1 mg/l (non-detect) |
| Total Manganese | 0.09 mg/l             |
| Total Iron      | 0.3 mg/l              |

Since the monitoring results show that the facility is not contributing to the impairment, it is recommended that monitoring for the respective parameters be eliminated from this draft permit.

**Chesapeake Bay Nutrient Requirements**

According to the Department's Chesapeake Bay Watershed Implementation Plan (WIP III) Supplemental, the facility is classified as a Phase 4 discharger and is subject to 1/month monitoring for total nitrogen and total phosphorus.

**Anti-Backsliding**

This draft permit will not propose to reduce any existing effluent limitations.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter                                     | Effluent Limitations                |                  |                       |                  |                |                  | Monitoring Requirements                      |                      |
|---|-------------------------------------|------------------|-----------------------|------------------|----------------|------------------|--|----------------------|
|   | Mass Units (lbs/day) <sup>(1)</sup> |                  | Concentrations (mg/L) |                  |                |                  | Minimum <sup>(2)</sup> Measurement Frequency | Required Sample Type |
|   | Average Monthly                     | Weekly Average   | Minimum               | Average Monthly  | Weekly Average | Instant. Maximum |  |                      |
| Flow (MGD)                                    | Report                              | Report Daily Max | XXX                   | XXX              | XXX            | XXX              | Continuous                                   | Metered              |
| pH (S.U.)                                     | XXX                                 | XXX              | 6.0                   | XXX              | 9.0 Max        | XXX              | 1/day  | Grab                 |
| DO  | XXX                                 | XXX              | Report                | XXX              | XXX            | XXX              | 1/day  | Grab                 |
| TRC   | XXX                                 | XXX              | XXX                   | 0.5              | XXX            | 1.6              | 1/day  | Grab                 |
| CBOD5   | 63                                  | 100              | XXX                   | 25               | 40             | 50               | 1/week                                       | 8-Hr Composite       |
| TSS   | 75                                  | 113              | XXX                   | 30               | 45             | 60               | 1/week                                       | 8-Hr Composite       |
| Fecal Coliform (No./100 ml)<br>Oct 1 - Apr 30 | XXX                                 | XXX              | XXX                   | 2000<br>Geo Mean | XXX            | 10000            | 1/week                                       | Grab                 |
| Fecal Coliform (No./100 ml)<br>May 1 - Sep 30 | XXX                                 | XXX              | XXX                   | 200<br>Geo Mean  | XXX            | 1000             | 1/week                                       | Grab                 |
| Total Nitrogen                                | XXX                                 | XXX              | XXX                   | Report           | XXX            | XXX              | 1/month                                      | 8-Hr Composite       |
| Total Phosphorus                              | XXX                                 | XXX              | XXX                   | Report           | XXX            | XXX              | 1/month                                      | 8-Hr Composite       |
| BOD5<br>Raw Sewage Influent                   | Report                              | Report           | XXX                   | Report           | XXX            | XXX              | 1/week                                       | 8-Hr Composite       |
| TSS<br>Raw Sewage Influent                    | Report                              | Report           | XXX                   | Report           | XXX            | XXX              | 1/week                                       | 8-Hr Composite       |
| e. Coli                                       | XXX                                 | XXX              | XXX                   | Report           | XXX            | XXX              | 1/quarter                                    | Grab                 |

Other Comments: All of the above effluent limitations and monitoring frequencies are the same as the existing permit, with the exception of the elimination of the TMDL related metals as described above and the addition of E. coli monitoring in accordance with the Department's SOP for reissuance of NPDES permits. It is recommended a draft permit be sent as described within this fact sheet.