

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0115363  
APS ID 1084048  
Authorization IC 1431990

**Applicant and Facility Information**

Applicant Name	<u>Buffalo Township Municipal Sewer Authority</u>	Facility Name	<u>Mazeppa Village Sewer System STP</u>
Applicant Address	<u>2188 Johnson Mill Road</u> <u>Lewisburg, PA 17837-7704</u>	Facility Address	<u>2188 Johnson Mill Road</u> <u>Lewisburg, PA 17837-7704</u>
Applicant Contact	<u>Daryl Beiler, Chairman</u>	Facility Contact	<u>Daryl Beiler, Chairman</u>
Applicant Phone	<u>(570) 966-4004</u>	Facility Phone	<u>(570) 966-4004</u>
Client ID	<u>41099</u>	Site ID	<u>245384</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Buffalo Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Union</u>
Date Application Received	<u>March 20, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES permit for a discharge of treated sewage</u>		



**Summary of Review**

The subject facility is a municipal wastewater treatment plant serving the area of the village of Mazeppa in Buffalo Township, Union County. A map of the discharge location is attached.

Sludge use and disposal description and location(s): The facility's sludge is sent to other wastewater treatment facilities for further processing. Per the application 4.789 tons were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		 Keith C. Allison / Project Manager	September 26, 2023
✓		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	September 26, 2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.08</u>
Latitude	<u>40° 58' 29.55"</u>	Longitude	<u>-76° 58' 40.73"</u>
Quad Name	<u>Lewisburg, PA</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Buffalo Creek</u>	Stream Code	<u>18920</u>
NHD Com ID	<u>66920507</u>	RMI	<u>8.21</u>
Drainage Area	<u>78.5 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.125</u>
Q <sub>7-10</sub> Flow (cfs)	<u>9.81</u>	Q <sub>7-10</sub> Basis	<u>USGS gage No. 01555000, Penns Creek at Penns Creek, PA. (1931-2008)</u>
Elevation (ft)	<u>482.1</u>	Slope (ft/ft)	<u>0.00184</u>
Watershed No.	<u>10-C</u>	Chapter 93 Class.	<u>TSE, MF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>PATHOGENS</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	<u></u>	Name	<u></u>
Nearest Downstream Public Water Supply Intake	<u>Sunbury Municipal Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Distance from Outfall (mi)	<u>Approx. 13</u>

Changes Since Last Permit Issuance: None

Other Comments:

Because there is no Final TMDL for the impairment to Buffalo Creek, no changes to the permit limits or monitoring will be made at this time. Per a review of the facility DMRs, the Mazeppa Village STP generally meets its Fecal Coliform limits. This permit will also include periodic e. coli sampling.

No downstream public water supply is expected to be affected by this discharge at this time with the monitoring and limitations proposed.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Village Of Mazeppa STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>	<b>Permit Covered:</b>		
6097401	7/18/1997	Construction of additional 40,000 gpd treatment train and additional collection system serving Vicksburg and Buffalo Crossroads		
6093401	3/29/1993	Construction of initial 40,000 GPD extended aeration plant and sewers for Village of Mazeppa		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Hypochlorite	0.08
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.2	140	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The treatment facility as permitted by WQM Permit Nos. 6093401 and 6097401 consists of bar screen, two equalization tanks, two aeration tanks, two clarifiers, two chlorinators with chlorine contact tanks and two sludge holding tanks in two parallel trains. The first train was permitted by the 1993 WQM permit and the second was added with the 1997 permit.

Compliance History

DMR Data for Outfall 001 (from August 1, 2022 to July 31, 2023)

Parameter	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22
Flow (MGD) Average Monthly	0.043	0.041	0.046	0.047	0.054	0.066	0.08	0.063	0.042	0.038	0.038	0.034
Flow (MGD) Daily Maximum	0.054	0.044	0.056	0.082	0.055	0.080	0.083	0.172	0.062	0.043	0.045	0.038
pH (S.U.) Instantaneous Minimum	7.2	7.1	7.2	7.2	7.2	7.1	7.3	7.2	7.2	7.2	7.2	7.2
pH (S.U.) Instantaneous Maximum	7.8	7.6	7.5	7.5	7.5	7.8	7.9	7.9	7.5	7.5	7.4	7.5
DO (mg/L) Instantaneous Minimum	2.3	2.3	2.1	2.0	1.8	2.4	2.1	2.0	2.4	3.1	2.7	2.6
TRC (mg/L) Average Monthly	0.22	0.25	0.28	0.28	0.17	0.26	0.19	0.11	0.17	0.24	0.21	0.25
TRC (mg/L) Instantaneous Maximum	0.75	0.67	0.75	0.87	0.65	0.60	0.65	0.39	0.52	0.32	0.52	0.71
CBOD5 (lbs/day) Average Monthly	2	2	3	3.0	5	4	2	4	3	2	2	1
CBOD5 (lbs/day) Weekly Average	2	2	4	3.0	6	4	2	4	4	2	3	2
CBOD5 (mg/L) Average Monthly	4.9	4.9	7.2	6.4	10.1	5.9	3.7	9.3	8.7	5.1	7.2	4.7
CBOD5 (mg/L) Weekly Average	5.5	5.4	8.1	7.0	13.9	6.1	4	9.3	10.8	6.2	7.2	6.4
BOD5 (mg/L) Raw Sewage Influent Average Monthly	195	177	170	187	201	222	64	230	214	33	166	146
TSS (lbs/day) Average Monthly	2	4	4	3.0	5	6	4	5	5	4	2	1
TSS (lbs/day) Weekly Average	3	5	5	5.0	8	6	5	5	7	4	2	1
TSS (mg/L) Average Monthly	7	10	11	8.0	11	9	6	13	13	13	6	4

**NPDES Permit Fact Sheet  
Mazeppa Village Sewer System STP**

**NPDES Permit No. PA0115363**

TSS (mg/L) Raw Sewage Influent Average Monthly	239	317	248	291	229	132	125	249	206	275	238	302
TSS (mg/L) Weekly Average	8	15	14	11.0	18	10	8	14	19	13	6	4
Fecal Coliform (No./100 ml) Geometric Mean	34	4	37	5	> 420	176	117	940	38	42	11	4
Fecal Coliform (No./100 ml) Instantaneous Maximum	49	4	108	5	> 2420	214	186	> 2420	40	70	20	6
Ammonia (mg/L) Average Monthly	3.1	0.8	6.2	0.10	0.10	0.1	0.10	0.1	0.19	0.1	0.6	1.88
Ammonia (mg/L) Instantaneous Maximum	4.8	1.5	12.2	0.10	0.10	0.1	0.10	0.1	0.27	0.1	1.1	2.8

**Compliance History**

**Effluent Violations for Outfall 001, from: August 1, 2022 to: July 31, 2023**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	03/31/23	Geo Mean	> 420	No./100 ml	2000	No./100 ml
Fecal Coliform	03/31/23	IMAX	> 2420	No./100 ml	10000	No./100 ml
Fecal Coliform	12/31/22	IMAX	> 2420	No./100 ml	10000	No./100 ml

**Compliance History**

<b>Summary of Inspections:</b>	The facility has been inspected periodically by the Department over the past permit term. The most recent inspection on December 22, 2022 noted an eDMR effluent violation but no other operational violations at the time of inspection.
<b>Other Comments:</b>	There are no open violations in eFACTS for Buffalo Township Municipal Sewer Authority.

**Existing Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	17	27	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
TSS	20	30	XXX	30	45	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	Report Annl Avg	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Ammonia	XXX	XXX	XXX	Report	XXX	Report	2/month	8-Hr Composite
Total Phosphorus	Report Annl Avg	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.08</u>
<b>Latitude</b> <u>40° 58' 29.63"</u>	<b>Longitude</b> <u>-76° 58' 40.10"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and included in the existing permit.

**Water Quality-Based Limitations**

**DO, CBOD5 and NH3-N**

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. WQM7.0 modeling was performed for the discharge to Buffalo Creek for the previous review and showed that no limitations are necessary beyond the technology-based secondary treatment limits listed above (see Attachment B).

**Total Residual Chlorine**

The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's TRC in a receiving stream, accounting for available dilution. The attached results of the TRC spreadsheet from the previous review (see Attachment C) show that the existing Technology-based limit of 0.5 mg/l is adequate to protect the receiving stream.

**Toxics Management**

No further "Reasonable Potential Analysis" was performed to determine additional parameters as candidates for limitations or monitoring for this minor POTW with no industrial influent.

**Chesapeake Bay/Nutrient Requirements**

According to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is an existing Phase 5 Chesapeake Bay sewage discharger that is not expanding, and as such requires no nutrient loading limits. Annual nutrient monitoring was included in current permit. The average Total Nitrogen concentration over the past permit term was 44.5 mg/L and the Average Phosphorus concentration was 5.0 mg/L. Because the nutrient load has been adequately characterized no additional nutrient monitoring will be required at this time consistent with the Phase III WIP Wastewater Supplement.

**Best Professional Judgment (BPJ) Limitations**

Comments: None needed beyond the Technology and Water Quality-Based limits noted above.

**e. Coli**

Quarterly e. coli monitoring will be required at this time due to recent changes to Chapter 93 of the Departments regulations and Department policy.

**Anti-Backsliding**

No proposed limitations are less stringent than the existing consistent with anti-backsliding provisions of the Clean Water Act and 40 CFR 122.44(l).



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	17	27	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
TSS	20	30	XXX	30	45	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia	XXX	XXX	XXX	Report	XXX	Report	2/month	8-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab



Compliance Sampling Location: Outfall 001

Other Comments: TN and TP monitoring has been removed as mentioned above. E. Coli monitoring is new as mentioned above.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment <b>B</b> )
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment <b>C</b> )
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 03/24/2021
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Model



## Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10C	18920	BUFFALO CREEK	<b>8.210</b>	482,10	78,50	0,00000	0,00	

### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Reh Trav Time	Reh Velocity	WD Ratio	Reh Width	Reh Depth	Tributary		Stream	
	(efsm)	(cfs)	(efs)	(days)	(fps)		(ft)	(ft)	Temp	pH	Temp	pH
<b>07-10</b>	0.125	0.00	0.00	0,000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
<b>01-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
<b>Buffalo Twp-Maz</b>	PA0115363	0.0800	0.0000	0.0000	0.000	25.00	7.50

### Parameter Data

Parameter Name	Disc Cone (mg/L)	Trib Cone (mg/L)	Stream Cone (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0,00	1.50
Dissolved Oxygen	3.00	8.24	0,00	0.00
NH3-N	25.00	0.00	0,00	0.70

## Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (1Vft)	PWS Withdrawal (m9d)	Apply FC
10C	18920	BUFFALO CREEK	6.400	460.00	90.00	0.00000	0.00	i>J

### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Reh Trav Time	Reh Velocity	WD Ratio	Reh Width	Reh Depth	Tributary		Stream	
	(efsm)	(cfs)	(efs)	(days)	(fps)		(ft)	(ft)	Temp	pH	Temp	pH
Q7-10	0.125	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

### Discharge Data

Name	Permit Number	Existing Disc Flow (m9d)	Permitted Disc Flow (m9d)	Design Disc Flow (m9d)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

### Parameter Data

Parameter Name	Disc Cone (m9/L)	Disc Cone (m9/L)	Disc Cone (m9/L)	Disc Cone (m9/L)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code				Stream Name						
10C		18920				BUFFALO CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
8.210	9.81	0.00	9.81	.1238	0.00231	.762	47.78	62.72	0.27	0.405	20.06	7.00
<b>Q1-10 Flow</b>												
8.210	6.28	0.00	6.28	.1238	0.00231	NA	NA	NA	0.21	0.518	20.10	7.01
<b>Q30-10 Flow</b>												
8.210	13.35	0.00	13.35	.1238	0.00231	NA	NA	NA	0.32	0.342	20.05	7.00

## WQM 7.0 Modeling Specifications

<b>Parameters</b>	Both	Use Inputted 01-10 and 030-10 Flows	
WLA Method	EMPR	<b>Use Inputted W/D Ratio</b>	<input type="checkbox"/>
01-10/07-10 Ratio	0.64	<b>Use Inputted Reach Travel Times</b>	<input type="checkbox"/>
030-10/07-10 Ratio	1.36	<b>Temperature Adjust Kr</b>	
<b>D. O. Saturation</b>	<b>90.00%</b>	<b>Use Balanced Technology</b>	
D.O. Goal	6		

## WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
10C	18920	BUFFALO CREEK

---

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
8.210	Buffalo Twp-Maz	9.57	50	9.57	50	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
8.210	Buffalo Twp-Maz	1.91	25	1.91	25	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
8.21	Buffalo Twp-Maz	25	25	25	25	3	3	0	0



## WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
10C	18920	BUFFALO CREEK

<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
8.210	0.080	20.062	7.004
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
47.777	0.762	62.721	0.273
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.29	0.158	0.31	0.703
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.178	6.008	Tsivoglou	6
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>		
0.405	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>
	(days)	(mg/L)	(mg/L)
			<u>D.O.</u>
			(mg/L)
	0.041	2.27	0.30
	0.081	2.26	0.29
	0.122	2.24	0.29
	0.162	2.23	0.28
	0.203	2.21	0.27
	0.243	2.20	0.26
	0.284	2.19	0.26
	0.324	2.17	0.25
	0.365	2.16	0.24
	0.405	2.14	0.23

## WQM 7.0 Effluent Limits

SWP Basin		Stream Code		Stream Name			
10C		18920		BUFFALO CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
8.210	Buffalo Twp-Maz	PA0115363	0.080	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

### TRC EVALUATION

Client	Date
<b>9.81</b> = Q stream (cfs)	<b>0.5</b> = CVDailv
<b>0.08</b> = Q discharge (MGD)	<b>0.5</b> = CV Hourlv
<b>30</b> = no. samples	<b>0.972</b> = AFC Partial.Mix Factor
<b>0.3</b> = Chlorine Demand of Stream	<b>1</b> = CFC Partial Mix Factor
<b>0</b> = Chlorine Demand of Discharae	<b>15</b> = AFC Criteria Compliance Time /mini
<b>0.5</b> = BAT/BPJ Value	<b>720</b> = CFC Criteria Comoliance Time (min)
<b>= % Factor of Safety (FOS)</b>	<b>0</b> =Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	<b>1.3.2.iii</b>	WLAafc= 24.597	<b>1.3.2.iii</b>	WLAafc= 24.663
PENTOXSD TRG	<b>5.1a</b>	LTAMULT afc = 0.373	<b>5.1c</b>	LTAMULT cfc = 0.581
PENTOXSD TRG	<b>5.1b</b>	LTA afc= 9.165	<b>5.1d</b>	LTA cfc= 14.338
		WQBEL afc= <b>11.282</b>		WQBEL cfc= 17.648

Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l)= 0.500	BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635	

WLAafc	$(.019/e(-k*AFC\_tc)) + [(AFC\_Yc*Qs*.019/Qd*e(-k*AFC\_tc))... + Xd + (AFC\_Yc*Qs*Xs/Qd)]*(1-FOS/100)$
LTAMULT afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$
LTA_afc	wla_afc'LTAMULT_afc
<b>WLA_cfc</b>	$(.011/e(-k'CFC\_tc) + [(CFC\_Yc*Qs'.011/Qd*e(-k'CFC\_tc) )... + Xd + (CFC\_Yc*Qs*Xs/Qd)]*(1-FOS/100)$
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no\_samples+1))-2.326*LN(cvd^2/no\_samples+1)^0.5)$
<b>LTA_cfc</b>	wla_cfc'LTAMULT_cfc
AML MULT	$EXP(2.326*LN((cvd^2/no\_samples+1)^0.5)-0.5*LN(cvd^2/no\_samples+1))$
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)'AML_MULT)
INST MAX LIMIT	$1.5*((av\_mon\_limit/AML\_MULT)/LTAMULT\_afc)$